Omaha Public Power District

444 South 16th Street Mall
Omaha NE 68102-2247

June 11, 2004
LIC-04-0023

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: May 2004 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for May 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

R. L. Phelps
Division Manager
Nuclear Engineering

RLP/EPM/epm

Attachment

c: B. S. Mallett, PhD, NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector
INPO Records Center

LIC-04-0023
Attachment

OPERATING DATA REPORT

DOCKET NO.	50-285
UNIT NAME	**Fort Calhoun Station**
DATE	June 1, 2004
COMPLETED BY	E. P. Matzke
TELEPHONE	(402) 533-6855

REPORT PERIOD: May 2004

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	MONTH	YR-TO-DATE	CUMULATIVE
Number of Hours Reactor was Critical:	744	3383	218251
Number of Hours Generator was On-line:	744	3366	216891
Unit Reserve Shutdown Hours:	0	0	0
Net Electrical Energy Generated (MWh):	357404	1612545	94138648

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason[1]	Method of Shutting Down Reactor[2]	Cause & Corrective Action Comments

(1) Reason:
- **A-Equipment Failure (Explain)**
- **B-Maintenance or Test**
- **C-Refueling**
- **D-Regulatory Restriction**
- **E-Operator Training/License Examination**
- **F-Administrative**
- **G-Operational Error (Explain)**
- **H-Other (Explain)**

(2) Method:
- **1-Manual**
- **2-Manual Trip/Scram**
- **3-Automatic Trip/Scram**
- **4-Continuation**
- **5-Other (Explain)**

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the month of May 2004.