

# WOLF CREEK

NUCLEAR OPERATING CORPORATION

Kevin J. Moles  
Manager Regulatory Affairs

June 9, 2004

RA 04-0073

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001


Subject: Docket No. 50-482: May 2004 Monthly Operating Report

Gentlemen:

Attached to this letter is the May 2004, Monthly Operating Report for the Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Wolf Creek Generating Station Technical Specification 5.6.4, "Monthly Operating Reports."

This submittal follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have any questions regarding this report, please contact me at (620) 364-4126, or Ms. Diane Hooper at (620) 364-4041.

Very truly yours,

  
Kevin J. Moles

KJM/rlg

Attachment

cc: J. N. Donohew (NRC), w/a  
D. N. Graves (NRC), w/a  
B. S. Mallett (NRC), w/a  
Senior Resident Inspector (NRC), w/a

IE24

**OPERATING DATA REPORT**  
Report Number: 231

**DOCKET NO.:** 50-482  
**UNIT NAME:** Wolf Creek Generating Station  
**DATE:** June 9, 2004  
**COMPLETED BY:** D. M. Hooper  
**TELEPHONE:** (620) 364-4041

**REPORT MONTH: May 2004**

1.	Design Electrical Rating (MWe - Net):	1170
2.	Maximum Dependable Capacity (MWe - Net):	1166

		This Month	Year to Date	Cumulative
3.	Number of Hours Reactor Critical:	744.00	3,591.73	141,368.40
4.	Number of Hours Generator On-Line:	744.00	3,579.50	140,121.35
5.	Unit Reserve Shutdown Hours:	0.00	0.00	339.80
6.	Net Electrical Energy Generated (MWH)	879,963.00	4,221,051.00	159,202,212.00

## UNIT SHUTDOWN AND POWER REDUCTIONS

**DOCKET NO.:** 50-482  
**UNIT NAME:** Wolf Creek Generating Station  
**DATE:** June 9, 2004  
**COMPLETED BY:** D. M. Hooper  
**TELEPHONE:** (620) 364-4041

No.	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

**SUMMARY:** The unit operated in Mode 1, at or near 100% power, from May 1, 2004, until 2400 on May 31, 2004.

(1) REASON: A: EQUIPMENT FAILURE (EXPLAIN)  
B: MAINTENANCE OR TEST  
C: REFUELING  
D: REGULATORY RESTRICTION  
E: OPERATOR TRAINING & LICENSE  
EXAMINATION  
F: ADMINISTRATIVE  
G: OPERATIONAL ERROR (EXPLAIN)  
H: OTHER (EXPLAIN)

(2) METHOD: 1: MANUAL  
2: MANUAL TRIP/ SCRAM  
3: AUTOMATIC TRIP/ SCRAM  
4: CONTINUATION  
5: OTHER (EXPLAIN)