

June 9, 2004

Technical Specification 5.6.4

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001


Palisades Nuclear Plant
Docket 50-255
License No. DPR-20

Monthly Operating Report

In accordance with Technical Specification 5.6.4, attached is the Monthly Operating Report for May 2004, for the Palisades Nuclear Plant.

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments.



for
Daniel J. Malone
Site Vice President, Palisades Nuclear Plant
Nuclear Management Company, LLC

Enclosure (1)

CC Administrator, Region III, USNRC
Project Manager, Palisades, USNRC
Resident Inspector, Palisades, USNRC
LBrandon, Michigan Department of Environmental Quality
RJAben, Michigan Department of Labor
RDWhale, Michigan Public Service Commission
Records Center, INPO
TLShillair, P-26-305

JE24

ENCLOSURE OPERATING DATA REPORT

DOCKET NO: 50-255
DATE : 06-01-04
COMPLETED BY: SFPierce
TELEPHONE (269) 764-2239
NOTES:

Operating Data:

UNIT NAME Palisades
REPORTING PERIOD: May 2004

1. DESIGN ELECTRICAL RATING (NET Mwe) 805
2. MAXIMUM DEPENDABLE CAPACITY (NET Mwe) * 730

	This Month	Yr-to-Date	Cumulative
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	3647.0	181118.5
4. HOURS GENERATOR ON-LINE	744.0	3647.0	175540.8
5. UNIT RESERVE SHUTDOWN HOURS	0	0	0
6. NET ELECTRICAL ENERGY GENERATED (MWH)	583466	2883113	121104453

* Based on condenser backpressure

ENCLOSURE OPERATING DATA REPORT

REPORT MONTH

May 2004

DOCKET NO. 50-255
UNIT NAME Palisades
DATE(Mo/Da/Yr) 06/01/04
COMPLETED BY SFPierce
TELEPHONE 269-764-2239

UNIT SHUTDOWNS

No.	Date (YrMoDa)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down ²	Cause / Corrective Actions Comments
-----	------------------	-----------------------------------	---------------------	---------------------	---	--

NONE

1. Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

2. Method:

1-Manual

2-Manual Trip/Scram

3-Automatic Trip/Scram

4-Other (Explain)

SUMMARY: The plant operated at essentially full power for the entire month.