

**ENERGY
NORTHWEST**

P.O. Box 968 ■ Richland, Washington 99352-0968

June 15, 2004
GO2-04-109

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397
MONTHLY OPERATING REPORT
MAY 2004**

Dear Sir or Madam:

Transmitted herewith is the Monthly Operating Report for the month of May 2004 as required by Technical Specification 5.6.4.

Respectfully,



WS Oxenford
Plant General Manager
Mail Drop 927M

Attachment

cc: BS Mallett - NRC RIV
WA Macon - NRC NRR
NRC Senior Resident Inspector - 988C
TC Poindexter - Winston & Strawn
INPO
ANI Library
Utility Data Institute
RN Sherman - BPA / 1399

IE24

OPERATING STATUS REPORT
for Columbia Generating Station

Date: June 1, 2004

1. Docket: 50-397
2. Reporting Period: May 2004
3. Utility Contact: Patricia Campbell (509) 377-4664
4. Design Electrical Rating (Net MW_e): 1153
5. Maximum Dependable Capacity - summer (Net MW_e): 1107

	MONTH	YEAR	CUMULATIVE
6. Hours Reactor Critical	744.0	3,647.0	130,505.5
7. Hours Generator On-Line	744.0	3,647.0	127,060.6
8. Unit Reserve Shutdown Hours	0.0	0.0	3,274.7
9. Net Electrical Energy (MWH)	786,513	3,995,056	126,862,708

