

Exelon Generation Company, LLC Quad Cities Nuclear Power Station 22710 206th Avenue North Cordova, IL 61242-9740 www.exeloncorp.com

Nuclear

June 14, 2004

SVP-04-060

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

> Quad Cities Nuclear Power Station, Units 1 and 2 Facility Operating License Nos. DPR-29 and DPR-30 NRC Docket Nos. 50-254 and 50-265

Subject:

Monthly Operating Report for May 2004

In accordance with Technical Specifications, Section 5.6.4, "Monthly Operating Reports," we are submitting this Monthly Operating Report for Quad Cities Nuclear Power Station (QCNPS), Units 1 and 2.

Additionally, QCNPS has implemented the relaxation designated in NRC Generic Letter 97-02, "Revised Contents of the Monthly Operating Report," which allowed a reduction in information that was being submitted in the Monthly Operating Report. These changes are and will be reflected in this and future reports.

Should you have any questions concerning this letter, please contact Mr. Wally Beck at (309) 227-2800.

Respectfully,

Timothy J. Tulon Site Vice President

Quad Cities Nuclear Power Station

Attachment

cc: Regional Administrator - NRC Region III

NRC Senior Resident Inspector - Quad Cities Nuclear Power Station

TEX

ATTACHMENT

QUAD CITIES NUCLEAR POWER STATION UNITS 1 AND 2 MONTHLY OPERATING REPORT FOR MAY 2004

EXELON NUCLEAR

AND

MIDAMERICAN ENERGY COMPANY

FACILITY OPERATING LICENSE NOS. DPR-29 AND DPR-30

NRC DOCKET NOS. 50-254 AND 50-265

TABLE OF CONTENTS

- I. Introduction
- II. Summary of Operating Experience
 - A. Unit One
 - B. Unit Two
- III. Operating Data Statistics
 - A. Operating Data Report Quad Cities Unit One
 - B. Operating Data Report Quad Cities Unit Two
- IV. Unit Shutdowns
 - A. Unit One Shutdowns
 - B. Unit Two Shutdowns
- V. Challenges to Safety and Relief Valves

I. <u>INTRODUCTION</u>

Quad Cities Nuclear Power Station is composed of two Boiling Water Reactors and Steam Turbine/Generators located in Cordova, Illinois. Unit One has a Maximum Dependable Capacity of 855 MWe Net, and Unit Two has a Maximum Dependable Capacity of 855 MWe Net. The Station is jointly owned by Exelon Nuclear and MidAmerican Energy Company. The Nuclear Steam Supply Systems are General Electric Company Boiling Water Reactors. The Architect/ Engineer was Sargent & Lundy, Incorporated, and the primary construction contractor was United Engineers & Constructors. The Mississippi River is the condenser cooling water source. The plant is subject to license numbers DPR-29 and DPR-30, issued October 1, 1971, and March 21, 1972, respectively, pursuant to Docket Numbers 50-254 and 50-265. The dates of initial Reactor criticality for Units One and Two were October 18, 1971, and April 26, 1972, respectively. Commercial generation of power began on February 18, 1973, for Unit One and March 10, 1973, for Unit Two.

II. SUMMARY OF OPERATING EXPERIENCE

A. Unit One

Unit One continued to operate at approximately 780 MWe due to ongoing Extended Power Uprate (EPU) evaluation. A planned load reduction occurred on May 30, 2004, to approximately 695 MWe for Main Turbine surveillance testing.

B. Unit Two

Unit Two operated the month of May at approximately 800 MWe due to ongoing EPU evaluation. A planned load reduction occurred on May 23, 2004, to approximately 620 MWe for a Control Rod Pattern Adjustment, Scram Timing and Main Turbine testing. During the recovery, the Unit was held at approximately 770 MWe to troubleshoot the #3 Turbine Control Valve. The Unit was returned to approximately 800 MWe on May 24, 2004, and remained there for the remainder of the reporting period.

III. **OPERATING DATA STATISTICS**

A. **Quad Cities Unit One Operating Data Report for May 2004**

DOCKET NO.:

50-254

DATE:

June 14, 2004

COMPLETED BY: Debbie Cline

TELEPHONE:

(309) 227-2801

OPERATING STATUS

REPORTING PERIOD: May 2004

GROSS HOURS IN REPORTING PERIOD: 744

CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2957

1. DESIGN ELECTRICAL RATING (MWe-Net): 867

MAX. DEPEND. CAPACITY (MWe-Net): 855 2.

UNIT 1 OPERATING STATUS

	PARAMETER	THIS MONTH	YTD	CUMULATIVE
3.	NUMBER OF HOURS THE REACTOR WAS CRITICAL	744.00	3,647.00	221,404.24
4.	HOURS GENERATOR ON-LINE	744.00	3,647.00	215,963.99
5.	UNIT RESERVE SHUTDOWN HOURS	0.00	0.00	1,655.20
6.	NET ELECTRICAL ENERGY GENERATED (MWH)	551,503.00	2,716,206.00	143,750,364.00

OPERATING DATA STATISTICS 111.

Quad Cities Unit Two Operating Data Report for May 2004 B.

DOCKET NO.:

50-265

DATE:

June 14, 2004

COMPLETED BY: Debbie Cline

TELEPHONE:

(309) 227-2801

OPERATING STATUS

REPORTING PERIOD: May 2004

GROSS HOURS IN REPORTING PERIOD: 744

CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2957

DESIGN ELECTRICAL RATING (MWe-Net): 867 1.

MAX. DEPEND. CAPACITY (MWe-Net): 855 2.

UNIT 2 OPERATING STATUS

	PARMETER	THIS MONTH	YTD	CUMULATIVE
3.	NUMBER OF HOURS THE REACTOR WAS CRITICAL	744.00	2,851.69	213,567.29
4.	HOURS GENERATOR ON-LINE	744.00	2,818.87	208,673.02
5.	UNIT RESERVE SHUTDOWN HOURS	0.00	0.00	2,312.90
6.	NET ELECTRICAL ENERGY GENERATED (MWH)	570,379.00	2,253,070.00	144,643,182.00

IV. <u>UNIT SHUTDOWNS</u>

A. Unit ONE Shutdowns for May 2004

NO. FOR YEAR	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN (3)	CORRECTIVE ACTIONS/COMMENTS
	None					

B. Unit TWO Shutdowns for May 2004

NO. FOR YEAR	DATE	TYPE (1)	DURATION (HOURS)	REASON (2)	METHOD OF SHUTTING DOWN (3)	CORRECTIVE ACTIONS/COMMENTS
	None					

Legend

(1) TYPE	(2) REASON	(3) METHOD	
F – Forced S – Scheduled	A. Equipment Failure (Explain) B. Maintenance or Test C. Refueling D. Regulatory Restriction E. Operator Training/License Examination F. Administrative G. Operational Error (Explain) H. Other (Explain)	 Manual Manual Trip/Scram Automatic Trip/Scram Continuation Other (Explain) 	

V. CHALLENGES TO SAFETY AND RELIEF VALVES

May 2004

may 2004			
Unit 1	None		
Unit 2	None		