

From: Michelle Honcharik
To: McCutchen, Edward L.
Date: 4/14/04 2:40PM
Subject: One Time TS SR Extension

Ed,
Please see attached.
Michelle

CC: Paul Fleming

Plant: Cooper
Docket: 50-298
PM: Michelle
Honcharik

Questions regarding attachment 1 of January 30, 2004, submittal:

- 1) Page 15 last sentence of last paragraph. When going from the 18-month to 24-month calibration interval – was a linear extrapolation used or another method? If another method, please explain.
- 2) Page 24 third line of the third paragraph under “Service Test for the 250VDC Division I Battery” heading. Are you sure the 192% is correct? Typically this is only 20-30% above what is needed.

Mail Envelope Properties (407D85A0.58B : 11 : 19583)

Subject: One Time TS SR Extension
Creation Date: 4/14/04 2:40PM
From: Michelle Honcharik

Created By: MCH3@nrc.gov

Recipients	Action	Date & Time
nppd.com	Transferred	04/14/04 02:40PM
elmccut (McCutchen, Edward L.)		
pvflemi CC (Paul Fleming)		

Post Office	Delivered	Route
		nppd.com

Files	Size	Date & Time
MC1914_April questions.doc	24064	04/14/04 10:39AM
MESSAGE	550	04/14/04 02:40PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
Reply Requested: No
Return Notification:
 Send Notification when Opened

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened