Bill Eaton, BWRVIP Chairman Entergy Operations, Inc. Echelon One 1340 Echelon Parkway Jackson, MS 39213-8202

SUBJECT: SUPPLEMENTARY REQUEST FOR ADDITIONAL INFORMATION - REVIEW

OF BWR VESSEL AND INTERNALS PROJECT REPORT, BWRVIP-84, "GUIDELINES FOR SELECTION AND USE OF MATERIALS FOR REPAIRS"

Dear Mr. Eaton:

By letter dated October 31, 2000, you submitted for NRC staff review, Electric Power Research Institute (EPRI) proprietary report, BWRVIP-84, "Guidelines for Selection and Use of Methodology for Repairs." The purpose of this document was to provide guidance for the selection and use of materials for repair and/or replacement of specific BWR internal components.

The staff had initially submitted a request for additional information (RAI) for the BWRVIP-84 report on September 16, 2003, and the BWRVIP responded to those RAIs on March 24, 2004. Based on the BWRVIP's responses to the staff's RAIs of the BWRVIP-16 report, "Core Spray Replacement Design Criteria," the staff determined the need for supplementary RAIs with respect to the BWRVIP-84 report. The staff's supplementary RAIs that are needed to complete the review of the BWRVIP-84 report are provided in the attachment. Please contact Meena Khanna of my staff at 301-415-2150 if you have any further questions regarding this subject.

Sincerely,

/RA/

Matthew A. Mitchell, Acting Chief Vessels & Internals Integrity and Welding Section Materials and Chemical Engineering Branch Division of Engineering

Project No. 704 Enclosure: As stated

cc: BWRVIP Service List

Bill Eaton, BWRVIP Chairman Entergy Operations, Inc. Echelon One 1340 Echelon Parkway Jackson, MS 39213-8202

SUBJECT: SUPPLEMENTARY REQUEST FOR ADDITIONAL INFORMATION - REVIEW

OF BWR VESSEL AND INTERNALS PROJECT REPORT, BWRVIP-84, "GUIDELINES FOR SELECTION AND USE OF MATERIALS FOR REPAIRS"

Dear Mr. Eaton:

By letter dated October 31, 2000, you submitted for NRC staff review, Electric Power Research Institute (EPRI) proprietary report, BWRVIP-84, "Guidelines for Selection and Use of Methodology for Repairs." The purpose of this document was to provide guidance for the selection and use of materials for repair and/or replacement of specific BWR internal components.

The staff had initially submitted a request for additional information (RAI) for the BWRVIP-84 report on September 16, 2003, and the BWRVIP responded to those RAIs on March 24, 2004. Based on the BWRVIP's responses to the staff's RAIs of the BWRVIP-16 report, "Core Spray Replacement Design Criteria," the staff determined the need for supplementary RAIs with respect to the BWRVIP-84 report. The staff's supplementary RAIs that are needed to complete the review of the BWRVIP-84 report are provided in the attachment. Please contact Meena Khanna of my staff at 301-415-2150 if you have any further questions regarding this subject.

Sincerely,

/RA/

Matthew A. Mitchell, Acting Chief Vessels & Internals Integrity and Welding Section Materials and Chemical Engineering Branch Division of Engineering

Project No. 704 Enclosure: As stated

cc:BWRVIP Service List

Distribution:

EMCB R/F EMCB A

MWeston AHiser

CMoyer NChokshi

WCullen MLesser, R2

RLorson, R1 CMarschall, R4

DHills, R3

ADAMS Accession No.: ML041810666

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY/ENCL, "N"=NO COPY

OFFICE	EMCB:DE	Е	EMCB:DE	Е	EMCB:DE	
NAME	MKhanna		GCheruvenki by MKhanna		MMitchell	
DATE	06/17/2004		06/21/2004		06/21/2004	

CC:

Tom Mulford, EPRI BWRVIP
Integration Manager
Raj Pathania, EPRI BWRVIP
Mitigation Manager
Ken Wolfe, EPRI BWRVIP
Repair Manager
Larry Steinert, EPRI BWRVIP
Electric Power Research Institute
P.O. Box 10412
3412 Hillview Ave.
Palo Alto, CA 94303

Robin Dyle, Technical Chairman BWRVIP Integration Committee Southern Nuclear Operating Co. 42 Inverness Center Parkway (M/S B234) Birmingham, AL 35242-4809

Jim Meister, Executive Chairman BWRVIP Assessment Committee Exelon Corp. Cornerstone II at Cantera 4300 Winfield Rd. Warrenville, IL 60555-4012

Al Wrape, Executive Chairman BWRVIP Intergration Committee PPL Susquehanna, LLC 2 N. 9th St. Allentown, PA 18101-1139

H. Lewis Sumner, Executive Chairman BWRVIP Mitigation Committee Vice President, Hatch Project Southern Nuclear Operating Co. M/S BIN B051, P.O. BOX 1295 40 Inverness Center Parkway Birmingham, AL 35242-4809

Robert Carter, EPRI BWRVIP Assessment Manager Greg Selby, EPRI BWRVIP Inspection Manager EPRI NDE Center P.O. Box 217097 1300 W. T. Harris Blvd. Charlotte, NC 28221

Denver Atwood, Technical Chairman BWRVIP Repair Focus Group Southern Nuclear Operating Co. Post Office Box 1295 40 Inverness Center Parkway (M/S B031) Birmingham, AL 35242-4809 Dale Atkinson, BWRVIP Liason to EPRI Nuclear Power Council Energy Northwest Columbia Generating Station (M/S PEO8) P. O. Box 968 Snake River Complex North Power Plant Loop Richland, WA 99352-0968

Richard Ciemiewicz, Technical Vice Chairman BWRVIP Assessment Committee Exelon Corp. Peach Bottom Atomic Power Station M/S SMB3-6 1848 Lay Road Delta, PA 17314-9032

Gary Park, Chairman BWRVIP Inspection Focus Group Nuclear Management Co. Monticello Nuclear Plant 2807 W. Country Road 75 Monticello, MN 55362-9635

George Inch, Technical Chairman BWRVIP Assessment Committee Constellation Nuclear Nine Mile Point Nuclear Station (M/S ESB-1) 348 Lake Road Lycoming, NY 13093

Jeff Goldstein, Technical Chairman BWRVIP Mitigation Committee Entergy Nuclear NE 440 Hamilton Ave. (M/S K-WPO-11c) White Plains, NY 10601

U.S. NUCLEAR REGULATORY COMMISSION OFFICE OF NUCLEAR REACTOR REGULATION SAFETY EVALUATION OF THE BWRVIP VESSEL AND INTERNALS PROJECT, "BWR VESSEL AND INTERNALS PROJECT, GUIDELINES FOR SELECTION AND USE OF MATERIALS FOR REPAIRS (BWRVIP-84)"

SUPPLEMENTARY REQUEST FOR ADDITIONAL INFORMATION

Note: These additional requests for additional information (RAIs) were generated based on the Boiling Water Reactor Vessels and Internals Program (BWRVIP) response of the BWRVIP-16 RAIs.

Supplementary RAI 84-1

Item 4.1-Material requirement specified in Section 9.1 of BWRVIP-16

Section 9.1.2 of the BWRVIP-16 report states that materials conforming to the American Society of Mechanical Engineers (ASME) Code or the American Society for Testing of Materials (ASTM) can be used for the fabrication of BWR reactor internals. The staff's RAI indicates that materials shall be manufactured in accordance with ASME or equivalent ASTM specifications. In response to this RAI, the BWRVIP stated that all material-related issues addressed in Sections 9.1 and 9.1.2 will be deleted from the BWRVIP-16 report and will be incorporated in the BWRVIP-84 report. Item 3.2 of Section 3 in the BWRVIP-84 report states that materials for reactor internals shall meet the requirements of ASTM specifications. The staff requests that the BWRVIP revise the second sentence of Item 3.2 of Section 3 of the BWRVIP-84 report to state that materials must meet the requirements of the ASME Code Section II specifications, equivalent ASTM specifications, ASME Code Cases approved by the NRC in Regulatory Guide 1.147, material specifications used during original fabrication, or other material specifications that have been previously accepted by the staff.

Supplementary RAI 84-2

Item 4.3-Material Specifications

Section 9.1.5 of the BWRVIP-16 report references EPRI-7032, "Material Specification for Alloy X-750 for use in LWR Internal Components, Rev.1," and EPRI #84-MG-18, "Nuclear Grade Stainless Steel, Procurement, Manufacturing and Fabrication Guidelines." In response to this RAI, the BWRVIP indicated that all material-related issues addressed in Sections 9.1 and 9.2 will be deleted from the BWRVIP-16 report and will be incorporated in the BWRVIP-84 report. The staff noted that these documents have not been included in the BWRVIP-84 report. The staff requests that these referenced EPRI documents be included in Sections A and B of the BWRVIP-84 report, with a note indicating that any exceptions to these documents require acceptance by the NRC.

Supplementary RAI 84-3

Section 5 of the BWRVIP-84 report, "General Welding and Fabrication Guidelines," indicates that underwater welding shall be performed in accordance with ASME Code Case N-516-1. This Code Case has been superseded by Code Case N-516-2 in the latest version of Regulatory Guide 1.147 (Rev.13). The staff requests that the BWRVIP revise the BWRVIP-84 report, to indicate that ASME Code Case N-516-2 should be used for underwater welding of reactor internals.