

Research Reactor Center University of Missouri-Columbia Research Park Columbia, MO 65211

PHONE (573) 882-4211 FAX (573) 882-6360

June 21, 2004

Mr. Alexander Adams, Jr. U.S. Nuclear Regulatory Commission Mail Stop O12-G13 Washington, DC 20555-0001

SUBJECT: University of Missouri Research Reactor Facility Docket No. 50-186 Monthly Operations Summary

Dear Mr. Adams:

Enclosed is a copy of MURR's Monthly Operations Summary for May 2004. If you have any questions, please contact me at (573) 882-5276.

Sincerely,

white NK /

Leslie Foyto Reactor Manager

LM/sm cc. Craig Bassett Enclosure: May Operation Summary – 4 pages



UNIVERSITY OF MISSOURI RESEARCH REACTOR

OPERATIONS MONTHLY SUMMARY

May 2004

Prepared by: Operations Staff

INTRODUCTION

4

1

The reactor operated continuously in May with the following exceptions: 4 shutdowns for scheduled maintenance and refueling; 2 unscheduled shutdowns.

MAINTENANCE ACTIVITIES

5/3/04	Refueled - removed core 04-20, loaded core 04-21.
5/6/04	Replaced heaters in NMC Model RAK Stack Monitor motor.
5/10/04	Refueled - removed core 04-21, loaded core 04-22. Reinstalled refurbished Secondary Coolant System Flow Distribution Valve S-20. Repaired Domestic Cold Water leak downstream of Secondary Coolant System Make-up water flow meter.
5/17/04	Refueled - removed core 04-22, loaded core 04-23. Completed Modification Record 01-05 Add. 1, "Replace PT-912P and 912Q Differential Pressure Transmitters."
5/19/04	Shipped eight spent fuel elements to Savannah River Site.
5/23/04	Refueled – removed core 04-23, loaded core 04-24.
5/23/04	Completed CP-26, "Containment Building Compliance Test."
5/24/04	Replaced SF-1 (building supply fan) shaft and bearings.
5/31/04	Refueled – removed core 04-24, loaded core 04-25.

UNSCHEDULED SHUTDOWNS

Date	<u>No.</u>	<u>Tvpe</u>	Cause
5/3/04	NA	Manual Scram	Adjustment of Nuclear Instrument Channel 4 indication

On May 3, the reactor was shutdown to adjust Nuclear Instrument Channel 4 indication. The indication was reading low and the gain potentiometer for that drawer was at its maximum setting. The dipswitches on Signal Processor drawer 1 were adjusted to bring the gain potentiometer to the middle of the operating range. The reactor was subsequently returned to 10 MW operation.

5/17/04 1172 Rod Run -In Activating the Rod Control System Automatic Shim Circuit

On May 17, a Rod Run-In was automatically initiated when a six-inch sample holder was being removed to introduce a very small positive reactivity addition in order to activate the Automatic Shim Circuit for training purposes just prior to the normally scheduled weekly shutdown. The sample holder was removed causing the Regulating Blade to insert to the 10% point, which initiated the Rod Run-in.

OPERATION SUMMARY FOR MONTH OF University of Missour Research Reactor Center (MURR)	May-04					
HOURS OPERATED THIS PERIOD	665.01					
TOTAL HOURS OPERATED, REACTOR	258,565.47					
HOURS OPERATED AT FULL POWER, THIS PERIOD	662.55					
TOTAL HOURS AT FULL POWER, REACTOR	255,242.28					
INTEGRATED POWER THIS PERIOD	276.22 MWD					
TOTAL INTEGRATED POWER, REACTOR	100,551.29 MWD					
Submitted by:	<u></u>					
MWD Custodian/Reactor Physicist						
Date:6/3/c4						

.

7

.

1

ł

:

.

·

.