

TABLE OF CONTENTS

3.5.5	Trisodium Phosphate (TSP) .....	3.5.5-1
3.6	CONTAINMENT SYSTEMS.....	3.6.1-1
3.6.1	Containment .....	3.6.1-1
3.6.2	Containment Air Locks .....	3.6.2-1
3.6.3	Containment Isolation Valves .....	3.6.3-1
3.6.4	Containment Pressure .....	3.6.4-1
3.6.5	Containment Air Temperature .....	3.6.5-1
3.6.6	Containment Spray and Cooling Systems .....	3.6.6-1
3.6.7	Deleted	
3.6.8	Iodine Removal System (IRS) .....	3.6.8-1
3.7	PLANT SYSTEMS.....	3.7.1-1
3.7.1	Main Steam Safety Valves (MSSVs) .....	3.7.1-1
3.7.2	Main Steam Isolation Valves (MSIVs) .....	3.7.2-1
3.7.3	Auxiliary Feedwater (AFW) System .....	3.7.3-1
3.7.4	Condensate Storage Tank (CST) .....	3.7.4-1
3.7.5	Component Cooling (CC) System .....	3.7.5-1
3.7.6	Service Water (SRW) System .....	3.7.6-1
3.7.7	Saltwater (SW) System .....	3.7.7-1
3.7.8	Control Room Emergency Ventilation System (CREVS) ..	3.7.8-1
3.7.9	Control Room Emergency Temperature System (CRETS) ..	3.7.9-1
3.7.10	Emergency Core Cooling System (ECCS) Pump Room Exhaust Filtration System (PREFS) .....	3.7.10-1
3.7.11	Spent Fuel Pool Exhaust Ventilation System (SFPEVS) .....	3.7.11-1
3.7.12	Penetration Room Exhaust Ventilation System (PREVS) .....	3.7.12-1
3.7.13	Spent Fuel Pool (SFP) Water Level .....	3.7.13-1
3.7.14	Secondary Specific Activity .....	3.7.14-1
3.7.15	Main Feedwater Isolation Valves (MFIVs) .....	3.7.15-1
3.7.16	Spent Fuel Pool (SFP) Boron Concentration .....	3.7.16-1
3.8	ELECTRICAL POWER SYSTEMS.....	3.8.1-1
3.8.1	AC Sources - Operating .....	3.8.1-1
3.8.2	AC Sources - Shutdown .....	3.8.2-1
3.8.3	Diesel Fuel Oil .....	3.8.3-1
3.8.4	DC Sources - Operating .....	3.8.4-1
3.8.5	DC Sources - Shutdown .....	3.8.5-1
3.8.6	Battery Cell Parameters .....	3.8.6-1
3.8.7	Inverters - Operating .....	3.8.7-1
3.8.8	Inverters - Shutdown .....	3.8.8-1

<u>Amendment No.</u>	<u>Additional Conditions</u>	<u>Implementation Date</u>
246	This amendment requires the licensee to incorporate in the Updated Final Safety Analysis Report (UFSAR) changes associated with the aircraft hazards analysis which was evaluated by the staff in the Safety Evaluation dated August 29, 2001.	Next update of the UFSAR
248	This amendment requires the licensee to incorporate in the Updated Final Safety Analysis Report (UFSAR) changes associated with the loss of feedwater flow analysis which was evaluated by the staff in the safety evaluation dated February 26, 2002.	Next update of the UFSAR
267	This amendment requires the licensee develop a long-term coupon surveillance program for the Carborundum samples. This program must verify that the Carborundum degradation rates assumed in the licensee's analyses to prove subcriticality, as required by 10 CFR 50.68, remain valid over the seventy-year life span of the Unit 1 spent fuel pool. The licensee must submit this modified coupon surveillance program to the NRC under the 10 CFR 50.90 requirements for its review and approval.	3 years after approval of this amendment