



TXU Power
Comanche Peak Steam
Electric Station
P O Box 1002 E01
Glen Rose, TX 76043
Tel: 254 897 5209
Fax: 254 897 6652
mike.blevins@txu.com

Mike Blevins
Senior Vice President &
Chief Nuclear Officer

Ref: 10 CFR 50.55a(3)(i)

CPSES-200401688
Log # TXX-04121

July 1, 2004

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446;
CORRECTION TO RELIEF REQUEST B-4 FOR THE SECOND
10 YEAR ISI INTERVAL FOR UNIT 1 AND B-15 FOR THE FIRST
10 YEAR ISI INTERVAL FOR UNIT 2 FROM 10 CFR 50.55a FOR
THE PURPOSE OF INVOKING CODE CASE N-566-2,
"CORRECTIVE ACTION FOR LEAKAGE AT BOLTED
CONNECTIONS, SECTION XI, DIVISION 1."
(UNIT 1 SECOND INTERVAL START DATE AUGUST 2000
UNIT 2 FIRST INTERVAL END DATE: AUGUST 2004)
(TAC NOS. MB1958 AND MB1959)**

**REF: TXU Power Letter logged TXX-03199 dated January 2, 2004, from
Mike Blevins to the NRC**

Via the referenced letter TXU Generation Company LP (TXU Power) requested relief from the AMSE Code pursuant to 10CFR50.55a. After a review of the subject relief requests, the NRC staff requested a letter confirming correction of a typo regarding the 1989 Code Edition in Paragraph III of the attachment to the referenced letter. The correct code edition is the 1986 Code Edition.

TXU Power requests that the NRC authorize the use of ASME Code Case N-566-2, "Corrective Action for Leakage at Bolted Connections, Section XI, Division 1," as an alternative to certain requirements of IWA-5250(a)(2) for the evaluation and corrective actions associated with leaking ASME Class 1, 2, and 3 bolted connections.

A047

A member of the **STARS** (Strategic Teaming and Resource Sharing) Alliance

Callaway • Comanche Peak • Diablo Canyon • Palo Verde • South Texas Project • Wolf Creek

TXX-04121

Page 2 of 2

This communication contains no new licensing basis commitments regarding CPSES.


If you have any questions regarding this request, please contact Jack Hicks at (254) 897-6725.

Sincerely,

TXU Generation Company LP

By: TXU Generation Management Company LLC,
Its General Partner

Mike Blevins

By: 
Fred W. Madden
Regulatory Affairs Manager

JCH/jch

c - B. S. Mallet, Region IV
W. D. Johnson, Region IV
M. C. Thadani, NRR
Resident Inspectors, CPSES
Terry Parks, Chief Inspector, TDLR
J.C. Hair ANII, CPSES