

June 29, 2004

NEF#04-026

**ATTN: Document Control Desk
Director
Office of Nuclear Material Safety and Safeguards
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**

**Louisiana Energy Services, L. P.
National Enrichment Facility
NRC Docket No. 70-3103**

Subject: Ground Water Discharge Permit and Air Quality Notice of Intent Applications

- References:**
- 1. Letter NEF#03-003 dated December 12, 2003, from E. J. Ferland (Louisiana Energy Services, L. P.) to Directors, Office of Nuclear Material Safety and Safeguards and the Division of Facilities and Security (NRC) regarding "Applications for a Material License Under 10 CFR 70, Domestic licensing of special nuclear material, 10 CFR 40, Domestic licensing of source material, and 10 CFR 30, Rules of general applicability to domestic licensing of byproduct material, and for a Facility Clearance Under 10 CFR 95, Facility security clearance and safeguarding of national security information and restricted data"**
 - 2. Letter NEF#04-002 dated February 27, 2004, from R. M. Krich (Louisiana Energy Services, L. P.) to Director, Office of Nuclear Material Safety and Safeguards (NRC) regarding "Revision 1 to Applications for a Material License Under 10 CFR 70, "Domestic licensing of special nuclear material," 10 CFR 40, "Domestic licensing of source material," and 10 CFR 30, "Rules of general applicability to domestic licensing of byproduct material"**

By letter dated December 12, 2003 (Reference 1), E. J. Ferland of Louisiana Energy Services (LES), L. P., submitted to the NRC applications for the licenses necessary to authorize construction and operation of a gas centrifuge uranium enrichment facility. Revision 1 to these applications was submitted to the NRC by letter dated February 27, 2004 (Reference 2). The National Enrichment Facility (NEF) Environmental Report was included in these applications.

During an April 26, 2004, telephone discussion between representatives of the NRC and LES regarding the NEF Environmental Report, the NRC requested that copies of the LES Ground Water Discharge Permit and Air Quality Notice of Intent applications to the State of New Mexico be provided. This letter provides the requested applications and subsequent responses received from the State of New Mexico Environment Department.

NMSS01

Attachment 1 to this letter provides a copy of the LES Ground Water Discharge Permit Application dated April 26, 2004.


Attachment 2 to this letter provides a copy of the LES Air Quality Notice of Intent Application dated April 20, 2004.

Attachment 3 to this letter provides a copy of a letter dated May 17, 2004, from J. Schoeppner (New Mexico Environment Department) to Louisiana Energy Services, L. P., regarding the determination by the New Mexico Environment Department that the LES Ground Water Discharge Permit Application is administratively complete. This letter also informed LES of applicant's public notice requirements.

Attachment 4 to this letter provides a copy of a letter dated May 27, 2004, from B. D. Taylor (New Mexico Environment Department) to R. M. Krich (Louisiana Energy Services, L. P.) regarding the determination by the New Mexico Environment Department, based on the submitted LES application, that an air quality permit is not required for the NEF.

If you have any questions or need additional information, please contact me at 630-657-2813.

Respectfully,



R. M. Krich
Vice President – Licensing, Safety, and Nuclear Engineering

Attachments:

1. LES Ground Water Discharge Permit Application
2. LES Air Quality Notice of Intent Application
3. Letter dated May 17, 2004, from J. Schoeppner (New Mexico Environment Department) to Louisiana Energy Services, L. P., Regarding "Administrative Completeness Determination and Applicant's Public Notice Requirements, DP-1481, National Enrichment Facility"
4. Letter dated May 27, 2004, from B. D. Taylor (New Mexico Environment Department) to R. M. Krich (Louisiana Energy Services, L. P.) Regarding "Notice of Intent No. 3062 - National Enrichment Facility (NEF)"

cc: T.C. Johnson, NRC Project Manager (w/o Attachments)
M.C. Wong, NRC Environmental Project Manager

ATTACHMENT 1

**Louisiana Energy Services
Ground Water Discharge Permit Application**



BILL RICHARDSON
GOVERNOR

State of New Mexico
ENVIRONMENT DEPARTMENT

Ground Water Quality Bureau
Harold Runnels Building
1190 St. Francis Drive, P.O. Box 26110
Santa Fe, New Mexico 87502-6110
Telephone (505) 827-2900
Fax (505) 827-2965
www.nmenv.state.nm.us



RON CURRY
SECRETARY

DERRITH WATCHMAN-MOORE
DEPUTY SECRETARY

GROUND WATER DISCHARGE PERMIT APPLICATION

Enclosed is a Ground Water Discharge Permit Application Form (Form) and checklist. Section 20.6.2.3104 NMAC of the NM Water Quality Control Commission Regulations (20.6.2 NMAC) requires that any person proposing to discharge effluent or leachate so that it may move directly or indirectly into ground water must have an approved discharge permit, unless a specific exemption is provided for in the Regulations. The enclosed Form is a general guideline for use by applicants to ensure that an application is complete and provides all of the information required by sections 20.6.2.3106, 20.6.2.3107, 20.6.2.3108, and 20.6.2.3109 NMAC.

Mail three complete copies of your application with a \$100 filing fee check made payable to the New Mexico Environment Department (NMED) at the address below:

Maura Hanning, Program Manager
Ground Water Pollution Prevention Section
NM Environment Department
P. O. Box 26110
Santa Fe, NM 87502

Pursuant to Regulation 20.6.2.3108 NMAC, NMED will, within thirty (30) days of deeming the application administratively complete, publish a public notice and allow 30 days for public comment before taking final action on a discharge permit. A public hearing will be held if NMED determines that there is significant public interest. It takes approximately 180 days to process a complete application and issue a discharge permit if no public hearing is held.

All applications must be accompanied by a filing fee of \$100. An additional fee will be assessed prior to permit issuance to cover the estimated cost to the NMED for investigation, and, issuance of the permit. Permit fees are listed in the Regulation 20.6.2.3114 NMAC.

If you have any questions about this discharge permit application, call the Ground Water Pollution Prevention Section at 505-827-2900

COMPLETION CHECKLIST

<input checked="" type="checkbox"/>	All portions of the Ground Water Discharge Permit Application Form have been addressed. (The application will not be considered complete if there are omissions, which will delay publication of the public notice and issuance of the permit.)
<input checked="" type="checkbox"/>	Submitter has included operational, monitoring, contingency, and closure plans that are appropriate for the proposed treatment and disposal system, and meet the site-specific conditions for the proposed facility.
<input checked="" type="checkbox"/>	Plans and specifications for the entire effluent or leachate conveyance, collection, treatment, distribution, and disposal system have been included as required by Regulation 20.6.2.1202 NMAC. For septic tank/leachfield systems, designs should be consistent with NMED's guidelines for Plans and Specifications for Discharge Permit Applications Using Septic Tank/Leachfields.
<input checked="" type="checkbox"/>	The application has been signed and dated by the responsible party, generally the owner or lessee.
<input checked="" type="checkbox"/>	If your facility site includes an archeological site on the State Register of Cultural Properties or National Register of Historic Places, the State Historic Preservation Office has the authority to require an archeological or historical study prior to NMED taking final action on your discharge permit.
<input checked="" type="checkbox"/>	Four maps have been included: 1) area United States Geological Survey (USGS) topographic map that includes the location of the facility and all of the information required in the application item 7.b, 2) local road map clearly defining the location of the facility and the route to get to the facility, 3) detailed site map that includes all discharge locations (lagoons, leachfields, land application areas, outfalls...), all water supply and monitoring wells, all water courses on the property and all buildings and 4) United States Department of Agriculture (USDA) soils map.
<input checked="" type="checkbox"/>	Three copies of all required information have been enclosed.
<input checked="" type="checkbox"/>	A filing fee check in the amount of \$100, has been enclosed, made payable to the NM Environment Department at the address on page 1.
<input checked="" type="checkbox"/>	The SUMMARY OF APPLICANT'S PUBLIC NOTICE REQUIREMENTS has been reviewed and the option for Public Notice Has been selected on the application page 3.

ADMINISTRATIVE COMPLETENESS

To be deemed administratively complete for publication of a public notice, the following information must be provided. [20.6.2.3106, 20.6.2.3108 NMAC]

Review the **SUMMARY OF APPLICANT'S PUBLIC NOTICE REQUIREMENTS** (attached) to select an option below.

Public Notice Option 1 Public Notice Option 2 Public Notice Option 3

1. Name of the proposed discharger and facility [20.6.2.3106, 20.6.2.3108.C.1 NMAC]:

National Enrichment Facility (NEF)

Type of facility or operation (dairy, municipal wwtp, mining, school, etc.): Uranium Enrichment Plant

	Name	Address*	City	State	Zip	Telephone & Fax
Facility*	National Enrichment Facility	To be determined	Eunice	NM	88231	To be determined
Owner	Louisiana Energy Services, LP	100 Sun Lane NE, Suite 204	Albuquerque	NM	87109	505-944-0194 Ph. 505-944-0198 Fax
Responsible Party	R. M. Krich	2600 Virginia Ave. NW Suite 610	Washington	DC	20037	202-222-0391 Ph. 202-337-2421 Fax
Facility Representative	R. M. Krich	2600 Virginia Ave. NW Suite 610	Washington	DC	20037	202-222-0391 Ph. 202-337-2421 Fax
Consultant	AREVA	400 Donald Lynch Blvd.	Marlborough	MA	01752	978-568-2728 Ph. 978-568-3731 Fax 505-994-0099 Ph.
	GL Environmental	4200 Meadowlark Lane, Suite 1A	Rio Rancho	NM	87124	505-994-0093 Fax
Other (specify) Current Land Owner	New Mexico State Land Office	310 Old Santa Fe Trail, P.O. Box 1148	Santa Fe	NM	87504-1148	505-827-5760 Ph. 505-827-5766 Fax

*For the facility address, enter physical address- not mailing address.

2. Locations of the Discharges [20.6.2.3106.C.2 and 20.6.3108.C.2 NMAC]:

List the locations of the discharges covered by this permit. Add rows as necessary to include all discharge locations. Sections should be described to the nearest ¼ of a ¼ of a ¼ section (please see attachment).

Discharge Location (lagoons, leachfields, land application areas, outfalls, etc.)	County	Township	Range	Section	Latitude	Longitude
Site Storm Water Detention Basin (SSDB)	Lea	T21S	R38E	SE, SE, SW 32	32°25' 52" N	103°04' 35" W
Uranium Byproduct Cylinder (UBC) Storage Pad Storm Water Retention Basin (USPSRB)	Lea	T21S	R38E	SW, NE, NE 32	32°26' 07" N	103°05' 02" W
Treated Effluent Evaporative Basin (TEEB)	Lea	T21S	R38E	SE, NW, NW 32	32°26' 02" N	103°04' 55" W
Septic Tank-Leachfield 1 (ST/L 1)	Lea	T21S	R38E	SE, NE, SW 32	32°25' 57" N	103°04' 36" W
Septic Tank-Leachfield 2 (ST/L 2)	Lea	T21S	R38E	NW, SE, SW 32	32°26' 11" N	103°05' 06" W
Septic Tank-Leachfield 3 (ST/L 3)	Lea	T21S	R38E	NE, SW, SW 32	32°26' 10" N	103°04' 49" W
Septic Tank-Leachfield 4 (ST/L 4)	Lea	T21S	R38E	SE, NW, SE 32	32°25' 59" N	103°04' 46" W
Septic Tank-Leachfield 5 (ST/L 5)	Lea	T21S	R38E	SE, NE, NW 32	32°26' 02" N	103°04' 39" W
Septic Tank-Leachfield 6 (ST/L 6)	Lea	T21S	R38E	SE, SE, NE 32	32°25' 52" N	103°04' 29" W

Note: Refer to NEF Detailed Site Map (Attachment A) for basin and discharge locations

3. Brief Description of Discharge [20.6.2.3108.C.3 NMAC]:

Briefly describe the activities which produce the discharge(s) including the treatment and disposal methods. Attach additional pages as necessary.

The **Site Storm Water Detention Basin** at the south side of the site will collect runoff from various developed parts of the site including roads, parking areas and building roofs. It is unlined and will have an outlet structure to control discharges above the design level. The normal discharge will be through evaporation/infiltration into the ground. The basin is designed to contain runoff for a volume equal to that for the 24-hour, 100-year return frequency storm, a 15.2 cm (6.0 in) rainfall. The basin will have approximately 23,350 m³ (100 acre-ft) of storage capacity. Area served includes about 39 ha (96 acres) with the majority of that area being the developed portion of the 220 ha (543 acres)

NEF site. Effluent is not treated prior to release. If required, all storm water discharges will be regulated by a National Pollutant Discharge Elimination System (NPDES) Storm Water Permit, including a General Permit for construction and a Multi Sector General Stormwater Permit for facility operations.

The **Uranium Byproduct Cylinder (UBC) Storage Pad Storm Water Retention Basin** is utilized for the collection and containment of water discharges from three sources: (1) cooling tower blowdown discharges, (2) storm water runoff from the UBC Storage Pad and (3) heating boiler blowdown. The ultimate disposal of basin water will be through evaporation of water and impoundment of the residual dry solids after evaporation. It is designed to contain runoff for a volume equal to twice that for the 24-hour, 100-year return frequency storm, a 15.2-cm (6.0-in) rainfall plus an allowance for cooling tower and heating boiler blowdown water. The UBC Storage Pad Storm Water Retention Basin is designed to contain a volume of approximately 77,700 m³ (63 acre-ft). Area served by the basin includes 9.2 ha (22.8 acres), the total area of the UBC Storage Pad. This basin is designed with a membrane lining to minimize any infiltration into the ground. To provide adequate chemical resistance to the various liquids, the liner material may consist of High Density Polyethylene (HDPE) or Ethylene Interpolymer Alloy (Coolgard[®] XR-5[®] or Ultra Tech[®]). Liner thickness will be specified during final design. Effluent is not treated prior to release to the basin. The basin liner will comply with the NM Environment Department Ground Water pollution Prevention Sections, Guidelines for Liner Material and Site Preparation for Synthetically Lined Lagoons, December 11, 1995. The basin does not have an outlet.

Cooling Tower blowdown composition: pH will be in the range of 6.5 to 9.0, dissolved constituents with the exception of bicarbonate and sulfate will be those present in the potable water supply at a concentration factor of approximately 3 times. Sulfate will be higher and bicarbonate will be lower than three times the potable water concentrations due to the addition of sulfuric acid to the cooling water for pH adjustment to prevent carbonate scaling. Oxidizing biocide, corrosion inhibitor and dispersant chemical constituents will also be present as dissolved components of cooling tower blowdown.

Typical blowdown concentrations will be as follows:

- Phosphate = 4-12 ppm
- Epoxy carboxylate = 4-8 ppm
- Hydroxyl sulfate polymer = 5-10 ppm
- Copper inhibitor HRA = 2-4 ppm

Typical chemicals used in cooling tower water treatment are as follows:

- 96% Sulfuric Acid
- Continuum AEC3109
- Liquid Bromine

Heating Boiler blowdown contains potential concentrations of sulfites (50 ppm), neutralizing amine (10 ppm), phosphate (30 ppm), and polymer (40 ppm).

Discharge of routine plant liquid effluents will be to the **Treated Effluent Evaporative Basin** on the site. The Treated Effluent Evaporative Basin is utilized for the collection and containment of waste water discharge from the Liquid Effluent Collection and Treatment System. The ultimate disposal of

waste water will be through evaporation of water and impoundment of the residual dry solids' byproduct of evaporation. Total annual discharge to that basin will be approximately 2,535 m³ per year (669,844 gal/yr). Evaporation will provide the only means of liquid disposal from this basin. The Treated Effluent Evaporative Basin will include a double membrane liner and a leak detection system. To provide adequate chemical resistance to the various liquids, the liner material may consist of High Density Polyethylene (HDPE) or Ethylene Interpolymer Alloy (Coolgard[®] XR-5[®] or Ultra Tech[®]). Liner thickness will be specified during final design. Of the liquid effluent discharges to the basin, only uncontaminated liquid wastes are released to the Treated Effluent Evaporative Basin for evaporation without treatment. Contaminated liquid effluent is neutralized and treated for removal of uranium, as required, prior to discharge to the basin. Effluents unsuitable for the evaporative disposal will not be discharged to the basin. They will be removed off-site by a licensed contractor in accordance with regulatory requirements. The basin will have two synthetic liners with leak detection that will comply with the NM Environment Department Ground Water Pollution Prevention Sections, Guidelines for Liner Material and Site Preparation for Synthetically Lined Lagoons, December 11, 1995. The basin does not have an outlet.

The site will be served by six standard septic systems with leachfields to dispose of sanitary wastes at the site.

*** Note: Dry Residual Solids**

For the three basins: Site Stormwater Detention Basin (SSDB), UBC Storage Pad Stormwater Retention Basin (USPSRB) and the Treated Effluent Evaporative Basin (TEEB), dry residual solids are expected to consist principally of:

- Silt from rainwater runoff (SSDB and USPSRB), and
- Silt/sand from natural wind-blown materials (SSDB, USPSRB, and TEEB)

Minor constituents include:

- Concrete dust from the UBC Storage Pad (USPSRB)
- Trace amounts of residual non-volatile fractions of boiler blowdown chemicals: sulfites, neutralizing amine, phosphate, and polymer (USPSRB)
- Trace amounts of residual non-volatile fractions of Cooling Tower blowdown chemicals: sulfate (concentrated from potable water), oxidizing biocide, corrosion inhibitor, and dispersant chemical (USPSRB)
- Small residual amounts of uranium (TEEB)

4. Discharge Characteristics [20.6.2.3106.C.1 and 20.6.2.3108.C.4 NMAC]:

4.a. Quantity:

<p>Peak design discharge rate* in gallons per day (gpd) (design capacity of the treatment and disposal system):</p>	<p>SSDB: 15.6 million gpd USPSRB: 3.73 million gpd TEEB: 5,350 gpd ST/L 1: 40 gpd ST/L 2: 40 gpd ST/L 3: 2,275 gpd ST/L 4: 4,980 gpd ST/L 5: 3,020 gpd ST/L 6: 250 gpd</p>
<p>Average discharge rate on annual basis in gpd (actual flow):</p>	<p>SSDB: 99,850 gpd USPSRB: 37,750 gpd TEEB: 1,840 gpd (treated effluent only) ST/L 1: 20 gpd ST/L 2: 20 gpd ST/L 3: 1,140 gpd ST/L 4: 2,490 gpd ST/L 5: 1,510 gpd ST/L 6: 125 gpd</p>
<p>Methods used to meter or calculate discharge volume:</p>	<p><u>SSDB</u>: Peak and average discharge rates were calculated using peak precipitation event and average annual rainfall, respectively, times the area serviced assuming no infiltration or evaporation. <u>USPSRB</u>: Peak and average discharge rates were calculated using peak precipitation event and average annual rainfall, respectively, times the area serviced assuming no infiltration or evaporation. This amount was increased by the volume of blowdown from the cooling tower (13,840 gpd) and heating boiler (100 gpd). <u>TEEB</u>: Discharges are based on process flow calculations. The liquid effluent will be discharged in batch releases. All discharge volumes along with time of release will be maintained in log books based on tank volumes and release times for tank contents. <u>ST/L</u>: Design flow, based on the number of employees served, is derived from 20.7.3 NMAC; Septic tank specifications based on manufacturer's information from Richard Septic Systems, Inc. Peak flows based on design for 422 persons. Average flows based on actual employee count of 210.</p> <p>Additional details on the calculation of discharge volumes summarized above are provided in Attachment B.</p>

*Peak design discharge rate is the maximum volume of wastewater the system was designed to treat on a daily basis. This is generally based on the capacity of the different components of the system (size of lagoons, volume of tanks, etc.)

4.b. Quality: Add rows as necessary to include all contaminants and toxic pollutants.

Contaminant(s) or Toxic Pollutant(s) generally associated with facility type (contaminants of concern are listed in 20.6.2.7. and 20.6.2.3103 NMAC)	Influent Concentration (mg/L)	Effluent Concentration (mg/L)
SSDB:		
Total Dissolved Solids (TDS)	Note 1	Note 2
USPSRB:		
Total Dissolved Solids (TDS)	Note 3	Not Applicable
TEEB:		
Total Dissolved Solids (TDS)	Note 4	Not Applicable
Uranium	0.225	Not Applicable
ST/L:		
Total Dissolved Solids (TDS)	Note 5	Not Applicable

Notes:

1. Concentrations will be measured as part of sampling program. LES will provide this information to NMGWQB after initial sampling. They will be typical of industrial storm water runoff prior to settling basin.
2. Concentrations will be measured as part of sampling program. LES will provide this information to NMGWQB after initial sampling. They will be typical of industrial storm water runoff after settling basin.
3. Concentrations will be measured as part of sampling program. LES will provide this information to NMGWQB after initial sampling. For storm water component, they will be typical of industrial storm water runoff prior to settling basin. Blowdown TDS will range from 3 to 5 times the potable water supply obtained from the City of Hobbs.
4. Concentrations will be measured as part of sampling program. LES will provide this information to NMGWQB after initial sampling.
5. Concentrations will be typical of sanitary wastes.

4.c. Flow Characteristics:

Number of days per week discharge occurs:	SSDB: 7 days (Note 1) USPSRB: 7 days (Note 2) TEEB: 7 days (Note 3) ST/L: 7 days
Number of months per year discharge occurs (specify months):	12
Is flow continuous or intermittent:	SSDB: Intermittent USPSRB: Intermittent for storm water and for blowdown TEEB: Intermittent (periodic batch releases) ST/L: Continuous

Notes:

1. Flow is associated with precipitation runoff and is intermittent, but could occur on any day of the week or month of the year.
2. Flow is associated with precipitation runoff and blowdown (cooling tower and heating boiler). Flow associated with precipitation runoff is intermittent, but could occur on any day of the week or month of the year. Flow associated with blowdown is in batch releases and could occur on any day of the week or month of the year.
3. Flow is associated with periodic batch releases from Effluent Treatment System and could occur on any day of the week or month of the year.

5. Ground Water Conditions [20.6.2.3106.C.3 and 20.6.2.3108.C.5 NMAC]:

Sources for this information may be the New Mexico State Engineers Office, NMED, GWPPS web site (www.nmenv.state.nm.us), and USGS reports. If you do not have a TDS value, take a sample from the nearest well to the discharge location and submit the results from the analysis.

Depth to ground water below the discharge site:	Water-bearing unit: 214 to 222 feet bgl
Flow direction of ground water below the site:	South-southeast
Flow gradient of ground water below the site:	0.011 ft/ft
Reference* or source for depth, direction and gradient:	Hydrologic Investigation, Section 32; Township 21 Range 38, Eunice, NM, Cook-Joyce, Inc, Austin TX, 19 Nov, 2003.

* If determined from well logs, please provide photocopies of well logs with application. If depth is derived from a report include copies of appropriate pages and complete reference to report including author, title, and publication date.

Summary of Ground Water Conditions Under the Site

Ground water in the NEF site vicinity occurs sporadically, perched in the sand and gravel alluvium or localized pockets or in surface excavations north of the site, and to the east as detected in some monitoring wells on the adjacent property. This shallow ground water was not detected in 9 site borings or 3 monitoring wells on the site itself.

Nine borings were installed on the NEF site during the fall of 2003. The borings ranged in depth from 35 feet to 60 feet. The borings were gauged for a minimum of 24 hours and ground water was not identified in any of the nine borings.

Upon completion of the shallow subsurface ground water investigation, three monitor wells were drilled to a depth of 250 feet below ground surface.

In one of the three monitoring wells drilled at the NEF site a very limited ground water source was encountered at depth. Occurring at a depth of 214 to 222 feet below the ground surface, the source consists of a 15-foot thick zone of siltstone, and appears to correspond to a zone of intermittent ground water occurrence documented on the adjacent property to the east. This limited zone occurs within the Triassic redbeds of the Chinle formation, 150 feet to 200 feet thick, and generally an impermeable claystone. The site monitoring well providing water from the zone requires about a week to recover after purging for sampling. The hydraulic conductivity of the zone is calculated as 3.7×10^{-6} cm/sec, and the velocity of ground water flow in the zone is approximately 0.3 ft/yr. Based on data from monitoring wells to the east, ground water levels in this regime do not fluctuate much over time. Based on this information and the lack of ground water encountered in other site borings, the silt unit within the Chinle is not interpreted to meet the definition of an aquifer, which requires that the unit be able to transmit "significant quantities of water under ordinary hydraulic gradients."

The first occurrence of a defined aquifer beneath the site is the Triassic-aged Santa Rosa Formation, almost 800 ft below the land surface at the NEF site. The presence of the thick Chinle formation clay beneath the site essentially isolates that deep hydrologic system.

Attachment C is a copy of the Final Report of the Hydrologic Investigation for the site. It provides all backup ground water information for the site including borings logs for the nine shallow ground water investigation borings, the five geotechnical borings and the construction summaries for the three monitoring wells.

Total Dissolved Solids (TDS) concentration (mg/L) of ground water below the site:	2,500 to 6,650 mg/L
Reference or source for TDS:	NEF Environmental Report Sections 3.4.2 and 3.4.15 and Table 3.4.3 (Note 1)

Note:

1. TDS based on samples from site monitoring wells that ranged from 2,500 to 6,000 mg/L. This is supplemented by data from monitoring wells located on property directly east of the NEF that ranged from 2,880 to 6,650 mg/L.

TECHNICAL ADEQUACY

To be deemed technically adequate, for purposes of issuing the discharge permit, the following information must be provided. [20.6.2.3106, 20.6.2.3107, 20.6.2.3109 NMAC]. Operational, monitoring, contingency, and closure plans must be submitted and must be appropriate for the proposed treatment and disposal type and meet the site specific conditions for the proposed facility.

6. Permit Plans [20.6.2.3106.C.7, 20.6.2.3107.A, and 20.6.2.3109.C NMAC]:

6.a. Operational Plan [20.6.2.3106.C.7 and 20.6.2.3109.C NMAC]:

The operational plan must describe how the system(s) for conveyance, collection, treatment, distribution, and disposal of wastewaters or other discharges will be constructed, operated, inspected, and maintained. The operational plan must demonstrate that ground water standards will not be exceeded.

6.a.i. In the following table, identify all proposed conveyance, collection, treatment distribution, and disposal units included in the operational plan. Add rows as necessary to include all units.

<p align="center">Treatment/Storage/ or Disposal Unit</p> <p>Treatment units (lagoon, mechanical treatment plant, manure separator, clarifier, etc.)</p> <p>Disposal Units (land application area, leachfield, evaporative lagoon, leachstockpile, etc.)</p>	<p align="center">Construction Material</p>	<p align="center">Volumetric Capacity*/Area* (gallons or cubic yards/ acres)</p>
<p>Disposal Unit: Site Storm Water Detention Basin (SSDB) – The ultimate disposal of basin water (site storm water runoff) will be through infiltration to the ground and evaporation.</p>	<p>The basin will be constructed using a combination of excavation below the ground surface and an earth berm above grade. The basin is unlined. The basin will have a minimum of 2 feet of freeboard. The basin will have an outfall. The outfall will consist of a concrete structure with a discharge pipe sized and located to provide the proper flow attenuation.</p> <p>The basin will be maintained free of debris and will be enclosed by a fence to prevent entry by animals and unauthorized personnel.</p>	<p>The basin is sized to contain runoff for a volume equal to that for the 24-hour, 100-year return period storm.</p> <p>The basin will have approximately 23,350 m³ (100 acre-ft) of storage capacity.</p> <p>Surface Area at High Water Elevation = 19.0 acres.</p>
<p>Disposal Unit: UBC Storage Pad Storm Water Retention Basin (USPSRB) – The ultimate disposal of basin water (UBC Storage Pad storm water runoff, Cooling Tower blowdown and Heating Boiler blowdown) will be through evaporation.</p>	<p>The basin will be constructed using a combination of excavation below the ground surface and an earth berm above grade. The basin is designed with a synthetic membrane lining to minimize any infiltration into the ground and does not have an outlet. The synthetic liner will be used to impose a barrier between the contents of the basin and the underlying soils and potential access to ground water. Access to any ground water is further impeded by the impervious clay layer underlying the liner. The basin liner will be selected and installed in accordance with NMED Guidelines for Liner Material and Site Preparation for Synthetically-Lined Lagoons, dated December 11, 1995.</p> <p>To provide adequate chemical resistance to the various liquids, the liner material may consist of High Density Polyethylene (HDPE) or Ethylene Interpolymer Alloy (Coolgard[®] XR-5[®] or Ultra</p>	<p>The basin is sized to contain runoff for a volume equal to twice that for the 24-hour, 100-year return frequency storm.</p> <p>The design volume is approximately 77,700 m³ (63 acre-ft).</p> <p>Surface Area at High Water Elevation = 18.9 acres.</p>

	<p>Tech[®]). Liner thickness will be specified during final design.</p> <p>From the bottom up the proposed liner system will consist of:</p> <ul style="list-style-type: none"> • A prepared layer, minimum 2-foot thick, of on site clay-type soils, free from rock, compacted at optimum moisture content to 95% of Standard Proctor ASTM D698. The plastic limit of the clay will be approximately 20 and the material will be compacted to +3% of its optimum moisture content. • A geosynthetic fabric suitable for the material being retained. • A prepared layer, minimum 1-foot thick, of on site clay, free of rock, and compacted at optimum moisture content • Installation of the liner will be by manufacturer certified installers and will be installed and tested according to project specifications. <p>The basin will be maintained free of debris and will be enclosed by a fence to prevent entry by animals and unauthorized personnel.</p>	
<p>Disposal Unit: Treated Effluent Evaporative Basin (TEEB) – The ultimate disposal of liquid effluent from the Liquid Effluent Collection and Treatment System will be through evaporation.</p>	<p>The basin will be constructed using a combination of excavation below the ground surface and an earth berm above grade. The basin will be double-lined and provided with a leak detection system. The two synthetic liners are used to impose two barriers between the contents of the basin and the underlying soils and potential access to ground water. Access to any ground water is further impeded by the impervious clay layer underlying the liner. These synthetic liners are known as the primary (upper) and secondary (lower) liner. The basin is designed with a synthetic membrane lining to preclude any infiltration into the ground. The basin does not have an outlet. The basin liner will be selected and installed in accordance with NMED Guidelines for Liner Material and Site Preparation for Synthetically-Lined Lagoons, dated December 11, 1995.</p> <p>Access to ground water is further impeded by the impervious clay layer which underlies the secondary liner.</p> <p>Active liquid-sensor leak detection will be provided to detect leakage through the upper primary liner. The system is a drain/sump system.</p> <p>The chemical compatibility of the liners has been</p>	<p>Total annual discharge will be approximately 2,535 m³ per year (669,844 gal/yr).</p> <p>The basin has a surface area of 0.75 acres and a maximum normal operating depth of 1.1 feet above the bottom of the basin. Total basin depth is 4.2 feet.</p> <p>Surface Area at High Water Elevation = 1.75 acres</p>

verified with the liner manufacturer.

To provide adequate chemical resistance to the various liquids, the liner material may consist of High Density Polyethylene (HDPE) or Ethylene Interpolymer Alloy (Coolgard[®] XR-5[®] or Ultra Tech[®]). Liner thickness will be specified during final design.

From the bottom up the proposed liner system will consist of:

- A prepared layer, minimum 2-foot thick, of on site clay-type soils, free from rock, compacted at optimum moisture content to 95% of Standard Proctor ASTM D698. The plastic limit of the clay will be approximately 20 and the material will be compacted to +3% of its optimum moisture content.
- A geosynthetic fabric suitable for the material being retained.
- Leak collection piping, sump, and pumping system to pump any leaks back to the primary liner system.
- A geomembrane drainage mat with the imbedded leak collection piping.
- A geosynthetic fabric suitable for the material being retained
- A prepared layer, minimum 1-foot thick, of on site clay, free of rock, and compacted at optimum moisture content
- Installation of the liner will be by manufacturer certified installers and will be installed and tested according to project specifications.

The basin does not have an outlet.

The basin is designed to retain 30 years of solids accumulation and annual liquid effluent discharge and direct rainfall. The basin is sized to include a safety factor of 200% times the maximum storm water from a single rainfall event. The basin is designed for an annual evaporation of 80 inches per year.

The basin is designed with two cells, each designed to evaporate 50% of the annual liquid effluent discharge, allowing for periodic outages of each cell, while maintaining plant operations. Influent flow will be measured and totalized. Pond level gauges will be provided.

The basin will be maintained free of debris and will be enclosed by a fence to prevent entry by animals and unauthorized personnel. The basin

	will be covered by surface netting, or other suitable devices, to exclude waterfowl access to basin water.	
<p>Disposal Unit: Septic Tanks and Leachfields (ST/L) – The ultimate disposal is discharge underground via the leachfields.</p>	<p>Septic tank drain field systems will be constructed in accordance with 20.7.3 NMAC and requirements of the local building officials and health department.</p> <p>During final design the proposed location, length of drain field and orientation of septic systems will be selected by the design engineer and approved in the field by local building officials.</p>	<p>The percolation rate established by actual tests on the site is 8 minutes per inch. Utilizing this rate and allowing for 20-30 gallons per person per day, each person will require approximately 9 linear foot of trench utilizing a 36 inch wide trench filled with 24 inches of open graded crushed stone.</p> <p>The site population during operation is expected to be 210 persons. The building facilities are designed by architectural code analysis to accommodate approximately 420 persons. A total of approximately 3,200 linear feet of percolation drain field will be required.</p> <p>Thus the combined area of the leachfields will be approximately 9,600 ft².</p>

*Volumetric Capacity must be provided for all tanks, chambers, and impoundments or other storage units.

*Area must be provided for all land application areas, leachfields or other area features.

6.a.ii. Describe in detail the operational plan, including all conveyance, collection, treatment, distribution and disposal systems. Attach additional pages as necessary:

Site Storm Water Detention Basin

The Site Storm Water Detention Basin collects a portion of general site storm water from plant areas (except for the UBC Storage Pad area). Site runoff will be collected through a series of catch basins and roof drains connected to the site underground storm water system. The runoff will be conveyed to the basin via a system of underground pipes. All runoff will be discharged into the basin.

The NEF also will have a diversion ditch and berm to divert any upstream surface runoff (overland sheet flow) around the facility. The east portion of this diversion ditch also discharges through the Site Storm Water Detention Basin. The storm water from the diversion ditch will be routed through the basin, but will not be changed in either volume or runoff rate. The western portion of the diversion ditch will drain into the natural terrain and will eventually flow into the culvert system under New Mexico Highway 234. This diversion ditch will be designed to divert the 100-year return period storm around the plant structures.

This basin will have an outlet. The basin is designed to cause post-construction peak flow runoff rates to equal or be less than pre-construction release rates for the facility site runoff. The basin will be below 100 acre-feet of storage capacity and less than 15 feet in height. No treatment is provided for in the basin other than some settlement of solids in the runoff.

No plant contaminants are expected to be introduced to this discharge as a result of plant operation. The ultimate disposal of basin water will be through infiltration to the ground and evaporation. The runoff area served includes about 39 ha (96 acres) with the majority of that area being the developed portion of the 220 ha (543 acres) National Enrichment Facility site.

UBC Storage Pad Storm Water Retention Basin

UBC Storage Pad Storm Water Retention Basin is used for the collection of liquid effluent discharges from three sources: 1) storm water runoff from the UBC Storage Pad (8,691,000 gal/yr); 2) the cooling tower blowdown (5,050,000 gal/yr); and 3) the heating boiler blowdown water (36,500 gal/yr). Area served by the basin for storm water runoff includes 9.2 ha (22.8 acres), the total area of the UBC Storage Pad.

Trench drains/catch basins inside the UBC Storage Area will collect storm water within a bermed/sloped area of approximately 22.8 acres. The underground piping system conveying the flow away from the UBC Storage Area will be reinforced concrete pipe with rubber gasketed joints. The underground piping system will discharge into the basin.

The discharge to this basin has a low likelihood of containing trace amounts of uranium washed by rainfall from the exterior of the Uranium Byproduct Cylinders (UBCs) stored on the UBC Storage Pad. Monitoring of the basin will be performed to verify the runoff does not contain uranium.

Blowdown from the Cooling Towers and the Heating Boiler will be routed to the basin via underground piping.

No treatment is provided for in the basin. The basin is designed with a synthetic membrane lining to minimize any infiltration into the ground and does not have an outlet. The synthetic liner will be used to impose a barrier between the contents of the basin and any natural soils and potential access to the underlying soil. The ultimate disposal of basin water will be through evaporation.

Treated Effluent Evaporative Basin

The Treated Effluent Evaporative Basin receives discharge from the Liquid Effluent Collection and Treatment System. A description of the Liquid effluent Collection and Treatment System is provided in Attachment D. This description was adapted from the NEF Safety Analysis Report.

No treatment is provided for in the basin. The basin is designed with a double synthetic membrane lining system to preclude any infiltration into the ground. The basin does not have an outlet. The ultimate disposal of basin water will be through evaporation.

The basin area will be enclosed by a fence to prevent entry by animals and unauthorized personnel and the basin surface will contain a layer of netting or other suitable device to exclude waterfowl.

The facility's Liquid Effluent Collection and Treatment System provides a means to control liquid effluent within the plant including the collection, analysis, and processing of plant liquid effluents for disposal. Numerous types of aqueous and non-aqueous liquid effluents are generated in the NEF. These effluents may contain uranic compounds, may be potentially contaminated with low-levels of uranic compounds, or may be non-contaminated. Table E.1 in Attachment E summarizes the plant sources of potential effluent contamination

prior to treatment. Treated effluent from the NEF Liquid Effluent Collection and Treatment System is analyzed prior to release and pH adjusted to fall within the range of 6.5 to 9.0, which complies with the ground water standards of 20.6.2.3103 NMAC. Other than uranic content and pH, the plant processes should not affect or introduce any of the other water contaminants listed in 20.6.2.3103 NMAC to the NEF effluent that is discharged to the Treated Effluent Evaporative Basin.

The Liquid Effluent Collection and Treatment System will be constructed with appropriate corrosion resistant metallic or plastic materials. None of the effluents are of a chemical nature that require special construction materials. All process piping in the Liquid Effluent Collection and Treatment System is designed in accordance with American Society of Mechanical Engineers, ASME B31.3 process piping. To provide system integrity and prevent leaks, welded construction is used everywhere practical. All collection tanks are designed in accordance with the American Water Works Association (AWWA) or ASME standards. All tanks have inspection hatches. The tanks and piping of the system are periodically inspected and there are a number of check valves, gauges and other process enunciators and warning lights that provide the plant control room operator clear indications of process equipment failures and malfunction before an adverse environmental condition can develop.

The treated effluent from the Liquid Effluent Collection and Treatment System is discharged to the Treated Effluent Evaporative Basin (TEEB), located just east of the UBC Storage Pad Storm Water Retention Basin (see Attachment A, NEF Detailed Site Map). The TEEB is provided for the collection and containment of the liquid effluent discharge from the Liquid Effluent Collection and Treatment System. Total annual discharge to the TEEB will be approximately 2,535 m³/yr (669,844 gal/yr). The liquid effluent will be discharged in batch releases. The calculated average discharged concentration of uranic compounds into the TEEB (0.22 mg/L) is well below the 5 mg/L concentration limit listed in 20.6.2.3103 NMAC. The ultimate disposal of the liquid effluent discharge will be through evaporation of water and permanent impoundment of the residual dry solids by product evaporation.

On an annual basis approximately 570 grams (1.26 lbs) of uranic compounds will be discharged to the basin. The compounds are uranyl fluoride UO₂F₂ and uranium tetrafluoride UF₄ in both soluble and insoluble states.

Septic Tanks and Leachfields

The Septic System is designed to collect, transport and treat all domestic sewage generated at the NEF. The system is capable of handling approximately 10,600 gal/day based on a design number of employees of 422.

Based on the actual number of employees, 210, the system will receive approximately 5,300 gal/day.

The system includes multiple septic tanks and drain fields. A total of six septic tanks and fields are located around the site.

Conveyance, collection, treatment, distribution and disposal of septic wastes are provided by six separate septic systems including separate tanks and leachfields installed at various locations around the site (See Attachment A, NEF Detailed Site Map). Total annual design discharge will be approximately 3.87 million gal/yr. Designs will be consistent with NMED's Guidelines for Plans and Specifications for Discharge Permit Applications Using Septic Tank/Leachfields. Actual flows will be approximately 50 percent of the design values.

The percolation rate established by actual tests on the site is 8 minutes per inch. Utilizing this rate and allowing for 20-30 gallons per person per day, each person will require 9 linear foot of trench utilizing a 36 inch wide trench filled with 24 inches of open graded crushed stone.

The site population during operation is expected to be 210 persons. The building facilities are designed by architectural code analysis to accommodate up to 420 persons. Therefore a total of approximately 3,200 linear feet of percolation drain field will be required. Thus the combined area of the leachfields will be approximately 9,600 ft².

20.6.2.3109.C Approval Demonstration

The NEF Ground Water Discharge Plan addresses the three basins (Site Stormwater Detention Basin (SSDB), UBC Storage Pad Stormwater Retention Basin (USPSRB), and the Treated Effluent Evaporative Basin (TEEB)) and the series of septic systems. Periodic sampling and testing of discharges to the basins and sampling of ground water in monitoring wells at the site will assure no adverse ground water impacts.

The discharges resulting from the operation of the NEF are approvable under 20.6.2.3109.C NMAC because (1) the discharges will not exceed the ground water standards of 20.6.2.3103 NMAC and will not contain a toxic pollutant within the meaning of 20.6.2.7.VV NMAC; (2) the amount of effluent entering the subsurface from the TEEB will be minimized by use of double synthetic liners; (3) the amount of effluent entering the subsurface from the USPSRB will be minimized by use of a synthetic liner; and (4) the site discharges will not cause or contribute to concentrations in ground water in excess of the ground water standards in 20.6.2.3103 NMAC at a place of withdrawal for present or reasonably foreseeable future use.

Water quality impacts will be controlled during construction by compliance with the State of New Mexico's water quality regulations and the use of best management practices (BMPs) as detailed in the site Stormwater Pollution Prevention Plan (SWPPP). A SWPPP and a Spill Prevention, Control and Countermeasure (SPCC) plan will be implemented for the operating facility to minimize the possibility of spills of hazardous substances, minimize the environmental impact of any spills and ensure prompt and appropriate remediation.

The SSDB will receive runoff from various parts of the site including roads, parking areas and building roofs. The quality of the runoff will be typical of industrial facility stormwater runoff. The runoff is expected to meet the standards in 20.6.2.3103 NMAC. Some of the runoff will infiltrate into the ground under the basin. The infiltrated waters are expected to potentially recharge the limited ground water system at the 214 to 222 foot depth or return to the atmosphere via evapotranspiration. This ground water regime is not a reliable source of ground water supply. This is demonstrated by the difficulty in obtaining water samples at NEF and the adjacent facility, Waste Control Specialists (WCS), from this layer. No uranium or other plant constituents are expected to be contained in this runoff. The runoff is not expected to contain any of the toxic pollutants as defined in 20.6.2.7.VV NMAC. The runoff to the basin will be monitored as part of the site monitoring program. The basin has a single outlet and has sufficient freeboard so as not to overflow during extreme rainfall events (equal to the volume of the 24-hour, 100-year return period rainfall event). Therefore, based on the above, even if any of the infiltrated waters reach the ground water, the applicable ground water standards in 20.6.2.3103 NMAC will be met.

The USPSRB will receive runoff from the UBC Storage Pad and blowdown (cooling tower and heating boiler). The quality of the stormwater runoff will be typical of industrial facility stormwater runoff. The runoff and blowdown waters discharged to the basin are expected to meet the standards in 20.6.2.3103 NMAC. No uranium or other plant constituents are expected to be contained in this runoff. The runoff is not expected to contain any of the toxic pollutants as defined in 20.6.2.7.VV NMAC. The runoff to the basin will be monitored as part of the site monitoring program. The single lined basin will limit any infiltration into the ground.

The basin is designed with a synthetic membrane lining to minimize any infiltration into the ground and does not have an outlet. The synthetic liner will be used to impose a barrier between the contents of the basin and the underlying soils and potential access to ground water. Access to any ground water is further impeded by the impervious clay layer underlying the liner. The basin liner will be selected and installed in accordance with

NMED Guidelines for Liner Material and Site Preparation for Synthetically-Lined Lagoons, dated December 11, 1995. To provide adequate chemical resistance to the various liquids, the liner material may consist of High Density Polyethylene (HDPE) or Ethylene Interpolymer Alloy (Coolgard[®] XR-5[®] or Ultra Tech[®]). Liner thickness will be specified during final design.

Any minor leakage past the liner will infiltrate into the ground under the basin. The infiltrated waters are potentially expected to recharge the limited ground water system at the 214 to 222 foot depth or return to the atmosphere via evapotranspiration. This ground water regime is not a reliable source of ground water at the site. This is demonstrated by the difficulty in obtaining water samples at NEF and WCS from this layer. The basin has no outlet and has sufficient freeboard so as not to overflow during extreme rainfall events (twice the volume of the 24-hour, 100-year return period rainfall event). Therefore, based on the above, it is concluded that even if any of the basin waters infiltrated into the ground, the applicable ground water standards provided in 20.6.2 NMAC will be met.

The TEEB will receive discharge from the plant Liquid Effluent Collection and Treatment System. The facility's Liquid Effluent Collection and Treatment System provides a means to control liquid effluent within the plant including the collection, analysis, and processing of plant liquid effluents for disposal. These effluents may contain uranic compounds, may be potentially contaminated with low-levels of uranic compounds, or may be non-contaminated. Treated effluent from the NEF Liquid Effluent Collection and Treatment System is analyzed prior to release and pH adjusted to fall within the range of 6.5 to 9.0, which complies with the ground water standards of 20.6.2.3103 NMAC. Other than uranic content and pH, the plant processes should not affect or introduce any of the other water contaminants listed in 20.6.2.3103 NMAC to the NEF effluent that is discharged to the TEEB. The discharge to the TEEB is not expected to contain any of the toxic pollutants as defined in 20.6.2.7.VV NMAC. The discharge to the basin will be monitored as part of the site monitoring program. The basin has no outlet and has sufficient freeboard so as not to overflow during extreme rainfall events (twice the volume of the 24-hour, 100-year return period rainfall event).

The TEEB is designed with double synthetic membrane linings to minimize any infiltration into the ground and does not have an outlet. The synthetic liners will be used to impose a barrier between the contents of the basin and the underlying soils and potential access to ground water. Access to any ground water is further impeded by the impervious clay layer underlying the lower liner. The basin liners will be selected and installed in accordance with NMED Guidelines for Liner Material and Site Preparation for Synthetically-Lined Lagoons, dated December 11, 1995. To provide adequate chemical resistance to the various liquids, the liner material may consist of HDPE or Ethylene Interpolymer Alloy (Coolgard[®] XR-5[®] or Ultra Tech[®]). Liner thickness will be specified during final design.

Any minor leakage past the primary liner will be collected by the leak detection system. Annual discharge to the basin is 669,884 gallons per year (approximately 2.1 acre-feet per year). The double-lined basin with leak detection will impose a barrier between the contents of the basin and the underlying soils and potential access to ground water. Based on the above, all applicable ground water standards provided in 20.6.2.3103 NMAC will be met.

Moreover, any leak past the primary (upper) liner would be collected by a piping collection system and routed to a monitored sump. The sump will be continuously monitored with a level indicator. If the sump is collecting liquid the level monitor will alert site staff and compensatory measures will be taken. The secondary (lower) liner will preclude discharge to the subsurface in the case of a breach in the primary liner.

Catastrophic failure of both TEEB liners is not considered credible. Such a failure, if it were to occur, should be noticeable to plant staff due to rapid draining of any discharge into the TEEB. Given the average discharge to the TEEB is 1,835 gal/day, corrective actions would be taken before appreciable amounts of liquid reached the

subsurface. Since the discharge liquid effluent quality meets all 20.6.2.3103 NMAC standards, no adverse impacts would occur. The corrective actions taken would restore the system integrity.

The Site Septic Systems will discharge to the subsurface approximately 5,300 gallons per day for the 210 site employees. The quality of the discharge will be typical of sanitary wastes. The infiltrated waters are expected to potentially recharge the limited ground water system at the 214 to 222 foot depth or return to the atmosphere via evapotranspiration. This ground water regime is not a reliable source of ground water. This is demonstrated by the difficulty in obtaining water samples at NEF and WCS from this layer. The deeper Santa Rosa aquifer is well isolated from the septic system discharge. No uranium or other plant constituents are expected to be contained in this discharge. The discharge is not expected to contain any of the toxic pollutants as defined in 20.6.2.7.VV NMAC. The total surface area of the leach fields is 9,600 square feet. Given this area, the discharge rate of 5,300 gallons per day and approximately a 200-foot vertical separation between the leach fields and the limited ground water, travel time to the limited ground water source from the leach fields will be substantial. Therefore, based on the above, even if any of the infiltrated waters were to reach the ground water, the applicable ground water standards in 20.6.2.3103 NMAC will be met.

The limited ground water at a depth of 214 to 222 feet below the ground surface at NEF has a TDS concentration range between 2,500 to 6,650 mg/L. This range is based on data collected at NEF and WCS.

Very limited ground water was encountered at a depth of 214 to 222 feet below the ground surface at the site. To be ground water for which the standards are applicable, 20.6.2.7.Y NMAC requires that the water be capable of entering a well in sufficient amounts to be utilized as a water supply. The limited ground water source is demonstrated by the difficulty in obtaining ground water samples in the installed monitoring wells at the site and the slow recovery of the wells after sampling. Based on field studies at both NEF and WCS, sufficient ground water in this zone is not available under either site. The much deeper Santa Rosa aquifer is isolated from the surface by a substantial thickness of Chinle clay. Depth to the Santa Rosa aquifer is approximately 244 m (800 ft). This aquifer is separated from the surface by a thick (over 180 feet) red bed clay unit, the Chinle Formation. At the adjacent facility, WCS, water from the Santa Rosa is used as fire water and for some process systems. It is not used for potable water. Water from the Santa Rosa is also used locally as a source of water for cattle. These site features (limited ground water at a depth of 214 to 222 feet below the site and the well isolated Santa Rosa aquifer) negate any significant potential that ground water could be adversely impacted by plant discharges to the subsurface.

Based on the above, the discharges resulting from the operation of the NEF are approvable under 20.6.2.3109.C NMAC.

6.a.iii. Describe the operations and maintenance plan that will be followed to ensure the system is maintained as described. At a minimum the plan must include monthly inspections of all wastewater treatment and disposal units. Attach additional pages as necessary.

The Operations and Site Storm Water Detention Basin

The SSDB will be inspected monthly for debris, obstructions and other impediments to water flow. The SSDB outfall discharge point will also be inspected monthly to ensure the outfall is unobstructed so that storm water overflow is discharged in a controlled manner that does not cause soil erosion or wash-out areas near New Mexico Highway 234. Maintenance issues identified during the periodic inspections will be addressed to ensure proper system operation by implementing corrective measures. Since the SSDB contains only site rainwater runoff, there is little, or no possibility of plant-related contaminants entering the SSDB. The areas adjacent to and nearby the SSDB will be protected from site sources that could introduce contaminants through

the use of best management practices (BMPs). These BMPs will include: 1) site stabilization actions such as placing crushed stone on top of disturbed soil in areas of heavy runoff; 2) protection of disturbed areas with silt fencing and straw bales; 3) berming of all above-ground diesel storage tanks; 4) any hazardous materials will be handled by approved methods and shipped offsite to disposal sites, no hazardous waste will be stored onsite longer than 90 days; and 5) a Spill Prevention Control and Countermeasure (SPCC) plan will be implemented for the facility to identify potential spill substances, sources and responsibilities.

UBC Storage Pad Storm Water Retention Basin

The basin and UBC Storage Pad conveyance systems will be inspected on a monthly basis for debris, obstructions and other impediments to water flow. The UBC Storage Pad will be inspected for cracks in the concrete surface, and vegetation growth between expansion joints in the concrete surface. The basin will be inspected for build-up of solids. Maintenance issues identified during the periodic inspections will be addressed to ensure proper system operation by implementing corrective measures.

The UBC Storage Pad Storm Water Retention Basin is designed with two cells, each designed to evaporate 50% of the annual influent flow, allowing for periodic outages of each cell, while maintaining the plant operations. The design depth of the basin will be sufficient to allow for one annual outage of one month duration for inspection and maintenance of each cell. Influent flow will be measured and totalized; basin gauges will be provided. An all-weather access road will be provided to the basin to allow year-round maintenance of the basin and its conveyances. The added concentrations of biocides, corrosion inhibitors, dissolved solids, sulfates and pH adjusting chemicals in blowdown waters will be monitored and recorded periodically in accordance with the manufacturers' recommendations.

Periodic sampling of the basin water and basin sediments will allow for detection of radioactivity in the very unlikely event of radioactivity from the exterior of the Uranium Byproduct Cylinders (UBCs) entering the basin at above background levels.

Treated Effluent Evaporative Basin

The basin will be inspected on a monthly basis for debris, obstructions, other impediments to water flow and for the build-up of solids in the basin. Maintenance issues identified during the periodic inspections will be addressed to ensure proper system operation by implementing corrective measures.

The TEEB is designed with two cells, each designed to evaporate 50% of the annual influent flow, allowing for periodic outages of each cell, while maintaining the plant operations. The design depth of the basin will be sufficient to allow for one annual outage of one month duration for inspection and maintenance of each cell. Influent flow will be measured and totalized; basin gauges will be provided. An all-weather access road will be provided to the basin to allow year-round maintenance of the basin and its conveyances. The basin area will be enclosed with animal-friendly fencing to prevent wildlife access and unauthorized personnel. A surface net or equivalent covering will be placed over the basin to prevent the landing of waterfowl and other birds.

Two synthetic liners will be utilized to impose two barriers between the contents of the TEEB and the soil underneath. Access to the soil underneath is further impeded by the impervious natural clay layer. In addition, a drainage/sump leak detection system will be installed between the liners to detect liner failures. The leak detection system will be inspected monthly to monitor for any leakage. Periodic sampling of the TEEB water and sediment will ensure that the uranic concentrations of both are not above the levels expected for the discharge effluent from the Liquid Effluent Collection and Treatment System.

Site Septic System

The site septic system consists of six separate tanks each with one or more leachfields. Each tank will be periodically inspected and pumped for solids and each distribution manifold in the leachfield will be inspected, and if necessary, cleaned and repaired at the time of the solids pumping. A sample of the solids will be collected and analyzed for isotopic uranium to verify the absence of plant uranic materials in the tank sludge.

6.b. Monitoring Plan [20.6.2.3106.C.5 and 20.6.2.3107.A.1-9 NMAC]:

The monitoring plan must describe how the facility will be monitored to ensure the discharge will not adversely impact ground water quality. The plan must include all monitoring locations (effluent sampling, monitoring wells, lagoons, soil sampling, plant tissue analysis, etc.). Monitoring locations must be included on the facility map.

The NEF Monitoring Plan developed for the Ground Water Discharge Plan will incorporate the applicable requirements outlined in 20.6.2.3107 NMAC, in addition to other monitoring requirements at the NEF. Features of the overall monitoring plan are described below. Further details are provided in Attachment E.

The NEF Detailed Site Map (see Attachment A) indicates the location of onsite sampling locations. Media monitored includes soil, vegetation, basin water, basin sediment and ground water.

Each year, the NEF will submit a summary report of the environmental sampling program to the NMED, including all associated data as required by 20.6.2 NMAC. The report will include the types, numbers, and frequencies of environmental measurements and the identities and activity concentrations of facility-related nuclides found in environmental samples, in addition to the minimum detectable concentrations (MDC) for the analyses and the error associated with each data point. Significant positive trends in activities will also be noted in the report, along with any adjustment to the program, unavailable samples, and deviation to the sampling program.

6.b.i. Monitoring Locations. In the following tables, identify all monitoring locations. Add additional rows as necessary to include all monitoring locations.

Flow, Effluent and Ground Water Monitoring

Monitoring Location	Lat	Long	Northing	Easting	Elevation (also specify at what point in well casing)	Sampling Frequency per year	Reporting Frequency per year	Water or Soil Contaminant Type (please refer to 20.6.2.7.uu, and 20.6.3103 NMAC)
SSDB ¹	32° 25' 51"	103° 04' 41"	522743	928641	3393	Quarterly	Annual	Oil & grease, pH, uranium isotopic, fluoride, TDS, metals, nitrates, sulfate
USPSRB ²	32° 26' 02"	103° 03' 03"	523955	937027	3396	Quarterly	Annual	Oil & grease, pH, uranium isotopic, fluoride, TDS, metals, nitrates, sulfate
TEEB ³	32° 26' 2"	103° 4' 55"	523841	927428	3409	Quarterly	Annual	pH, uranium isotopic, fluoride, TDS, metals, sulfate
GW Well MW-1 ⁴	32° 26' 32"	103° 04' 58"	526870	927135	Well not installed	Quarterly	Annual	pH, uranium isotopic, fluoride, TDS, sulfate
GW Well MW-2 ⁴	32° 26' 13"	103° 04' 46"	524962	928186	Well not installed	Quarterly	Annual	pH, uranium isotopic, fluoride, TDS, sulfate
GW Well MW-3 ⁴	32° 26' 13"	103° 05' 05"	524943	926558	Well not installed	Quarterly	Annual	pH, uranium isotopic, fluoride, TDS, sulfate
GW Well MW-4 ⁴	32° 25' 54"	103° 05' 04"	523023	926666	Well not installed	Quarterly	Annual	pH, uranium isotopic, fluoride, TDS, sulfate
GW Well MW-5 ⁴	32° 25' 47"	103° 04' 32"	522348	929417	Well not installed	Quarterly	Annual	pH, uranium isotopic, fluoride, TDS, sulfate
LECTS ⁵ Discharge	To be provided in final design	To be provided in final design	To be provided in final design	To be provided in final design	To be provided in final design	Batch Release	Annual	pH, isotopic uranium, both soluble and insoluble forms
Septic Tanks	Varies	Varies	Varies	Varies	Varies	Prior to Pumping	Annual	isotopic uranium, both soluble and insoluble forms

1. Site Storm Water Detention Basin: flow only occurs during precipitation events
 2. UBC Storage Pad Storm Water Retention Basin
 3. Treated Effluent Evaporative Basin
 4. Ground Water Monitoring Well
 5. Liquid Effluent Collection & Treatment System pre-release tank sampling
- *Identify the sampling locations as designated or named by the facility.

Soil, Plant Tissue and Other Sampling

Monitoring Location*	Lat¹	Long¹	Sampling Frequency per year	Reporting Frequency per year	Water or Soil Contaminant Type
land application area soil sampling	NA				
land application area plant tissue analysis	NA				
Other: Soil/Vegetation	32° 25' 56"	103° 5' 26"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 25' 50"	103° 4' 55"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 25' 47"	103° 4' 32"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 25' 49"	103° 4' 45"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 26' 8"	103° 4' 27"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 26' 33"	103° 4' 35"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 26' 32"	103° 4' 58"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Soil/Vegetation	32° 26' 20"	103° 5' 26"	Quarterly ²	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Sediment SSDB	32° 25' 52"	103° 4' 35"	Annual	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Sediment UBCSR	32° 26' 7"	103° 5' 2"	Annual	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides
Other: Sediment TEEB	32° 26' 2"	103° 4' 55"	Annual	Annual	Isotopic U, Fluoride, metals, organics, pesticides and herbicides

1. Approximate locations, exact locations will be determined during final design
2. Samples in growing seasons for vegetation only

6.b.ii. Describe in detail the sampling protocols that will be used for sample collection at all monitoring locations. Attach additional pages as necessary.

The sample collector shall be required to don the appropriate personal protective equipment, safety equipment and have a companion collector in remote areas or when collecting at sites that may involve physical hazards (basins, culverts, septic tanks, etc.). In addition, all collection containers shall be labeled with the site identification information, GPS coordinates, date and time of the collection, the collectors name and phone number and the requested analyses. A laboratory sample submission form and a sample chain of custody form will be completed by the collector before transferring custody of the sample to someone else. Normal chain-of-custody procedures will be observed at all times and tamper-proof tape should be used on all container covers and lids. All sampling will be covered by procedures and sample collectors will be trained to these sampling procedures.

Sampling protocol details are provided in Attachment F for the following media:

- Water
- Basin Bottom Sediment
- Vegetation
- Soil
- Ground Water

The protocols address the actual collection of the sample, the amount of the sample, field addition of preserving chemicals if required, the container, container labeling, sample submission forms and shipping requirements.

6.b.iii. Standard Monitoring Requirements: The following paragraphs are standard permit conditions. Please read the condition and check the boxes that you will comply with as a condition of your permit.

- All monitoring wells will be installed according to NMED Monitoring Well Construction and Abandonment Guidelines (copy enclosed).
- All monitoring wells (if 3 or more monitoring wells are on site) will be surveyed to a common permanent benchmark and that the survey will be submitted to the NMED, GWQB within 60 days of installation of all monitoring wells. Survey data will include northing, easting, and elevation to the nearest hundredth of a foot. One of the wells may be used as the benchmark.
- This facility will measure the depth to ground water in each monitoring well to the nearest hundredth of a foot prior to purging and sampling, and that three well volumes will be purged from each monitoring well prior to sample collection.
- This facility will complete land application data sheets (LADS, copy enclosed) documenting the amount of nitrogen applied to each land application area if applicable. The LADS will incorporate the wastewater volume and analytical results of the wastewater testing to determine total nitrogen applied to each field.

Not Applicable (for land application of waste only)

6.c. Contingency Plan [20.6.2.3107.A.10 NMAC]:

The contingency plan must describe the actions to be taken if Regulation 20.6.2.3103 NMAC ground water standards are exceeded or if toxic pollutants are present (20.6.2.7.uu) as a result of discharges regulated under the proposed permit, and to cope with failure of the discharge permit or system.

6.c.i. Standard Contingency Requirements: The following paragraphs are standard permit conditions. Please read the condition and check the boxes that you will comply with as a condition of your permit.

This Facility will comply with the following contingency language:

In the event that monitoring indicates ground water standards are violated or may be violated during the term of the discharge permit or upon post closure monitoring, this facility will collect a confirmation sample from the monitoring wells within 15 days to confirm the initial sampling results. Upon confirmation of contamination, all ground water monitoring will be conducted monthly and a corrective action plan will be submitted to the NMED. The corrective action plan will include a site investigation to define the source, nature and extent of ground water contamination and a proposed abatement option; and a schedule for implementation. The site investigation and abatement option must be consistent with the requirements and provisions of Regulations 20.6.2.4101, 20.6.2.4103, 20.6.2.4106.E, 20.6.2.4107, and 20.6.2.4112 NMAC. The corrective action plan will be submitted to NMED for approval within 30 days of confirmation of ground water contamination, and will be initiated within 30 days of NMED approval.

This facility will comply with the following contingency language:

In the event of a spill or release that is not as prescribed in the approved discharge permit, this facility will take immediate corrective action to contain or mitigate the damage caused by the discharge and will initiate the notifications and corrective actions as required by Regulation 20.6.2.1203 NMAC. Within 24 hours discovery of the incident, this facility will verbally notify NMED and provide the information outlined in Regulation 20.6.2.1203.A.1. NMAC. Within 7 days of discovering the incident, this facility will submit a written verifying the oral notification and providing any additional pertinent information or changes. Within 15 days of the incident, this facility will submit a corrective action plan describing actions taken and/or to be taken to remedy the impact of the unauthorized discharge.

6.c.ii. Specific Contingency Plan:

Describe any additional specific corrective actions or contingencies that will be taken to cope with failure of the discharge system: Attach additional pages as necessary.

Specific contingency planning includes periodic inspections of the discharge systems and investigation of all spills and release. In the event of a tear in any of the basin synthetic liners that results in a release to the environment, an effluent spill or unauthorized discharge, the Ground Water Quality Bureau will be notified pursuant to the standard permit condition 6.c.i.

The Permittee will assess damages to the environment and attempt to isolate any discharge, and corrective measures will be implemented immediately.

6.d. Closure Plan [20.6.2.3107.A.11 NMAC]:

The closure plan must describe the closure actions to be taken to prevent Regulation 20.6.2.3103 NMAC ground water standards from being exceeded, or the introduction of a toxic pollutant in ground water after cessation of operations. At a minimum, the closure plan must include a description of closure measures, post closure monitoring plans, and financial assurance (if required by NMED).

6.d.i. Specific Closure Plan: Describe the specific closure activities to ensure that ground water quality will be protected after cessation of operations. The plan shall include plugging, removal, and/or filling of all conveyance, collection, treatment, distribution and disposal features in order to prevent future discharges at the facility. The plan must also describe how all liquid and solid wastes will be removed and disposed of according to local, state, and federal laws. The plan must also describe how disturbed areas will be backfilled to blend with the original surface topography to prevent future ponding and to prevent a discharge at the facility from occurring after the cessation of operations. Attach additional pages as necessary.

Closure Plan

The plan for decommissioning the NEF is to promptly decontaminate or remove all materials from the site which prevent release of the facility for unrestricted use. This approach will avoid long-term storage and monitoring of wastes on site.

At the end of useful plant life, the enrichment facility will be decommissioned such that the site and remaining facilities may be released for unrestricted use as defined in 10 CFR 20.1402. Enrichment equipment will be removed; only building shells and the site infrastructure will remain. All remaining facilities will be decontaminated where needed to acceptable levels for unrestricted use.

Each of the three site basins and the septic system will be closed in accordance with any pertinent regulations.

The Treated Effluent Evaporative Basin is expected to contain residue from the effluent treatment systems. The sediment and soil over the top of the uppermost liner and the liner itself will be disposed of, if required, at a low-level waste facility. The leak detection system components will also be removed and disposed of appropriately. Excavations and berms will be leveled to restore the land to a natural contour.

The UBC Storage Pad Storm Water Retention Basin is not expected to contain any contaminants from the plant. The sediment and soil over the top of the liner and the liner itself will be tested and disposed of, as appropriate. Any components found containing contamination from the plant will be properly handled and disposed of in accordance with pertinent regulations. Excavations and berms will be leveled to restore the land to a natural contour.

During plant operation, a number of depleted uranium byproduct cylinders (UBC) will be stored on the UBC Storage Pad. These cylinders are sealed and checked prior to placement on the UBC Storage Pad and periodically inspected. All cylinders remaining on the UBC Storage Pad

at cessation of plant operation will be sent to a de-conversion facility or other off-site facility. The UBC Storage Pad will be addressed during facility decommissioning. No contamination of stormwater runoff from the UBC Storage Pad is expected during the life of the facility. This is corroborated by experience from the operating experience of similar facilities in Europe. However, the runoff will be monitored as part of the site monitoring program.

The Site Storm Water Detention Basin sediment will be sampled and tested and removed for proper disposal as needed. Excavations and berms will be leveled to restore the land to a natural contour.

Closure of site septic systems will be done in accordance with NMED's Guidelines for septic systems. Residual materials will be sampled and tested for contamination prior to system abandonment.

Ground water monitoring wells will be decommissioned in keeping with state regulations at a time when they are no longer required for monitoring activities.

All relevant closure documents will be retained post-decommissioning for the time period required for their retention.

LES intends to utilize a surety method, such as a letter or line of credit or surety bond, to provide reasonable assurance of decommissioning funding as required by 10 CFR 40.36(e)(2) and 70.25(f)(2). Finalization of the specific financial instruments to be utilized will be completed, and signed originals of those instruments will be provided to the NRC, prior to LES receipt of licensed material. LES intends to provide continuous financial assurance from the time of receipt of licensed material to the completion of decommissioning and termination of the license. Since LES intends to sequentially install and operate the Separations Building Modules over time, financial assurance for decommissioning will be provided during the operating life of the NEF at a rate that is in proportion to the decommissioning liability for these facilities as they are phased in.

The surety method adopted by LES will provide an ultimate guarantee that decommissioning costs will be paid in the event LES is unable to meet its decommissioning obligations at the time of decommissioning. The surety method will also be structured and adopted consistent with applicable NRC regulatory requirements and in accordance with NRC regulatory guidance contained in NUREG-1727.

6.d.ii. Standard Closure Requirements: The following paragraphs are standard permit conditions. Please read the condition and check the boxes that you will comply with as a condition of your permit.

This facility will comply with the following closure requirements:

- The discharger will notify NMED at least 30 days prior to cessation of operations and will provide a schedule for implementation of the closure plan.
- This facility will conduct post closure monitoring at the frequency and locations prescribed under the active permit for a period approved by NMED. If Regulation 20.6.2.3103 NMAC ground water standards are violated or toxic pollutants are present during post closure monitoring, this facility will implement the contingency plan required in the active permit.

All monitoring wells will be plugged and abandoned in accordance with NMED Monitoring Well Construction and Abandonment Guidelines once NMED has agreed in writing that post closure ground water monitoring may cease.

Once NMED has approved all closure activities, this facility will submit a letter requesting termination of the discharge permit.

TECHNICAL SUPPORT

The following information must be submitted as required by Regulation 20.6.2.3106, and 20.6.2.3109 NMAC.

7. Other Discharge Locations [20.6.2.3106.C.2 NMAC]:

7.a. List the locations of any other discharges at this facility not covered by this permit but permitted under the New Mexico Liquid Waste Disposal Regulations, Hazardous Waste Management Regulations, Federal Clean Water Act (NPDES), and any un-permitted discharges. Add rows as necessary to include all other discharge locations.

No other discharge locations are present.

Discharge Type (septic tank/leachfields, surface water discharges, etc.)	Permit Identification	Discharge Location Description

7.b. Area Map: On the appropriate United States Geological Survey (USGS) 7.5 minute topographic quadrangle map, identify the location of all water supply wells, injections wells, seeps, springs, bodies of water, and watercourses within one mile of the outside perimeter of the discharge site.

The area map is provided in Attachment G.

The local road map is provided in Attachment H.

Directions to the site: Drive 5 miles eastbound from the City of Eunice, New Mexico, on New Mexico Highway 234. The NEF site is approximately one mile west of the Texas border on the north side of New Mexico Highway 234.

8. Flooding Potential [20.6.2.3106.C.4 NMAC]:

- 8.a. Describe the flooding potential of the discharge site based on the latest Federal Emergency Management Agency flood plain map or site specific analysis:**

Flooding Potential

The NEF site is located above the 100 or 500-year flood elevation. The NEF site is contained within the Landreth-Monument Draw Watershed. The closest water conveyance is Monument Draw, a typically dry, intermittent watercourse located about 2.0 miles west of the site. The maximum historical flow for Monument Draw is 1,280 ft³/s measured June 10, 1972. All other historical maximum measurements are below 70 ft³/s.

The location of the NEF site is not mapped by the FEMA flood mapping program due to the lack of surface hydrologic features in the area and low flood potential.

Flood information for the City of Eunice from FEMA is provided in Attachment I.

The potential for flash flooding is considered minimal due to the high percolation rate of the soils in the vicinity of the site.

Source for Information: FEMA and the National Enrichment Facility Environmental Report (Part of NRC License Application – Submitted December 2003).

- 8.b. Describe the methods used to control flooding, run-on and run-off at the discharge site (berms, diversion channels, etc.):**

Based on setting the grade level of the facility above the maximum foreseeable flood level, the only potential flooding of the facility results from local intense rainfall. Protection against flooding is provided by establishing the facility floor level at 0.15 m (0.5 ft) above the high point of finished grade elevation and all roads are set at least 0.45 m (1.5 ft) below this. Based on these design features, the probability of the water level reaching the building finished floor is negligible.

Storm water runoff from the site is directed to two storm water basins as described in Section 6.a.ii of the Permit Application.

A diversion ditch and berm will be constructed along the northern portion of the site to divert upstream overland sheet flow around the NEF buildings. This diversion ditch will be designed to divert the 24-hour, 100-year rainfall. The eastern portion of the diversion ditch will be routed through the Site Storm Water Detention Basin (SSDB). The storm water from the diversion ditch will be routed through the basin, but will not be changed in either volume or runoff rate. The western portion of the diversion ditch will be discharged into the natural terrain and will flow south via overland flow to the existing multiple culverts under New Mexico Highway 234.

Mitigation measures will be in place to minimize potential impact on soils from storm water runoff. These include the following items:

- Cleared areas not covered by structures or pavement will be stabilized by acceptable means as soon as practical.
- Surface runoff will be collected in temporary (during construction) and permanent retention/detention basins.
- Drainage culverts and ditches will be stabilized and lined with rock aggregate/rip-rap to reduce flow velocity and prohibit scouring.

9. Geologic and Soil Information [20.6.2.3106.5 NMAC]:

9.a. Lithology: Describe the lithology and thickness of each geologic unit below the discharge site and indicate which units bear water. This information may be obtained from a driller's log or geologic report. Include photocopies of all well logs with the application. Add rows as necessary to include all units.

Unit Description	Thickness (feet)	Water Bearing (Y/N)
<u>Mescalero Sands/Blackwater Draw Formation</u> : Dune or dune-related sands	0 to 10	N
<u>Gatuña/Antlers Formation</u> : Pecos River Valley alluvium consisting of Sand and silty sand with interbedded caliche near the surface and a sand and gravel base layer. Light yellow to reddish brown, dry, very dense silty fine- to medium-grained, caliche-cemented sand with some caliche lenses.	25 to 50	N
<u>Chinle Formation</u> (Dockum Group redbeds): clay mudstone interbedded with silt and sandstone layers. Red to purple, very hard, high plasticity clay.	180 to 450	Y: isolated silt layer only
<u>Santa Rosa Formation</u> (Dockum Group) Sandy red beds, conglomerates and shales.	450 to 760	Y

Source for Information:

National Enrichment Facility Environmental Report, Revision 1, February 2004, Table 3.3-1 based on: BLM, 2003; TTU, 2000; DOE 1997b:

BLM, 2003. Assessment Of Water Resources In Dewey Lake And Santa Rosa Formations, Lea County, New Mexico, A Proposal Through BLM Field Office, Allan Sattler (Sandia National Laboratories) and Jerry Fant (BLM), September 16, 2003.

TTU, 2000. Geology of the WCS-Flying W Ranch, Andrews County, Texas, Texas Tech University Water Resources Center, April, 2000.

DOE, 1997b. Waste Isolation Pilot Plant Disposal Phase Final Supplemental Environmental Impact Statement, Chapter 4, Description of the Affected Environments, U.S. Department of Energy, September, 1997.

Hydrologic Investigation, Section 32; Township 21 Range 38, Eunice, NM, Cook-Joyce, Inc, Austin TX, 19 Nov, 2003.

Note: Attachment C is a copy of the Final Report of the Hydrologic Investigation for the site. It provides all backup ground water information for the site including borings logs for the nine shallow ground water investigation borings, the five geotechnical borings and the construction summaries for the three monitoring wells.

9.b. Soil Map: Attach a copy of the United States Department of Agriculture (USDA) Natural Resources Conservation Service (NRCS) soil survey map and descriptive information for soil(s) associated with the discharge site.

The soil map (see Attachment J) is a taken from the latest county soil survey: USDA Soil Survey of Lea County New Mexico, U.S. Department of Agriculture, Soil Conservation Service in Cooperation with New Mexico Agricultural Experiment Station, January 1974. Site soils are generally sandy, derived from dune sands or the underlying alluvium, are locally cemented by or contain caliche.

10. Signatures:

Owner: I certify that I am the legal owner of the property in which all discharges will occur. I certify that I am knowledgeable about the information contained in this application, and believe the information is true, complete and accurate.

Print Name: _____

Signature: _____

Date _____

Responsible Party* (if property is leased or operated by someone other than the owner):

I certify that I am knowledgeable about the information contained in this application, and believe the information is true, complete and accurate.

Print Name: R. M. Krich
Vice President - Licensing, Safety and Nuclear Engineering
Louisiana Energy Services, LP

Signature:  _____

Date 4/26/04

* Enclose a signed copy of the lease agreement between the responsible party and the owner of the property on which the proposed discharge will occur. Lease agreement should be valid for the duration of the discharge permit or until the discharge permit is modified to reflect a new lessee.

Attachment K provides the Grant of Easement and Right of Way from the State of New Mexico to LES and the Agreement Regarding Land Use Restrictions or Conditions from the State of New Mexico.

SUMMARY OF APPLICANT'S PUBLIC NOTICE REQUIREMENTS FOR GROUND WATER DISCHARGE PERMITS

The New Mexico Water Quality Control Commission Regulations (20.6.2 NMAC) public notice requirements of 20.6.2.3108 NMAC were revised effective **September 15, 2002** to require the applicant to provide notice to neighboring properties during the discharge permit application process. This document summarizes the applicant's public notice requirements and provides answers to frequently asked questions.

The Water Quality Control Commission Regulations are available on the New Mexico Environment Department's (NMED) internet web site. The web site address is:

www.nmenv.state.nm.us

Click on the heading "Environmental Protection Regulations", then "Water Quality-- Ground and Surface Water Protection". The public notice regulations are in Section 20.6.2.3108 NMAC. You can also call the Ground Water Quality Bureau at (505) 827-2900 and we will mail you a copy of the regulations.

STEP 1 – SELECTING AND IMPLEMENTING A PUBLIC NOTICE OPTION

Anyone applying for a new permit or renewing or modifying an existing permit must provide public notice to neighboring properties (See FAQs). The applicant must select one of three public notice options by checking the selected box on page 3 of the Ground Water Discharge Permit Application. **When the NMED receives the application and deems it administratively complete, we will send the applicant the instructions and materials necessary to implement the selected public notice option.** The applicant must implement the public notice option within 30 days of submitting their application to the NMED. The applicant's public notice options are:

Public Notice Option 1

Posting a sign: The sign must be prominently posted in a conspicuous public location at or near the existing or proposed facility for 30 days. The sign should be visible so that passersby are likely to see it. The sign will be a synopsis of the full public notice prepared by NMED.

and

Sending direct notice to adjacent property owners: The public notice prepared by NMED must be sent to all "adjacent property" "owners of record" by certified mail, return receipt requested.

and

Sending direct notice to the owner of the discharge site: If the applicant is not the owner of the discharge site, the applicant must send the public notice prepared by NMED to the owner, by certified mail, return receipt requested.

Public Notice Option 2

Posting a sign: The sign must be prominently posted in a conspicuous public location at or near the existing or proposed facility for 30 days. The sign should be visible so that passersby are likely to see it. The sign will be a synopsis of the full public notice prepared by NMED.

and

Placing a display advertisement: The display ad must be at least two inches by three inches in size and must be published in a newspaper of general circulation in the location of the proposed discharge. The display ad will be a synopsis of the full public notice prepared by NMED.

and

Sending direct notice to the owner of the discharge site: If the applicant is not the owner of the discharge site, the applicant must send the public notice prepared by NMED to the owner, by certified mail, return receipt requested.

Public Notice Option 3

Sending direct notice to property owners within 1/2 mile of the discharge site: The public notice prepared by NMED must be sent to all property "owners of record" within 1/2 mile of the discharge site by certified mail, return receipt requested.

and

Sending direct notice to the owner of the discharge site: If the applicant is not the owner of the discharge site, the applicant must send the public notice prepared by NMED to the owner, by certified mail, return receipt requested.

Step 2 - Providing Proof that the Applicant Completed Public Notice

Proof of Notice

Within 15 days of completion of the public notice requirements above, the applicant must submit proof of notice to NMED. Depending on the option selected, proof of notice may include list of property owners' names and addresses, copies of certified mail return receipts, a copy of the published display ad indicating the newspaper and date of publication, and an affidavit of sign posting. If the department determines that the notice provided is inadequate, the department may require additional notice in accordance with the requirements above.

Important Definitions

The following definitions are excerpted from the Water Quality Control Commission regulations, 20.6.2 NMAC.

"adjacent properties" means properties that are contiguous to the discharge site or property that would be contiguous to the discharge site but for being separated by a public or private right of way, including roads and highways.

"discharge site" means the entire site where the discharge and associated activities will take place.

"owner of record" means an owner of property according to the property records of the tax assessor in the county in which the discharge site is located.

Frequently Asked Questions

Where can I get a copy of the new public notice regulations?

The Water Quality Control Commission Regulations are available on the New Mexico Environment Department's (NMED) internet web site. The web site address is:

www.nmenv.state.nm.us

Click on the heading "Environmental Protection Regulations", then "Water Quality-- Ground and Surface Water Protection". The public notice regulations are in Section 20.6.2.3108 NMAC.

You can also call the Ground Water Quality Bureau at (505) 827-2900 and we will mail you a copy of the regulations.

When do the new public notice regulations go into effect?

September 15, 2002

Do the new public notice regulations apply to me?

The regulations apply to all applications for new permits, renewals, and modifications that are submitted to NMED on or after September 15, 2002. Page 3 of the application has a section for the applicant to select one of three public notice options. If you submitted an application for a new discharge permit, renewal or modification before September 15, 2002, then the regulations will not apply to you until you renew or modify your permit, even if your permit has not yet been issued.

Where at my facility should the sign be posted?

In many cases the sign should be posted in a location near the front entrance to the facility where it is likely to be seen by passersby. Other conspicuous public locations can be approved in advance by the Ground Water Quality Bureau if they are more likely to provide notice to the public. You can contact the Ground Quality Bureau at the number below to obtain approval for an alternate sign posting location.

Where do I get the sign that will be posted at my facility?

When the NMED receives the application and deems it administratively complete, we will send the applicant the instructions and a laminated poster with an invoice for \$15.00.

How long do I have to keep the sign up at my facility?

The sign must be posted for 30 days.

What properties are considered to be "adjacent" to my property?

"Adjacent properties" are those properties that are contiguous to the discharge site or that would be contiguous to the discharge site except for being separated by a public or private right of way, including roads and highways.

Who are property "owners of record" and where can I find their names and addresses?

An "owner of record" is an owner of property according to the property records of the tax assessor in the county in which the discharge site is located. You can call your county tax assessor and they can, in most cases, provide names and addresses of owners of record within 24 hours. You will need to provide the tax assessor with the location of your discharge site and ask for names and addresses of adjacent properties.

Is there a letter format I should use for the direct notice to property owners?

When the NMED receives the application and deems it administratively complete, we will send the applicant the instructions and materials necessary to provide direct notice to property owners.

What if there are no adjacent properties other than properties I own?

If the applicant owns the adjacent properties, then they must implement Option 2 by posting a sign, placing a display ad and notifying the property owner if the owner is different from the applicant.

Is there a required format for the display advertisement?

When the NMED receives the application and deems it administratively complete, we will send the applicant the instructions and materials necessary to place a display advertisement.

What proof must I provide to the NMED to demonstrate that I provided public notice in accordance with the new regulations?

Within 15 days of completion of the public notice requirements, the applicant must submit proof of notice to NMED. Depending on the option selected, proof of notice may include a list of property owners' names and addresses, copies of certified mail return receipts, a copy of the published display ad indicating the newspaper and date of publication, and a signed affidavit that the sign was posted. If the department determines that the notice provided is inadequate, the department may require additional notice in accordance with the new regulations.

Who do I contact if I have additional questions?

You may contact Jerry Schoepner, Chief of the Ground Water Quality Bureau or Maura Hanning, Manager of the Ground Water Pollution Prevention Section at (505) 827-2900.

ATTACHMENTS

ATTACHMENT A: NEF DETAILED SITE MAP

ATTACHMENT B: METHODS USED TO CALCULATE DISCHARGE VOLUMES

ATTACHMENT C: SITE GEOLOGIC REPORT

ATTACHMENT D: DESCRIPTION OF LIQUID EFFLUENT COLLECTION TREATMENT SYSTEM

ATTACHMENT E: MONITORING PLAN

ATTACHMENT F: SAMPLING PROTOCOL

ATTACHMENT G: NEF AREA MAP

ATTACHMENT H: NEF ROAD MAP


ATTACHMENT I: FEMA FLOOD INFORMATION

ATTACHMENT J: NEF SITE SOILS MAP

ATTACHMENT K: NEI LAND EASEMENT AND LAND USE RESTRICTION

ATTACHMENT A

NEF DETAILED SITE MAP



①
②
MW1
LAT 32°26'32"
LONG 103°04'58"
ELEV 3436.30

①
②
LAT 32°26'33"
LONG 103°04'35"
ELEV 3430.80

①
②
LAT 32°26'20"
LONG 103°05'26"
ELEV 3415.20

①
②
LAT 32°26'08"
LONG 103°04'27"
ELEV 3416.10

①
②
LAT 32°25'56"
LONG 103°05'26"
ELEV 3389.90

LAT 32°26'02"
LONG 103°05'03"
ELEV 3398.50


LAT 32°25'50"
LONG 103°04'55"
ELEV 3401.90

LAT 32°25'49"
LONG 103°04'45"
ELEV 3393.00

LAT 32°25'51"
LONG 103°04'41"
ELEV 3393.00

LAT 32°25'47"
LONG 103°04'32"
ELEV 3403.60

- LEGEND:
- ① SOIL SAMPLE
 - ② VEGETATION SAMPLE
 - ③ WATER SAMPLE / SEDIMENT SAMPLE
 - ④ TERMINATION OF DIVERSION DITCH
 - T1 SEPTIC TANK LOCATION (TYPICAL)
 - MW1 GROUNDWATER MONITORING WELL (EXACT LOCATIONS TO BE DETERMINED AT A LATER DATE) (TYPICAL)



REFERENCE NUMBER
FIGURE 6.1-2.dwg



NEF DETAILED SITE MAP
NM GROUNDWATER DISCHARGE PERMIT

ATTACHMENT B

METHODS USED TO CALCULATE DISCHARGE VOLUMES

ATTACHMENT B

Methods Used to Calculate Discharge Volumes

Peak Discharge Flows

For runoff calculations to the SSDB and USPSRB, peak discharge volumes are based on the 24-hr, 100-yr rainfall of 6 inches times the runoff area. For the USPSRB, the two blowdown components were also added to yield a total peak discharge.

For the TEEB, peak discharge volume is the maximum estimated discharge from the Liquid Effluent Collection and Treatment System in a single day.

Peak discharge into the site septic systems is based on the design capacity serving 422 employees.

Average Discharge Flows

For runoff calculations to the SSDB and USPSRB, average discharge volumes are based on the annual rainfall of 14 inches (1.17 feet) evenly distributed throughout the year times the runoff area. For the USPSRB, the two blowdown components were also added to yield a total average discharge.

For the TEEB, average discharge volume is the average daily discharge from the Liquid Effluent Collection and Treatment System.

Average discharge into the site septic systems is based on the actual staff of NEF which is based on an employee count of 210.

Peak and average discharge flows into the three basins are summarized in the attached two sheets.

Peak Discharge Flows

Location	Source	Rainfall Depth (ft)	Runoff Area (acres)	Total Flow (acre-ft/day)	Total Flow (gpd)
SSDB Total	Rainfall Runoff 24- hr, 100-yr Storm	0.5	95.6	47.8	15,574,617
USPSRB	Rainfall Runoff 24- hr, 100-yr Storm	0.5	22.8	11.4	3,714,448
				Total Flow (gpy)	
	Cooling Tower Blowdown			5,051,845	13,841
	Boiler Blowdown			36,500.00	100
USPSRB Total					3,728,389
TEEB	Process discharge flow				5,350
TEEB Total					5,350

Average Discharge Flows

Location		Rainfall Depth (ft)	Runoff Area (acres)	Total Flow (acre- ft/year)	Total Flow (gpd)
SSDB Total	Annual Rainfall	1.17	95.6	111.9	99,848
USPSRB	Annual Rainfall	1.17	22.8	26.7	23,813
				Total Flow (gpy)	
	Cooling Tower Blowdown			5,051,845	13,841
	Boiler Blowdown			36,500	100
USPSRB Total					37,754
TEEB	Process discharge flow			669,884	1,835
TEEB Total					1,835

ATTACHMENT C

SITE GEOLOGIC REPORT



HYDROGEOLOGIC INVESTIGATION
SECTION 32; TOWNSHIP 21 RANGE 38
Eunice, New Mexico

19 NOVEMBER 2003

Prepared for:

Lockwood Greene Engineering & Construction
1500 International Drive
Spartanburg, South Carolina 29304





TABLE OF CONTENTS

SECTION		PAGE
1.0	INTRODUCTION.....	1
1.1	Site Description	1
1.2	Adjacent properties.....	1
2.0	HYDROGEOLOGIC INVESTIGATION FIELD ACTIVITIES	3
2.1	General Geologic Conditions.....	3
2.2	Shallow subsurface investigation.....	4
2.3	Deep subsurface investigation.....	4
2.3.1	Geophysical Borings	5
2.3.2	Monitor Well Drilling and Installation Program	5
2.4	Survey Data.....	6
2.5	Groundwater Level Data Collection	6
2.6	Groundwater Sampling.....	7
3.0	DATA ANALYSIS	8
4.0	CONCLUSIONS.....	9





LIST OF TABLES

TABLE

- 1 Shallow Borehole Data
- 2 Groundwater Level Data

LIST OF FIGURES

FIGURE

- 1 Site Location Map
- 2 Adjacent Property Location Map
- 3 Boring Location Map
- 4 Redbed Contact Structure Map
- 5 Groundwater Gradient

LIST OF APPENDICES

APPENDIX

- A Geologic Boring Logs
- B Summary of Field Activities
- C Geophysical Boring Logs
- D Monitor Well Construction Diagrams
- E Hydraulic Conductivity Calculations
- F Groundwater Velocity Calculations
- G Survey Results





1.0 INTRODUCTION

In accordance with the Scope-of-Services outlined in a letter from Cook-Joyce, Inc. (CJI) dated 19 August 2003, CJI was contracted by Lockwood-Greene Engineering and Construction (LG) to conduct a hydrogeologic investigation of an undeveloped property in southeastern New Mexico. The hydrogeologic investigation was conducted on behalf of Louisiana Energy Services' efforts to license and operate a uranium enrichment facility at this site. The following sections detail CJI investigational activities at the site.

1.1 SITE DESCRIPTION

The approximate 560-acre site is located 2 miles east of Highway 18 in Eunice, Lea County, New Mexico, as shown on the Site Location Map (Figure 1). The property includes the portion of Section 32, Township 21, and Range 38 of the New Mexico State grid system that lies north of New Mexico State Highway 234, which runs east and west across the southern portion of Section 32. There are no permanent structures on-site. Currently the property is used for cattle grazing.

The site is characterized by sandy topsoil, sparse vegetation including mesquite trees, some rolling sand dunes, and about 30 feet of topographic relief from north to south. Although there are numerous operational oil wells within close proximity to the site, there are none on the subject property. There are three man-made features on-site. The first is a gravel road that trends north-south near the center of the site. The road is primarily used by haul trucks entering and exiting an adjacent surface mine facility that is located north of the site. The second man-made feature is a gravel pad approximately 200' x 300' that was constructed in early September during field activities. The third feature is an underground carbon dioxide gas pipeline that is operated by Trinity Pipeline and crosses the site from approximately the northwest corner to the southeast corner of the property.

1.2 ADJACENT PROPERTIES

There are several industrial developments within relatively close proximity to the site (see Figure 2). The site is bordered to the north by a railroad spur that operates between the town of





Eunice and Waste Control Specialists, LLC (WCS). WCS operates a permitted RCRA landfill and waste storage and processing facilities, and specializes in hazardous and low-level nuclear waste at their facility. The WCS facility, which is located just across the border in the State of Texas, is located within about one-half mile east/northeast of the eastern-most portion of the subject property. WCS also owns the adjacent undeveloped property to the east (Section 33), between Section 32 and the WCS facility.

The Lea County Municipal Landfill is located immediately south of State Highway 234 near the southeast corner of the subject property. With the exception of the Lea County Municipal Landfill and a few oil wells, adjacent property south of State Highway 234 is undeveloped. Although primarily undeveloped property borders the site to the west, there is a landfarm in operation within about one-half mile of the western boundary of the subject site. Though not thoroughly investigated as a part of this project, the D & D Landfarm appears to remediate soil from off-site sources that may have been affected by oil exploration processes.

There are two industrial facilities located about one-quarter mile north of the subject property. The two facilities are Wallach Gravel Quarry and Sundown. Wallach has operated a surface mining operation on their property since about the 1950's. Sundown operates an oil recovery/recycling facility which includes a sludge pond and an oil storage tank farm that is used to store oil and sludge recovered from oil exploration processes.

In addition to the active facilities located in the area of the site, an abandoned sand and gravel quarry is located to northeast of the site on WCS property and which is referred to on USGS maps as Baker Spring.





2.0 HYDROGEOLOGIC INVESTIGATION FIELD ACTIVITIES

On 25 August 2003, CJI personnel mobilized to the site to conduct field activities related to the hydrogeologic investigation. The field activities were conducted to collect data to identify and characterize the hydrogeologic conditions of the uppermost water-bearing zone beneath the site. The investigation consisted of the installation of nine borings to the top of the redbed to determine: a) the depth to the redbed, and b) if shallow groundwater is present in the overlying sand unit. Because groundwater was not located in the shallow sand unit, three additional monitor wells were installed into a silty sand unit in the redbeds at an approximate depth of 240 feet below ground level (bgl). These three monitor wells were gauged to evaluate if groundwater was present. Only one of the three wells produced groundwater. Groundwater samples were collected from this monitor well. Detailed field activities are described in Appendix B.

2.1 GENERAL GEOLOGIC CONDITIONS

Prior to initiation of the field investigation, the general hydrogeologic conditions were evaluated. The data reviewed were obtained from past investigations of the WCS property, the Lea County Landfill, and pedestrian surveys of the Wallach sand and gravel operation to the north. The area is underlain with approximately 25 to 50 feet of primarily unconsolidated sand with thin to medium lenses of gravel. Perched or localized pockets of groundwater in this unit were identified as being present to the north of the site in the Wallach mining excavation and to the east in some piezometers located on the WCS property.

The sand unit is underlain by the Triassic aged Dockum Group or redbeds. The redbed consist primarily of a clay mudstone that is interbedded with silt and sandstone zones. Laterally consistent silt and sandstone zones have been identified at depths of approximately 125 feet and 230 feet below ground level (bgl). In addition, a discontinuous silt zone at approximately 180 feet BGL has been identified in past investigations of the WCS property. Groundwater has not been identified in the 125-foot silty sandstone zone. Groundwater in the 180-foot zone is present at some locations but not continuously across the WCS property. Groundwater is present in a 230-foot zone across the entire portion of the WCS property that has been investigated.





2.2 SHALLOW SUBSURFACE INVESTIGATION

Prior to mobilizing to the site, nine proposed boring locations based on a 1,00-foot center grid pattern were overlain on an USGS-based site map (see Figure 3) and the associated coordinates for each of these boring locations was ascertained. On 25 August 2003, CJI personnel conducted a walking survey of the majority of the site while the predetermined boring locations were staked. Boring locations were located using a hand-held GPS unit. With the exception of B-1, each boring location was staked as close to the predetermined coordinates as possible. Due to the presence of sand dunes, it was necessary to field-locate B-1 about 75' northwest of its mapped location.

Nine borings, B-1 through B-9, were installed and geologically logged to the geological contact of the "redbeds". The borings were drilled using solid and hollow stem augers and the borings were geologically logged from the cuttings. The boring logs are presented in Appendix A. The borings ranged in depth from 35 feet to 60 feet. The depth and elevation of the redbed in each of the borings is shown in Table 1. Once the borings were advanced to the contact, the boreholes were then allowed to remain open for a minimum of 24 hours to determine if shallow groundwater was present.

The upper unit was typically described as a dry, red and gray, silty sand with some gravel and gravel layers present. The borings were gauged for a minimum period of 24 hours and groundwater was not identified in any of the nine borings. Following the gauging period, the borings were backfilled with cuttings from the drilling operations.

2.3 DEEP SUBSURFACE INVESTIGATION

Upon completion of the shallow subsurface investigation, an investigation of the underlying strata was conducted for the purpose of identifying the uppermost water-bearing zone at the expected depth of 230 feet bgl. This portion of the investigation consisted of the installation of three test borings to define the interval of the suspected 230-foot uppermost groundwater-bearing zone. Once the subsurface geologic data were obtained through geophysical logs, these data were used to design three monitor wells (MWs) near B-1, B-7, and B-9. A summary of the field activities is presented in Appendix B.





2.3.1 Geophysical Borings

Three test borings were drilled with air rotary method to a depth of 250 feet bgl without the collection of soil or core samples. The borings were filled with water from a supply well on the WCS property that is completed into the Santa Rosa formation of the Dockum Group. CJL personnel then geophysically logged the borings. The three test boreholes (B-3, B-7, and B-9) were logged for resistivity using a Mineral Logging Systems unit 1502-282. The geophysical logs of the three test boreholes can be found in Appendix C of this report.

The geophysical logs indicate that more resistive zones, which are indicative of zones of higher sand and silt content than the baseline clay zones, are located at approximate depths of 100 feet and 225 feet BGL in each of the three borings. A discontinuous resistive zone, at an approximate depth of 185 feet BGL, was also detected in Borings B-3 and B-9, but not in B-7.

2.3.2 Monitor Well Drilling and Installation Program

The three monitor wells were designed based on the results of the geophysical logs. The design consisted of the placement of the screened interval across the 230-foot zone that is approximately 15 feet in thickness. A sand filter pack was placed in the annular space around the screen and extended a minimum of 3 feet above the screen. Well centralizers were placed approximately every 50 feet along the well casing to prevent the well from contacting the borehole wall to ensure a proper filter pack and well seal. Above the sand filter pack, bentonite chips were placed to seal the screened interval from potential infiltration from above. The bentonite chips were placed to a depth of 75 feet bgl. A cement-bentonite grout was placed above the bentonite chip seal. Monitor Well Completion Diagrams for each of the wells are presented in Appendix D.

The wells were completed at the surface with 4-inch square steel box tubing with a lockable cap and a 4-foot square concrete pad. Cattle panels were placed around the wells to help prevent livestock from damaging the wells. A detailed summary of the monitor well drilling and construction activities is included in Appendix B.





2.4 SURVEY DATA

A survey of the locations and elevations of the 9 borings and 3 monitor wells was conducted by Pettigrew and Associates, a Registered Professional Surveyor. In addition, top-of-casing elevation and top of concrete pad elevation data were collected at each of the monitor wells. The results of these data are shown on the boring logs and the Monitor Well Construction Diagrams and a report of the survey results are presented in Appendix G. The boring and monitor well surveyed locations are shown on Figure 3.

2.5 GROUNDWATER LEVEL DATA COLLECTION

On 22 September, CJI began collecting groundwater elevation data from MW-1, MW-2, and MW-3 to evaluate groundwater recharge in the screened interval. Measurements were collected using an electric e-line that records to 0.01 foot. The results of the groundwater level data are presented on Table 2.

Groundwater was present in Monitor Well MW-2 but Monitor Wells MW-1 and MW-3 did not produce groundwater. Groundwater levels continued to recharge in MW-2 throughout the monitoring period.

Due to the lack of groundwater in Monitor Wells MW-1 and MW-3, deionized water was placed in the wells. The wells were surged in an attempt to remove any smearing of the borehole walls that might have been present and that could have prevented the well from producing groundwater. The wells were surged a total of five times over a five day period using a surge block that forced water to move back and forth through the borehole wall to remove any fines that may have caused smearing. Water levels were recorded for a three-week period after surging. The water level in MW-1 remained relatively constant and the water level in MW-3 fell during the monitoring period, which would indicate that the screened intervals in these two wells are dry.





2.6 GROUNDWATER SAMPLING

Groundwater samples were collected from Monitor Well MW-2. Lockwood Greene coordinated the delivery of the sample containers and determined the parameters to be analyzed for the sampling events. Severn Trent Laboratories (STL) and Framatome supplied the sample containers. Two groundwater sampling events were conducted. Due to the short holding times of some of the parameters, each of the sampling events was conducted over a two day period. Samples were collected on 14 October 2003 and 11 November 2003 for the containers supplied by STL. Samples were collected on 19 October 2003 and 12 November 2003 for the containers supplied by Framatome.

Because groundwater had not reached equilibrium in MW-2 prior to each sampling event, the available groundwater in the well had not stagnated and therefore purging was not conducted prior to sampling. The samples were collected using new dedicated disposable 2-inch diameter bailers. The samples were placed in the laboratory supplied containers and placed on ice for next day delivery to the laboratories. The samples were transported under standard chain-of-custody procedures. During the sampling activities, the sampling team donned latex gloves to prevent cross contamination.





3.0 DATA ANALYSIS

The data collected from the field investigation activities and from past investigations on the WCS property to the east have been used to develop a general model of the site characteristics. The model includes a top of redbed contour map, a hydraulic gradient map of groundwater in the 230-foot zone, and a hydraulic conductivity calculation of the 230-foot zone.

The top of redbed structure map is presented as Figure 4. The top of red bed represents the paleogeographic surface of this unit prior to being covered by the overburden sand and silt material that extends to the current land surface. Based on the structure map there is a northwest-southeast trending ridge in the redbed that is located to the northeast of the subject site. Along the southwest toe of this ridge appears to be a top of redbed drainage that slopes to the south. To the east of the subject site in Section 33, the redbeds generally slope towards this drainage feature. Beneath the site, the drainage feature generally slopes to the southwest corner of the property in an east to west drainage feature. This drainage feature has relief of approximately 40 feet.

A groundwater gradient map from wells completed in the 230-foot zone on the WCS site has been extended to include the groundwater elevation data from Monitor Well MW-2. The groundwater gradient map is presented as Figure 6. The gradient is shown to be in a south-southwesterly direction on the WCS site and appears to be in a south-southeasterly direction in the area of MW-2 on the LES property. The gradient in the area of MW-2 is approximately 0.011 feet per foot.

Based on recovery rates of groundwater in Monitor Well MW-2, the hydraulic conductivity of the 230-foot zone has been calculated at 3.7×10^{-6} cm/sec (3.8 feet/year). The hydraulic conductivity was calculated using Hvorslev's rising head slug test method. The hydraulic conductivity calculations are presented in Appendix E.

Using the calculated groundwater gradient and the hydraulic conductivity value, the groundwater velocity has been calculated to be 0.3 feet per year. The calculation of groundwater velocity is presented in Appendix F. It should be noted that the porosity value used in the calculation was developed from laboratory analysis of soil samples collected from this zone from the WCS site.





4.0 CONCLUSIONS

Based on the field activities and data collected to date, the following conclusions have been made:

- The surface soils at the site consist mainly of fine sand and silt. There are minimal amounts of gravel in certain zones but gravel is not consistently present throughout the site;
- The upper geologic contact of the redbeds, in boreholes B-1 through B-9, is found between 23' BGL and 46' BGL. The red bed surface is a paleogeographic surface that slopes towards the southwest corner of the property;
- Shallow groundwater was not detected above the redbeds in boreholes B-1 through B-9;
- The 230-zone, that is believed to correspond with the water-bearing zone that WCS is monitoring, is found to be approximately 15 feet thick and was encountered at depths ranging from 214 feet to 222 feet BGL;
- Based on interpretation of on-site and off-site data the groundwater gradient in the 230-foot zone is approximately 0.011 feet per foot to the south-southeast beneath the area of investigation;
- The hydraulic conductivity of the 230-foot zone has been calculated to be 3.7×10^{-6} cm/sec; and
- The velocity of the groundwater flow is approximately 0.3 feet per year.





TABLES





TABLE 1
SHALLOW BORHOLE SURVEY DATA
Lockwood Greene Engineering and Construction
Eunice, New Mexico

Boring	Surface Elevation (feet MSL)	Depth to Redbed (feet MSL)	Elevation at Top of Redbed (feet MSL)
B-1	3,396	55	3,341
B-2	3,402	34	3,368
B-3	3,403	23	3,380
B-4	3,401	45	3,356
B-5	3,409	43	3,366
B-6	3,415	45	3,370
B-7	3,415	26	3,389
B-8	3,423	38	3,385
B-9	3,421	46	3,375





TABLE 2
GROUNDWATER LEVEL DATA
 Lockwood Greene Engineering and Construction
 Eunice, New Mexico

Monitor Well MW-1	
DATE	DTW TOC
9/22/03	dry
9/23/03	dry
9/24/03	dry
9/25/03	dry
9/26/03	dry
9/29/03	dry
9/30/03	dry
10/1/03	dry
10/2/03	dry
10/3/03	dry
10/6/03	dry
10/7/03	dry
10/8/03	dry
10/9/03	dry
10/10/03	dry
10/13/03	dry
10/14/03	dry
10/15/03	dry
10/16/03	212.1
10/17/03	215.02
10/18/03	215.03
10/19/03	214.56
10/20/03	214.52
10/22/03	214.43
10/24/03	214.32
10/27/03	214.35
11/4/03	214.37
11/7/03	214.4
11/10/03	214.36
11/11/03	N/A
11/12/03	N/A

Monitor Well MW-2	
DATE	DTW TOC
9/22/03	190.78
9/23/03	165.04
9/24/03	153.85
9/25/03	149.68
9/26/03	148.67
9/29/03	138.71
9/30/03	135.11
10/1/03	164.07
10/2/03	149.14
10/3/03	142.58
10/6/03	145.03
10/7/03	138.11
10/8/03	140.64
10/9/03	136.9
10/10/03	133.68
10/13/03	N/A
10/14/03	140.53
10/15/03	165.48
10/16/03	148.52
10/17/03	141.86
10/18/03	N/A
10/19/03	133.55
10/20/03	147.56
10/22/03	130.79
10/24/03	125.54
10/27/03	120.33
11/4/03	115.84
11/7/03	115.02
11/10/03	114.91
11/11/03	114.24
11/12/03	121.82

Monitor Well MW-3	
DATE	DTW TOC
9/22/03	dry
9/23/03	dry
9/24/03	dry
9/25/03	dry
9/26/03	dry
9/29/03	dry
9/30/03	dry
10/1/03	dry
10/2/03	dry
10/3/03	dry
10/6/03	dry
10/7/03	dry
10/8/03	dry
10/9/03	dry
10/10/03	dry
10/13/03	dry
10/14/03	dry
10/15/03	dry
10/16/03	220.36
10/17/03	224.37
10/18/03	224.58
10/19/03	224.73
10/20/03	224.79
10/22/03	224.98
10/24/03	225.23
10/27/03	225.5
11/4/03	228.14
11/7/03	228.31
11/10/03	226.58
11/11/03	N/A
11/12/03	N/A

DTWTOC - Depth to water from top of casing.

Monitor Well MW-2 was developed on 9/30, 10/2, 10/7, 10/8, and 10/10.



Groundwater samples were collected from MW-2 on 10/14, 10/15, 10/19, 11/11, and 11/12.

Monitor Wells MW-1 and MW-3 were surged five times using 12 to 13 gallons of DI water from 10/16 - 10/20.





FIGURES







LEGEND
 - - - - - LES SITE

REV.	DATE	DESCRIPTION	DR BY	APP BY
COOK-JOYCE INC. ENGINEERING AND CONSULTING 812 WEST ELEVENTH 612-474-0097 AUSTIN, TEXAS 78701				
PROJECT: LOCKWOOD GREENE				
SHEET TITLE: SITE LOCATION MAP				
DES BY	DOB	ELJ	SCALE: SEE BAR SCALE	
CHK BY	DHG	DHA	PROJECT NO. 03070	
APP BY	DHG	DHA	CR NO. 03070007	
DATE ISSUED: 11-19-2003			SHEET 1 OF 1 SHEETS	
PURPOSE: REPORT			FIGURE NO. 1	





LEGEND
 - - - - - LES SITE
 - - - - - WCS SITE

REV.	DATE	DESCRIPTION	DR BY	APP BY
COOK-JOYCE INC. ENGINEERING AND CONSULTING 612 WEST ELEVENTH ST. AUSTIN, TEXAS 78701 512-474-6007				
PROJECT: LOCKWOOD GREENE				
SHEET TITLE: LAND USE MAP				
DES BY	EDB	SJB	SCALE: SEE BAR SCALE	
DR BY	DHG	DVA	PROJECT NO. 03070	
CHK BY	DHG	DVA	CR NO. 03070008	
APP BY	DHG	DVA	SHEET 1 OF 1 SHEETS	
DATE ISSUED: 11-19-2003			FIGURE NO. 2	
PURPOSE: REPORT				



- LEGEND**
- LES SITE BOUNDARY
 - TOP OF REDBED BORING
 - ⊕ MONITOR WELLS

REV.	DATE	DESCRIPTION	DR BY	APP BY
COOK-JOYCE INC. ENGINEERING AND CONSULTING 612 WEST ELEVENTH 612-474-6087 AUSTIN, TEXAS 78701				
PROJECT: LOCKWOOD GREENE				
SHEET TITLE: BORING LOCATION MAP				
DES BY	SOB	SDS	SCALE: SEE BAR SCALE	
OR BY	DHG	DHG	PROJECT NO. 03070	
CHK BY	DHG	DHG	JOB NO. 03070006	
APP BY	DHG	DHG	SHEET 1 OF 1 SHEETS	
DATE ISSUED: 11-19-2003			FIGURE NO. 3	
PURPOSE: REPORT				



- LEGEND**
- LES SITE BOUNDARY
 - CJA BORING
 - ⊕ MONITOR WELLS
 - ⊕ WEAVER BOOS BORINGS
 - ⊗ EXISTING PIEZOMETER
 - JACK HOLT BORINGS
 - ⊗ MACTEC BORINGS


NOTE:

- * ELEVATION IS A REASONABLE INTERPRETATION OF GEOLOGIC CONTACT AND IS CONSIDERED TO BE ACCURATE TO ±2 FEET.
- ** COPIES OF BORING LOGS FOR MACTEC BORINGS (MAC-B-1 THRU MAC-B-5) INCLUDED IN APPENDIX A OF THIS REPORT.

REV.	DATE	DESCRIPTION	DR BY	APP BY
 COOK-JOYCE INC. ENGINEERING AND CONSULTING 812 WEST ELEVENTH 812-474-8087 AUSTIN, TEXAS 78701				
PROJECT: LOCKWOOD GREENE				
SHEET TITLE: TOP OF RED BED STRUCTURE MAP				
DES BY:	SDB	SCALE:	SEE BAR SCALE	
DR BY:	SDB	PROJECT NO.:	03070	
CHK BY:	EEH	CJA NO.:	03070004	
APP BY:	DHG	SHEET:	1 OF 1 SHEETS	
DATE ISSUED:	11-10-2003	FIGURE NO.:	4	
PURPOSE: REPORT				

LEGEND

- PIEZOMETERS
- SUPPLEMENTAL WELLS
- ⊕ MONITORING WELL
- GROUNDWATER FLOW DIRECTION



REV.	DATE	DESCRIPTION	DR BY	APP BY

LOCKWOOD-JOYCE INC.
 ENGINEERING AND CONSULTING
 612 WEST ELEVENTH ST. SUITE 200
 AUSTIN, TEXAS 78701

PROJECT: **LOCKWOOD GREENE
 SITE INVESTIGATION**

SHEET TITLE		2003 FALL 230-FOOT ZONE GROUNDWATER GRADIENT CONTOURS	
DES BY	DHG	CHK BY	DIVA
DR BY	SDS	APP BY	DIVA
DATE ISSUED	11-16-2003	PURPOSE	REPORT
SCALE	SEE BAR SCALE	PROJECT NO.	03070
		CU NO.	03070003
		SHEETS	1 OF 1 SHEETS
		FIGURE NO.	5



APPENDIX A
LITHOLOGIC LOGS



LOG OF BORING NO. B-1
 Lockwood Greene Engineering and Construction

TYPE: 6" Flight Augers

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC/(ROD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 522,969.2 E 925,623.0 El 3396.49					
5				Fine sand with silt - very loose, very dry, red, (SM).					
10									
15				Fine sand with silt and gravel (<1/2" Dia.) - very dry, red and gray, (SW).	3381.5 15.0				
20									
25									
30				Fine sand with silt and gravel (<1-1/2" Dia) - very dry, gray and red, (SW).					
35									
40				Fine sand with silt and abundant gravel (<1-1/2" Dia.) - very dry, red, (SW).					
45									
50									
55				Top of red bed, silty clay - very dry, red, (CL).	3341.5 55.0				
60				TD-60'	3336.5 60.0				

COMPLETION DEPTH: 60.0'

DATE: 8-28-03

PROJECT NO.: 03070

GEOT2 03070 11-17-03



LOG OF BORING NO. B-2
 Lockwood Greene Engineering and Construction

TYPE: 8" Hollow-Stems

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC/(RQD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH
				N 522,906.4 E 927,284.7 EI 3402.31	
				Fine sand with silt and gravel (<1/2" Dia.) - very loose, very dry, tan, (SW).	
5				Fine sand with silt and gravel (<1/2" Dia.) - very loose, very dry, red, (SW).	
10					
15				Fine sand with silt and gravel (<1/2" Dia.) - very dry, gray and red, (SW).	
				Gravel layer from 15.5' - 16.5'	
20					
25					
30					
35				Top of red bed, silty clay - very dry, red, some chert present, (CL).	3368.3 34.0
40				TD=40'	3362.3 40.0

COMPLETION DEPTH: 40.0'

DATE: 8-27-03

PROJECT NO.: 03070

NOTE 03070 11-17-03

LOG OF BORING NO. B-3

Lockwood Greene Engineering and Construction

TYPE: 6" Flight Augers

LOCATION: Emice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC/(ROD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 522,942.0 E 928,870.2 E1 3403.38					
5				Fine sand with silt - very loose, very dry, red, (SM).	3396.4				
10				Fine sand with silt and gravel (<1/4" Dia.) - very dry, gray, (SW).	7.0				
15									
20				Fine sand with silt and gravel (<1/2" Dia.) - very dry, gray and red, some chert present, (SW).					
25				Top of red bed, silty clay - very dry, red, (CL).	3380.4 23.0				
30									
35				TD=35'	3368.4 35.0				

COMPLETION DEPTH: 35.0'

DATE: 8-28-03

PROJECT NO.: 03070

GEOTE 03070 11-17-03



COOK-JOYCE INC.
ENGINEERING AND CONSULTING
812 WEST ELEVENTH
AUSTIN, TEXAS 78701-2000
(512)474-8097 FAX (512)474-8463

LOG OF BORING NO. B-4

Lockwood Greene Engineering and Construction

TYPE: 6" Flight Augers

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	FLOWS PER FOOT OR REC/(ROD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 524,233.0 E 925,711.8 EI 3400.66					
5				Fine sand with silt - very loose, very dry, gray and red, (SM).					
10									
15									
20					3379.7				
25				Fine sand with silt and gravel (<1" Dia.) - very dry, red and gray, (SW).	21.0				
30									
35									
40				Fine sand with silt and gravel (<1" Dia.) - very dry, gray and red, (SW).					
45					3355.7				
50				Top of red bed, silty clay - very dry, red, (CL).	45.0				
55									
60					3340.7				
				TD=60'	60.0				

COMPLETION DEPTH: 60.0'

DATE: 8-28-03

PROJECT NO.: 03070

03070 03070 11-19-03

LOG OF BORING NO. B-5

Lockwood Greene Engineering and Construction

TYPE: 0-40' Hollow-Stems 40-45' Air Rotary

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC(ROD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 524,274.0 E 927,281.5 El 3408.85					
5				Fine sand with silt - very loose, very dry, red, (SM).					
10				Fine sand with silt - very dry, red and gray, caliche present, (SM).					
15									
20									
25									
30				Fine sand with silt and gravel (< 1/2" Dia.) - very dry, gray and red, (SW). 6" gravel layer from 32'-32.5'.	3378.9 30.0				
35				3" gravel layer					
40					3365.9				
45				Top of red bed, silty clay - very dry, red, (CL).	43.0				
				TD=45'	3363.9 45.0				

COMPLETION DEPTH: 45.0'

DATE: 8-27-03

PROJECT NO.: 03070

GEOTE 03070 11-17-03



LOG OF BORING NO. B-6

Lockwood Greene Engineering and Construction

TYPE: 6" Flight Augers

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC/(RQD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH			
				N 524,346.4 E 928,685.6 El 3414.75				
5				Fine sand with silt - very loose, very dry, red, (SM).				
10				Fine sand with silt - very dry, red and gray, (SM).	3404.8			
15				Fine sand with silt and gravel (<1/4" Dia.) - very dry, gray, (SW).	10.0			
20				Fine sand with silt and gravel (<1/2" Dia.) - very dry, gray, (SW).				
25								
30								
35								
40				Fine sand with silt - very dry, red and gray, (SM).	3374.8			
45				Top of red bed, silty clay - very dry, red, (CL).	40.0			
50					3369.8			
55					45.0			
60				TD=60'	3354.8			
					60.0			

COMPLETION DEPTH: 60.0'

DATE: 8-28-03

PROJECT NO.: 03070

03070 11-19-03

LOG OF BORING NO. B-7

Lockwood Greene Engineering and Construction

TYPE: 6" Flight Augers

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC/(RQD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 525,545.0 E 925,661.4 El 3415.00					
5				Fine sand with silt - very loose, very dry, red, (SM).					
10				Fine sand with silt - very dry, red and gray, (SM).					
15									
20									
25				Fine sand with silt and gravel (<1" Dia.) - very dry, gray and red, (SW).	3392.0 23.0				
30				Top of red bed, silty clay - very dry, red, (CL).	3389.0 26.0				
35									
40				TD=40'	3375.0 40.0				

COMPLETION DEPTH: 40.0'

DATE: 8-28-03

PROJECT NO.: 03070

03070 11-17-03

LOG OF BORING NO. B-8

Lockwood Greene Engineering and Construction

TYPE: Hollow-Stem Augers 0-40', 40-45' Air Rotary

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC(ROD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 525,604.7 E 927,274.2 El 3423.29					
5				Fine sand with silt - very loose, very dry, red, (SM).					
10									
15									
20						3403.3			
25				Fine sand with silt and gravel (<1" Dia.) - very dry, caliche and chert present, red, gray, and tan, (SW).	20.0				
30									
35									
40				Top of red bed, silty clay - very dry, red, (CL).	3385.3				
45					38.0				
45				TD-45'	3378.3				
					45.0				

COMPLETION DEPTH: 45.0'

DATE: 8-26-03

PROJECT NO.: 03070

GEO72 03070 11-17-03



LOG OF BORING NO. B-9

Lockwood Greene Engineering and Construction

TYPE: 6" Flight Augers

LOCATION: Eunice, N.M.

DEPTH, FT	SYMBOL	SAMPLES	BLOWS PER FOOT OR REC/(ROD), %	STRATUM DESCRIPTION	LAYER ELEV./DEPTH				
				N 525,735.9 E 928,595.5 EI 3421.33					
5				Fine sand with silt - very loose, very dry, red, (SM).	3415.3				
10				Fine sand with silt and gravel (< 1/2" Dia.) - very loose, slightly moist, (SW).	6.0				
15				Fine sand with silt - very dry, red and gray, (SM).	3407.3				
20				Fine sand with silt - very dry, gray, (SM).	14.0				
25									
30									
35				Fine sand with silt - very dry, red and gray, (SM).					
40									
45					3375.3				
50				Top of red bed, silty clay - very dry, red, (CL).	46.0				
55									
60				TD=60'	3361.3				
					60.0				

COMPLETION DEPTH: 60.0'

DATE: 8-28-03

PROJECT NO.: 03070

GEOLOGIST 11-17-03

GROUP SYMBOLS	TYPICAL NAMES	GROUP SYMBOLS	TYPICAL NAMES	Undisturbed Sample 1.5-2.0 = Recovered (ft) / Pushed (ft)
	TOPSOIL		CONCRETE	Split Spoon Sample
				Auger Cuttings
				Rock Core 60-100 = RQD / Recovery
	ASPHALT		DOLOMITE	No Sample
				Crandall Sampler
				Rotary Drill
	GRAVEL		LIMESTONE	Water Table at time of drilling
				No Recovery
				Water Table after 24 hours
	FILL		SHALE	
	SUBSOIL		LIMESTONE/SHALE - Limestone with shale interbeds	
	ALLUVIUM		SANDSTONE	
	COLLUVIUM		SILTSTONE	
	RESIDIUM - Soft to firm		AUGER BORING	
	RESIDIUM - Stiff to very hard		UNDISTURBED SAMPLE ATTEMPT	

Correlation of Penetration Resistance
with Relative Density and Consistency

SAND & GRAVEL		SILT & CLAY	
No. of Blows	Relative Density	No. of Blows	Consistency
0 - 4	Very Loose	0 - 2	Very Soft
5 - 10	Loose	3 - 4	Soft
11 - 20	Firm	5 - 8	Firm
21 - 30	Very Firm	9 - 15	Stiff
31 - 50	Dense	16 - 30	Very Stiff
Over 50	Very Dense	31 - 50	Hard
		Over 50	Very Hard

BOUNDARY CLASSIFICATIONS: Soils possessing characteristics of two groups are designated by combinations of group symbols.

SILT OR CLAY	SAND			GRAVEL		Cobbles	Boulders
	Fine	Medium	Coarse	Fine	Coarse		
	No.200	No.40	No.10	No.4	3/4"	3"	12"


U.S. STANDARD SIEVE SIZE

KEY TO SYMBOLS AND DESCRIPTIONS



MACTEC Engineering and Consulting, Inc.
1725 Louisville Drive
Knoxville, Tennessee 37921-5904
865-588-8544 • Fax: 865-588-8028

Reference: The Unified Soil Classification System, Corps of Engineers, U.S. Army Technical Memorandum No. 3-357, Vol. 1, March, 1953 (Revised April, 1960)



SOIL 3043031049 01.GPJ LAW_CITBB.GDT 10/2/03

REMARKS: STANDARD PENETRATION RESISTANCE TESTING PERFORMED USING A SAFETY HAMMER. NO GROUND WATER ENCOUNTERED AT TIME OF EXPLORATION. BACK FILLED ON 9/9/2003.

SOIL TEST BORING RECORD


PROJECT: NEF - Lea County, New Mexico

DRILLED: September 9, 2003 **BORING NO.:** B-1

PROJ. NO.: 3043031049/0001 **PAGE 1 OF 1**

THIS RECORD IS A REASONABLE INTERPRETATION OF SUBSURFACE CONDITIONS AT THE EXPLORATION LOCATION. SUBSURFACE CONDITIONS AT OTHER LOCATIONS AND AT OTHER TIMES MAY DIFFER. INTERFACES BETWEEN STRATA ARE APPROXIMATE. TRANSITIONS BETWEEN STRATA MAY BE GRADUAL.





SOIL 3043031049 01.GPJ LAW GIBB.GDT 10/2/03

REMARKS: STANDARD PENETRATION RESISTANCE TESTING PERFORMED USING A SAFETY HAMMER. NO GROUND WATER ENCOUNTERED AT TIME OF EXPLORATION. BACK FILLED ON 9/9/2003.

SOIL TEST BORING RECORD


PROJECT: NEF - Lea County, New Mexico

DRILLED: September 9, 2003 **BORING NO.:** B-2

PROJ. NO.: 3043031049/0001 **PAGE 1 OF 1**

THIS RECORD IS A REASONABLE INTERPRETATION OF SUBSURFACE CONDITIONS AT THE EXPLORATION LOCATION. SUBSURFACE CONDITIONS AT OTHER LOCATIONS AND AT OTHER TIMES MAY DIFFER. INTERFACES BETWEEN STRATA ARE APPROXIMATE. TRANSITIONS BETWEEN STRATA MAY BE GRADUAL.





SOIL 3043031049 01.GPJ LAW GIBB.GDT 10/2/03


REMARKS: STANDARD PENETRATION RESISTANCE TESTING PERFORMED USING A SAFETY HAMMER. NO GROUND WATER ENCOUNTERED AT TIME OF EXPLORATION. BACK FILLED ON 9/10/2003.

SOIL TEST BORING RECORD

PROJECT: NEF - Lea County, New Mexico
 DRILLED: September 10, 2003 BORING NO.: B-3
 PROJ. NO.: 3043031049/0001 PAGE 1 OF 3

THIS RECORD IS A REASONABLE INTERPRETATION OF SUBSURFACE CONDITIONS AT THE EXPLORATION LOCATION. SUBSURFACE CONDITIONS AT OTHER LOCATIONS AND AT OTHER TIMES MAY DIFFER. INTERFACES BETWEEN STRATA ARE APPROXIMATE. TRANSITIONS BETWEEN STRATA MAY BE GRADUAL.






SOIL 3043031049_01.GPJ LAW GIBB.GDT 10/26/03

REMARKS: STANDARD PENETRATION RESISTANCE TESTING PERFORMED USING A SAFETY HAMMER. NO GROUND WATER ENCOUNTERED AT TIME OF EXPLORATION. BACK FILLED ON 9/10/2003.

SOIL TEST BORING RECORD	
PROJECT: NEF - Lea County, New Mexico	BORING NO.: B-
DRILLED: September 10, 2003	
PROJ. NO.: 3043031049/0001	PAGE 2 OF

THIS RECORD IS A REASONABLE INTERPRETATION OF SUBSURFACE CONDITIONS AT THE EXPLORATION LOCATION. SUBSURFACE CONDITIONS AT OTHER LOCATIONS AND AT OTHER TIMES MAY DIFFER. INTERFACES BETWEEN STRATA ARE APPROXIMATE. TRANSITIONS BETWEEN STRATA MAY BE GRADUAL.




SOIL 3043031049 01.073 LAW GIBB.GDT 10/2/03

REMARKS: STANDARD PENETRATION RESISTANCE TESTING PERFORMED USING A SAFETY HAMMER. NO GROUND WATER ENCOUNTERED AT TIME OF EXPLORATION. BACK FILLED ON 9/9/2003.

THIS RECORD IS A REASONABLE INTERPRETATION OF SUBSURFACE CONDITIONS AT THE EXPLORATION LOCATION. SUBSURFACE CONDITIONS AT OTHER LOCATIONS AND AT OTHER TIMES MAY DIFFER. INTERFACES BETWEEN STRATA ARE APPROXIMATE. TRANSITIONS BETWEEN STRATA MAY BE GRADUAL.

SOIL TEST BORING RECORD	
PROJECT: NEF - Lea County, New Mexico	BORING NO.: B-4
DRILLED: September 9, 2003	
PROJ. NO.: 3043031049/0001	PAGE 1 OF 1



SOIL 3043031049 01.GPJ LAW GIDB.GDT 10/3/03

REMARKS: STANDARD PENETRATION RESISTANCE TESTING PERFORMED USING A SAFETY HAMMER. NO GROUND WATER ENCOUNTERED AT TIME OF EXPLORATION. BACK FILLED ON 9/10/2003.

THIS RECORD IS A REASONABLE INTERPRETATION OF SUBSURFACE CONDITIONS AT THE EXPLORATION LOCATION. SUBSURFACE CONDITIONS AT OTHER LOCATIONS AND AT OTHER TIMES MAY DIFFER. INTERFACES BETWEEN STRATA ARE APPROXIMATE. TRANSITIONS BETWEEN STRATA MAY BE GRADUAL.

SOIL TEST BORING RECORD	
PROJECT: NEF - Lea County, New Mexico	BORING NO.: B-5
DRILLED: September 10, 2003	
PROJ. NO.: 3043031049/0001	PAGE 1 OF 1



APPENDIX B
SUMMARY OF FIELD ACTIVITIES





SUMMARY OF FIELD ACTIVITIES

Shallow Boring Program

On 26 August 2003, Total Support Services, Inc. (TSS), LG, and CJI personnel were on-site with a Mobil B-59 drill rig to install the nine shallow subsurface soil borings. Initially, CJI proposed to air rotary drill each of the borings to the redbeds. However, due to the looseness and subsequent continuous cave-ins of the sandy soil near the surface, hollow-stem augers were used to keep the boreholes open. After attempts to air rotary drill B-8 and B-5 through hollow-stem augers proved difficult, solid-stem augers were determined to be the preferred method of installing the shallow boreholes. Although hollow-stem augers were used to advance B-2, solid-stem augers were utilized to advance the remaining six shallow boreholes.

In each of the nine shallow boreholes, a CJI geologist lithologically logged the soil using the USCS classification system from borehole cuttings. Particular attention was paid to the upper contact of the redbeds (see Figure 4). The lithologic logs of each of these borings can be found in Appendix A of this report. Upon reaching the upper contact of the redbeds, each borehole was over-drilled several feet so that the borehole might remain open below the contact. On 28 August 2003, the last of the shallow boreholes were completed. On 29 August, each borehole was gauged using an electric water level indicator to determine whether any groundwater had collected in the boring. The top of redbed depths and elevations are shown on Table 1.

Deep Boring Program

The deep subsurface investigation was originally proposed to be conducted using mud rotary drilling techniques which would allow the collection of soil core samples in B-1, B-7, and B-9 from the top of the redbeds to the bottom of the uppermost water-bearing zone. The lower contact of the shallowest water-bearing zone was anticipated to be between 220' and 250' BGS.

On 3 September, TSS personnel mobilized to the site with a Mobil B-53 drill rig to conduct the deep subsurface investigation. TSS set up on B-1 and attempted to set hollow-stem augers to the top of the redbeds. However, due to geologic conditions (the presence of large gravel), the





hollow-stem augers became lodged in the borehole at a depth of about 50' BGL. Numerous unsuccessful attempts were made to dislodge the augers. Eventually another borehole was advanced near the first borehole location. The result was the same and the augers were lodged at about 45' BGL. After unsuccessfully attempting to retrieve the drilling equipment from the two boreholes, the equipment was abandoned. A total of 40' of hollow-stem augers was lost in B-1. At that time, due to geologic conditions, a decision to abandon B-1 and replace that monitor well location with B-3 was made.

Following the abandonment of B-1, TSS moved to B-7. Prior to mud rotary drilling B-7, hollow-stem augers were advanced to the top of the redbeds to keep the upper sand from collapsing into the borehole. Once the hollow-stems were in place, mud rotary drilling was to be used to advance the borehole to total depth (TD). However, due to prior drilling difficulties and time constraints, the decision to utilize air rotary drilling methods to advance B-7 to 180' BGS prior to converting to mud rotary drilling techniques was made. On 7 September, TSS began core sampling B-7 starting at 180' BGS. Due to mud rotary drilling difficulties there was essentially no recovery of core soil samples from 180'-205' BGS. After numerous unsuccessful attempts to collect core soil samples from B-7, a decision was made to air core each of the three test boreholes to 250' BGS and then geophysically log the boreholes to determine monitor well design information.

At that time, TSS began advancing B-9 to 250' using air rotary drilling techniques. After casing the upper 45' of soil using 8-1/4" outer diameter (OD) hollow-stem augers, test borehole B-9 was advanced to a TD of 250' BGS. After tripping the drilling equipment out of the borehole, an electric water level indicator was used to check for the presence of groundwater. It was determined that there was no groundwater in the test borehole immediately upon completion of drilling activities. The borehole was allowed to remain open overnight and was checked the following day. On 10 September, CJI personnel determined groundwater in B-9 was at about 232.22' BGS. Using the same drilling methods, the test borehole at B-7 and the first test borehole at B-3 were completed to about 250' BGS on 11 September and 12 September, respectively. The test boreholes were dry to TD immediately upon completion of drilling activities. Groundwater was not present in B-7 even after allowing it to remain open overnight.





The test borehole at B-3 was geophysically logged immediately after drilling and was not allowed to remain open overnight for subsequent groundwater level data collection.

Before geophysical logging activities could be completed in the test borehole at B-3, the borehole collapsed to 25' BGS. Therefore, a second test borehole was drilled at B-3 to about 250' BGS on 13 September. The second test borehole was also dry upon completion of drilling activities and was geophysically logged immediately thereafter.

Monitor Well Drilling and Installation Program

After the test boreholes at B-3, B-7, and B-9 were geophysically logged, TSS began to make preparations to advance a borehole at each of these locations in which a monitor well would be installed. The boreholes would be cased to the top of the redbeds using 10" OD hollow-stem augers and then air drilled to TD using air rotary drilling methods with a 6"-diameter bit. After setting up to begin this process at B-3, the B-59 drill rig broke down and was not able to be repaired. For this reason, TSS and CJ demobilized from the site on 14 September.

On 18 September, TSS and CJ mobilized to the site. In addition, due to additional time constraints, a second drill rig (CME 75) supplied by Enviro-Drill, Inc. (EDI) was on-site to facilitate monitor well drilling and installation processes.

TSS set up on B-7 (MW-1) and advanced 10" OD hollow-stem augers to 30' BGS. After completing this task, TSS moved to B-3 and began drilling MW-3 by also installing 30' of 10" OD augers. EDI began drilling at B-9 (MW-2) by installing 50' of 10" OD hollow-stem augers. TSS and EDI advanced each monitor well boring to TD using air rotary drilling techniques and 6"-diameter bits. Both crews were using Sullair 900 air compressors. However, EDI drilled using 125 pounds per square inch (PSI) air pressure while TSS drilled using 150 PSI air pressure. On 19 September, TSS reached TD of 240' BGS in MW-3 borehole and EDI reached TD of 235.5' BGS in MW-2 borehole. After completing the installation of MW-3, TSS set up over the augers previously set in the MW-1 borehole. On 20 September, TSS reached TD of 231' BGS in MW-1 borehole.





Upon reaching TD, each crew installed the monitor well material, as witnessed by CJI and LG personnel. Monitor well construction diagrams detailing the installations can be found in Appendix D of this report. Each monitor well was constructed using 2-inch diameter Schedule 40 PVC sealed in its factory packaging. Personnel who handled the unpackaged screen or casing donned latex gloves prior to handling the material. Each monitor well was constructed using 15' of 0.010-inch slotted screen and enough riser to bring the monitor well to the surface. Stainless steel centralizers were attached to the riser about every 50' to hold the monitor well in place. After inserting the screen and riser into the monitor well borehole, a sand filter pack was poured from the surface to bring the sand filter at least three feet above the top of the screened interval. Following placement of the sand filter, bentonite chips were poured from the surface to a level of 75' BGS. The bentonite chips were then hydrated using 10 gallons of distilled water. After pouring in the distilled water, the chips were allowed to hydrate. A cement/bentonite slurry was then placed into the monitor well borehole to fill the annulus to about ground level. Then grout was placed into the annulus by pressure grouting from the bottom up using tremie pipe. After the grout was placed to this level, the hollow-stem augers were removed. The monitor wells were then allowed to set up overnight. The following day, bentonite chips were added to bring the plug to about surface level. After pouring in the appropriate amount of bentonite chips, they were hydrated with five gallons of distilled water. The drop in the level of the cement/bentonite slurry was between 7' and 17' BGS in the three monitor wells.

A variance from the general construction process in Monitor Well MW-1 is noted. While removing the hollow-stem augers from Monitor Well MW-1, TSS experienced some difficulties. About 15' of augers became lodged in the hole and, due to darkness, had to remain in the borehole overnight. The augers were eventually removed the following day. However, in the process of removing them, some loose soil caved in on top of the cement/bentonite slurry.

Each of the monitor wells was surface-completed with a 4'x4'x6" concrete pad and a protective steel upright casing. Prior to pouring concrete for the pads, plastic was laid down within the form to help keep the moisture from being drawn out to the underlying sandy soil. In addition, 6"x6" wire mesh was cut and laid in the forms to help strengthen the concrete. A three-sided, pre-fabricated metal fence was then placed around each pad to protect the monitor well from





cows and other potential harm. In addition, each of the protective casings was locked with a padlock to help prevent tampering.





APPENDIX C
GEOPHYSICAL LOGS



**THIS PAGE IS AN
OVERSIZED DRAWING OR
FIGURE,**

**THAT CAN BE VIEWED AT THE
RECORD TITLED:
"COOK-JOYCE INC. ELECTRIC LOG
HOLE NO. B-3, HOLE NO.B-7. HOLE
NO.B-9."**

WITHIN THIS PACKAGE..

D-01



APPENDIX D
MONITOR WELL CONSTRUCTION DIAGRAM




Well No.: MW-1
 Boring No.: B-7



MONITOR WELL CONSTRUCTION SUMMARY

Survey Coordinates: 525569.741 N Elevation Ground Level: 3415.44'
925710.071 E Top of Casing: 3418.37'
 New Mexico State Plane Zone 3001 (NAD83) Screened Interval: 3186.7' - 3201.7'



DRILLING SUMMARY			CONSTRUCTION TIME LOG ⁽¹⁾				
Total Depth: 231'			Start		Finish		
Borehole Diameter: 10" Augers 0 - 30' BGS			Task	Date	Time	Date	Time
6" Air 30' - 231' BGS			Drilling:				
			Augers	9/18	17:25	9/18	17:55
			Air Drill	9/20	10:30	9/20	14:20
Casing Stick-up Height: 2.93'							
Driller: Total Support Services			Geophys Log:	9/12	10:45	9/12	11:30
			Casing:	9/20	16:05	9/20	16:35
Rig: B-59							
Bit(s): 6" Rotary Bit, 10" Hollow Stem Augers			Filter Placement:	9/20	16:40	9/20	16:47
Drilling Fluid: Air			Cementing:	9/20	17:42	9/20	18:02
Protective Casing: 4" x 4" Steel			Bentonite Seal:	9/20	16:47	9/20	17:42
				9/21	11:03	9/21	11:15
WELL DESIGN AND SPECIFICATIONS			WELL DEVELOPMENT				
Basis: Geologic Log <input type="checkbox"/> Geophysical Log <input checked="" type="checkbox"/> X							
Casing String(s): C = Casing S = Screen							
Depth	String(s)	Elevation					
0' - 213.8'	C	3201.7' - 3415.4'					
213.8' - 228.8'	S	3186.7' - 3201.7'					
			WELL COMPLETION				
Casing:	C1	2" Flush Threaded Schedule 40 PVC	Filter Pack: 211' - 229' BGS (7-50 lb. bags of 20-40 filtered Unimin silica sand)				
	C2		Bentonite Seal: 75' - 211' BGS (40 1/2-50 lb. Bags)				
Screen:	S1	2" Flush Threaded Schedule 40 PVC, 0.01" Slot	Grout Seal: 2 pours: 1 st pour, 100 gallons water, 6-82.5 bags Portland cement, and 1/2-50 lb. bag CETCO Super Gel; 2 nd pour 75-gallons water, 4-82.5 lb. bags Portland cement and 1/3-50 lb. bag CETCO Super Gel.				
	S2						
COMMENTS: ⁽¹⁾ All dates 2003. Hydrated chips from 75' - 211' BGS with 10 gallons distilled water. On 9/21, added 13 bags of Bentonite from 1' - 13' BGS and hydrated with 5 gallons of distilled water. Centralizers at 51', 101', 151', and 201' BGS.							

Site Name: LES EUNICE, N.M.


Supervised by: Edward E. Hooper
 Date: 11/19/03

Well No.: MW-2
 Boring No.: B-9



MONITOR WELL CONSTRUCTION SUMMARY

Survey Coordinates: 525770.200 N Elevation Ground Level: 3422.14'
928625.728 E Top of Casing: 3425.25'
 New Mexico State Plane Zone 3001 (NAD83). Screened Interval: 3180.32' - 3205.32'



DRILLING SUMMARY			CONSTRUCTION TIME LOG ⁽¹⁾				
Total Depth: 235.5'			Start		Finish		
			Date	Time	Date	Time	
Borehole Diameter: 10" Augers 0 - 50' BGS			Task				
6" Air 50' - 235.5' BGS			Drilling:				
Casing Stick-up Height: 3.11'			Augers	9/18	17:49	9/18	19:35
			Air Drill	9/19	08:25	9/19	12:45
Driller: Enviro-Drill, Inc.			Geophys Log:	9/10	12:00	9/10	19:00
			Casing:	9/19	15:40	9/19	16:20
Rig: CME-75							
Bit(s): 6" Cutter Bit, 10" Hollow Stem Augers			Filter Placement:	9/19	16:25	9/19	16:35
Drilling Fluid: Air			Cementing:	9/19	19:05	9/19	20:32
Protective Casing: 4" x 4" Steel			Bentonite Seal:	9/19	16:36	9/19	17:02
				9/20	11:15	9/20	11:25
WELL DESIGN AND SPECIFICATIONS			WELL DEVELOPMENT				
Basis: Geologic Log <input type="checkbox"/> Geophysical Log <input checked="" type="checkbox"/>							
Casing String(s): C = Casing S = Screen							
Depth	String(s)	Elevation					
0' - 216.82'	C1	3200.32' - 3422.14'					
216.82' - 231.82'	S1	3180.32' - 3205.32'					
Casing: C1	2" Flush Threaded Schedule 40 PVC	Filter Pack: 212' - 232' BGS (8-50 lb. bags of 20-40 filtered Unimin silica sand)					
C2		Bentonite Seal: 75' - 212' BGS (41 1/3-50 lb. Bags)					
Screen: S1	2" Flush Threaded Schedule 40 PVC, 0.010" Slot	Grout Seal: 3 pours: 1 st pour, 160 gallons of water, 6-92.5 lb. Bags Portland cement, and 1-50 lb. bag CETCO Super Gel. 2 nd pour, 60 gallons of water, 2-92.5 lb bags of Portland, and 1/3-50 lb bag of CETCO Supergel. 3rd pour, 25 gallons of water, 1-92.5 lb bags of Portland, and 1/8-50 lb bag of CETCO Supergel.					
S2							
COMMENTS: ⁽¹⁾ All dates 2003. Hydrated chips with 10 gallons distilled water from 75' - 212'.							
Centralizers at 47', 97', 147', and 197' BGS. On 9/20 added 7 bags of Bentonite chips from 1' - 10' BGS and hydrated with 5 gallons of distilled water.							

Site Name: LES
EUNICE, N.M.


Supervised by: Edward E. Dejeu
 Date: 11/19/03

Well No.: MW-3
 Boring No.: B-3



MONITOR WELL CONSTRUCTION SUMMARY

Survey Coordinates: 522989.922 N Elevation Ground Level: 3403.98'
928883.152 E Top of Casing: 3406.98'
 New Mexico State Plane Zone 3001 (NAD83) Screened Interval: 3168.08' - 3183.08'



DRILLING SUMMARY			CONSTRUCTION TIME LOG ⁽¹⁾			
			Start		Finish	
Total Depth: 240'	Task		Date	Time	Date	Time
Borehole Diameter: 10" Augers 0 - 30' BGS	Drilling:					
6" Air 30' - 240' BGS	Augers		9/18	19:14	9/18	19:48
	Air Drill		9/19	10:45	9/19	14:45
Casing Stick-up Height: 3.0'						
Driller: Total Support Services, Inc..	Geophys Log:		9/13	16:00	9/13	17:50
	Casing:		9/19	17:15	9/19	17:55
Rig: B-59						
Bit(s): 6" Rotary Bit, 10" Hollow Stem Augers	Filter Placement:		9/19	18:00	9/19	18:08
Drilling Fluid: Air	Cementing:		9/19	18:15	9/19	18:33
Protective Casing: 4" x 4" Steel	Bentonite Seal:		9/19	18:10	9/19	18:42
			9/20	08:18	9/20	08:30
WELL DESIGN AND SPECIFICATIONS			WELL DEVELOPMENT			
Basis: Geologic Log <input type="checkbox"/> Geophysical Log <input checked="" type="checkbox"/>						
Casing String(s): C = Casing S = Screen						
Depth	String(s)	Elevation				
0' - 220.9'	C	3183.08' - 3403.98'				
220.9' - 235.9'	S	3168.08' - 3183.08'				
			WELL COMPLETION			
Casing: C1	2" Flush Threaded Schedule 40 PVC	Filter Pack: 217.8' - 235.8' BGS (7-1/2 50 lb. bags of 20-40 filtered Unimin silica sand)				
C2		Bentonite Seal: 75' - 217.8' BGS (44 1/2-50 lb. Bags)				
Screen: S1	2" Flush Threaded Schedule 40 PVC, 0.010" Slot	Grout Seal: 2 pours: 1 st pour; 17' - 75' BGS, 150 gallons water, 8-50 lb. bags Portland cement, and 2/3 50-lb. bag CETCO Super Gel. 2 nd pour; 95 gallons of water, 4-50 lb. bags Portland cement, and 1/3-bag of CETCO Supergel.				
S2						
COMMENTS: ⁽¹⁾ All dates 2003. Hydrated chips with 10 gallons distilled water (75' - 217.8' BGS). On 9/20, added 17 bags of Bentonite chips from 1' - 17' BGS and hydrated with 5 gallons of distilled water. Centralizers at 51', 101', 151', and 201' BGS.						

Site Name: LES FUNICE, N.M.

Supervised by: Edward E. Heph
 Date: 11/19/03



APPENDIX E
HYDRAULIC CONDUCTIVITY CALCULATIONS



PROJECT LOCKWOOD GREENE JOB NO. 03070 PREP. BY DG DATE 11/17/03
 SUBJECT HORSELEU SLOPE TEST CALC. CHKD. BY _____ DATE _____
 PHASE/TASK _____ APP. BY _____ DATE _____

TD = 235.5 FT
 H = 120.5 FT
 H₀ = 44.72 FT
 H - H₀ = 75.78 FT

TIME (HRS)	DT (FT)	h (FT)	$\frac{H-h}{H-H_0}$
0	190.78	44.72	1
24	165.04	70.46	0.66
48	153.85	81.65	0.51
72	149.68	85.82	0.46
96	148.67	86.83	0.44
168	138.71	96.79	0.31
192	135.11	100.39	0.27

$$K = \frac{r^2 \ln(L/R)}{2LT_0}$$


$$= \frac{(0.083 \text{ FT})^2 \ln(15 \text{ FT} / 0.25 \text{ FT})}{2 \cdot 15 \text{ FT} \cdot 130 \text{ MIN}}$$

$$= 7.2 \times 10^{-6} \text{ FT/MIN}$$

$$= 3.7 \times 10^{-6} \text{ CM/SEC}$$

$$= 3.8 \text{ FT/YR}$$

K₂Σ SEMI-LOGARITHMIC 46 5153
2 CYCLES X 140 DIVISIONS MADE IN U.S.A.
KEUPPEL & BESSER CO.





APPENDIX F
GROUNDWATER VELOCITY CALCULATIONS



PROJECT LOCKWOOD GREENE JOB NO. 03070 PREP. BY DG DATE 11/17/03
SUBJECT GROUNDBWATER VELOCITY CALC. CHKD. BY _____ DATE _____
PHASE/TASK _____ APP. BY _____ DATE _____

$$V = \frac{K i}{n}$$

K = HYDRAULIC CONDUCTIVITY

i = HYDRAULIC GRADIENT

n = POROSITY

V = VELOCITY

$$K = 3.8 \text{ FT/YR}$$

$$i = 0.011$$

$$n = 0.14$$

$$V = \frac{3.8 \text{ FT/YR} \times 0.011}{0.14}$$

$$V = 0.3 \text{ FT/YR}$$



APPENDIX G
SURVEY RESULTS





PETTIGREW and ASSOCIATES

1110 N. GRIMES
 HOBBS, NEW MEXICO 88240
 (505) 393-9827

DEBRA F. HICKS, P.E./L.S.J.
 WILLIAM N. HICKS, III, P.E./P.S.

23 September, 2003

Cook-Joyce Inc.
 812 West Elevneth
 Austin, Texas 78701-2000
 Facsimile Number: 512-474-8463

ATTN: Ed Hughes / Doug Granger
 RE: Location of monitoring wells and borehole locations within the LES site east of Eunice
 New Mexico.

Dear Mr. Granger:

Below I have tabulated the data you have requested for the borehole locations:

Borehole locations			
Northing	Easting	Elevation	Description
622969.203	925622.959	3396.49	BH-1
622906.403	927284.708	3402.31	BH-2
622941.969	928870.232	3403.38	BH-3
624232.996	925711.777	3400.66	BH-4
624273.953	927281.455	3408.85	BH-5
624346.448	928685.553	3414.76	BH-6
625545.025	925661.407	3415.00	BH-7
625604.689	927274.151	3423.29	BH-8
625735.902	928595.512	3421.33	BH-9

Additionally here is the data you requested for the three monitoring wells:

Monitoring Wells			
Northing	Easting	Elevation	Description
625569.741	925710.071	3418.31	MW-1 VAULT
		3418.37	MW-1 CASING
		3416.00	MW-1 CONC
		3415.44	MW-1 GRND
625770.200	928625.728	3425.11	MW-2 VAULT
		3425.25	MW-2 CASING
		3422.60	MW-2 CONC
		3422.14	MW-2 GRND
622989.922	928883.152	3406.97	MW-3 VAULT
		3406.98	MW-3 CASING
		3404.33	MW-3 CONC
		3403.98	MW-3 GRND

Page 2

RE: Location of monitoring wells and borehole locations within the LES site east of Eunice New Mexico.

All observations were made from USC&GS Benchmark 12DD. We used real-time differentially corrected global positioning system observations at each location. Horizontal and vertical control values (X,Y,Z) at benchmark 12DD were derived from 3 continuously operating reference stations in the area. The above listed coordinates are referenced to New Mexico State Plane Coordinates Zone 3001 (NAD83), with the vertical referenced to NAVD(88). The X&Y values have been scaled to ground values.

Sincerely,
PETTIGREW and ASSOCIATES, P.A.



Daniel R. Muth, PS

ATTACHMENT D

DESCRIPTION OF LIQUID EFFLUENT COLLECTION TREATMENT SYSTEM

ATTACHMENT D

Ground Water Discharge Permit Application

D.1 Liquid Effluent Collection and Treatment System

Various types of aqueous and non-aqueous liquid wastes are generated in the facility. These effluents may be contaminated, potentially contaminated with low amounts of contamination, or non-contaminated.

A Liquid Effluent Collection and Treatment System is located in the Liquid Effluent Collection and Treatment Room in the Technical Services Building (TSB). A block flow diagram of the Liquid Effluent Collection and Treatment System is provided in Figure D-1. The Liquid Effluent Collection and Treatment System equipment location and arrangement is shown in Figure 3.5-29, Liquid Effluent Collection and Treatment Room, Equipment Arrangement. Non-contaminated aqueous effluents that are generated are collected, monitored for contamination, and discharged directly to the Treated Effluent Evaporative Basin (TEEB) if found to meet all regulatory and administrative requirements. Non-aqueous liquid wastes that are generated are collected and disposed of in accordance with all federal, state, and local regulations and in accordance with good and accepted industrial practice. All effluent collection, treatment, and disposal is done with respect to the safety of all personnel and in strict accordance with all federal, state, and local regulations. All contaminated effluents are handled to keep radiation doses to operating personnel and the public as low as reasonably achievable (ALARA).

D.1.1 Aqueous Liquid Effluents

Quantities of radiologically contaminated, potentially radiologically contaminated, and non-radiologically contaminated aqueous liquid effluents are generated in a variety of operations and processes in the TSB and in the Separations Building. All aqueous liquid effluents generated in the TSB are categorized as contaminated, potentially contaminated, or non-contaminated based on their uranic content. The majority of all potentially radiologically contaminated aqueous liquid effluents are generated in the TSB. All aqueous liquid effluents generated in the TSB are collected in tanks that are located in the Liquid Effluent Collection and Treatment Room in the TSB. The collected effluent is sampled and analyzed to determine if treatment is required before release to the TEEB.

D.1.1.1 System Description

D.1.1.1.1 Citric Acid

When the Citric Acid Tank in the Decontamination Workshop is drained, all the effluent is transferred to the Spent Citric Acid Collection Tank in the Liquid Effluent Collection and Treatment Room (see Figure 3.5-30, Process Flow Diagram, Spent Citric Acid). A "sludge" remains in the bottom of the Citric Acid Tank. This "sludge" consists primarily of uranium and metal particles. This sludge is flushed out with DI water. The combination of the sludge and the DI water also goes to the Spent Citric Acid Collection Tank. The spent citric acid effluent/sludge contains the wastes from the Sample Bottle and Flexible Hose Decontamination Cabinets, which are manually transferred to the Citric Acid Tank in the Decontamination System. The contents of the Spent Citric Acid Collection Tank are constantly agitated to keep all solids in suspension and to provide a homogeneous solution. This is necessary to prevent build-up of uranic material in the bottom of the tank.

D.1.1.1.2 Degreaser Water

When the Degreaser Tank in the Decontamination Workshop is drained, all the effluent is transferred to the Degreaser Water Collection Tank in the Liquid Effluent Collection and Treatment Room (see Figure 3.5-31, Process Flow Diagram, Degreaser Water). A "sludge" remains in the bottom of the Degreaser Tank after the degreasing water is drained. This "sludge" consists primarily of Fomblin oil and uranium. This sludge is flushed out with DI water. The combination of the sludge and the DI water also goes to the Degreaser Water Collection Tank. The contents of the Degreaser Water Collection Tank remain agitated to keep all solids in suspension and to provide a homogeneous solution. This is necessary to prevent build-up of uranic material in the bottom of the tank. Since this effluent contains Fomblin oil, it is not possible to send the degreaser water to the Precipitation Treatment Tank for treatment. Therefore, the Fomblin oil must be removed first.

For Fomblin oil removal, the contents of the Degreaser Water Collection Tank circulate through a small centrifuge. The oil and sludge are centrifuged off, collected in a container, and sent for offsite low-level waste disposal.

D.1.1.1.3 Laboratory Effluent

Aqueous laboratory effluents with uranic concentrations are sampled to determine their uranic content and then pumped from the labs to the agitated Miscellaneous Effluent Collection Tank in the Liquid Effluent Collection and Treatment Room (see Figure 3.5-32, Process Flow Diagram, Miscellaneous Effluent). Floor washings are sampled to determine their uranic content and then manually emptied into the Miscellaneous Effluent Collection Tank. Condensate may be either manually transported or pumped through piping to the tank after sampling.

D.1.1.1.4 Laundry

All washing machine water is discharged from the clothes washers to the Laundry Effluent Monitor Tanks in the Liquid Effluent Collection and Treatment Room (see Figure 3.5-33, Process Flow Diagram, Laundry Effluent). Due to the very low contamination of this effluent and the constant flow into these tanks, they are not agitated. Samples of the effluents are regularly taken to the laboratory for analysis. Lab testing determines pH, soluble uranic content, and insoluble uranic content. The analysis determines if the effluent meets regulatory requirements and administrative levels set prior to release into the TEEB. Previous operating experience indicates that the clothes washed contain very small amounts of UO_2F_2 and trace amounts of UF_4 .

The laundry effluent is expected to meet the requirements mentioned above for release. If the effluent is determined to meet all the requirements, it is released to the TEEB. If the laboratory analysis shows it is not in conformance, then the effluent is held in one of the Laundry Effluent Monitor Tanks. Depending on the laboratory analysis, it can either be sent to the Precipitation Treatment Tank for processing through the treatment system, or it can be sent off-site for treatment and disposal as low-level waste.

D.1.1.1.5 Washes and Showers

All water from the personnel hand washes and showers in the TSB, Separations Building Modules, Blending and Liquid Sampling Area, and the Centrifuge Test and Post Mortem Areas

goes to the Hand Wash / Shower Monitor Tanks in the Liquid Effluent Collection and Treatment Room (see Figure 3.5-34, Process Flow Diagram, Hand Wash/Shower Effluent). Since these effluents are expected to be non-contaminated, there is no need to provide agitation in these tanks. Samples of the effluents are regularly taken to the laboratory for analysis. Lab testing determines pH, soluble uranic content, and insoluble uranic content. The analysis determines if the effluent meets all federal, state, and local requirements in addition to administrative levels set prior to release to the TEEB. If it is determined the effluent meets all the requirements, it is released to the TEEB. There is little probability these effluents are contaminated. Therefore, it is assumed the effluent always meets the requirements for release to the TEEB. No provisions are provided for any treatment of these effluents.

D.1.1.1.6 Precipitation Treatment Tank

When a batch has been added to, processed at, sampled at, and analyzed at the Spent Citric Acid Collection Tank, Degreaser Water Collection Tank, or Miscellaneous Effluent Collection Tank, the contents are transferred to the Precipitation Treatment Tank.

The Precipitation Treatment Tank (see Figure 3.5-35, Process Flow Diagram, Precipitation/Treatment) is used to remove the majority of the uranium that is in solution. After the effluent is transferred to the Precipitation Treatment Tank, a precipitating agent, such as potassium hydroxide (KOH) or sodium hydroxide (NaOH), is added. The addition of the precipitating agent raises the pH of the effluent to the range of 9 to 12. This makes the soluble uranium compounds become insoluble compounds that precipitate from the solution. The tank contents are constantly agitated to provide a homogeneous solution. The precipitated compounds are then removed from the effluent by circulation through a small filter press. The material removed by the filter press is deposited in a container and sent for off-site low-level waste disposal.

The clean effluent from the filter press is re-circulated back to the Precipitation Treatment Tank. Depending on the characteristics of the effluent and the filter press design, the effluent may have to be circulated through the filter press numerous times to obtain the percent of solids removal required. A sample of the effluent is taken to determine when the correct amount of solids has been removed. When it is determined that the correct amount of solids have been removed, the effluent is transferred to the Contaminated Effluent Hold Tank.

D.1.1.1.7 Contaminated Effluent Hold Tank

The effluent in the Contaminated Effluent Hold Tank is transferred to the agitated Evaporator/Dryer Feed Tank (see Figure 3.5-36, Process Flow Diagram, Evaporator/Dryer). Acid is added via a small chemical addition unit to reduce the pH back down to 7 or 8. This is necessary to help minimize corrosion in the Evaporator/Dryer.

D.1.1.1.8 Evaporator/Dryer Feed Tank and Evaporator/Dryer

From the Evaporator/Dryer Feed Tank, the effluent is pumped to the Evaporator/Dryer. The Evaporator/Dryer is an agitated thin film type that separates out the solids in the effluent. The Evaporator/Dryer is heated by steam (generated by an electric boiler in the room) in a jacket or from an electric coil. As the effluent enters the Evaporator/Dryer, the effluent is heated, and the water is vaporized. The Evaporator/Dryer discharges a "dry" concentrate into a container located at the bottom of the Evaporator/Dryer. Container contents are monitored for criticality, labeled, and stored in the radioactive waste storage area. When full, the container is sent for shipment off-site to a licensed radioactive waste disposal facility. Liquid vapor exits the

evaporator and is condensed in the Evaporator/Dryer Condenser, which is cooled with process chilled water.

The condensate from the condenser is collected in the Distillate Tank before being transferred to one of the Treated Effluent Monitor Tanks (see Figure 3.5-37, Process Flow Diagram, Treated Effluent Polishing). The effluent in these tanks is sampled and tested for pH and uranic content to validate compliance with regulatory and administrative guidelines prior to release to the TEEB. If the effluent test results are acceptable, then it is released to the TEEB. However, if the lab tests show the effluent does not meet regulatory and administrative guidelines, the effluent can be further treated. Depending on what conditions the lab testing show, the effluent is either directed back to the Evaporator/Dryer Feed Tank for another pass through the Evaporator/Dryer, or it can be directed through the Mixed Bed Demineralizers. After either option, the effluent is transferred back to a Treated Effluent Monitor Tank where it is again tested. When the lab tests are acceptable, the effluent is released to the TEEB.

D.1.1.2 Major Components

Handling and eventual disposition of the aqueous liquid effluents is accomplished in two stages, collection and treatment. All aqueous liquid effluents are collected in tanks that are located in the Liquid Effluent Collection and Treatment Room in the TSB.

Table 3.5-9, Liquid Effluent Collection and Treatment System, Collection Tanks, lists the collection tanks, their respective sizes, and the effluents deposited into them.

In addition to the listed tanks, which are used for effluent collection from the various areas throughout the plant, there are other tanks in the Liquid Effluent Collection and Treatment Room used for monitoring and treatment prior to release of the effluents to the TEEB.

These tanks, their size, and their purpose are listed in Table 3.5-10, Liquid Effluent Collection and Treatment System, Monitoring and Treatment Tanks.

D.1.1.3 Safety Considerations

Equipment for effluent collection and treatment in the Liquid Effluent Collection and Treatment Room in the TSB are separated into various radiological zones depending on contamination levels. The Laundry Effluent Tanks and the Wash/Shower Tanks are generally non-contaminated (or contain very low levels of uranium) and are located together in one corner of the room. The tanks with higher contamination are located in the opposite corner of the room. This separation helps keep exposures to ALARA (as low as reasonably achievable.) All tanks have overflow piping and atmospheric vents. The tanks also have inspection hatches to ensure that they are completely empty after a batch has been processed.

Tank contents are sampled and analyzed before being transferred to another tank or out of the system. Bookkeeping measures ensure that no tank holds more than a safe mass of uranium.

The Spent Citric Acid Collection Tank, Degreaser Water Collection Tank, Miscellaneous Effluent Collection Tank, and Precipitation Treatment Tank are all located in a contained area. The containment consists of a curb around all the above-mentioned tanks. The curbed area is capable of containing at least one catastrophic failure of one tank (1325 L (350 gal), minimum). In the event of a tank failure, the effluent in the confined area is pumped out with a portable pump set.

Due to the low probability of a uranic contamination in the Laundry Effluent Tanks or the Hand Wash/Shower Monitor Tanks, no curbed confinement of these tanks is provided in the event of a catastrophic failure. Any small amounts of these effluents that leak onto the floor drain to a floor sump. The effluents in this sump are pumped out with a portable pump set.

D.1.1.4 Operating Characteristics

The pH of the Dryer Feed Tank is important to minimize the corrosion in the equipment. The pH is always maintained within the manufacturer's recommended range.

Aqueous radiologically contaminated liquid effluents are processed on-site to remove the uranic content. After treatment these effluents and all non-contaminated aqueous effluents are discharged to the TEEB. Reduced volume, radiologically contaminated wastes that are produced as a by-product of the treatment system, as well as contaminated non-aqueous wastes, are packaged and shipped to a licensed radioactive waste disposal facility.

D.1.1.5 Design Considerations

The Liquid Effluent Collection and Treatment System and the system to collect non-aqueous wastes are sized to process effluents generated in an average year under normal conditions. The systems are designed with some extra capacity to handle upset or abnormal volumes. In the event of a catastrophic failure of the treatment system, provisions can be made to send all effluent off-site to a licensed processing and waste disposal facility.

All piping and equipment in the system that could contain potentially radioactive fluids are constructed of appropriate corrosion resistant metallic or plastic materials. None of the effluents are of such a chemical nature that special materials of construction is necessary. Industrial-grade piping and equipment is used.

All process piping is designed in accordance with American Society of Mechanical Engineers, ASME B31.3-2002, Process Piping (ASME, 2002). To provide system integrity and prevent leaks, welded construction is used everywhere practical. All collection tanks are designed in accordance with American Water Works Association (AWWA), American Petroleum Institute (API), or ASME Standards. The tanks are vertical cylindrical tanks with conical or dished-head bottoms to promote drainage. All outlets are at the low point of the tank – no space exists for solids to accumulate. All tank vents are open to atmosphere and directed away from personnel/equipment; all tank overflows are directed to sumps or do not pose a serious hazard. All tanks have inspection hatches to ensure the tanks are emptied. Mixers or recirculation loops are provided for each tank that requires mixing prior to sampling to ensure that each sample is representative of the tank contents.

D.1.2 Non-Aqueous Liquid Effluents

Various non-aqueous liquid effluents are generated throughout the plant. The majority of these are non-radiologically contaminated and are generated outside areas in which radioactive materials are handled. A small percentage may be radiologically contaminated. These wastes are ones that cannot be collected and treated in the Liquid Effluent Collection and Treatment System because of their chemical characteristics (i.e., they cannot be processed through the system because they might damage or decrease the performance of the equipment in the treatment system). These chemicals also might be EPA hazardous chemicals that cannot enter the aqueous waste stream that goes to the TEEB. Special treatment and/or disposal methods

are required for these wastes. They are not mixed with any of the effluent streams in the Liquid Effluent Collection and Treatment System.

Table 3.5-9 Liquid Effluent Collection and Treatment System, Collection Tanks

Page 1 of 1

TANK	QUANTITY	SIZE L (gal)	CONTENTS
Spent Citric Acid Collection	1	1,325 (350)	Spent citric acid
Degreaser Water Collection	1	1,325 (350)	Used degreaser water
Miscellaneous Effluent Collection	1	1,325 (350)	Lab wastes, condensate, floor washings
Hand Wash/Shower Monitor	3	15,142 (4,000)	Water from the active areas hand washes and showers
Laundry Effluent Monitor	3	3,785 (1,000)	Washing machine water

Table 3.5-10 Liquid Effluent Collection and Treatment System, Monitoring and Treatment Tanks

Page 1 of 1

TANK	QUANTITY	SIZE L (gal)	PURPOSE
Precipitation Treatment	1	1,325 (350)	Receives and treats effluents from the Citric Acid Collection Tank, the Degreaser Water Collection Tank, and, the Miscellaneous Effluent Hold Tank.
Contaminated Effluent Hold	1	1,325 (350)	Receives effluent from the Precipitation Treatment Tank. Provides capacity for the effluent batches processed in the Precipitation Treatment Tank.
Evaporator/Dryer Feed	1	1,325 (350)	Receives effluent from the Contaminated Effluent Hold Tank. Provides holding capacity for the effluent batches to be processed in the Evaporator/Dryer. pH is adjusted (lowered) in this tank prior to evaporation / drying.
Distillate	1	1,325 (350)	Receives effluent from the Evaporator/Dryer.
Treated Effluent Monitor	2	1,325 (350)	Receives effluent from Evaporator/Dryer Distillate Tank. Effluent is sampled and tested in these tanks prior to release to the TEEB or treatment in the polishing demineralizers.




FIGURE D-1



DESIGNED BY	REVIEWED BY	DATE	BY	DATE	BY
DESIGNED BY: R. CHAPPELL	REVIEWED BY: S. ROBERTS				
APPROVED BY: R. CHAPPELL					
CLIENT: N/A					
NO.	REV.	REASON			
A	05/22/04	ISSUED FOR PERMIT APPLICATION			

LOCKWOOD GREENE
ENGINEERING & CONSTRUCTION
Spartanburg, South Carolina

PROJECT NO. 01001.00
BLOCK FLOW DIAGRAM
LIQUID EFFLUENT COLLECTION
AND TREATMENT SYSTEM

LOUISIANA ENERGY SERVICES


PROJECT NO.	01001.00	REV. NO.	A
PLANT NO.	0000-R-1001	ISSUE DATE	
REV.	NONE	DATE	
			0000-R-1001



LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 REFERENCE NUMBER
 1500-R-2500



FIGURE 3.5-29
 LIQUID EFFLUENT COLLECTION AND
 TREATMENT ROOM
 EQUIPMENT ARRANGEMENT
 REVISION DATE: DECEMBER 2003



NOTES:

1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
2. HOSE CONNECTION CAN BE USED FOR DIKE PUMP-OUT OR DEIONIZED WATER WASHOUT.
3. PUMPED CONTENTS INCLUDE WASTE FROM SAMPLE BOTTLE AND FLEXIBLE HOSE DECONTAMINATION THAT WERE MANUALLY TRANSFERRED TO CITRIC ACID TANK IN DECONTAMINATION SYSTEM.


STREAM No.	◇
ANNUAL FLUID QUANTITY, l/yr	2720
gal/yr	720
ANNUAL URANIC QUANTITY, Kg/yr	22
lb/yr	48.5
BATCH FLUID QUANTITY, l	999
gal	261

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 Consulting, Inc. & Co.
 REFERENCE NUMBER
 1500-R-1101



FIGURE 3.5-30
 PROCESS FLOW DIAGRAM
 SPENT CITRIC ACID

REVISION DATE: DECEMBER 2003




- NOTES:**
1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
 2. HOSE CONNECTION CAN BE USED FOR DIKE PUMP-OUT OR DEIONIZED WATER WASHOUT.
 3. TOTAL ANNUAL SLUDGE DISCHARGES FROM THE DEGREASER WATER CENTRIFUGE, PRECIPITATION TREATMENT TANK FILTER PRESS, AND CONTAMINATED EFFLUENT EVAPORATOR/DRYER ARE ESTIMATED TO BE 400 KG (882 LB) OF SOLIDS, INCLUDING 57 KG (126 LB) OF URANIUM.
 4. URANIC CONTENT REMOVED BY THE CENTRIFUGE TO BE DETERMINED DURING FINAL DESIGN (SEE NOTE 3 ABOVE).

STREAM No.	3	4	16
ANNUAL FLUID QUANTITY, l/yr	3710	3710	
gal/yr	980	980	
ANNUAL URANIC QUANTITY, Kg/yr	18.5	NOTE 4	NOTE 3
lb/yr	40.8	NOTE 4	NOTE 3
BATCH FLUID QUANTITY, l	989	989	
gal	261	261	

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 REFERENCE NUMBER
 1500-R-1102

FIGURE 3.5-31
 PROCESS FLOW DIAGRAM
 DEGREASER WATER
 REVISION DATE: DECEMBER 2003



- NOTES:**
1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
 2. THIS STREAM MAY BE MANUALLY COLLECTED AND MANUALLY TRANSPORTED TO THE MISCELLANEOUS EFFLUENT COLLECTION TANK.
 3. HOSE CONNECTION CAN BE USED FOR DIKE PUMP-OUT OR DEIONIZED WATER WASHOUT.
 4. MISCELLANEOUS EFFLUENT IS SAMPLED AND ANALYZED PRIOR TO INPUT TO THIS TANK.


STREAM No.	5	6	8	10	13
ANNUAL FLUID QUANTITY, l/yr	20615	2400	40	80	23135
gal/yr	5446	634	10.6	21.1	6112
ANNUAL URANIC QUANTITY, Kg/yr	16	NONE	TRACE	TRACE	16
lb/yr	35.3	NONE	TRACE	TRACE	35.3
BATCH FLUID QUANTITY, l	56.5	6.6	20	40	
gal	14.9	1.74	5.28	10.6	

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 REFERENCE NUMBER
 1500-R-1103



FIGURE 3.5-32
 PROCESS FLOW DIAGRAM
 MISCELLANEOUS EFFLUENT

REVISION DATE: DECEMBER 2003



- NOTES:**
1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
 2. FINAL DESIGN WILL DETERMINE THE QUANTITY AND LOCATION OF THE SUMP(S) AND PUMP(S).
 3. HOSE CONNECTION IS PROVIDED TO ALLOW PUMP-OUT TO AN OUTSIDE CONTRACTOR FOR OFF-SITE DISPOSAL, IF REQUIRED.
 4. THIS STREAM IS NOT EXPECTED TO BE USED DURING NORMAL OPERATION OF THE PLANT.

STREAM No.	20	21
ANNUAL FLUID QUANTITY, l/yr	405,802	0
gal/yr	107,213	0
ANNUAL URANIC QUANTITY, Kg/yr	0.2	0
lb/yr	0.441	0
BATCH FLUID QUANTITY, l		0
gal		0
		NOTE 4


LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 REFERENCE NUMBER
 1500-R-1105



FIGURE 3.5-33
 PROCESS FLOW DIAGRAM
 LAUNDRY EFFLUENT

REVISION DATE: DECEMBER 2003

- NOTES:**
1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
 2. SUMP DESIGNED TO PREVENT ADDITION OF MISCELLANEOUS EFFLUENTS.




STREAM No.	◆
ANNUAL FLUID QUANTITY, l/yr	2,100,000
gal/yr	554,820
ANNUAL URANIC QUANTITY, Kg/yr	NONE
lb/yr	NONE
BATCH FLUID QUANTITY, l	5753
gal	1520

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 REFERENCE NUMBER
 1500-R-1104



FIGURE 3.5-34
 PROCESS FLOW DIAGRAM
 HAND WASH/SOWER EFFLUENT
 REVISION DATE: DECEMBER 2003



- NOTES:**
1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
 2. HOSE CONNECTION CAN BE USED FOR DIKE PUMP-OUT, DEIONIZED WATER WASHOUT, OR CHEMICAL ADDITION.
 3. TOTAL ANNUAL SLUDGE DISCHARGES FROM THE DEGREASER WATER CENTRIFUGE, PRECIPITATION TREATMENT TANK FILTER PRESS, AND CONTAMINATED EFFLUENT EVAPORATOR/DRYER ARE ESTIMATED TO BE 400 KG (882 LB) OF SOLIDS, INCLUDING 57 KG (126 LB) OF URANIUM.
 4. THIS STREAM IS NOT EXPECTED TO BE USED DURING NORMAL OPERATION OF THE PLANT.
 5. STREAM DATA DOES NOT INCLUDE FLOW FROM THE LAUNDRY SYSTEM.
 6. URANIC CONTENT REMOVED BY THE FILTER PRESS TO BE DETERMINED DURING FINAL DESIGN. (SEE NOTE 3 ABOVE).
 7. QUANTITY TO BE DETERMINED DURING FINAL DESIGN.
 8. URANIC CONTENT REMOVED BY THE CENTRIFUGE TO BE DETERMINED DURING FINAL DESIGN (SEE NOTE 3 ABOVE).

STREAM No.	1	4	13	18	21	23	24
ANNUAL FLUID QUANTITY, l/yr	2720	3710	23135		0	NOTE 7	29,565
gal/yr	719	980	6112		0		7811
ANNUAL URANIC QUANTITY, Kg/yr	22	NOTE 8	16	NOTE 3	0		NOTE 6
lb/yr	48.5	NOTE 8	35.3		0		NOTE 6
BATCH FLUID QUANTITY, l	989	989			0		
gal	261	261			0		
					NOTE 4		NOTE 5

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 CONSULTING, ARCHITECTS

REFERENCE NUMBER
 1500-R-1106




FIGURE 3.5-35
 PROCESS FLOW DIAGRAM
 PRECIPITATION/TREATMENT

REVISION DATE: DECEMBER 2003

NOTES:

1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
2. TOTAL ANNUAL SLUDGE DISCHARGES FROM THE DEGREASER WATER CENTRIFUGE, PRECIPITATION TREATMENT TANK FILTER PRESS, AND CONTAMINATED EFFLUENT EVAPORATOR/DRYER ARE ESTIMATED TO BE 400 KG (882 LB) OF SOLIDS, INCLUDING 57 KG (126 LB) OF URANIUM.
3. URANIC CONTENT REMOVED BY THE FILTER PRESS TO BE DETERMINED DURING FINAL DESIGN. (SEE NOTE 2 ABOVE).
4. STREAM DATA DOES NOT INCLUDE FLOW FROM THE LAUNDRY SYSTEM.
5. URANIC CONTENT REMOVED BY THE EVAPORATOR/DRYER TO BE DETERMINED DURING FINAL DESIGN. (SEE NOTE 2 ABOVE).
6. THIS STREAM IS NOT EXPECTED TO BE USED DURING NORMAL OPERATION OF THE PLANT.
7. QUANTITY TO BE DETERMINED DURING FINAL DESIGN.



STREAM No.	22	23	24	25	26	27
ANNUAL FLUID QUANTITY, l/yr	29,565	29,565	29,565		NOTE 7	0
gal/yr	7811	7811	7811		NOTE 7	0
ANNUAL URANIC QUANTITY, Kg/yr	NOTE 3		NOTE 5	NOTE 2		0
lb/yr	NOTE 3		NOTE 5	NOTE 2		0
BATCH FLUID QUANTITY, l						0
gal						0
		NOTE 4	NOTE 4			NOTE 6

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 REFERENCE NUMBER
 1500-R-1107




FIGURE 3.5-36
 PROCESS FLOW DIAGRAM
 EVAPORATOR/DRYER

REVISION DATE: DECEMBER 2003

NOTES:

1. THIS STREAM IS OPERATED IN A "BATCH" MODE.
2. URANIC CONTENT REMOVED BY THE EVAPORATOR/DRYER TO BE DETERMINED DURING FINAL DESIGN.
3. THIS STREAM IS NOT EXPECTED TO BE USED DURING NORMAL OPERATION OF THE PLANT.
4. THIS CONTAINS THE TOTAL ESTIMATED ANNUAL QUANTITY OF URANIC CONTENT TO BE DISCHARGED BY THE LIQUID EFFLUENT COLLECTION AND TREATMENT SYSTEM TO THE TREATED EFFLUENT EVAPORATIVE BASIN.
5. STREAM DATA DOES NOT INCLUDE FLOW FROM THE LAUNDRY SYSTEM.
6. FLUID QUANTITIES HAVE BEEN ROUNDED UP.



STREAM No.	12	20	26	30	31	32	33	34
ANNUAL FLUID QUANTITY, l/yr	2,100,000	405,802	29,565	0	0	0	435,400	2,535,400
gal/yr	554,820	107,213	7811	0	0	0	115,033	669,853
ANNUAL URANIC QUANTITY, Kg/yr	NONE	0.2	NOTE 2	0	0	0	0.57	0.57
lb/yr	NONE	0.441	NOTE 2	0	0	0	1.26	1.26
BATCH FLUID QUANTITY, l	5753			0	0	0		
gal	1520			0	0	0		
			NOTE 5	NOTE 3	NOTE 3	NOTE 3	NOTE 4	NOTE 4
							NOTE 6	NOTE 6

LOCKWOOD GREENE
INCORPORATED
 ENGINEERS & CONSTRUCTORS
 1500 R Street, N.W.
 Washington, D.C. 20004

REFERENCE NUMBER
 1500-R-1108



FIGURE 3.5-37
 PROCESS FLOW DIAGRAM
 TREATED EFFLUENT POLISHING

REVISION DATE: DECEMBER 2003

ATTACHMENT E

MONITORING PLAN

NOTE: THE DETAILED SITE MONITORING PLAN WILL BE DEVELOPED AT A FUTURE DATE PRIOR TO PLANT OPERATION. THE FEATURES OF THE MONITORING PLAN ARE PRESENTED IN THIS ATTACHMENT.

ATTACHMENT E

Ground Water Discharge Permit Application

NEF Monitoring Plan

The NEF Monitoring Plan developed for the Ground Water Discharge Plan will incorporate the applicable requirements outlined in 20.6.2.3107 NMAC, in addition to other monitoring requirements at the NEF. Features of the overall monitoring plan are described below.

The NEF Detailed Site Map (see Attachment A) indicates the location of onsite sampling locations. Media monitored includes soil, vegetation, basin water, basin sediment and ground water.

Each year, the NEF will submit a summary report of the environmental sampling program to the NMED, including all associated data as required by 20.6.2 NMAC. The report will include the types, numbers, and frequencies of environmental measurements and the identities and activity concentrations of facility-related nuclides found in environmental samples, in addition to the minimum detectable concentrations (MDC) for the analyses and the error associated with each data point. Significant positive trends in activities will also be noted in the report, along with any adjustment to the program, unavailable samples, and deviation to the sampling program.

Effluent Monitoring Plan

The New Mexico Environment Department requires, pursuant to 20.6.2.3106 and 20.6.2.3107 NMAC that facilities conduct surveys necessary to demonstrate compliance with these regulations and to demonstrate that the facility effluents are not potentially impacting ground water sources.

Compliance is demonstrated through effluent and environmental sampling data. If an accidental release of uranium should occur, then routine operational effluent data and environmental data will be used to estimate the extent of the release. Appropriate action levels and actions to be taken are specified for liquid effluents. Data analysis methods and criteria used in evaluating and reporting environmental sample results are appropriate and will indicate when an action level is being approached in time to take corrective actions.

The NEF effluent monitoring program is subject to periodic audits conducted by the facility QA personnel. Written procedures will be in place to ensure the collection of representative samples, use of appropriate sampling methods and equipment, proper locations for sampling points, and proper handling, storage, transport, and analyses of effluent samples. In addition, the plant's written procedures also ensure that sampling and measuring equipment, including ancillary equipment, are properly maintained and calibrated at regular intervals. Moreover, the effluent monitoring program procedures include functional testing and routine checks to demonstrate that monitoring and measuring instruments are in working condition. Employees involved in implementation of this program are trained in the program procedures.

Liquid Effluent Monitoring

Liquid effluents containing low concentrations of radioactive material, consisting mainly of spent decontamination solutions, floor washings, liquid from the laundry, and evaporator flushes, is expected to be generated by the NEF. Table E.1, Estimated Uranium in Pre-Treated Liquid Waste from Various Sources, provides estimates of the annual volume and radioactive material content in liquid effluent by source prior to processing through the Liquid Effluent Collection and Treatment System. Uranium is the only radioactive material expected in these wastes. Potentially contaminated liquid effluent is routed to the Liquid Effluent Collection and Treatment System for treatment. Most of the radioactive material is removed from liquid effluent in the Liquid Effluent Collection and Treatment System through a combination of clean-up processes that includes precipitation, evaporation, and ion exchange that has an aggregate uranic removal efficiency of greater than 99%. Post-treatment liquid effluent is sampled and undergoes isotopic analysis prior to discharge. Concentrated radioactive solids generated by the liquid treatment processes at the facility are handled and disposed of as low-level radioactive waste.

After treatment, the effluent is released to the double-lined Treated Effluent Evaporative Basin, which includes leak detection monitoring.

The design basis uranium source term for routine liquid effluent discharge to the Treated Effluent Evaporative Basin has been conservatively estimated to be 570 grams per year. There is no offsite release of liquid effluents.

Representative sampling is required for all batch liquid effluent releases. Liquid samples are collected from each liquid batch and analyzed prior to any transfer. Isotopic analysis is performed prior to discharge. The Minimum Detectable Concentration(s) for analysis of liquid effluent are presented in Table E.2, Required Lower Level of Detection for Effluent Sample Analyses. The liquid effluent sampling program supports the determination of quantities and concentrations of radionuclides discharged to the Treated Effluent Evaporative Basin.

Periodic sampling of liquid effluent is required since these effluents are treated in batches. Representative sampling is assured through the use of tank agitators and recirculation lines. All collection tanks are sampled before the contents are sent through any treatment process. Treated water is collected in Monitor Tanks, which are sampled before discharge to the Treated Effluent Evaporative Basin.

General site storm water runoff is routed to the Site Storm water Detention Basin. The UBC Storage Pad Storm water Retention Basin collects storm water runoff from the UBC Storage Pad as well as cooling tower and boiler blowdown water. Both of these basins, along with the Treated Effluent Evaporative Basin, will be included in the site Radiological Environmental Monitoring Program.

Radiological Environmental Monitoring Program

The Radiological Environmental Monitoring Program (REMP) at the NEF is a major part of the effluent compliance program. It provides a supplementary check of containment and effluent controls, establishes a process for collecting data for assessing radiological impacts on the environs and estimating the potential impacts on the public, and supports the demonstration of compliance with applicable ground water and radiation protection standards and guidelines.

The primary objective of the REMP is to provide verification that the operations at the facility do not result in detrimental radiological impacts on the environment. Through its implementation, the REMP provides data to confirm the effectiveness of effluent controls and the effluent monitoring program. In order to meet program objectives, representative samples from various environmental media are collected and analyzed for the presence of plant-related radioactivity. The types and frequency of sampling and analyses are summarized in Table E.3, Radiological Environmental Monitoring Program. Environmental media identified for sampling consist of ambient air, ground water, soil/sediment, and vegetation. All environmental samples will be analyzed onsite. However, samples may also be shipped to a qualified independent laboratory for analyses. The Minimum Detectable Concentrations (MDCs) for gross alpha (assumed to be uranium) in various environmental media are shown in Table E.2, Required MDC for Environmental Sample Analyses. Monitoring and sampling activities, laboratory analyses, and reporting of facility-related radioactivity in the environment will be conducted in accordance with industry-accepted and regulatory-approved methodologies.

The REMP includes the collection of data during pre-operational years in order to establish baseline radiological information that will be used in determining and evaluating impacts from operations at the plant on the local environment. The REMP will be initiated at least 2 years prior to plant operations in order to develop a sufficient database. The early initiation of the REMP provides assurance that a sufficient environmental baseline has been established for the plant before the arrival of the first uranium hexafluoride shipment. Radionuclides in environmental media will be identified using technically appropriate, accurate, and sensitive analytical instruments. Data collected during the operational years will be compared to the baseline generated by the pre-operational data. Such comparisons provide a means of assessing the magnitude of potential radiological impacts on members of the public and in demonstrating compliance with applicable ground water and radiation protection standards.

The REMP may be enhanced during the operation of the facility as necessary to maintain the collection and reliability of environmental data based on changes to regulatory requirements or facility operations. The REMP includes administrative action levels (requiring further analysis) and reporting levels for radioactivity in environmental samples.

Vegetation and soil samples, both from on and offsite locations will be collected on a quarterly basis in each sector during the pre-operational REMP. This is to assure the development of a sound baseline. During the operational years, vegetation and soil sampling will be performed semiannually in eight sectors, including three with the highest predicted atmospheric deposition. Vegetation samples may include vegetables and grass, depending on availability. Soil samples will be collected in the same vicinity as the vegetation samples. Ground water samples from onsite monitoring well(s) will be collected semiannually for radiological analysis. Sediment samples will be collected semiannually from both of the storm water runoff retention/detention basins onsite to look for any buildup of uranic material being deposited. With respect to the Treated Effluent Evaporative Basin, measurements of the expected accumulation of uranic material into the sediment layer will be evaluated along with nearby air monitoring data to assess any observed resuspension of particles into the air.

Physiochemical Monitoring

The primary objective of physiochemical monitoring is to provide verification that the operations at the NEF do not result in detrimental chemical impacts on the environment. Effluent controls are in place to assure that chemical concentrations in liquid effluents are maintained as low as reasonably achievable (ALARA). In addition, physiochemical monitoring provides data to

confirm the effectiveness of effluent controls. In conducting physiochemical monitoring, sampling protocols and emission/effluent monitoring will be performed for routine operations with provisions for additional evaluation in response to potential accidental release.

The NEF will have an Environmental Monitoring Laboratory, which will be equipped with analytical instruments needed to ensure that the operation of the plant activities complies with federal, state and local environmental regulations and requirements. Compliance will be demonstrated by monitoring/sampling at various plant and process locations, analyzing the samples and reporting the results of these analyses to the appropriate agencies. The sampling/monitoring locations will be selected by the Health, Safety and Environmental (HS&E) organization staff in accordance with facility permits and good sampling practices. The Environmental Monitoring Laboratory is located in the Technical Services Building (TSB) and is used to perform analyses that include the following:

- Hazardous material presence in waste samples
- pH, oil and other contaminants in liquid effluents

Chemical constituents that may be discharged to the environment in facility effluents will be below concentrations that have been established by state and federal regulatory agencies as protective of the public health and the natural environment (20.6.2.3103 NMAC). Under routine operating conditions, no significant quantities of contaminants will be released from the facility. This will be confirmed through monitoring and collection and analysis of environmental data. The facility will not directly discharge any industrial effluents to surface waters or grounds offsite, and there is no plant tie-in to a Publicly Owned Treatment Works (POTW). Except for discharges from the Septic System, all liquid effluents are contained on the NEF site via collection tanks and retention basins. Refer to NEF Detailed Site Map (see Attachment A) for the locations of the basins and septic tanks.

Parameters for continuing environmental performance will be developed from the baseline data and additional preoperational sampling. Operational monitoring surveys will also be conducted using sampling sites and at frequencies established from baseline sampling data and as determined based on requirements. Operational monitoring surveys are determined based on requirements contained in NMED Ground Water Discharge Permit/Plan.

The frequency of some types of samples may be modified depending on baseline data or the parameters of concern. As construction and operation of the enrichment plant proceeds, changing conditions (e.g., regulations, site characteristics, and technology) and new knowledge may require that the monitoring program be reviewed and updated. The monitoring program will be enhanced as appropriate to maintain the collection and reliability of environmental data. The specific location of monitoring points will be determined in detailed design.

Each year, NEF will submit a summary of the environmental sampling program and associated data to the New Mexico Environment Department, as required. This summary will include the types, numbers, samples collection frequency, analytical results and a data analyses that includes a trend analysis with previous years' and pre-operational data.

Physiochemical monitoring will be conducted via sampling of storm water, soil, sediment, vegetation, and ground water as defined in Table E.4, Physiochemical Sampling, to confirm that trace, incidental chemical discharges are below regulatory limits. There are no surface waters on the site, therefore no Surface Water Monitoring Program will be implemented; however soil sampling will include outfall areas such as the outfall at the Site Storm water Detention Basin. In

the event of any accidental release from the facility, these sampling protocols will be initiated immediately and on a continuing basis to document the extent/impact of the release until conditions have been abated and mitigated. The locations of these sampling points are shown on NEF Detailed Site Map (see Attachment A).

Storm Water Monitoring Program

A storm water monitoring program will be initiated during construction of the facility. Data collected from the program will be used to evaluate the effectiveness of measures taken to prevent the contamination of storm water and to retain sediments within property boundaries. A temporary detention basin will be used as a sediment control basin during construction as part of the overall sedimentation erosion control plan.

Storm water monitoring will continue upon initiation of facility operation. During plant operation, samples will be collected from the Uranium Byproduct Cylinders (UBC) Storage Pad Storm water Retention Basin and the Site Storm water Detention Basin in order to demonstrate that runoff does not contain any contaminants. A list of parameters to be monitored, testing analytes and monitoring frequencies is presented in Table E.5, Storm water Monitoring Program. This monitoring program will be refined, as necessary.

Table E.1
Estimated Uranium In Pre-Treated Liquid Waste From Various Sources

Source	Typical Annual Quantities, m³ (gals)	Typical Annual Uranic Content, kg (lbs)*
Laboratory/floor washings/miscellaneous condensates	23.14 (6112)	16 (35)
Degreaser water	3.71 (980)	18.5 (41)
Citric acid	2.72 (719)	22 (49)
Laundry effluent water	405.8 (107,213)	0.2 (0.44)
Hand wash & shower water	2100 (554,820)	None
TOTAL	2355 (669,844)	56 (125)

*Uranic quantity is before treatment. After treatment, approximately 1% of 0.57 kg (1.26 lb) of uranic material is expected to be discharged into the Treated Effluent Evaporative Basin.

Table E.2
Required Lower Level of Detection For Effluent Sample Analyses

Effluent Type	Nuclide	MDC^b In Bq/ml (μCi/ml)
Liquid	Isotopic U ^a	1.4x10 ⁻⁴ (3.0x10 ⁻⁶)
Vegetation	Isotopic U	3.7x10 ⁻⁶ (1.0x10 ⁻¹⁰)
Soil/Sediment	Isotopic U	1.1x10 ⁻² (3.0x10 ⁻⁷)
Ground Water ^c	Isotopic U	3.7x10 ⁻⁸ (1.0x10 ⁻¹²)

^a Isotopic analysis for ²³⁴U, ²³⁵U, ²³⁶U, and ²³⁸U.

^b. These MDCs are less than 2% of the limits in 10 CFR 20 Appendix B, Table 2 Effluent Concentrations

^c. For analyses of ground water samples, the MDC will be at least 3.7x10⁻⁸ Bq/ml (1.0x10⁻¹² μCi/ml), that represents <0.0004% of the concentration limits listed in Table 2 of Appendix B to 10 CFR 20.

**Table E.3
Radiological Environmental Monitoring Program**

Sample Type	Minimum Number of Sample Locations	Sampling and Collection Frequency	Type of Analysis
Liquid	Monitor Tank	Representative Grab Sample of (1 gallon)	Isotopic Analysis ^a Post-Treatment - Prior to Discharge.
Vegetation	8	1 to 2-kg (2.2 to 4.4-lb) samples collected semiannually	Isotopic analysis ^a
Ground Water	2	4-L (1.06-gal) samples collected semiannually	Isotopic analysis ^a
Basins	1 from each of 3 basins ^b	4-L (1.06-gal) water sample/1 to 2-kg (2.2 to 4.4-lb) sediment sample collected quarterly	Isotopic analysis ^a
Soil	8	1 to 2-kg (2.2 to 4.4-lb) samples collected semiannually	Isotopic analysis ^a

^a Isotopic analysis for ²³⁴U, ²³⁵U, ²³⁸U, and ²³⁸U.

^b Site Storm Water Detention Basin, UBC Storage Pad Storm Water Retention Basin and Treated Effluent Evaporative Basin.

Note: Physiochemical monitoring parameters are addressed separately

**Table E.4
Physiochemical Sampling**

Sample Type	Sample Location	Frequency	Sampling and Collections
Storm Water	Site Storm water Detention Basin and UBC Storage Pad Storm Water Retention Basin	Quarterly	Analytes as determined by baseline program
Vegetation	4 minimum ¹	Quarterly (growing seasons)	Fluoride uptake ²
Soil/Sediment	4 minimum ¹	Quarterly	Metals ³ , organics ⁴ , pesticides ⁶ , and herbicides
Ground Water	All selected ground water wells	Semiannually	Metals ³ , organics ⁴ , pesticides ⁶ and herbicides
Liquid Effluents	Treated Effluent Evaporative Basin		

¹ Location to be established by Health, Safety and Environmental (HS&E) organization staff

² Fluoride LLD: 0.5 mg/L

³ Metals LLD: Most are 5 ppm; Hg is 0.5 ppb

⁴ Organics LLD: 0.2-2.0 µg/L depending on analyte

⁶ Pesticides LLD: 0.01-0.5 µg/L depending on pesticide analyte

**Table E.5
Storm Water Monitoring Program for Detention and Retention Basins***

Monitored Parameter	Monitoring Frequency	Sample Type	LLD
Oil & Grease	Quarterly, if standing water exists	Grab	0.5 ppm
Total Suspended Solids	Quarterly, if standing water exists	Grab	0.5 ppm
5-Day Biological Oxygen Demand (BOD)	Quarterly, if standing water exists	Grab	2 ppm
Chemical Oxygen Demand (COD)	Quarterly, if standing water exists	Grab	1 ppm
Total Phosphorus	Quarterly, if standing water exists	Grab	0.1 ppm
Total Kjeldahl Nitrogen	Quarterly, if standing water exists	Grab	0.1 ppm
pH	Quarterly, if standing water exists	Grab	0.01 units
Nitrate plus Nitrite Nitrogen	Quarterly, if standing water exists	Grab	0.2 ppm
Metals	Quarterly, if standing water exists	Grab	Most are 5 ppm Hg is 0.5 ppb

* Site Storm Water Detention Basin, UBC Storage Pad Storm Water Detention Basin and any temporary basins used during construction.

ATTACHMENT F

SAMPLING PROTOCOL

ATTACHMENT F

Ground Water Discharge Permit Application

6.b.ii. Describe in detail the sampling protocols that will be used for sample collection at all monitoring locations. Attach additional pages as necessary.

Sampling Protocols

During implementation of the monitoring program, some samples may be collected in a different manner/method than specified herein. Examples of reasons for these deviations include severe weather events, changes in the length of the growing season, and changes in the number of plantings. Under these circumstances, documentation shall be prepared to describe how the samples were collected and the rationale for any deviations from normal monitoring program methods. If a sampling location has frequent unavailable samples or deviations from the schedule, then another location may be selected or other appropriate actions taken. In all examples presented below, the collector shall be required to don the appropriate personal protective equipment, safety equipment and have a companion collector in remote areas or when collecting at sites that may involve physical hazards (basins, culverts, septic tanks, etc.). In addition, all collection containers shall be labeled with the site identification information, GPS coordinates, date and time of the collection, the collectors name and phone number and the requested analyses. A laboratory sample submission form and a sample chain of custody form will be completed by the collector before transferring custody of the sample to someone else. Normal chain-of-custody procedures will be observed at all times and tamper-proof tape should be used on all container covers and lids.

Grab Water Samples

Depending upon the site, collect either one or two one-gallon samples from each sampling station (e.g., two one-quart samples are required for a gross beta AND gamma spectrometry/tritium analysis; one one-quart sample is required for a gross beta OR gamma spectrometry/tritium analysis).

In the field, fill a new properly labeled one (or two) one-gallon grab samples containing 80 mL of concentrated HCl and 100 mg of NaHSO₃ to each gallon of the representative water sample and mix thoroughly.

Within five days of collection, send the one or two one-gallon grab samples, along with the appropriate submission forms, to the laboratory service for analysis.

Bottom Sediment Samples

Bottom sediments and soil samples are usually collected at specified intervals from various locations by means of a two-inch ID coring device. Six core sections having a minimum core depth of six inches each shall be collected per sampling site. Ensure that recently collected samples are kept upright at all times. The core sections are grouped and labeled by sampling site and frozen in an upright position (surface layer at top) until

they are sent to the laboratory. The analyst subsequently sections the frozen core into increments (e.g., 0-5 cm, 5-10 cm, etc.).

If the sampling sludge from the bottom of one of the site's retention or detention basins, the collector will collect the sample when the basin is dry or near to being dry. Coring devices, trowels and other sharp-edged sample collection tools will not be used when sampling basins having liners. In these cases, sludge sample collections will be made using blunt-edged metal or plastic trowels, where the collector takes great care not to puncture or damage the liner. Approximately 1-2 kg mass of sludge should be collected and placed in a double thickness (double-bagged) plastic bag having a zip-lock or similar closing so that leakage does not occur. Screw-top plastic jars may also be used instead of plastic jars, and even may be preferred if the sludge or sediment has a high water content. The laboratory should be asked to analyze the dried sludge (solids) and liquid portions separately.

Vegetation Samples

Whenever possible, grab samples of vegetation (grasses) should be collected from 4 m² plots at various locations during the growing season. If the concentration of vegetation precludes collection of the specified biomass within the designated quadrant, additional vegetation may be collected from the immediate vicinity. The collector should stake off a 2 meter by 2 meter plot in an open area. Cut the grass approximately one inch above ground level. The collector then will package the grass in a labeled plastic bag and weigh the sample prior to shipping. Place two 125 g samples of the freshly picked grasses into two 32 oz. wide-mouth screw cap plastic bottles (which have been properly labeled). To each aliquot, add 400 mL of 0.5M NaOH before capping the container. Shake the capped container for a few seconds. Samples should be refrigerated if held prior to shipment to the laboratory. Specimens should be shipped in an insulated container, along with the appropriate sample submission form, within two days of collection.

Soil Sampling

Following the selection of an undisturbed site, lay out a straight line transect about 4.5 m long. If the site is to be resampled at a later time, record distances to fixed landmarks to identify the relative location of the transect or adopt a systematic scheme or grid. If the vegetation cover is not to be included with the soil sample, or is to be kept as a separate sample, the vegetation is removed to the surface level. Using the 5 cm depth top soil cutter, press it into the ground without twisting or disturbing the grass cover or surface soil. Place the core in a plastic sampling bag. Repeat the process until the desired number of cores have been sampled. It is recommended that 6-10 cores for providing a representative sample. Compositing the samples provides a larger sample volume and possibly a more representative sample of the area. Take 6-10 top soil cores in a straight line about 30 cm apart, placing the cores in a plastic bag. Sometimes it may not be possible to remove a 5 cm depth plug cleanly because of a thick root mat. If the top soil and bottom soil are to be combined, a 10 cm or 15 cm deep cutter may be used to remove the top soil by pounding it part way into the ground with the rubber mallet, until it is possible to remove the core intact. Next, take the subsoil samples down to the desired depth with the auger. Continue to use the auger until the desired depth has been

sampled. If rocks or roots impede the auger, it may be possible to carefully remove them. They should be included with the sample. If, however, this destroys the core, the sample should not be used. It is a useful practice to place the soil from the core as it is removed into a plastic pail until the entire depth is removed. Then, if the core is not suitable, it may be poured back into the hole. Only after the entire sample is successfully removed is the soil added to the sampling bag. Repeat the procedure for the remaining cores. After collection, label the plastic bag containing the sample, fold, and seal with a heavy duty stapler. If a portable scale is available, the wet weight can be taken in the field. Then place the sample in a double-thickness plastic bag and tie firmly. The label should include the date, location, and depth.

Ground Water Samples

Water samples should not be taken immediately following well development. Sufficient time should be allowed for the ground water flow regime in the vicinity of the monitoring well to stabilize and to let chemical equilibrium with the well construction materials be approached. This lag time will depend on site conditions and methods of installation but often exceeds one week

Well purging is nearly always necessary to obtain samples of water flowing through the geologic formations in the screened interval. Rather than using a general but arbitrary guideline of purging three casing volumes prior to sampling, it is recommended that an in-line water quality measurement device (e.g. flow-through cell) be used to establish the stabilization time for several parameters (e.g. pH, specific conductance, redox, dissolved oxygen, turbidity) on a well-specific basis. Data on pumping rate, drawdown, and volume required for parameter stabilization can be used as a guide for conducting subsequent sampling activities. As an alternative, the well could be purged using low flow pumping techniques as approved by NMED.

The following are recommendations to be considered before, during and after sampling:

- Use low-flow rates (<0.5 L/min) during both purging and sampling to maintain minimal draw down in the well. The amount of purging will be limited due to the slow recharge rate around the well casing and the low quantity of ground water at the site.
- Maximize tubing wall thickness and minimize tubing length.
- Place the sampling device intake at the desired sampling point
- Minimize disturbances of the stagnant water column above the screened interval during water level measurements and sampling device insertion
- Make proper adjustments to stabilize the flow rate as soon as possible
- Monitor water quality indicators during purging and do not purge any longer than is necessary to collect a representative sample.
- Collect unfiltered samples to estimate contaminant loading and transport potential in the subsurface system.

It is recommended that a device be used which will least disturb the water surface in the casing. Well depth should be obtained from the well logs. Measuring to the bottom of the well casing will only cause resuspension of settled solids from the formation and require longer purging times for turbidity equilibration. Measure well depth after sampling is completed. The water level measurement should be taken from a permanent reference point which is surveyed in relative to ground elevation.

Consideration should be given as to what the application of field-filtration is trying to accomplish. For assessment of truly dissolved (as opposed to operationally "dissolved" [ie. samples filtered with 0.45 µm filters]) concentrations of major ions and trace metals, 0.1 µm filters are recommended although 0.45 µm filters are normally used for most regulatory programs.

Upon parameter stabilization, sampling can be initiated. If an in-line device is used to monitor water quality parameters, it should be disconnected or bypassed during sample collection. Sampling flow rate may remain at established purge rate or may be adjusted slightly to minimize aeration, bubble formation, turbulent filling of sample bottles, or loss of volatiles due to extended residence time in tubing. Typically, flow rates less than 0.5 L/min are appropriate. The same device should be used for sampling as was used for purging. Sampling should occur in a progression from least to most contaminated well if this is known. Filtering should be done last and in-line filters should be used as discussed above. During both well purging and sampling, proper protective clothing and equipment must be used based upon the type and level of contaminants present.

The appropriate sample container will be prepared in advance of actual sample collection for the analytes of interest and include sample preservative where necessary. Water samples should be collected directly into this container from the pump tubing. Immediately after a sample bottle has been filled, it must be preserved as specified in the site Quality Assurance Project Plan (QAPP). It may be advisable to add preservatives to sample bottles in a controlled setting prior to entering the field in order to reduce the chances of improperly preserving sample bottles or introducing field contaminants into a sample bottle while adding the preservatives.



Sampling and Laboratory Quality Assurance

The NEF will ensure that the onsite laboratory and any contractor laboratory used to analyze NEF samples participates in third-party laboratory intercomparison programs appropriate to the media and analytes being measured. Examples of these third-party programs are the Mixed Analyte Performance Evaluation Program (MAPEP) and the DOE Quality Assurance Program (DOEQAP) that are administered by the Department of Energy. The NEF will require all radiological and non-radiological laboratory vendors to be certified by the National Environmental Laboratory Accreditation Conference (NELAC) or an equivalent state laboratory accreditation agency for the analytes being tested.

The Quality Control (QC) procedures used by the laboratories performing analyses for the plant's monitoring programs will be adequate to validate the analytical results and will conform with the guidance in NRC Regulatory Guide 4.15. These QC procedures include the use of established standards such as those provided by the National Institute of Standards and Technology (NIST), as well as standard analytical procedures such as those established by the National Environmental Laboratory Accreditation Conference (NELAC). Monitoring procedures will employ well-known acceptable analytical methods and instrumentation. The instrument maintenance and calibration program will be appropriate to the given instrumentation, in accordance with manufacturers' recommendations.

ATTACHMENT G

NEF AREA MAP



MAP SOURCE:
 USGS 7.5 MINUTE
 EUNICE NE QUADRANGLE
 TEX.-N. MEX. 1:24000
 CONTOUR INTERVAL:
 5 FEET





REFERENCE NUMBER
 Figure 3.4-1.dwg



NEF AREA MAP
 GROUNDWATER DISCHARGE PERMIT

ATTACHMENT H

NEF ROAD MAP



REFERENCE NUMBER
 New Mexico Figures.dwg



MAP SOURCE:
 U.S.CENSUS BUREAU
 2000 INCORPORATED PLACES


NEF ROAD MAP
 NM GROUNDWATER DISCHARGE PERMIT


ATTACHMENT I

FEMA FLOOD INFORMATION

FEMA Map Service Center (MSC) Product Map Search
 (<http://www.msc.fema.gov/index.shtml>)


- Legend**
- Major Cities**
- ⊙ Major Cities > 1,000,000
 - ⊙ Big Cities, 300,000-1,000,000
 - ⊙ State Largest Cities, 100,000-300,000
 - Cities, 100,000-300,000
- Highways**
- Major Highways
 - Highways
- State Borders**
- Lakes, Major Rivers**
- Big Rivers or Streams
 - Big Lakes or Ponds
- Parks**
- National Parks and Forests
- US Territories**
- States**
- Counties**
- Other Countries**






10-1281

DEPARTMENT OF HOUSING AND URBAN DEVELOPMENT
 Federal Insurance Administration
CITY OF EUNICE, NM
 (LEA CO.)




FLOOD HAZARD BOUNDARY MAP H - 01
 FLOOD INSURANCE RATE MAP I - 01

EFFECTIVE DATE
 8/22/78



01

KEY TO SYMBOLS



SPECIAL FLOOD HAZARD AREA

Sea Flood Elevation Line 813
 Sea Flood Elevation (513' MSL)
 Elevation Reference Mark RM7, X
 Near Mls - N 1.8

EXPLANATION OF ZONE DESIGNATIONS

A flood insurance map displays the zone designations for a community according to areas of designated flood hazards. The zone designations used by FIA are:

Zone Symbol	Category
A	Area of special flood hazards (SFH) and without base flood elevations determined.
A1 through A30	Area of special flood hazards (SFH) with base flood elevations. Zones are assigned according to flood hazard factors, and date of SFH identification.
A0	Area of special flood hazards that have shallow flood depths (less than two feet) and/or unpredictable flow paths. Base flood elevations are not determined.
V	Area of special flood hazards, with velocity, that are inundated by tidal flows. Zones are assigned according to flood hazard factors and date of SFH identification.
B	Area of moderate flood hazards.
C	Area of minimal flood hazards.
D	Area of unshaded, but graphic, flood hazards.

TO DETERMINE IF FLOOD INSURANCE IS AVAILABLE IN THIS COMMUNITY, CONTACT YOUR INSURANCE AGENT, OR CALL THE NATIONAL FLOOD INSURANCE PROGRAM, AT (800) 638-6820, OR (800) 424-8872.

INITIAL IDENTIFICATION DATE:
AUGUST 30, 1974

MAP REVISED: DECEMBER 12, 1976
CURVILINEAR FLOOD BOUNDARY
& ADD S.F.H.A. & REMOVE S.F.H.A.

MAP REVISED: AUGUST 22, 1978
CONVERSION FROM F.I.S.M. TO F.L.S.M.

DEPARTMENT OF HOUSING AND URBAN DEVELOPMENT
Federal Insurance Administration

FLOOD HAZARD BOUNDARY MAP H - 01
FLOOD INSURANCE RATE MAP I - 01


MAP INDEX

CITY OF EUNICE, NM
(LEA CO.)

COMMUNITY NO. 3500288

ATTACHMENT J

NEF SITE SOILS MAP



USDA SOIL DESIGNATION	SOIL NAME/DESCRIPTION	UNIFIED SOIL CLASSIFICATION DESIGNATIONS)
A1	ACTIVE (SAND) DUNE LAND.	SP
B0	BROWNFIELD-SPRINGER ASSOCIATION; MOSTLY FINE SAND WITH LOAM FINE SAND; LEVEL TO UNDLATING TOPOGRAPHY; MODERATELY RAPID PERMEABILITY AND SLOW RUNOFF.	SM
B3	BROWNFIELD-SPRINGER ASSOCIATION; MOSTLY FINE SAND WITH LOAM FINE SAND; DUNES AND HUMMOCKS FOR CONCAVE AND CONVEX ROLLING TERRAIN; DRAINAGE SIMLAR TO B0.	SM
KM	KERMIT SOILS AND DUNE LAND; EXCESSIVELY-DRAINED NON-CALCAREOUS SOILS; HUMMOCKY AND UNDLATING TOPOGRAPHY DUE TO EOLIAN PROCESSES.	SP-SM OR SM
MU	MIXED ALLUVIAL LANDS; UNCONSOLIDATED, STRATIFIED ALLUVIUM WITH VARIED TEXTURES OCCURRING INTERMITTENTLY IN DRAINAGE-WAYS A FEW FEET IN THICKNESS; MODERATE TO RAPID PERMEABILITY WITH SLOW RUNOFF.	VARIABLE
FG	PORTALES AND GOMEZ FINE SANDY LOAMS; LIGHT CLAY LOAM, WELL-DRAINED.	VARIABLE

SOURCE: (USDA, 1974)



REFERENCE NUMBER
MSWord Figures.dwg



NEF SITE SOIL MAP
NM GROUNDWATER DISCHARGE PERMIT

ATTACHMENT K

NEI LAND EASEMENT AND LAND USE RESTRICTION

ATTACHMENT K
NEI Land Easement and Land Use Restriction

The following two documents contain the Land Easement and the Land Use Restriction.

- 1) The Grant of Easement and Right of Way from the State of New Mexico to LES. This is the main document that gives LES the right to use the land for the NEF in accordance with the operating license from NRC. Under the Easement, the state still retains the mineral rights to the property.
- 2) The Agreement Regarding Land Use Restriction or Conditions from the State of New Mexico. This companion document prohibits the state from exercising its right to explore for, mine, develop, and produce minerals without LES consent.

**STATE OF NEW MEXICO
COMMISSIONER OF PUBLIC LANDS
GRANT OF EASEMENT AND RIGHT OF WAY**

Subject to the terms, conditions and limitations set out herein below, the New Mexico Commissioner of Public Lands (together with successors and assigns, "Grantor"), in his capacity as trustee of the land trust established by the Enabling Act (Act of June 20, 1910, 36 Statutes at Large 557, Chapter 310) and that trust's assets (the land trust and its assets, collectively, the "Trust"), hereby Grants to Louisiana Energy Services, L.P., a Delaware limited partnership (together with its successors and assigns, "Grantee"), whose address is 1133 Connecticut Ave, NW, Suite 200, Washington, DC 20036, an easement and right of way ("Easement"), in and to the Land (defined below).

1. **Land:** This Easement covers the State of New Mexico ("State") trust land ("Land") depicted in the attached Exhibit A.

2. **Term:** This Easement is for a term ("Term") of thirty-five (35) years, commencing on the day on which the Grantor executes this Easement ("Effective Date") and ending at 11:59 p.m. on the thirty-fifth (35th) annual anniversary of the Effective Date, or upon earlier termination or relinquishment of this Easement.

3. **Consideration:** As consideration ("Consideration") for this Easement, Grantee shall pay to Grantor:

(1) One hundred twenty thousand and no/100 Dollars (\$120,000) ("Initial Payment"), payable on the Effective Date. The Initial Payment is nonrefundable.

(2) Thirty thousand and no/100 Dollars (\$30,000) on the fifth (5th) anniversary of the Effective Date, and on each anniversary of the Effective Date thereafter up to and including the thirty-fourth (34th) anniversary of the Effective Date unless this Easement is earlier terminated or relinquished.

Grantor and Grantee acknowledge and agree that the Consideration is good and sufficient consideration for the grant of this Easement and for the other agreements contained in this instrument.

RECEIVED
STATE OF NEW MEXICO
COMMISSIONER OF PUBLIC LANDS
JUN 27 3 48

4. Uses of the Land; Improvements and Equipment:

A. This Easement authorizes Grantee to use and improve the Land in any manner that may be necessary or convenient to support and facilitate a gas centrifuge uranium enrichment facility ("Facility") in accordance with an operating license from the United States Nuclear Regulatory Commission ("NRC") or any other successor agency with jurisdiction, as the same may be renewed, revised, amended, supplemented, assigned, modified and/or renumbered from time to time in accordance with law and applicable regulations ("NRC License") and all applicable federal licensing or regulatory requirements ("Federal Requirements") and, subject to Paragraph 26 of this Easement, applicable state licensing or regulatory requirements ("State Requirements").

B. This Easement shall be liberally construed to assure that Grantee and its agents have sufficient legal rights to use and improve the Land as necessary to (i) support and facilitate the Facility; (ii) decommission the Facility in accordance with Federal Requirements and, subject to Paragraph 26 of this Easement, State Requirements, including but not limited to NRC requirements as specified in Title 10 of the Code of Federal Regulations (i.e., 10 CFR), Parts 70, "Special nuclear material," and 40, "Source material," sections 70.38 and 40.42, "Expiration and termination of licenses and decommissioning of sites and separate buildings or outdoor areas" (i.e., 10 CFR 70.38 and 10 CFR 40.42); and (iii) fully reclaim the Land in accordance with Federal Requirements, State Requirements and this Easement, subject to Paragraph 26 of this Easement. Subject to Paragraph 4.C below, Grantee's rights under this Easement shall include, *but are not limited to*, the right to use and improve the Land for the following purposes: (a) constructing and operating the Facility; (b) providing power, water, waste disposal and other utility services to the Facility; (c) providing access to the Facility; (d) limiting access to the Facility and the Land in proximity thereto as required by the NRC License or other Federal Requirements; (e) constructing, operating and maintaining primary and support buildings and facilities; (f) constructing facilities for uranium byproduct storage in accordance with Federal Requirements, including but not limited to the regulatory standards of NRC and, subject to Paragraph 26 of this Easement, State Requirements; (g) storing uranium byproduct in accordance with Federal Requirements, including but not limited to the regulatory standards of NRC and, subject to Paragraph 26 of this Easement, State Requirements; (h) constructing and

RECEIVED
MAY 3 11 18
OFFICE

maintaining access and maintenance roads; (i) decommissioning the Facility as required by Federal Requirements, including but not limited to the regulatory standards of NRC and, subject to Paragraph 26 of this Easement, State Requirements; (j) reclaiming the Land and removing improvements and equipment as provided in Paragraph 5.B-E of this Easement; and (k) housing furnishings, fixtures, equipment and vehicles related to the operations at the Facility; provided, however, that all uses and improvements under this Easement shall be in accordance with all Federal Requirements, including but not limited to the regulatory standards of NRC and, subject to Paragraph 26 of this Easement, State Requirements, and only as necessary or convenient to support and facilitate the Facility.

C. Grantee may use and operate such equipment on the Land, and may construct, operate, maintain and replace improvements on the Land, as may be reasonably necessary to carry out the purposes of this Easement, as set forth in Paragraph 4.A above. As of the Effective Date, Grantee anticipates that it will construct, operate, maintain and replace, as necessary, the following improvements and equipment on the Land:

(1) The buildings, administrative facilities, access roads, storage facilities, electrical lines and poles, pipelines, fencing, security apparatus, ponding areas and other improvements depicted on Exhibit B to this Easement;

(2) A septic tank and leaching field; and

(3) Such other improvements, personal property and fixtures as may be necessary or desirable to carry out the purpose of this Easement, as set forth in Paragraph 4.A above.

The foregoing description of improvements and equipment is not intended to be an exhaustive list.

D. Grantor understands and agrees that access to the Facility and to the Land in proximity thereto will be limited in accordance with Federal Requirements, including but not limited to NRC requirements specified in 10 CFR 73, "Physical protection of plants and materials," as directed by 10 CFR 70.22, "Contents of licenses," paragraph (h)(1), and, subject to Paragraph 26 of this Easement, State Requirements.

E. Except as limited by Paragraph 17, (i) documents related to substantial improvements on the Land shall be kept at the operations office for the Facility; (ii) Grantor shall have the right to inspect such records and improvements provided that Grantor shall request

such inspection by giving Grantee reasonable notice thereof and provided that Grantee is able to permit access to the Facility at the time requested by Grantor; and (iii) Grantee shall provide Grantor with copies of documents that it provides to NRC, the New Mexico Environmental Department and any other federal or state agency with jurisdiction, showing the location and/or type of the improvements and equipment located on the Land. If Grantee is unable to provide access to the Facility at the specific time requested by Grantor, such access will be available to Grantor at such other time as is mutually agreeable to Grantor and Grantee.

5. Reclamation and Removal of Improvement and Equipment.

A. Prior to termination of this Easement, Grantee shall decommission the Facility as required by, and in accordance with, Federal Requirements, including but not limited to NRC regulatory requirements in 10 CFR 70.38 and 10 CFR 40.42, and subject to Paragraph 26 of this Easement, State Requirements. Grantee also shall provide assurances that adequate funding will be available to decommission the Facility in accordance with Federal Requirements, including but not limited to NRC requirements in 10 CFR 70.25 and 10 CFR 40.36, "Financial assurance and recordkeeping for decommissioning" and, subject to Paragraph 26 of this Easement, State Requirements. Documentation thereof shall be delivered to Grantor as and when it is delivered to NRC.

B. Grantee shall reclaim the land in accordance with Federal Requirements and State Requirements. Grantee shall submit a proposed reclamation plan ("Reclamation Plan") to Grantor for Grantor's approval, which approval Grantor shall not unreasonably withhold. The Reclamation Plan shall be submitted to Grantor concurrently with Grantee's submission to NRC of its plan for decommissioning the Facility ("Decommissioning Plan") as required by Federal Requirements, including but not limited to 10 CFR 70.38 and 10 CFR 40.42, and, subject to Paragraph 26 of this Easement, State Requirements. Grantor agrees that the Reclamation Plan may provide that reclamation required by Section 19.2.10.27, N.M.A.C. and removal of improvements and equipment shall commence after completion of the activities required by the Decommissioning Plan. Grantee shall reclaim the Land in accordance with the Reclamation Plan approved by Grantor.

C. Prior to relinquishment or termination of this Easement, Grantee shall remove all improvements and equipment on the Land except as otherwise provided herein, or

RECEIVED
2011 JUN 29 11:11 AM

except as required by the Reclamation Plan approved by Grantor, or in a written agreement between Grantor and Grantee.

D. If Grantee fails to remove improvements and equipment on Land as required in Paragraph 5.C, Grantor may, at Grantor's discretion, declare that all or any such remaining improvements and equipment are forfeited to Grantor. Any such declaration shall be in writing and shall be sent to Grantee in the manner contemplated for giving notice under this Easement. In the event of forfeiture, Grantee shall execute such bills of sale, assignments, or such other instruments as Grantor may request to acknowledge the transfer of title to Grantor.

E. If Grantee fails to remove any non-forfeited improvements and equipment as required herein, Grantee shall be deemed a holdover tenant and shall pay Grantor monthly rent, in advance, equal to three (3) times the then current rental value of the Land on which the improvements and/or equipment is located. Such rental value shall be calculated assuming the Land's highest and best use, as determined solely by the Grantor, and shall be based on no fewer than 10 acres. This provision shall not be deemed liquidated damages, shall not constitute a penalty and shall not entitle Grantee to continued use or possession of the Land.

F. Paragraphs 5.A through 5.E shall survive termination of this Easement.

6. Rights Reserved to Grantor:

A. This Easement conveys only the rights and interest in the Land expressly described. This Easement conveys no right, title or interest in the Land by implication.

B. Subject to the limitations set forth in Paragraph 6.C, Grantor hereby expressly reserves from this Easement:

(1) all subsurface and mineral rights, including the right to explore for, mine, develop and produce minerals such as sand and gravel, coal, caliche and humate and to issue oil; gas; geothermal resources and any other minerals related to the Land, provided that such rights, issues and leases shall be subject to this Easement;

(2) the right to sell or exchange the Land, provided that (i) Grantor shall give Grantee such notice as required by law, rules and regulations of its intent to sell or exchange and (ii) such sale or exchange (if not to Grantee) shall be subject to this Easement; and

(3) the right to use and possession of the Land free of this Easement after relinquishment or termination of this Easement, subject only to Grantee's right and duty to remove improvements and equipment and reclaim the Land.

C. Grantor shall execute and record in the records of the State Land Office a Land Use Restriction or Condition ("LURC") that provides that, absent Grantee's prior written consent, (i) Grantor shall neither exercise Grantor's rights under Paragraph 6.B(1) nor exercise Grantor's right to lease or otherwise dispose of or encumber the Land or any interest incident thereto, for any purpose, or grant additional easements, rights-of-way and grants across, under or over the Land, including the development of any sand and gravel, coal, caliche, humate, oil and gas or other minerals and (ii) there shall be no surface disturbance of the Land and no right to explore for, mine, develop and/or produce oil, geothermal resources, gas and/or minerals during the Term of this Easement. As good and adequate consideration for the LURC, Grantee shall pay to Grantor Five Thousand and no/100 Dollars (\$5,000.00) per year, beginning on the fifth (5th) anniversary of the Effective Date and on each anniversary of the Effective Date thereafter up to and including the thirty-fourth (34th) anniversary of the Effective Date, or so long thereafter as Grantee occupies and uses the Land, unless this Easement is earlier terminated or relinquished; provided that if the Easement is terminated by a sale or exchange of the Land to Grantee or to Lea County, New Mexico, (a) both the restrictions and conditions in the LURC and Grantee's obligation to pay the consideration therefor in the amount, and for the time, set forth in this Paragraph shall survive and (b) the instrument conveying the Land shall expressly recite the restrictions set forth in the LURC. Grantee may record the LURC in the real property records of Lea County, New Mexico.

D. If Grantor offers the land for sale or exchange, Grantee agrees to participate in the sale or exchange process and submit and offer to purchase or exchange the land directly or through an intermediary with a bid of at least the fair market value of the unimproved land and the fair market value of third party improvements and comply with Grantor's rules and regulations on land sales or exchanges.

7. Compliance with Law: Grantee shall comply with all laws, whether statutory or court-made, regulations, rules, ordinances, and requirements, including, but not limited to, those addressed to environmental protection and all State Land Office Rules applicable to the Land or

to Grantee's use of the Land and improvements thereon. Grantee's compliance obligations include, but are not limited to:

A. Grantee agrees not to discriminate against any person on the basis of race, color, religion, national origin, sex, sexual preference, age or handicap.

B. Grantee shall not permit any nuisance to be maintained on the Land, provided that no use of the Land permitted by this Easement shall be deemed to constitute, or cause, a nuisance.

C. Grantee shall comply with applicable environmental laws in Chapter 74, NMSA 1978, and regulations promulgated pursuant thereto.

D. Grantee shall diligently maintain and protect the Land and improvements thereon from waste and trespass, provided that no use of the Land permitted by this Easement shall be deemed to constitute, or cause, waste of the Land.

8. **No Warranty.** Grantor makes no warranties as to Grantor's title, fitness of the Land for a particular purpose or as to any other matter. Grantee shall use, improve and accept the Land "as is." The rights granted hereby are subject to existing rights. Grantee agrees that it is solely responsible for determining whether any third party has or claims any prior and superior right, title or interest in or to the Land that may conflict with this Easement. Grantee shall at Grantee's sole expense resolve any such conflicting claims and, in the event of litigation, Grantor shall not be an indispensable or necessary party.

9. **Existing Rights.** Except as may be required by the NRC License or with applicable NRC requirements, Grantee shall not interfere with any leases, rights-of-way, Grants or other rights or interests in or to the Land that were granted by the State of New Mexico in existence on the Effective Date ("Existing Rights"). Grantee specifically agrees to use its best efforts to (i) avoid destruction or injury to any improvements or livestock on the Land pursuant to Existing Rights; (ii) close all gates immediately upon passing through same; and (iii) pay promptly the reasonable and just damages for injury or destruction arising from Grantee's use of the Land. Notwithstanding the foregoing, Grantee shall have the right to negotiate with the Grantor and the grantee of that certain Grant of Right of Way No. RW-22760 to relocate the carbon dioxide pipeline permitted thereby.

10. **Pipelines.** Unless otherwise expressly agreed by Grantor in writing, Grantee shall bury at least twenty inches (20") below the surface all pipelines that are installed by

Grantee on the Land except temporary pipelines, or pipelines whose sole purpose is to support a construction project.

11. **Assignment.** Except as otherwise provided in this Paragraph, Grantee shall not assign this Easement, either in whole or in part, without the prior written consent of Grantor. Grantor's consent may be conditioned upon the agreement by Grantee's assignee to additional conditions and covenants and may require payment of additional consideration to Grantor; provided that, for any authorized assignment occurring on or before January 1, 2009, no additional covenants and conditions and no additional payment shall be required. Grantor hereby consents to (i) Grantee's assignment of this Easement, or a leasehold or other interest in this easement, to Lea County, New Mexico ("County") and to the County's grant to Grantee, or its designee, of a lease, license, permit or other authorization to use the Easement, or such interest in the Easement, for the purposes authorized in this Easement and pursuant to both the County Industrial Bond Revenue Act, Chapter 4, Article 59 N.M.S.A 1978, as amended, and other applicable law, if any; provided, that such assignment shall not diminish, alter or affect Grantee's duties, liability or responsibilities under this Easement; and (ii) the grant of mortgage or other encumbrance on or against this Easement to secure obligations incurred in financing for the Facility. Additionally, notwithstanding any other provision in this Easement, Grantee may, without Grantor's consent, grant licenses, permits or other authorizations to third parties to carry out the purposes of this Easement; provided, however, that such licenses, permits or other authorizations by Grantee shall not constitute an assignment of this Easement and shall not diminish, alter or affect Grantee's duties, liability or responsibilities under this Easement.

12. **Abandonment.** Grantor may deem that Grantee has abandoned its rights and interest under this Easement if after January 1, 2009, Grantee fails for a continuous period in excess of twelve (12) consecutive months to use the Land, or some portion thereof, for at least one of the purposes authorized by this Easement. In such event, at Grantor's discretion, this Easement shall be subject to termination pursuant to Paragraph 15 below *unless* Grantee's non-use is the result of a court or administrative order or is otherwise involuntary, as set forth in an affidavit provided to Grantor by Grantee. Furthermore, no abandonment shall be deemed to have occurred as to any disturbed portion of Land that has not been fully reclaimed in accordance with this Easement.

13. **Relinquishment.**

A. Grantee may request relinquishment of this Easement, in whole or in part, by requesting such relinquishment in writing. Grantee shall not, by relinquishment, avoid or be released from any liability arising from or related to Grantee's use of the Land, including the duty to remove improvements and equipment and reclaim the Land. Upon relinquishment, Grantee shall not be entitled to any refund of money previously paid as Consideration under this Easement.

B. Notwithstanding the foregoing Paragraph 13.A, a relinquishment by Grantee of the Easement shall not be effective, and Grantor shall not have a right to possession or control of the Land and the improvements and equipment thereon, until the Facility has been decommissioned and all applicable federal and state licenses, including but not limited to the NRC License, have been terminated.

14. Indemnity. Grantee shall save and hold harmless, defend and indemnify the State of New Mexico, the Commissioner of Public Lands, and his agents or employees (collectively, "indemnitees"), in their official and individual capacities, from and against any and all liability, claims, losses, or damages arising out of or alleged to arise out of this Easement or the use and occupation of the Land by Grantee or Grantee's agents, licensees, permittees, employees, contractors (including subcontractors), and invitees; provided, however, that Grantee shall be under no obligation to indemnify or hold indemnitees harmless from: (i) liability, claims, losses or damages based on a third party claim that this Easement is invalid or void; and Grantee specifically waives any claims or damages against the Grantor arising out of or directly or indirectly related to third party claims that the Easement is invalid or void; or (ii) liability, claims, losses, or damages caused by the sole negligence or willful or intentional act(s) of indemnitees, or any of them. This Paragraph shall survive termination of this Easement.

15. Termination.

A. Grantor may terminate this Easement for material violation of any of the terms and conditions of this Easement ("default"); provided, however, that before any such termination shall become effective, Grantor shall mail to Grantee (or any approved assignee), by certified or registered mail addressed to the post office address of Grantee or such assignee shown by Land Office records, a sixty (60) day notice of default, specifying the default for which the Easement is subject to termination. No proof of receipt or further notice shall be necessary, and sixty (60) days after such mailing, this Easement shall terminate unless Grantee cures the

default within the sixty-day period; or, if the default cannot reasonably be remedied within sixty (60) days, Grantee submits for Grantor's approval within thirty (30) days of the default notice a plan for cure, including a schedule for expeditiously implementing such plan in order to cure the default as soon as reasonably possible. Grantor shall not unreasonably withhold approval of such plan. In the event of early termination of this Easement for any reason, Grantee shall not be entitled to any refund of money previously paid as consideration under this Easement, nor shall Grantee be relieved of its duty hereunder to remove its improvements and equipment and reclaim the Land in accordance with Paragraph 5 of this Easement.

B. Notwithstanding the foregoing Paragraph 15.A, a termination of this Easement shall not be effective, and Grantor shall not have a right to possession or control of the Land and the improvements and equipment thereon, until the Facility has been decommissioned and all applicable federal and state licenses, including but not limited to the NRC License, have been terminated.

16. **Amendment.** Any amendment of this Easement shall be in writing and shall be executed by each of Grantor and Grantee.

17. **Limitation on Disclosure.** Notwithstanding any other provision in this Easement, to the extent any obligation of Grantee under this Easement to disclose or otherwise tender to Grantor information or documents of any kind or to any other person ("Disclosure Obligation"), in Grantee's good faith judgment, based on written opinion of counsel, conflicts with, or is contrary to, Grantee's obligation under any Federal or state statute, regulation, policy, directive or order regarding safety, safeguards, security, national security or secrecy related to the Facility or otherwise to Grantee's activities on the Land ("Security Obligation"), the Security Obligation shall control; and Grantee shall not be required to comply with the Disclosure Obligation.

18. **Existing Leases and Rights of Way Not Affected.** This Easement does not modify or amend or change in any way those rights and obligations now or hereafter obtained by Grantee under separate instruments, including but not limited to (i) that certain Oil and Gas Lease No. B-4467 from Grantor to Gypsy Oil Company, to be assigned in part from Chevron U.S.A. Inc., successor in interest to Gypsy Oil Company, to Grantee; (ii) that certain Agricultural Lease No. GR-1855 from Grantor to Wallach Ranch, LLC, to be assigned in part to Grantee; and (iii) any other existing grants from Grantor or Grantee in the Land.

19. **Reporting.** Subject to the provisions in Paragraph 17 of this Easement, Grantee shall provide to Grantor copies of periodic reports made to NRC.

20. **Enforcement.** Venue for any court action brought by either party relating to this Easement shall be exclusively in New Mexico State Court, First Judicial District, Santa Fe County, New Mexico, after all administrative remedies are exhausted.

21. **Governing Law.** The provisions of this Easement shall be construed and enforced in accordance with New Mexico law.

22. **No Third Party Beneficiaries.** There are no third-party beneficiaries of any provision of this Easement.

23. **Exhibits.** All Exhibits attached to this Easement are incorporated herein by reference.

24. **Costs.** Grantee's performance of its obligations under this Easement shall be at Grantee's sole cost and expense.

25. **Severability.** If a court of competent jurisdiction determines that a provision or provisions of this Easement is or are invalid or illegal, such determination shall not invalidate or render unenforceable any other provision hereof; provided, however, that if enforcement of this Easement absent such invalid or unenforceable provision(s) would destroy an essential purpose of this Easement, then this Easement shall be deemed modified to the extent necessary to make this Easement valid or enforceable consistent with its true intent.

26. **Conflict between Federal and State Law.** If there is a conflict between Federal Requirements or other federal law and State Requirements or other state law applicable to the Land and/or the Facility, or Grantee's use of them, such that Grantee cannot reasonably comply with both Federal Requirements or other federal law and State Requirements or other state law, Grantee shall not be deemed to be in "default" under this Easement (as defined in Paragraph 15.A hereof) if Grantee does not comply with State Requirements or other state law until a resolution of the conflict is, and Grantee's obligations are, finally determined by negotiation or agreement among Grantee and the relevant agencies or by a court of competent jurisdiction and last resort; provided that Grantee shall comply with rulings of a court of competent jurisdiction during the pendency of such conflict, unless such ruling(s) is appealed to, stayed by or otherwise abated by a court of competent jurisdiction or by operation of law.

If there is a dispute over whether Federal Requirements or other federal law or State Requirements or other state law apply to the to the Land and/or the Facility, or Grantee's use of them, Grantee shall not be in "default" under this Easement (as defined in Paragraph 15.A hereof) if Grantee does not comply with State Requirements or other state law during the pendency of the dispute, provided that Grantee shall comply with rulings of a court of competent jurisdiction during the pendency of such conflict, unless such ruling(s) is appealed to, stayed by or otherwise abated by a court of competent jurisdiction or by operation of law.

Grantee shall pay the costs and expenses, and shall bear any liability related to, resolution of conflicts between, and disputes regarding the applicability of, Federal Requirements or other federal law and State Requirements or other state law.

GRANTOR:

NEW MEXICO COMMISSIONER OF PUBLIC LANDS

By: Patrick H. Lyons *P.H.L.*
Patrick H. Lyons, Commissioner



GRANTEE:

LOUISIANA ENERGY SERVICES, L.P.

By: **SEE ATTACHED SIGNATURE AND
ACKNOWLEDGMENT PAGE**

Exhibits

Exhibit A : Land subject to this Easement
Exhibit B = Improvements

SIGNATURE PAGE - EASEMENT

LOUISIANA ENERGY SERVICES, L.P.

By: [Signature]
Its: E. James Ferland, President

District of Columbia
STATE OF

COUNTY OF


)
) ss.
)

The foregoing instrument was acknowledged before me this 20th day of August, 2003, by E. James Ferland, President of LOUISIANA ENERGY SERVICES, L.P., a Delaware limited partnership, on behalf of said limited partnership.

My Commission Expires:

12/14/2007

[Signature]



NOTARY PUBLIC
ROXANNE B. RIKER
Notary Public
District of Columbia
My Commission Expires December 14, 2007

000 100 1000 1-834 P.001/003 P-162
Page 1 of 3
GL ENVIRONMENTAL INC.

APPLICATION

FOR STATE OF NEW MEXICO LAND

TOWNSHIP 21 SOUTH, RANGE 38 EAST, N.M.P.M.

SECTION 32
NE1/4-NE1/4
NW1/4-NE1/4
SW1/4-NE1/4
SE1/4-NE1/4
NE1/4-NW1/4
NW1/4-NW1/4
SW1/4-NW1/4
SE1/4-NW1/4
NE1/4-SE1/4
NW1/4-SE1/4
SW1/4-SE1/4
SE1/4-SE1/4
NE1/4-SW1/4
NW1/4-SW1/4
SW1/4-SW1/4
SE1/4-SW1/4




LEA COUNTY, NEW MEXICO

RECEIVED
2003 JUN 22 PM 3:48
STATE LAND OFFICE
SANTA FE, N.M.

42974

2

EXHIBIT "A"



LEGEND	
	SET MONUMENT 3/4\"/>
	FOUND MONUMENT AS NOTED
	BARBED WIRE FENCE
	RAILROAD
	UNDERGROUND PIPE LINE
	UNDERGROUND TELECOM

State of New Mexico, County of _____, I hereby certify that this instrument was filed for record on:

The _____ Day of _____, 20____ A.D.

At _____ O'Clock _____ M.

Book _____ Page _____

By _____, County Clerk

By _____, Deputy

PETTIGREW AND ASSOCIATES		
1110 N. GARDNER	MOORE, N.M. 87106	(505) 293-9277
0	02/14/2003	PLOTTED
00	02/13/2003	PRELIMINARY PLAT
02/11/2003-02/12-2003		DATE OF SURVEY
REV	DATE	DESCRIPTION

INDEXING INFORMATION FOR COUNTY CLERK
OWNER: STATE OF NEW MEXICO
LOC: SEC. 32 T21S R38E

PLAT OF BOUNDARY SURVEY FOR GL ENVIRONMENTAL INC.	
4200 MEADOWLARK LANE	
RIO RANCHO, NEW MEXICO 87124	
PROJ. No. 2003.1076	DRN BY: J. C. JOHNSON
DWG Survey of Environment\LD\DIS\2121R38E.dwg	
BOOK LTA CO. #1	SHT. 1 of 2

LEGAL DESCRIPTION

A PARCEL OF LAND WITHIN SECTION 32, TOWNSHIP 21 SOUTH, RANGE 38 EAST, NEW MEXICO PRINCIPAL MERIDIAN, LEA COUNTY, NEW MEXICO.

BY SINNER at the one-quarter corner between Sections 31 and 32, (a found GLO brass cap on a 2-inch iron pipe);

THENCE N00°38'22"W along the section line between Sections 31 and 32 a distance of 2638.37 feet to the corner of Sections 29, 31 and 30, (a found GLO brass cap on a 2-inch iron pipe);

THENCE N89°18'08"E along the section line between sections 29 and 32 a distance of 2640.69 feet to a set 5/8-inch rebar with a 2-inch aluminum cap marked "MUTH PLS 13239";

THENCE N89°18'08"E along the section line between sections 29 and 32 a distance of 2640.69 feet to the corner of Sections 28, 3, 32 and 29, (a found GLO brass cap on a 2-inch iron pipe);

THENCE S00°39'20"E along the section line between Sections 32 and 33 a distance of 2640.49 feet to the one-quarter corner between Sections 32 and 33, (a found GLO brass cap on a 1-inch iron pipe);

THENCE S00°41'56"E along the section line between Sections 32 and 33 a distance of 2324.52 feet to a found railroad iron marking the right-of-way for New Mexico State Highway No. 234; from whence the corner of Sections 33 and 32 of Township 21 South, Range 38 East, and Sections 4 and 5 of Township 22 South, Range 38 East (a found 1/2-inch rebar) bears S00°41'56"E a distance of 340.08 feet;

THENCE N80°10'49"W along the observed northerly right-of-way line of New Mexico State Highway No. 234 a distance of 1377.12 feet to a point of intersection with the section line between Sections 31 and 32 (set 5/8-inch rebar with a 2-inch aluminum cap marked "MUTH PLS 13239"); from whence the corner of Sections 31 and 32 of Township 21 South, Range 38 East, and Sections 6 and 5 of Township 22 South, Range 38 East (a found GLO brass cap on a 2-inch iron pipe) bears S00°35'16"E a distance of 1321.66 feet;

THENCE N00°35'16"W along the section line between Sections 31 and 32 a distance of 1345.14 to the POINT OF BEGINNING

Said Parcel CONTAINS 542.80 ACRES more or less

CERTIFICATE OF SURVEY-

I, Daniel R. Muth, New Mexico Professional Surveyor, hereby certify that this Boundary Survey Plat was prepared from an actual ground survey performed by me or under my supervision, that this survey is true and correct to the best of my knowledge and belief, that this Boundary Survey Plat and the field survey upon which it is based meet the Minimum Standards for Surveying in New Mexico, and that this survey is not a land division or subdivision as defined in the New Mexico Subdivision Act. This is a Boundary Survey Plat of an existing tract or tracts.

[Signature]
Daniel R. Muth NMPS# 13239



RECEIVED
STATE OF NEW MEXICO
14 Aug 2003
Date
OFFICE
8:24 AM

(5521)
42414

State of New Mexico, County of Lea, I here by certify that this instrument was filed for record on:
The 14th Day of August, 2003 A.D.
At 8:55 O'Clock A.M.
Book 1 Page 566
By Delinda Hughes, County Clerk
By R. Johnson, Deputy

ETTIGREW AND ASSOCIATES 1116 N. GRANDE (302) 772-7577		INDEXING INFORMATION FOR COUNTY CLERK	PLAT OF BOUNDARY SURVEY FOR GL ENVIRONMENTAL INC. 4200 MEADOWLARK LANE RIO RANCHO, NEW MEXICO 87124
0	08/14/2003	PLOTTED	OWNER: STATE OF NEW MEXICO LOC: SEC. 32 T21S R38E
20	08/13/2003	PRELIMINARY PLAT	PROJ. No. 2003.1076
21	08/12/2003	DATE OF SURVEY	DRN BY: C. JOHNSON
EV	DATE	DESCRIPTION	DWG Survey Of Environmental Leas 12121R38E.dwg
			BOOK LEA CO. #1
			SHEET 2 of 2

COPY

**NEW MEXICO STATE
COMMISSIONER OF PUBLIC LANDS
AGREEMENT REGARDING LAND USE RESTRICTION OR CONDITION**

This Agreement Regarding Land Use Restriction or Condition ("Agreement") is entered into effective August 22, 2003 by and between the New Mexico Commissioner of Public Lands (together with its successors and assigns, "Commissioner") and Louisiana Energy Services, L.P., a Delaware limited partnership (together with its successors and assigns, "LES") whose address is 1133 Connecticut Ave. NW, Suite 200, Washington, D.C. 20036.

RECITALS

A. On August 22, 2003, the Commissioner executed Grant of Easement and Right of Way No. 28583 pursuant to which the Commissioner granted to LES an easement and right-of-way over, on and to the land described in Exhibit A to this Agreement ("Land").

B. Paragraph 6.C of the Grant of Easement and Right of Way provides that, subject to certain terms and conditions, the Commissioner shall execute and record in the records of the State Land Office a Land Use Restriction or Condition that provides that, absent LES's prior written consent, (i) the Commissioner shall neither exercise the Commissioner's rights under Paragraph 6.B(1) of the Grant of Easement and Right of Way nor exercise the Commissioner's right to lease or otherwise dispose of or encumber the Land or any interest incident thereto, for any purpose, or grant additional easements, rights-of-way and grants across, under or over the Land, including without limitation, the development of any sand and gravel, coal, caliche, humate, oil and gas or other minerals and (ii) there shall be no surface disturbance of the Land and no right to explore for, mine, develop and/or produce oil, geothermal resources, gas and/or minerals during the term of the Grant of Easement and Right of Way.

C. The Commissioner and LES are entering into this Agreement pursuant to Paragraph 6.C of the Grant of Easement and Right of Way.

AGREEMENT

NOW, THEREFORE, FOR GOOD AND ADEQUATE CONSIDERATION, THE RECEIPT AND SUFFICIENCY OF WHICH IS ACKNOWLEDGED, THE COMMISSIONER AND LES AGREE:

1. Absent LES's prior written consent, (i) the Commissioner shall neither exercise the Commissioner's right to explore for, mine, develop and produce minerals such as sand and gravel, coal, caliche, humate, oil and gas or other minerals related to the Land nor exercise the Commissioner's right to lease or otherwise dispose of or encumber the Land or any interest incident thereto, for any purpose, or grant additional easements, rights-of-way and grants across, under or over the Land, including for the development of any sand and gravel, coal, caliche, humate, oil and gas or other minerals and (ii) there shall be no surface disturbance of the Land and no right to explore for, mine, develop and/or produce oil, geothermal resources, gas and/or minerals related to the Land during the term of the Grant of Easement and Right of Way.

2. As good and adequate consideration for this Agreement, LES shall pay to the Commissioner Five Thousand and no/100 Dollars (\$5,000.00) per year, beginning on August 22 of 2008 and continuing on August 22 of each year thereafter up to and including August 22 of 2037, or of each year in succession thereafter during which Grantee occupies and uses the Land, unless the Grant of Easement and Right of Way is earlier terminated or relinquished.

3. This Agreement shall be recorded in the records of the State Land Office and in the real property records of Lea County, New Mexico.

4. The term shall begin on the date on which the Commissioner executes this Agreement and shall end on August 22, 2038, or so long thereafter as LES occupies and uses the Land, unless the Grant of Easement and Right of Way is earlier terminated or relinquished; provided that if the Grant of Easement and Right of Way is terminated by a sale or exchange of the Land to LES or to Lea County, New Mexico, (a) both the restrictions and conditions in this Agreement and LES's obligation to pay the consideration therefor in the amount, and for the time, set forth in this Paragraph shall survive and (b) the instrument conveying the Land shall expressly recite the restrictions set forth in this Agreement.

5. If a court of competent jurisdiction determines that a provision or provisions of this Easement is or are invalid or illegal, such determination shall not invalidate or render unenforceable any other provision hereof; provided, however, that if enforcement of this Easement absent such invalid or unenforceable provision(s) would destroy an essential purpose of this Easement, then this Easement shall be deemed modified to the extent necessary to make this Easement valid or enforceable consistent with its true intent.

6. This Agreement shall be binding upon, and shall inure to the benefit of, the Commissioner and LES and their respective assigns and successors in interest.

Executed in duplicate.

NEW MEXICO COMMISSIONER OF PUBLIC LANDS

By: Patrick H. Lyons
Patrick H. Lyons, Commissioner

THIS SPACE INTENTIONALLY LEFT BLANK

LES SIGNATURE PAGE FOR LURC

LOUISIANA ENERGY SERVICES, L.P.

By: 
E. James Ferland, President

DISTRICT OF COLUMBIA)
) ss.
)

This instrument was acknowledged before me on November 19, 2003 by E. James Ferland, President of LOUISIANA ENERGY SERVICES, L.P. a Delaware limited partnership.


NOTARY PUBLIC

My commission expires:

February 28, 2008

Exhibit A

Land subject to this Agreement

GL ENVIRONMENTAL INC.

APPLICATION

FOR STATE OF NEW MEXICO LAND




TOWNSHIP 21 SOUTH, RANGE 38 EAST, N.M.P.M.

SECTION 32
NE1/4-NE1/4
NW1/4-NE1/4
SW1/4-NE1/4
SE1/4-NE1/4
NE1/4-NW1/4
NW1/4-NW1/4
SW1/4-NW1/4
SE1/4-NW1/4
NE1/4-SE1/4
NW1/4-SE1/4
SW1/4-SE1/4
SE1/4-SE1/4
NE1/4-SW1/4
NW1/4-SW1/4
SW1/4-SW1/4
SE1/4-SW1/4

LEA COUNTY, NEW MEXICO

42974

EXHIBIT "A"



LEGEND	
○	SET MONUMENT BY REBAR W/ F ALUM CAP MARKED "NORTH P.L. 13238"
●	FOUND MONUMENT AS NOTED
—X—	BARRIED W/ FENCE
	RAILROAD
—u—	UNDERGROUND PIPE LINE
—t—	UNDERGROUND TELECOM

State of New Mexico, County of _____, I here by certify that this instrument was filed for record on:

The _____ Day of _____, 20____ A.D.

At _____ O'Clock _____ M.

Book _____ Page _____

By _____, County Clerk

By _____, Deputy

PETTIGREW AND ASSOCIATES		
0116 N. UNIVERSITY BLVD. SUITE 200, ALBUQUERQUE, N.M. 87102 (505) 261-4277		
8	08/14/2003	PLOTTED
90	08/13/2003	PRELIMINARY PLAT
10/11/2003-08/12/2003		DATE OF SURVEY
REV	DATE	DESCRIPTION

INDEXING INFORMATION FOR COUNTY CLERK	
OWNER: STATE OF NEW MEXICO	
LOC. REC. 32 1218 R338	
Exhibit A	

PLAT OF BOUNDARY SURVEY FOR GL ENVIRONMENTAL INC.	
4200 MEADOWLARK LANE	
RIO RANCHO, NEW MEXICO 87124	
PROJ. No. 120011976	DRN BY: J.C. JOHNSON
DWG. Survey/CL/Env/Inc/001/001/001/001/001	DATE: 08/14/05
BOOK LEA CO. #1	PAGE 1 of 2

LEGAL DESCRIPTION

A PARCEL OF LAND WITHIN SECTION 32, TOWNSHIP 21 SOUTH, RANGE 38 EAST, NEW MEXICO PRINCIPAL MERIDIAN, LEA COUNTY, NEW MEXICO.

BEGINNING at the one-quarter corner between Sections 31 and 32, (a found GLO brass cap on a 2-inch iron pipe);

THENCE N00°18'22"W along the section line between Sections 31 and 32 a distance of 2638.37 feet to the corner of Sections 29, 32, 31 and 30, (a found GLO brass cap on a 2-inch iron pipe);

THENCE N89°18'08"E along the section line between sections 29 and 32 a distance of 2640.69 feet to a set 5/8-inch rebar with a 2-inch aluminum cap marked "MUTH PLS 13239";

THENCE N89°18'08"E along the section line between sections 29 and 32 a distance of 2640.69 feet to the corner of Sections 28, 33, 32 and 29, (a found GLO brass cap on a 2-inch iron pipe);

THENCE S00°39'20"E along the section line between Sections 32 and 33 a distance of 2640.49 feet to the one-quarter corner between Sections 32 and 33, (a found GLO brass cap on a 1-inch iron pipe);

THENCE S00°41'56"E along the section line between Sections 32 and 33 a distance of 2324.52 feet to a found railroad iron marking the right-of-way for New Mexico State Highway No. 234; from whence the corner of Sections 33 and 32 of Township 21 South, Range 38 East, and Sections 4 and 5 of Township 22 South, Range 38 East (a found 1/2-inch rebar) bears S00°41'56"E a distance of 340.08 feet;

THENCE N80°10'49"W along the observed northerly right-of-way line of New Mexico State Highway No. 234 a distance of 5377.12 feet to a point of intersection with the section line between Sections 31 and 32 (set 5/8-inch rebar with a 2-inch aluminum cap marked "MUTH PLS 13239"); from whence the the corner of Sections 31 and 32 of Township 21 South, Range 38 East, and Sections 6 and 5 of Township 22 South, Range 38 East (a found GLO brass cap on a 2-inch iron pipe) bears S00°35'16"E a distance of 1321.66 feet;

THENCE N00°35'16"W along the section line between Sections 31 and 32 a distance of 1345.14 to the POINT OF BEGINNING

Said Parcel CONTAINS 542.80 ACRES more or less

CERTIFICATE OF SURVEY-

"I, Daniel R. Muth, New Mexico Professional Surveyor, hereby certify that this Boundary Survey Plat was prepared from an actual ground survey performed by me or under my supervision, that this survey is true and correct to the best of my knowledge and belief, that this Boundary Survey Plat and the field survey upon which it is based meet the Minimum Standards for Surveying in New Mexico, and that this survey is not a land division or subdivision as defined in the New Mexico Subdivision Act. This is a Boundary Survey Plat of an existing tract or tracts.

Daniel R. Muth
Daniel R. Muth NMPS# 13239



14 Aug 2003
Date

42974

(5521)

State of New Mexico, County of Lea, I here by certify that this instrument was filed for record on:

The 14th Day of August, 20 03 A.D.

At 9:55 o'clock A.M.

Book 1 Page 566

By Melinda Hughes, County Clerk

By R. Dawson, Deputy

PETTIGREW AND ASSOCIATES
1110 N. GARDNER
MORNING, N.M. 86504
(505) 753-9221

INDEXING INFORMATION FOR COUNTY CLERK


PLAT OF BOUNDARY SURVEY FOR GL ENVIRONMENTAL INC. 4200 MEADOWLARK LANE RIO RANCHO, NEW MEXICO 87124

0	08/14/2003	FLOTTED
01	08/13/2003	PRELIMINARY PLAT
02/11/2003-03/12/2003		DATE OF SURVEY
REV	DATE	DESCRIPTION

OWNER: STATE OF NEW MEXICO
LOC. REC. 32 7218 8388

PROJ. No. 120031074
DWG. Survey/OLE/Environmental/LEA/03/21/03/13239.dwg
BOOK | LEA CO. #1 | SHEET | 1 of 2

Exhibit B



KEY

- | | | | |
|--|--|--------------------------|--------------------|
| 1 ADMINISTRATION BLDG - 15,100SF | 6 CASCADE HILLS 1&2 - 137,000SF | 11 UIC PND (30 YRS SIC) | 16 COOKING KITCHEN |
| 2 RECI SVCS BLDG (15B) - 99,000SF | 7 CASCADE HILLS 3&4 - 137,000SF | 12 SECURITY BUILDING | 17 GUARD HOUSE |
| 3 CENTRAL UTILITIES BLDG - 21,100SF | 8 CASCADE HILLS 5&6 - 137,000SF | 13 FACILITY PARKING | 18 SECURITY FENCE |
| 4 BLENDING & SAMPLING - 16,000SF | 9 CYL. RECEIPT & DISPATCH - 106,000SF | 14 FIRE WATER TANKS | 19 VISITOR CENTER |
| 5 W.B. AREA - 11 ASSEY / EACH
122,300SF | 10 CENTRAL UTILITY ASSEY BLDG (CAB) -
122,300SF | 15 ELECTRICAL SWITCHGEAR | |


STATE OF TEXAS
COUNTY OF ...
OFFICE OF ...
NO. 449

<p>JACKWORTH ENGINEERS ENGINEERING & CONSTRUCTION</p>	CONCEPTUAL SITE PLAN	NATIONAL ENRICHMENT FACILITY	SK-01
	<p>DATE: ...</p>	<p>SCALE: ...</p>	<p>PROJECT NO. ...</p>

RECEIVED

ATTACHMENT 2

**Louisiana Energy Services
Air Quality Notice of Intent Application**

Mail Application To: New Mexico Environment Department Air Quality Bureau New Source Review Unit 2048 Galisteo Santa Fe, NM 87505 Phone (505) 827-1494 http://www.nmenv.state.nm.us		Application No. _____ AIRS No. _____ <p style="text-align: right;"><i>For NMED use only</i></p>
---	---	---

Air Quality Permit Application And Notice Of Intent Universal (General) to Construct or Modify

Acknowledgement: I acknowledge that a pre-application meeting is available to me upon request
 Permit filing fee enclosed, Check No.: N/A

Part I – General Information

I-A: Company Information

1	Company name: Louisiana Energy Services, LP	Date application notarized: April 20, 2004
2	Facility name: National Enrichment Facility (NEF)	SIC code (4 digits): 2819
3	Company mailing address: 100 Sun Lane NE, Suite 204, Albuquerque, New Mexico 87109	
4	Contact person: R. M. Krich	Title: Vice President of Licensing, Safety and Nuclear Engineering
5	Phone No: (202) 222-0391	Fax No: (202) 337-2421
		E-mail: rkrich@nefnm.com

I-B: Current Facility Status

1	This application is for (check one): <input checked="" type="checkbox"/> New Facility, <input type="checkbox"/> Modification to an existing facility, or <input type="checkbox"/> Revision	
2	Has this facility already been constructed? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, is it currently operating in New Mexico? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
3	Is the plant currently shut down? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, give month and year of shut down (MM/YY): <u>N/A</u>
4	Was this facility constructed before 1972 and operated since 1972? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5	Does this facility have an operating permit under 20 NMAC 2.70? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the permit No. is: P- <u>N/A</u>
6	Has this facility been issued a No Permit Required (NPR)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the NPR number is: <u>N/A</u>
7	Has this facility been issued a Notice of Intent (NOI)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the NOI Number is: <u>N/A</u>
8	Does this facility have a construction permit (20 NMAC 2.72, Section 200.A or 200.B) <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	• If yes, the permit No. is: <u>N/A</u>	
9	Has this facility been issued a general permit (GCP-1, GCP-2,...)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the registration No. is: <u>N/A</u>
10	Is this a "major source" under the PSD rules? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Unsure.	Is this a "major source" under Title V (20 NMAC
	2.70)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Unsure.	Is this a major modification under the PSD rules (20 NMAC 2.74)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Unsure.
11	If Yes or Unsure to any of the questions in question No. 10, contact the AQB to see if a pre-application meeting is required.	

Table I-B: Current Facility Status (continued)

12	What is the facility's maximum input capacity, specify units (reference here and list capacities in Attachment L if more room is required)		
• Current	Hourly: N/A	Daily: N/A	Annually : N/A
• Proposed	Hourly: 1.1 tons UF ₆ (Feed)	Daily: 26.0 tons UF ₆ (Feed)	Annually: 9,480 tons UF ₆ (Feed)
13	What is the facility's maximum production rate, specify units (reference here and list capacities in Attachment L, if more room is required)		
• Current	Hourly: N/A	Daily: N/A	Annually N/A
• Proposed	Hourly: 0.1 tons UF ₆ (Product) 1.0 tons UF ₆ (Depleted)	Daily: 2.4 tons UF ₆ (Product) 23.6 tons UF ₆ (Depleted)	Annually : 880 tons UF ₆ (Product) 8,600 tons UF ₆ (Depleted)

Table I-C: Facility Location Information



1	Section: 32	Range: 38E	Township: 21S	County: Lea County	Elevation (ft): 3,415
2	UTM Zone: <input type="checkbox"/> 12 or <input checked="" type="checkbox"/> 13		UTMH (record to one tenth of a km): 680.6	UTMV (record to one tenth of a km): 3,590.1	
OR	Latitude (deg., min., sec.): 32°, 26 m, 1.74 s N		Longitude (deg., min., sec.): 103°, 04 m, 43.47 s W		
3a	Name and zip code of nearest New Mexico town: Eunice, New Mexico 88231				
3b	Distance and Direction from nearest New Mexico town: 5 miles East from Eunice, New Mexico				
4	Detailed Driving Instructions from nearest NM town (See NEF Local Map): The facility is <u>5</u> (distance) miles <u>East</u> (direction) of <u>Eunice, New Mexico</u> (nearest town).				
5	Status of land at facility (check one): <input type="checkbox"/> Private <input type="checkbox"/> Indian/Pueblo <input checked="" type="checkbox"/> Government (New Mexico Land Office)				
6	Name of nearest Class I area to the facility (see Figure 1.0): Carlsbad Caverns National Park.				
7	Shortest distance from facility boundary to the boundary of the nearest Class I area (record to one tenth of a km): 98.0 km (61 mi)				

Table I-D: Proposed Operating Schedule

1	Facility maximum operating ($\frac{\text{hours}}{\text{day}}$): 24	($\frac{\text{days}}{\text{week}}$): 7	($\frac{\text{weeks}}{\text{year}}$): 52	($\frac{\text{hours}}{\text{year}}$): 8,760	
2	Facility's maximum daily operating schedule (if less than 24 $\frac{\text{hours}}{\text{day}}$): Start: N/A		<input type="checkbox"/> AM <input type="checkbox"/> PM	End: N/A	<input type="checkbox"/> AM <input type="checkbox"/> PM
3	Month and year of anticipated start of construction: October 2006				
4	Month and year of anticipated construction completion: October 2013 (achieve full nominal output-last cascade completed)				
5	Month and year of anticipated startup of new or modified facility: December 2008 (start-up of first cascade hall)				
6	Will this facility operate at this site for more than one year? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				

Table I-E: Other

1	Is this application in response to a Notice of Violation (NOV)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
•	If yes, NOV date: N/A	NOV Tracking No: N/A
2	Is air quality dispersion modeling being submitted with this application? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
3	Does this facility require an "Air Toxics" permit under 20 NMAC 2.72, Part IV, Tables A and/or B in Part V? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
4	Will this facility be a source of federal Hazardous Air Pollutants? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
•	If yes, list applicable subparts in 40 CFR 61 & 63: There are no Subparts that directly apply to this facility.	



REFERENCE NUMBER
Figure 3.10-1.dwg



MAP SOURCE:
JAL AND HOBBS QUADRANGLES
NEW MEXICO - TEXAS 1:10000
CONTOUR INTERVAL: 10 METERS

NEF LOCAL MAP
NM AIR QUALITY NOTICE OF INTENT

Part II – Required Attachments

The following Attachments are required, please label each accordingly. A complete application shall include:

Attachment A A process flow sheet and/or block diagram indicating the individual equipment, all emission points and types of control applied to those points. Numbering system should cross reference with Attachment B.

Attachment B A plot plan drawn to scale, showing emissions points, structures, tanks, and fences of property owned, leased, or under direct control of the applicant.

Attachment C All calculations used to determine both the hourly and annual controlled and uncontrolled emission rates. Reference where emission factors were obtained. If identical units are being permitted and will be subject to the same operating conditions, submit calculations for only one unit and a note specifying what other units the calculations represent.

Attachment D Information Used to Determine Emissions

- If manufacturer data are used, include specifications for emissions units and control equipment.
- If test data are used, include a copy of the complete test report. If the test data are for an emissions unit other than the one being permitted, the emission units must be identical. Test data may not be used if any difference in operating conditions of the unit being permitted and the unit represented in the test report significantly effect emission rates.
- If the most current copy of AP-42 is used, reference the section and date located at the bottom of the page. Include a copy of the page containing the emissions factors, and clearly mark the factors used in the calculations.
- If an older version of AP-42 is used, include a complete copy of the section.
- If an EPA document or other material is referenced, include a complete copy.
- Fuel specifications sheet.
- If computer models are used to estimate emissions, include an input summary (if available) and a detailed report, and a disk containing the input file(s) used to run the model. For tank-flashing emissions, include a discussion of the method used to estimate tank-flashing emissions, relative thresholds (i.e., permit or major source (NSPS, PSD or Title V)), accuracy of the model, the input and output from simulation models and software, all calculations, documentation of any assumptions used, descriptions of sampling methods and conditions, copies of any lab sample analysis.

Attachment E A map such as a 7.5 minute topographic quadrangle showing the exact location of the source. The map shall also include the following:

The UTM or Longitudinal coordinate system on both axes	An indicator showing which direction is north
A minimum radius around the plant of 5km (3.1 miles)	The nearest occupied structure(s)
Topographic features of the area	Access and haul roads
The name of the map	Facility property boundaries
A scale	The area which will be restricted to public access

Attachment F Proof of public notice: Include a copy of the certified letter receipts, a list of the places where the public notice has been posted, and: (see guidance document)

a sample of the letters sent to land owners	a sample and verification of the local postings
a sample of the letters sent to municipalities	a copy of the display ad and its affidavit of publication
a copy of the announcement sent to a local radio station	a copy of the classified ad and its affidavit of publication

Attachment G A written description of the routine operations of the facility. Include a description of how each piece of equipment will be operated, how controls will be used, and the fate of both the products and waste generated. For modifications and/or revisions, explain how the changes will affect the existing process.

Attachment H A PSD applicability determination for all sources. For PSD major sources applying for a significant permit revision, use the procedures for Determining the Net Emissions Change at a Source as specified by Table A-5 (Page A.45) of the EPA New Source Review Workshop Manual to determine if the revision is subject to PSD review.

Attachment I A discussion demonstrating compliance with each applicable state & federal regulation. If there is a state or federal regulation for your facility's source category that does not apply to your facility, explain why. For example 40 CFR 60 Subpart OOO (crushers), 40 CFR 63 Subpart HHH (HAPs), or 20 NMAC 2.74 (PSD major sources).

- Attachment J** A preliminary operational plan defining the measures to be taken to mitigate source emissions during malfunction, startup, or shutdown.
- Attachment K** An air quality dispersion modeling demonstration (if applicable) as outlined in the Air Quality Bureau's Dispersion Modeling Guidelines.
- Attachment L** Other relevant information. Use this attachment to clarify any part in the application that you think needs explaining. Reference the section, table, column, and/or field.

Submit the original signed and notarized copy of the application package and;

- 1) One working copy for department use, and
- 2) One copy if air dispersion modeling is included (include disks with input and output files), and
- 3) One copy if public notice was required, and
- 4) If subject to PSD review under 20 NMAC 2.74 (PSD) one copy for US EPA, one copy for each federal land manager affected (NPS, USFS, FWS, USDI), and one copy for each affected regulatory agency other than the Air Quality Bureau.

Part III – Production and Control Equipment

Table III-A: Regulated Equipment (Unit and stack numbering must correspond throughout the application package.)

Note: If applying for a NOI under 20 NMAC 2.73, equipment exemptions under 2.72, 202 do not apply, and all equipment should be listed here.

Unit No.	Manufacturer	Model No.	Type (Source Description)	Capacity (Specify Units)	For Each Piece of Equipment, Check One	Applicable State Reg. (s) 20 NMAC 2.X, ...	Replacing Unit No.
	Date of Manufacture/Reconstruction (MM/DD/YY)	Serial No.					
1	Unknown	Unknown	Technical Services Building Confinement Ventilation System	13,100 cfm	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
2	Superior Boiler Works, Inc	1500, (Seminole 3 pass wetback packaged boiler)	Hot Water Boiler #1, Natural gas	300 HP	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
3	Superior Boiler Works, Inc	1500, (Seminole 3 pass wetback packaged boiler)	Hot Water Boiler #2, Natural gas (standby unit)	300 HP	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
4	Caterpillar	CAT 3512B TA	Emergency Diesel Generator (CAT 3512B TA Diesel Engine and CAT SR4B Generator DM6610)	1500 kW	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
5	Caterpillar	CAT 3512B TA	Emergency Diesel Generator (CAT 3512B TA Diesel Engine and CAT SR4B Generator DM6610)	1500 kW	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
6	Baltimore Aircoil	HXV-641-OM	Closed Circuit Hybrid Cooling Tower No. 3	138,350 cfm	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
7	Baltimore Aircoil	HXV-641-OM	Closed Circuit Hybrid Cooling Tower No. 4	138,350 cfm	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
8	Baltimore Aircoil	HX-641-OM	Closed Circuit Hybrid Cooling Tower No. 3	117,900 cfm	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					
9	Baltimore Aircoil	HXV-641-OM	Closed Circuit Hybrid Cooling Tower No. 4	117,900 cfm	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Modified <input type="checkbox"/> To be Replaced	20.2.73	N/A
	Unknown	Unknown					

Part III – Production and Control Equipment (continued)

Table III-A: Regulated Equipment (Unit and stack numbering must correspond throughout the application package.) Note: If applying for a NOI under 20 NMAC 2.73, equipment exemptions under 2.72, 202 do not apply, and all equipment should be listed here.								
Unit No.	Manufacturer	Model No.	Type (Source Description)	Capacity (Specify Units)	For Each Piece of Equipment, Check One		Applicable State Reg. (s) 20 NMAC 2.X, ...	Replacing Unit No.
	Date of Manufacture/Reconstruction (MM/DD/YY)	Serial No.			<input type="checkbox"/> Existing (unchanged)	<input type="checkbox"/> To be Removed		
10 (a, b)	AMCOR	CVLT-6000	Two (2) 6,000 gallon #2 Diesel Fuel Tanks	6000 gallons each	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	Unknown	Unknown			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
11	Unknown	Unknown	CAB Centrifuge Test and Post Mortem Facilities Exhaust Filtration System	5,500 cfm	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	Unknown	Unknown			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
12	Unknown	Unknown	Technical Services Building Gaseous Effluent Vent System (TSB GEVS)	11,000 cfm	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	Unknown	Unknown			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
13	Unknown	Unknown	Separations Building Gaseous Effluent Vent System (SB GEVS)	6,474 cfm	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	Unknown	Unknown			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
B1	N/A	N/A	UBC Storage Pad Stormwater Retention Basin	20,528,340 gal	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
B2	N/A	N/A	Treated Effluent Evaporative Basin	985,306 gal	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
B3	N/A	N/A	Site Stormwater Detention Basin	6,169,070 gal	<input checked="" type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	20.2.73	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		

Table III-B: 20 NMAC 2.72, 202.B Exempted Equipment (If exempt under 20 NMAC 2.72, 202.B.5, list emission rates in Table IV-A.)

(Unit and stack numbering must correspond throughout the application package.)

Note: This table is applicable only if applying for a 20 NMAC 2.72 permit. Exemptions under 20 NMAC 2.72, 202 do not apply to facilities requesting a NOI under 20 NMAC 2.73. See application form instructions and Exemptions Procedure for instructions on this form.

Unit No.	Manufacturer	Model No.	Type (Source Description)	Capacity (Specify Units)	For Each Piece of Equipment, Check One		Site Specific 20 NMAC 2.72.202 Exemption (e.g. 2.72.202.B.5)	Other Required Information
	Date of Mfg. (MM/DD/YY)	Serial No.			<input type="checkbox"/> Existing (unchanged)	<input type="checkbox"/> To be Removed		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		
N/A	N/A	N/A	N/A	N/A	<input type="checkbox"/> New/Additional	<input type="checkbox"/> Replacement Unit	N/A	N/A
	N/A	N/A			<input type="checkbox"/> To be Modified	<input type="checkbox"/> To be Replaced		

Table III-C: Emissions Control Equipment (Additional Information)**

(Unit and stack numbering must correspond throughout the application package.)

Unit No.	Control Equipment Description	Controlled Pollutant(s)	Controlling Emissions for Unit(s) No.	% Control by Weight	Estimation Method
1	Technical Services Building Confinement Ventilation System (see Attachment A, Sheets #1 & #2)	Uranium (U) particulates & Hydrogen Fluoride (HF)	1	Prefilter-85% (U); Carbon Absorbers-99.9% (HF) & HEPA Filters-99.97% (U)	ASHRAE Std 52.1, IES* and ASME AG-1
11	Centrifuge Test and Post Mortem Facilities Exhaust Filters (Flanders Corp.) (See Attachment A, Sheets #1 & #3)	Uranium (U) particulates & Hydrogen Fluoride (HF)	11	Prefilter-85% (U); Carbon Absorbers-99.9% (HF) & HEPA Filters-99.97% (U)	ASHRAE Std 52.1, IES* and ASME AG-1
12	Technical Services Building, Gaseous Effluent Vent System Filters (Flanders Corp.) (See Attachment A, Sheets #1, #4 & #5)	Uranium (U) particulates & Hydrogen Fluoride (HF)	12	Prefilter-85% (U); Carbon Absorbers-99.9% (HF) & HEPA Filters-99.97% (U)	ASHRAE Std 52.1, IES* and ASME AG-1
13	Separations Building, Gaseous Effluent Vent System Filters (Flanders Corp.) (See Attachment A, Sheets #1, #6 & #7)	Uranium (U) particulates & Hydrogen Fluoride (HF)	13	Prefilter-85% (U); Carbon Absorbers-99.9% (HF) & HEPA Filters-99.97% (U)	ASHRAE Std 52.1, IES* and ASME AG-1
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A

Only list control equipment for TAPs if the TAP's PER is over its respective threshold as listed in 20 NMAC 2.72 Subpart V Tables A and B

*Institute of Environmental Sciences, IES#IERS-RP-CC-008-84

**The above equipment information is provided for completeness. The TAP's PER is below the respective threshold as listed in 20 NMAC 2.72 Subpart V Table A. See Attachment C and Table C-3

Part IV - Emission Calculations

Table IV-A: Unit Emissions Rates List Toxic Air Pollutants (TAPs) In Table IV-C
 (Unit and stack numbering must correspond throughout the application package.) Include tank-flashing emissions estimates.

Potential emission rate (PER) ¹								Potential to emit (PTE) ²							
Unit No.	TSP lb/hr	PM10 lb/hr	NOx lb/hr	CO lb/hr	VOC lb/hr	SOx lb/hr	□ Lead □ H ₂ S lb/hr	TSP lb/hr	PM10 lb/hr	NOx lb/hr	CO lb/hr	VOC lb/hr	SOx lb/hr	□ Lead □ H ₂ S lb/hr	
	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	
2 or 3	0	0	1.26	0.13	0.20	0	N/A	0	0	1.26	0.13	0.20	0	N/A	
	0	0	5.52	0.55	0.88	0	N/A	0	0	5.52	0.55	0.88	0	N/A	
4 and 5	0.36	0.36	40.76	3.15	0.97	0	N/A	0.36	0.36	40.76	3.15	0.97	0	N/A	
	0.11 ^a	0.11 ^a	12.23 ^a	0.94 ^a	0.29 ^a	0 ^a	N/A	0.11 ^a	0.11 ^a	12.23 ^a	0.94 ^a	0.29 ^a	0 ^a	N/A	
6	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
7	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
8	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
9	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
	0	0	0	0	0	0	N/A	0	0	0	0	0	0	N/A	
10a and 10b	N/A	N/A	N/A	N/A	1.00x10 ⁻³	N/A	N/A	N/A	N/A	N/A	N/A	N/A	1.00x10 ⁻³	N/A	N/A
	N/A	N/A	N/A	N/A	4.38x10 ⁻³	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.38x10 ⁻³	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	a-Based on a total annual operating time of 600 hours combined for both generators; neither will operate more than 500 hours per year.							
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Totals →	0.36	0.36	42.02	3.28	1.17	0	N/A	0.36	0.36	42.02	3.28	1.17	0	N/A	
	0.11	0.11	17.75	1.49	1.17	0	N/A	0.11	0.11	17.75	1.49	1.17	0	N/A	

¹ (PER) or "Potential Emission Rate" means the emission rate of a source at its maximum capacity to emit a regulated air contaminant under its physical and operational design, provided any physical or operational limitation on the capacity of the source to emit a regulated air contaminant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored or processed, shall be treated as part of its physical and operational design only if the limitation or the effect it would have on emissions is enforceable by the Department pursuant to the Air Quality Control Act or the federal Act.

² (PTE) or "Potential to emit" means the maximum capacity of a stationary source to emit a regulated air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the source to emit a regulated air contaminant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design if the limitations or the effect it would have on emissions is federally enforceable. Secondary emissions do not count in determining the potential to emit of a stationary source. 20 NMAC 2.72, 300.E PTE does include reductions in emissions due to federally enforceable limits.

Table IV-B: Stack Exit and Fugitive¹ Emission (PTE) Rates for Pollutants and Stack Exit Conditions List Toxic Air Pollutants (TAPs) and Hazardous Air Pollutants (HAPs) in Table IV-C (Unit and stack numbering must correspond throughout the application package.) Include tank-flashing emissions estimates.

		Stack Exit Emission Rates for Criteria Pollutants							Stack Exit Conditions (Not Applicable for Fugitives)				
Stack No.	Unit No.(s) from Table III-A	TSP Lb/hr	PM10 lb/hr	NOx lb/hr	CO lb/hr	VOC lb/hr	SOx lb/hr	□ Lead □ H ₂ S lb/hr	Orientation (H=Horizontal V=Vertical)	Height Above Ground (ft)	Flow Rate (acfm)	Moisture by Volume (%)	Inside Diameter or L x W (ft)
		ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	Rain Caps (Yes or No)	Temp. (F)	(dscfm)	Velocity (ft/sec)	
2 or 3	2 or 3	0	0	1.26	0.13	0.20	0	N/A	Vertical	39.6	4560	Unknown	1.33
		0	0	5.52	0.55	0.88	0	N/A	Yes	420	Unknown	54.7	
4 and 5	4 and 5	0.36	0.36	40.76	3.15	0.97	0	N/A	Vertical	≈20	22,966	Unknown	0.67
		0.11 ^a	0.11 ^a	12.23 ^a	0.94 ^a	0.29 ^a	0*	N/A	Yes	847	Unknown	542	
6	6	0	0	0	0	0	0	N/A	N/A	≈20	138,350	Variable	N/A
		0	0	0	0	0	0	N/A	N/A	82.5	Unknown	Unknown	
7	7	0	0	0	0	0	0	N/A	N/A	≈20	138,350	Variable	N/A
		0	0	0	0	0	0	N/A	N/A	82.5	Unknown	Unknown	
8	8	0	0	0	0	0	0	N/A	N/A	≈20	117,900	Variable	N/A
		0	0	0	0	0	0	N/A	N/A	82.5	Unknown	Unknown	
9	9	0	0	0	0	0	0	N/A	N/A	≈20	117,900	Variable	N/A
		0	0	0	0	0	0	N/A	N/A	82.5	Unknown	Unknown	
10	10a	N/A	N/A	N/A	N/A	5.00x10 ⁻⁴	N/A	N/A	N/A	9	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	2.19x10 ⁻³	N/A	N/A	N/A	70	N/A	N/A	
10	10b	N/A	N/A	N/A	N/A	5.00x10 ⁻⁴	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	2.19x10 ⁻³	N/A	N/A	N/A	N/A	N/A	N/A	
F	Maintenance VOCs	N/A	N/A	N/A	N/A	0.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	0.94	N/A	N/A	N/A	N/A	N/A	N/A	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Totals →		0.36	0.36	42.02	3.28	1.38	0	N/A	a-Based on a total annual operating time of 600 hours combined for both generators; neither will operate more than 500 hours per year.				
		0.11	0.11	17.75	1.49	2.11	0	N/A					

¹ List all fugitives that are associated with the normal, routine, or non-emergency operation of the facility.

Table IV-C: Stack Exit Emission Rates for HAPs and TAPs (Describe Stack Exit Conditions in Table IV-B)*
 (Unit and stack numbering must correspond throughout the application package.) Include tank-flashing emissions estimates

Stack No.	Unit No.(s)	Specify the name of the HAP or TAP as it appears in Section 112. (b) of the 1990 CAAA or 20 NMAC 2.72 Subpart V in the space provided below.							
		PTE Uranium Particulate (U)	PTE Hydrogen Fluoride (HF)	PER Uranium Particulate (U)	PER Hydrogen Fluoride (HF)	N/A	N/A	N/A	N/A
		HAP <input checked="" type="checkbox"/> TAP <input checked="" type="checkbox"/>	HAP <input checked="" type="checkbox"/> TAP <input checked="" type="checkbox"/>	HAP <input checked="" type="checkbox"/> TAP <input checked="" type="checkbox"/>	HAP <input checked="" type="checkbox"/> TAP <input checked="" type="checkbox"/>	HAP <input type="checkbox"/> TAP <input type="checkbox"/>	HAP <input type="checkbox"/> TAP <input type="checkbox"/>	HAP <input type="checkbox"/> TAP <input type="checkbox"/>	HAP <input type="checkbox"/> TAP <input type="checkbox"/>
		lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr	lb/hr
		ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr	ton/yr
1	1	Trace ¹	Trace ¹	Trace ¹	Trace ¹	N/A	N/A	N/A	N/A
		Trace ¹	Trace ¹	Trace ¹	Trace ¹	N/A	N/A	N/A	N/A
11	11	Trace ¹	Trace ¹	Trace ¹	Trace ¹	N/A	N/A	N/A	N/A
		Trace ¹	Trace ¹	Trace ¹	Trace ¹	N/A	N/A	N/A	N/A
12	12	1.58 x 10 ⁻⁶	1.58 x 10 ⁻⁴	5.18 x 10 ⁻³	5.13 x 10 ⁻²	N/A	N/A	N/A	N/A
		6.93 x 10 ⁻⁵	6.93 x 10 ⁻¹	2.27 x 10 ⁻²	2.25 x 10 ⁻¹	N/A	N/A	N/A	N/A
13	13	9.32 x 10 ⁻⁷	9.33 x 10 ⁻⁵	3.05 x 10 ⁻³	3.02 x 10 ⁻²	N/A	N/A	N/A	N/A
		4.08 x 10 ⁻⁶	4.09 x 10 ⁻¹	1.34 x 10 ⁻²	1.32 x 10 ⁻¹	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
TOTAL	→	2.51 x 10 ⁻⁶	2.52 x 10 ⁻⁴	8.23 x 10 ⁻³	8.16 x 10 ⁻²	N/A	N/A	N/A	N/A
		1.10 x 10 ⁻⁵	1.10 x 10 ⁻³	3.61 x 10 ⁻²	3.57 x 10 ⁻¹	1 - Trace means not distinguishable from background levels			

Only list TAPs that have a PER greater than the threshold emission rate listed in 20 NMAC 2.72 Subpart V, Tables A and B
 *Emission rates are below thresholds listed in 20 NMAC 2.72 Subpart V, Table A, but are provided for completeness.

Part V – Fuel

Table V-A: Fuel Characteristics and Usage (Unit and stack numbering must correspond throughout the application package.)						
Unit No.	Fuel Type (No. 2 Diesel, Natural Gas, Coal, ...)	Specify Units				
		Lower Heating Value	Hourly Usage	Annual Usage	% Sulfur	% Ash
2, 3	Natural Gas	1,035 BTU/ft ³	5,915 hrs/year	9 x 10 ⁹ BTU/Yr	N/A	N/A
4, 5	Number 2 Diesel Fuel	18,390 BTU/lb@85°F	104 gal/hr @ 100% load	62,400 gallons total, both generators	0.5 max	<0.01
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A

Part VI – Material Storage and Handling

Table VI-A: Liquid Storage Data¹ (Use additional sheets if necessary.) (Unit and stack numbering must correspond throughout the application package.) Include appropriate tank-flashing modeling input data. Use an addendum to this table for unlisted data categories								
Tank No.	Material Name	Composition	Liquid Density (lb/gal)	Vapor Molecular Weight (lb/(lb*mol))	Average Storage Conditions		Max Storage Conditions	
					Temperature (°F)	True Vapor Pressure (psia)	Temperature (°F)	True Vapor Pressure (psia)
10a	Number 2 Diesel Fuel	Number 2 Diesel Fuel	7.3	Unknown	65 °F	0.0406	70 °F	0.0411
10b	Number 2 Diesel Fuel	Number 2 Diesel Fuel	7.3	Unknown	65 °F	0.0406	70 °F	0.0411
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

¹ If tank is to be used for storage of different materials, list all the materials, run the newest version of TANKS on each and use the material with the highest emission rate to determine PER and PTE.

Table VI-B: Liquid Storage Tank Data (Use additional sheets if necessary.) (Unit and stack numbering must correspond throughout the application package.)
 Include appropriate tank-flashing modeling input data. Use an addendum to this table for unlisted data categories.

Tank No.	Date Installed/ Modified (MM/YY)	Materials Stored	Roof Type (Table VI-C)	Seal Type (Table VI-C)	Capacity ¹		Diameter (M)	Vapor Space (M)	Color (Table VI-C)		Paint Condition (Table VI-C)	Annual Through-put (gal/yr)	Turn-overs per year
					(bbl)	(M ³)			Roof	Shell			
10a or 10b	Not Installed	Number 2 Diesel Fuel	FX	N/A	143	22.7	5.3 (L) 2.4 (W) 2.7 (H)	0.35	LG	LG	Good	31,200 per tank	6 per tank
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Table VI-C: Liquid Storage Tank Data Codes

Roof Type	Seal Type, Welded Tank Seal Type		Seal Type, Riveted Tank Seal Type		Roof, Shell Color	Paint Cond.
FX, Fixed Roof	1. Mechanical Shoe Seal	2. Liquid-mounted resilient seal	3. Vapor-mounted resilient seal	4. Seal Type	WH, White	Good
IF, Internal Floating Roof	A, Primary only	A, Primary only	A, Primary only	A, Mechanical shoe, primary only	AS, Aluminum (specular)	Poor
EF, External Floating Roof	B, Shoe-mounted secondary	B, Weather shield	B, Weather shield	B, Shoe mounted secondary	AD, Aluminum (diffuse)	
IP, Pressure	C, Rim-mounted secondary	C, Rim-mounted secondary	C, Rim-mounted secondary	C, Rim-mounted secondary	LG, Light Gray	
					MG, Medium Gray	
					BL, Black	
					OT, Other	

$0.159 \text{ M}^3 = 42.0 \text{ gal} = 1.00 \text{ bbl}$

Table VI-D: Materials Processed and Produced (Use additional sheets if necessary.)

Material Processed				Material Produced			
Description	Chemical Composition	Phase ¹	Quantity (specify units)	Description	Chemical Composition	Phase ¹	Quantity (specify units)
Feed Material	Uranium Hexafluoride (UF ₆)	S	9,480 tons/yr	Product Material	Uranium Hexafluoride (UF ₆)	S	880 tons/yr
N/A	N/A	N/A	N/A	Depleted Material	Uranium Hexafluoride (UF ₆)	S	8,600 tons/yr
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

¹G = Gas, L = Liquid, or S = Solid

Part VII – Emissions Measurement

Table VII-A: Continuous Emissions Measurement (CEM) Equipment (Use additional sheets if necessary.) (Unit and stack numbering must correspond throughout the application package.)									
Stack No.	Pollutant(s)	Manufacturer	Model No.	Serial No.	Sample Frequency	Averaging Time	Range	Sensitivity	Accuracy
1	HF,* Uranium Particulates	Canberra Industries	RADACS Display and Control System; ADM616 Multifunction Control and Display Unit; iCAM Alpha/Beta Air Monitor	Unknown, since equipment has not been ordered	Continuous	15 Seconds	HF: 0-1 mg/m ³ Alpha: 0-100 Bq/m ³	Unknown at this time, information will be available when equipment is purchased	Unknown at this time, information will be available when equipment is purchased
11	HF,* Uranium Particulates	Canberra Industries	RADACS Display and Control System; ADM616 Multifunction Control and Display Unit; iCAM Alpha/Beta Air Monitor	Unknown, since equipment has not been ordered	Continuous	15 Seconds	HF: 0-1 mg/m ³ Alpha: 0-100 Bq/m ³	Unknown at this time, information will be available when equipment is purchased	Unknown at this time, information will be available when equipment is purchased
12	HF,* Uranium Particulates	Canberra Industries	RADACS Display and Control System; ADM616 Multifunction Control and Display Unit; iCAM Alpha/Beta Air Monitor	Unknown, since equipment has not been ordered	Continuous	15 Seconds	HF: 0-1 mg/m ³ Alpha: 0-100 Bq/m ³	Unknown at this time, information will be available when equipment is purchased	Unknown at this time, information will be available when equipment is purchased
13	HF,* Uranium Particulates	Canberra Industries	RADACS Display and Control System; ADM616 Multifunction Control and Display Unit; iCAM Alpha/Beta Air Monitor	Unknown, since equipment has not been ordered	Continuous	15 Seconds	HF: 0-1 mg/m ³ Alpha: 0-100 Bq/m ³	Unknown at this time, information will be available when equipment is purchased	Unknown at this time, information will be available when equipment is purchased

Note: If CEM data will be used as part of a federally enforceable permit condition, or used to satisfy the requirements of a state or federal regulation, include a copy of the CEM's manufacturer specification sheet in Attachment D.

*CEM equipment is required under U.S. Nuclear Regulatory Commission Regulatory Guide 4.16. The NRC will regulate uranium emissions.

Part VIII – Certification

Company Name: Louisiana Energy Services, LP

I, R. M. Krich, hereby certify that the information and data submitted in this application are true and as accurate as possible, to the best of my knowledge and professional expertise and experience.

Signed this 20th day of April, 2004, upon my oath or affirmation, before a notary of the State of District of Columbia.


Signature


4/20/04
Date

R. M. Krich
Printed Name

Vice President, Licensing, Safety
Title & Nuclear Engineering


Scribed and sworn before me on this 20th day of April, 2004.

My authorization as a notary of the State of District of Columbia expires on the 31st day of July, 2007.


Notary's Signature

4/20/04
Date

Elizabeth A. Kenney
Notary's Printed Name



Class 1 Wilderness Areas:

1. Wheeler Peak
2. San Pedro Parks
3. Bandelier
4. Pecos
5. Gila
6. Bosque del Apache
7. White Mountain
8. Salt Creek
9. Carlsbad Caverns N. P.

Meteorological Stations:
indicated by | | |





Figure 1.0

ATTACHMENT A

Process Flow Diagrams



BLACKWOOD ENGINEERING
ENGINEERING & CONSTRUCTION
Quality, All Years

REFERENCE NUMBER
0000R1002.dwg




ATTACHMENT A
NEF PROCESS BLOCK DIAGRAM
NM AIR QUALITY NOTICE OF INTENT

AIR HANDLING UNITS
 CAPACITY:
 HEATING: 63 KW/EA
 (213,000 BTU/EA)
 COOLING: 37 KW/EA
 (10.5 TONS/EA)
 NUMBER OF UNITS: (2 TOTAL)
 (2 ACTIVE)

SUPPLY FANS
 CAPACITY: 11,129 M³/HR/EA
 (6,550 CFM/EA)
 NUMBER OF FANS: (2 TOTAL)
 (2 ACTIVE)

FILTRATION UNITS
 CAPACITY: 11,129 M³/HR/EA
 (6,550 CFM/EA)
 NUMBER OF UNITS: (2 TOTAL)
 (2 ACTIVE)

FILTRATION EXHAUST FANS
 CAPACITY: 22,257 M³/HR/EA
 (13,100 CFM/EA)
 NUMBER OF FANS: (2 TOTAL)
 (1 ACTIVE 1 STANDBY)



FRAMATOME ANP, INC
 02-5034019B-03


NO.	DATE	DESCRIPTION
1	10/1/88	ISSUED FOR PERMITTING
2	10/1/88	ISSUED FOR CONSTRUCTION
3	10/1/88	ISSUED FOR OPERATION
4	10/1/88	ISSUED FOR MAINTENANCE
5	10/1/88	ISSUED FOR REVISION

LOCKWOOD GREENE
 ENGINEERING & CONSTRUCTION
 Spartanburg, South Carolina

FLOW DIAGRAM
 TSB CONTAMINATION WORKSHOPS
 HVAC SYSTEM

LOUISIANA ENERGY SERVICES

REV.	DATE	DESCRIPTION
NONE	1500-M-1001	



FRAMATOME ANP, INC
02-5034015B-01

NO.	DESCRIPTION	DATE	BY


LOCKWOOD GREENE
A. A. JAMES COMPANY
ENGINEERING & CONSTRUCTION
Springfield, South Carolina

PPD
GEYS
TECHNICAL SERVICES BUILDING

LOUISIANA ENERGY SERVICES

NO.	DESCRIPTION	DATE	BY

PACKAGE BOUNDARY - TO BE SUPPLIED BY OTHERS



FRAMATOME ANP, INC
02-5034016B-03

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION


LOCKWOOD GREENE
ENGINEERING & CONSTRUCTION
Spartanburg, South Carolina

GEVS
TECHNICAL SERVICES BUILDING

LOUISIANA ENERGY SERVICES

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION

PACKAGE BOUNDARY - TO BE SUPPLIED BY OTHERS



GEYS SEPARATION/BLEND & SAMPLE
0064-N-1500

FRAMATOME ANP, INC
02-5034013B-01

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION

LOCKWOOD GREENE
A J.A. JONES COMPANY
ENGINEERING & CONSTRUCTION
Charlotte, North Carolina

GEYS-SEPARATION/BLEND & SAMPLE





LOUISIANA ENERGY SERVICES

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION

ATTACHMENT B

**Detailed Plot Plan
&
NEF Site Buildings
(from Attachment G)**





HATCHED AREAS INDICATE HAZARDOUS WASTE STORAGE AREAS.

LEGEND:

- | | | |
|--|---|-----------------------------------|
| 1. URANIUM BYPRODUCT CYLINDERS (UBC) STORAGE PAD | 10. URANIUM HEXAFLUORIDE (UF ₆) HANDLING AREA | 19. ADMINISTRATION BUILDING |
| 2. LIQUID NITROGEN (N ₂) TANK NO. 4 | 11. LIQUID N ₂ TANK NO. 3 | 20. VISITOR CENTER |
| 3. CENTRIFUGE ASSEMBLY BLDG. | 12. LIQUID N ₂ TANK NO. 2 | 21. EMPLOYEE PARKING |
| 4. CASCADE HALLS 1&2 | 13. UBC STORAGE PAD STORMWATER RETENTION BASIN | 22. SECURITY BLDG. |
| 5. CASCADE HALLS 3&4 | 14. SITE STORMWATER DETENTION BASIN | 23. GUARD HOUSE |
| 6. CASCADE HALLS 5&6 | 15. TREATED EFFLUENT EVAPORATIVE BASIN | 24. CENTRAL UTILITIES BLDG. (CUB) |
| 7. CYLINDER RECEIPT & DISPATCH BLDG. | 16. LIQUID N ₂ TANK NO. 1 | 25. METEOROLOGICAL TOWER |
| 8. BLENDING & LIQUID SAMPLING AREA | 17. COOLING TOWER | |
| 9. TECHNICAL SERVICES BLDG. (TSB) | 18. ELECTRICAL SWITCH GEAR | |



Scale: FEET



Scale: METERS



NORTH



REFERENCE NUMBER
600002.dwg



FIGURE G-1
NEF SITE BUILDING

ATTACHMENT C

Calculations to Support Emission Rates

Attachment C

Calculations to Support Emission Rates

1.0 PURPOSE

This attachment describes how the emission rates were calculated in Part IV of the Notice of Intent. Supporting information used in the calculations is located in Attachment D.

2.0 SCOPE

The calculations support the emission rates of the following tables in Part IV of the NOI application:

- Table IV-A: Unit Emission Rates
- Table IV-B: Stack Exit and Fugitive Emission (PTE) Rates for Pollutants and Stack Exit Conditions
- Table IV-C: Stack Exit Emission Rates for HAPs and TAPs

3.0 CALCULATIONS

The calculations performed were for five air emission sources:

- Hot Water Boilers (Unit Nos. 2 and 3)
- Emergency Diesel Generators (Unit Nos. 4 and 5)
- Diesel Fuel Tanks (Unit Nos. 10a and 10b)
- Technical Service Building Gaseous Effluent Vent System (TSB GEVS) - Unit No. 12
- Separations Building Gaseous Effluent Vent System (SB GEVS) - Unit No. 13

Attachment G describes the basic components and functional requirements of each source.

A calculation was also performed for fugitive emissions, but five other air emission sources did not require a calculation. Two of these air sources, the Technical Services Building Confinement Vent System and the CAB Centrifuge Test Post Mortem Facilities Exhaust Filtration System (referenced in Table III-A as Unit Nos. 1, 11) release trace amounts uranium and hydrogen fluoride. Trace is defined as not distinguishable from background levels. The other three air sources include the site basins, referenced in Table III-A as Unit Nos. B1 through B3. The basins dispose of their liquid effluent through evaporation, which in the case of Unit No. B-1 includes trace amounts of cooling tower additives.

The emission rate for each air source calculated is discussed below. The method used to calculate the emission rate depended on the information source. The hot water boilers, for instance, used the manufacture's calculations as the emission rates. The diesel

Attachment C (continued)

generators, on the other hand, used the manufacture's data as input and a spreadsheet to calculate the emission rates. The fuel tanks also used manufacture's data as input, but the U.S. EPA software program TANKS to calculate the emission rate. The TSB and SB GEVS as well as fugitive emissions used internal input data and a spreadsheet to calculate the emission rates.

3.1 Hot Water Boilers

There are two Hot Water Boilers, which are referenced as Units No. 2 and No. 3 in Table III-A. The two boilers are manufactured by Superior Boiler Works, Inc. Each is fired by natural gas and has a capacity of 300 HP. One of the boilers is a backup, standby unit.

The emission rates come from the calculation performed by W.C. Rouse & Son, Inc., the boiler sales and equipment company (see the four-page fax in Attachment D). W.C. Rouse & Son calculated the emission rate for the maximum boiler load, although the actual load will be considerably less. The W.C. Rouse & Son values were initially in pounds per million BTUs and then converted to pounds per hour (lb/hr) by applying a factor of 300 HP equals approximately 12.6 million BTU per hour, which yielded the following values as shown on page 2 and 4 of the fax in Attachment D:

Emission Parameter	Rate (lb/million BTU)	Conversion Factor (million BTU/hr)	Rate* (lb/hr)
Particulate Mater (PM)	0	12.6	0
Carbon Monoxide (CO)	.01	12.6	0.126
Nitrogen Oxides (NOx)	.10	12.6	1.26
Sulfur Oxides (SOx)	0	12.6	0
Hydrocarbons (as VOC)	.016	12.6	0.2016

* Column 2 multiplied by Column 3

Chart 2 on page 3 of the fax in Attachment D is used to calculate flue gas flow rate and is not relevant to the emission rates.

LES multiplied the above column four emission rates in lb/hr by 8,760 hr/yr to get lb/yr and then divided by 2,000 lbs/ton to get tons/year using an internally developed spreadsheet (see Table C-1). The resultant values were then entered into Table IV-A as the Potential Emission Rate (PER). The same values were used as the Potential to Emit (PTE) and entered into Table IV-B as well because the boilers will not have any pollution control device.

3.2 Emergency Diesel Generators

There are two Emergency Diesel Generators, which are referenced as Units No. 4 and No. 5 in Table III-A. Both emergency generators use a Caterpillar model engine, each with a 1500 kW capacity. The generators will be for emergency use only and each is

Attachment C (continued)

limited to a maximum annual use of 300 hours, but not simultaneously. LES is presently evaluating other smaller standby diesel generators to provide backup power to some specific systems. The number and size are not defined at this time. None of these generators will have pollution control devices, but will be limited to an annual maximum 300 hours of operation.

LES calculated the emission rate using the manufacture's data as input and an internally developed spreadsheet (see Table C-2). Note that particulate matter (PM) was conservatively assumed to equal the PM10. Likewise, the Total Suspended Particulates (TSP) was assumed to equal the PM as a worst case.

The Table C-2 spreadsheet values were entered into Table IV-A as the Potential Emission Rate (PER). The same values were used as the Potential to Emit (PTE) and entered into Table IV-B as well because the generators will not have any pollution control device and will be restricted to an annual maximum 300 hours of operation.

3.3 Diesel Fuel Tanks

There are two, 6,000-gallon above ground fuel tanks. They are referenced as Units 10a and 10b in Table III-A. The fuel type will be Number 2 diesel, with a maximum annual throughput of 31,200 gallons for each tank, or 62,400 gallons for both tanks.

LES calculated the emission rate using the manufacture's data as input (see Table VI-B and Attachment D) and the U.S. EPA software program TANKS (see Exhibit C-1). If TANKS input data were not readily available, the TANKS default values were used.

The only emission from the fuel tanks is Volatile Organic Chemicals (VOC) because there is no fuel combustion. From the TANKS output (see Exhibit C-1), the total annual VOC emission for one tank is 4.38 lb/yr. For both tanks, the total is 8.76 lb/yr, which converts to 1.00×10^{-3} lb/hr (8.76/8760) and 4.38×10^{-3} ton/yr (8.76/2,000). These values were entered into Table IV-A as the Potential Emission Rate (PER). The same values were used as the Potential to Emit (PTE) and entered into Table IV-B as well because the tanks will not have any pollution control device.

3.4 TSB GEVS

The Technical Service Building Gaseous Effluent Vent System (TSB GEVS) is referenced as Unit 12 in Table III-A. The TSB GEVS is designed to remove the toxic air pollutants (TAPs) uranium and hydrogen fluoride from the exhaust system.

LES used internal input data and an internally developed spreadsheet to calculate the emission rate. The emission rate for each TAP was first calculated with controls because of ready available information (see Attachment D, ER Tables 3.12-1 and 3.12-3) and then without controls. Spreadsheet Table C-3 shows the results.

Attachment C (continued)

With controls, the annual total for uranium and hydrogen fluoride released is 10 grams and 1 kg, respectively. The values are the Potential to Emit (PTE) and are directly from ER Table 3.12-3.

Without controls, the estimated annual uranium released is 32.7 grams. This value is the Potential Emission Rate (PER) and comes from ER Table 3.12-1. It is based on the total weight of uranium contained in the filter media for activated carbon and alumina plus the ventilation filter ($25+2.2+5.5=32.7$). Also from ER Table 3.12-1, the total weight in a year of activated alumina used to trap hydrogen fluoride is 2,160 kg. From internal operational experience, each gram of alumina traps approximately 0.15 grams of hydrogen fluoride. Therefore, without controls, the annual release of hydrogen fluoride would be 324 kg (2160×0.15) and may be considered the Potential Emission Rate (PER) value.

The above values were then adjusted to account for the TSB GEVS percent distribution of emissions for each TAP based on total plant flow, converted to appropriate units, and entered into Table IV-C. Spreadsheet Table C-3 shows the results.

3.5 SB GEVS

The Separations Building Gaseous Effluent Vent System (SB GEVS) is referenced as Unit 13 in Table III-A. The SB GEVS, like the TSB GEVS, is designed to protect workers from uranium and hydrogen fluoride exposure.

Also, like the TAB GEVS, LES used the same internal input data and an internally developed spreadsheet to calculate the emission rate (see Table C-3). The methodology is the same, only the adjusted percent distribution due to flow is different.

3.6 Fugitive Emissions

Fugitive emissions comprise volatile organic chemicals (VOCs) emitted during routine plant maintenance. They are referenced in Table IV-B as "F" in the Stack No. column.

The principal chemicals used during maintenance are Ethanol (ethyl alcohol) and Methylene Chloride. From ER Table 3.12-3, the annual use of Ethanol is 10.6 gallons and 161 gallons of Methylene Chloride. Accounting for each chemical's specific gravity and converting from gallons to pounds, the annual use of each chemical is 81 lbs. and 1801 lbs., respectively, for a VOC total of 1882 lbs. (see Table C-4).

The fugitive emission rate for VOCs, from spreadsheet Table C-4, is 0.21 lb/hr ($1882/8760$), or 0.94 tons/yr ($1882/2000$). These values were entered into Table IV-B as the Potential Emission Rate (PER) because there are no controls when performing routine maintenance using Ethanol and Methylene Chloride.

Attachment C (continued)

Table C-1
Hot Water Boilers Emissions Spreadsheet

EMISSION CALCULATIONS FOR HOT WATER BOILERS

	A	B	C	D	E	F
1						
2	Manufacturer's Emission Data					
3	W.C. Rouch & Sons, Inc. Fax dated 2-12-04					
4						
5	Emission	NOx	CO	HC (VOC)	PM	SOx
6						
7	lb/yr	1.26	0.126	0.2016	0	0
8						
9	tons/yr	=B7*8760/2000	=C7*8760/2000	=D7*8760/2000	=E7*8760/2000	=F7*8760/2000
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						

Attachment C (continued)

Table C-2
Emergency Generator Emissions Spreadsheet

EMISSION CALCULATIONS FOR DIESEL GENERATORS

	A	B	C	D	E	F	G	H	I	J
1										
2	Manufacturer's Emission Data									
3	Caterpillar Technical Data, CAT 3512 TA Diesel Engine									
4										
5	Emission	NOx	CO	HC	PM	TSP		(Note 1)		
6										
7	g/hp-hr	8.42	0.65	0.20	0.075	0.075				
8										
9	Number of Hours per Year Each Generator is Operated =						300		(Note 2)	
10	Horsepower of Each Generator =				2198			(Note 3)		
11										
12	lb/hr	40.76	3.15	0.97	0.36	0.36				
13										
14	tons/yr	12.23	0.94	0.29	0.11	0.11		(Note 4)		
15										
16										
17	Note 1: HC includes VOCs; PM is all Particulate Matter, including PM10; and TSP is assumed to equal PM as a worst case.									
18	Note 2: Per C. Funk e-mail, dated 4/15/04.									
19	Note 3: Each generator is operated <300 hours per year, but not simultaneously.									
20	Note 4: Based on a total annual operating time of 600 hours combined for both generators.									

EMISSION CALCULATIONS FOR DIESEL GENERATORS

	A	B	C	D	E	F	G	H	I	J
1										
2	Manufacturer's Emission Data									
3	Caterpillar Technical Data, CAT 3512 TA Diesel Engine									
4										
5	Emission	NOx	CO	HC	PM	TSP		(Note 1)		
6										
7	g/hp-hr	8.42	0.65	0.2	0.075	0.075				
8										
9	Number of Hours per Year Each Generator is Operated =						300	(Note 2)		
10	Horsepower of Each Generator =				2188			(Note 3)		
11										
12	lb/hr	=B7*E10/454	=C7*E10/454	=D7*E10/454	=E7*E10/454	=F7*E10/454				
13										
14	tons/yr	=B12*2*G9/2000	=C12*2*G9/2000	=D12*2*G9/2000	=E12*2*G9/2000	=F12*2*G9/2000		(Note 4)		
15										
16										
17	Note 1: HC includes VOCs; PM is all Particulate Matter, including PM10; and TSP is assumed to equal PM as a worst case.									
18	Note 2: Per C. Funk e-mail, dated 4/15/04.									
19	Note 3: Each generator is operated <300 hours per year, but not simultaneously.									
20	Note 4: Based on a total annual operating time of 600 hours combined for both generators.									

Attachment C (continued)

Table C-3
TBS and SB GEVS Emission Spreadsheet

Attachment C (continued)

Table C-4
Fugitive Emission Spreadsheet

	A	B	C	D	E	F	G
1							
2			Fugitive Emission Data				
3							
4	Chemical	Ethanol		M. Chloride		Totals	
5							
6	gal/yr	10.6		161.0		171.6	(Note 1)
7							
8	sp. gr.	0.915		1.335			(Note 2)
9							
10	lb/yr	81.3		1801.2		1882.4	(Note 3)
11							
12	lb/hr	0.009		0.206		0.21	
13							
14	tons/yr	0.041		0.901		0.94	
15							
16							
17	Note 1: From ER Table 3.12-3.						
18	Note 2: From The Condensed Chemical Dictionary, 9th Ed.						
19	Note 3: Using 1 gallon equivalent to 8.38 lbs.						

	A	B	C	D	E	F	G
1							
2			Fugitive Emission D				
3							
4	Chemical	Ethanol		M. Chloride		Totals	
5							
6	gal/yr	10.6		161		=B6+D6	(Note 1)
7							
8	sp. gr.	0.915		1.335			(Note 2)
9							
10	lb/yr	=B6*B8*8.38		=D6*D8*8.38		=B10+D10	(Note 3)
11							
12	lb/hr	=B10/8760		=D10/8760		=B12+D12	
13							
14	tons/yr	=B10/2000		=D10/2000		=B14+D14	
15							
16							
17	Note 1: From ER Table 3.12-3.						
18	Note 2: From The Condensed Chemical Dictionary, 8th Ed.						
19	Note 3: Using 1 gallon equivalent to 8.38 lbs.						

Attachment C (continued)

Exhibit C-1
TANKS Emission Report

TANKS 4.0
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: TANK 10A
City: Eunice
State: New Mexico
Company: LES
Type of Tank: Horizontal Tank
Description: Horizontal, fixed roof tank
5.3 m long by 2.4 m wide by 2.7
m high
22.7 m3 capacity

Tank Dimensions

Shell Length (ft): 17.38
Diameter (ft): 7.87
Volume (gallons): 5,200.00
Turnovers: 6.00
Net Throughput (gal/yr): 31,200.00
Is Tank Heated (y/n): N
Is Tank Underground (y/n): N

Paint Characteristics

Shell Color/Shade: Gray/Light
Shell Condition: Good

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Midland-Odessa, Texas (Avg Atmospheric Pressure = 13.28 psia)

TANKS 4.0
Emissions Report - Detail Format
Liquid Contents of Storage Tank

Mixture/Component	Month	Daily Liquid Surf. Temperatures (deg F)			Liquid Bulk Temp. (deg F)	Vapor Pressures (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	All	71.74	60.33	83.15	65.62	0.0095	0.0066	0.0135	130.0000			166.00	Option 5: A=12.101, B=6907

TANKS 4.0

Emissions Report - Detail Format

Detail Calculations (AP-42)

Annual Emission Calculations	
Standing Losses (lb):	3.4654
Vapor Space Volume (cu ft):	538.5047
Vapor Density (lb/cu ft):	0.0002
Vapor Space Expansion Factor:	0.0619
Vented Vapor Saturation Factor:	0.9990
Tank Vapor Space Volume	
Vapor Space Volume (cu ft):	538.5047
Tank Diameter (ft):	7.8700
Effective Diameter (ft):	13.2001
Vapor Space Outage (ft):	3.9350
Tank Shell Length (ft):	17.3900
Vapor Density	
Vapor Density (lb/cu ft):	0.0002
Vapor Molecular Weight (lb/lb-mole):	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0095
Daily Avg. Liquid Surface Temp. (deg. R):	531.4068
Daily Average Ambient Temp. (deg. F):	63.2750
Ideal Gas Constant R (psia cuft / (lb-mol-deg R)):	10.731
Liquid Bulk Temperature (deg. R):	525.1850
Tank Paint Solar Absorptance (Shell):	0.5400
Daily Total Solar Insulation Factor (Btu/sqft day):	1,689.4692
Vapor Space Expansion Factor	
Vapor Space Expansion Factor:	0.0619
Daily Vapor Temperature Range (deg. R):	45.6331
Daily Vapor Pressure Range (psia):	0.0069
Breather Vent Press. Setting Range (psia):	0.0500
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0095
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.0066
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	0.0135
Daily Avg. Liquid Surface Temp. (deg R):	531.4068
Daily Min. Liquid Surface Temp. (deg R):	519.9965
Daily Max. Liquid Surface Temp. (deg R):	542.6150
Daily Ambient Temp. Range (deg. R):	27.9000
Vented Vapor Saturation Factor	
Vented Vapor Saturation Factor:	0.9990
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0095
Vapor Space Outage (ft):	3.9350
Working Losses (lb):	
Working Losses (lb):	0.8140
Vapor Molecular Weight (lb/lb-mole):	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0095
Annual Net Throughput (gal/yr.):	31,200.0000
Annual Turnovers:	6.0000
Turnover Factor:	1.0000
Tank Diameter (ft):	7.8700

TANKS 4.0
Emissions Report - Detail Format
Detail Calculations (AP-42)- (Continued)

Working Loss Product Factor: 1.0000

Total Losses (lb): 4.3794

TANKS 4.0
Emissions Report - Detail Format
Individual Tank Emission Totals

Annual Emissions Report

Components	Losses(lbs)		Total Emissions
	Working Loss	Breathing Loss	
Distillate fuel oil no. 2	0.91	3.47	4.38

ATTACHMENT D

Information Used to Determine Emissions

ATTACHMENT D (continued)

**Information Used to Determine Emissions
for
Hot Water Boilers**

W.C. ROUSE & SON, INC. BOILER ROOM EQUIPMENT AND SERVICES P.O. BOX 19046 GREENSBORO, NC 27419 110 LONGALE ST.-27409 (336)-299-8035 FAX: (336)-299-9896	<h1>FAX PAGE</h1>
---	-------------------

TO: <i>L.G.</i> <i>CHRIS FUNK</i>	FROM: <i>F.A.</i>
---	--------------------------

ATTN:	DATE: <i>2-12-04</i>
--------------	-----------------------------

FAX: <i>864 599 8317</i>	PAGES INCLUDING COVER:
---------------------------------	-------------------------------

SUBJECT: <i>300 HP</i> <i>EMISSIONS</i>

Churn. If required, a low rise burner design can be provided at extra cost if desired.

RATE IS 25% TO 75% OF THIS AMOUNT OR LESS.

NATURAL FIRING GAS

USUALLY ADJUST TO 0

PARTICULATE MATTER	0	0
CO	01 lbs/min x 12.6	0.126 16/hr
NOx - STANDARD BURNER	10 lbs/min x 12.6	1.24 16/hr
SOx	0	0
CO ₂	115 lbs/min x 12.6	1449 16/hr
HYDROCARBONS (VOC)	016 lbs/min x 12.6	.2016 16/hr

FIRING OIL

Does not Apply

PARTICULATE MATTER	0.5 lbs/min x 12.6	0.378 16/hr
CARBON MONOXIDE	0	0
NOx	20 lbs/min x 12.6	2.52 16/hr
SOx	$\frac{10,000,000}{1,000,000} \times 7.0 \frac{\text{lb}}{\text{MMBTU}} \times \frac{0.11 \text{ sulfur}}{100} \times 2 = 15.4 \%$	15.4% Sulfur
CO ₂	160 lbs/min x 12.6	2016 16/hr
HYDROCARBONS	0.29 lbs/min x 12.6	0.3654 16/hr
LEAD		0

GAS OUTLET TEMPERATURE MAX 420 OIL OR GAS

$\pi \left(\frac{10}{12}\right)^2$


STACK OUTLET SIZE 20" DIA = 2.18 SQ. FT.

FLUE GAS @ MAX. FIRING RATE = 4560 CFM

STACK VELOCITY 4560 / 2.18 = 2092 FPM MAX

CHART 2. — EXHAUST GAS VOLUMES FOR TYPICAL BOILER OPERATING CONDITION

STACK CALCULATIONS:



1520
4000

$$1520 / 100 \text{ HP} \times 3 = 4560$$

$$\text{FLOWRATE, } \frac{\text{CFM}}{\text{min}} \left(\frac{\text{E}^3}{\text{min}} \right) = \text{AREA (F}^2) \times \text{VELOCITY } \left(\frac{\text{F}}{\text{MIN}} \right)$$

$$\therefore \text{VEL} = \frac{\text{CFM}}{\text{AREA}}$$




SUPER SEMINOLE

DIMENSIONAL DATA
STEAM BOILERS
15 AND 150 PSIG

3 PASS WET BACK

70 THRU 1000 BoHP

5 SQ. FT. / BoHP



FORM CAT#382P
REVISED: 9-21-65

NOMINAL BOILER HORSEPOWER	70	80	100	125	150	200	250	300	350	400	500	600	700	750	800	900	1000	
UNIT MODEL NUMBER	250	400	600	825	750	1000	1250	1600	1750	2000	2500	3000	3500	3750	4000	4500	6000	
LENGTHS: Overall	A	154	171	187	193	205	210	241	270	278	283	305	301	297	305	318	324	343
Shell	B	124	137	148	148	170	180	191	220	228	211	253	248 1/2	244	252	258	282	281
Base	C	116	128	164	136 1/2	153 1/2	160	181	220	224	208	250	247 1/2	236	244	258	283	282
Front Plate To																		
Front Side Extension	D	28	28	28	28	28	40	40	40	40	40	40	40	40	40	40	40	40
Rear Plate To																		
Center Line Of Stack	E	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
Front Of Base To																		
End Of Burner	F																	
(GP).....				8	8	8	8									15	12	
(GC).....				15	15	11	11	12	12	15	20	23						
Front Plate To																		
Nozzle	G	43	43	47	47	52	52	52	53	53	57	74	64	64	64	64	64	64
WIDTHS: Overall	H	73	73	73	80	80	80	80	86	107	107	113	124	124	124	130	130	
Centerline To																		
Lagging	I	23	23	23	26 1/2	26 1/2	41 1/2	41 1/2	41 1/2	41 1/2	60	60	63	67	67	67	61	61
Water Column/Panel	J	40	40	40	43 1/2	43 1/2	48 1/2	48 1/2	48 1/2	61	67	67	67	67	67	67	60	60
Over Jacket	K	68	68	68	73	73	83	83	83	80	100	106	114	114	114	122	122	122
Base Width Outside	L	80	80	80	80 1/2	80 1/2	85 1/2	85 1/2	85 1/2	70 1/2	80	87	87	87	87	87	87	87
Base Width Inside	M	42	42	42	42 1/2	42 1/2	47 1/2	47 1/2	47 1/2	70	70	77	77	77	77	77	77	77
HEIGHTS: Overall	N	85	85	85	82	82	102	102	108	118	118	125	133	133	133	141	141	
Centerline of Burner	N1	34	34	34	35 1/2	35 1/2	39	39	40	43	43	45	45	45	45	50	50	
Centerline of Boiler	N2	45	45	45	48 1/2	48 1/2	53 1/2	53 1/2	53 1/2	62	62	65	69	69	69	75	75	
Top of Steam Nozzle	N3	78 1/2	78 1/2	80 1/2	80 1/2	80 1/2	89 1/2	89 1/2	89 1/2	105 1/2	118 1/2	118 1/2	122 1/2	130 1/2	130 1/2	130 1/2	140 1/2	140 1/2
Base to Stack Outlet	O	61 1/2	61 1/2	61 1/2	60	60	69	69	69	105	116	116	122	130	130	140	140	
Base to Lagging	P	12	12	12	12	12	12	12	12	12	12	12	12	12	12	14	14	
Height of Runner	Q	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	
CONNECTIONS:																		
Feedwater-Right/Left	R	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2	2	
Auxiliary Conn-Right/Top	S	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Surface Blowoff-Right	T	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
Auxiliary Conn-Top	U	1 1/2	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2	2	2	2	
Low Fire Hook-Left Side	U1	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
Flanged Stack Conn LD.	V	15 1/2	15 1/2	15 1/2	17 1/2	17 1/2	18 1/2	18 1/2	18 1/2	23 1/2	23 1/2	23 1/2	25 1/2	25 1/2	25 1/2	25 1/2	25 1/2	
HIGH PRESSURE																		
Steam Nozzle	W	3	3	4 1/2	4 1/2	4 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	6 1/2	
Blowdown Front	X						1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
Blowdown Rear	Y	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
LOW PRESSURE																		
Steam Nozzle	W	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	6"	
Blowdown Front	X						2	2	2	2	2	2	2	2	2	2	2	
Blowdown Rear	Y	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	2	2	2	2	2	2	2	2	2	2	2	
ACCESS OPENINGS:																		
Handhole 2" x 4"	Z	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	
Manway 12" x 18"	ZZ	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
MINIMUM CLEARANCES**																		
Tube Removal Front	TF	60 1/2	103 1/2	129 1/2	114 1/2	138 1/2	123 1/2	164 1/2	193 1/2	193 1/2	198 1/2	210 1/2	203 1/2	196 1/2	204 1/2	230 1/2	214 1/2	
Rear Door Swing Rear	DR	94	94	94	98	98	98	98	98	98	98	98	98	98	98	98	98	

NOTE: * 150 PSIG RF FLANGE
† 300 PSIG RF FLANGE

NOTE: All Dimensions Are Approximate And May Be Used For Layout Only.
SUPERIOR BOILER WORKS, Inc Reserves The Right To Change
Dimensions Due To Product Revisions Or Job Requirements.
** Check Local, State And Federal Code.

SUPER SEMINOLE 3 PASS STEAM BOILER



FORM 007/2000
REVISED 0-01-00

RATINGS: STEAM 15/150 PSIG

Sea Level To 2000'

5 sq.ft./BoHP

NOMINAL BOILER HORSEPOWER	70	80	100	125	150	200	250	300	350	400	500	600	700	750	800	900	1000
UNIT MODEL NUMBER	350	400	500	625	750	1000	1250	1500	1750	2000	2500	3000	3500	3750	4000	4500	5000
OUTPUT MBH	2343	2678	3348	4184	5021	6695	8369	10043	11716	13390	16738	20065	23433	25106	26780	30128	33475
STEAM 150 PSIG (lb)	2415	2760	3450	4312	5175	6900	8625	10350	12075	13800	17250	20700	24150	25875	27600	31050	34500
INPUT GAS (1000 BTU) CU. FT.	2829	3348	4184	5230	6276	8369	10461	12553	14645	16738	20922	25106	29291	31383	33475	37659	41844
OIL (140,000 BTU) GAL.	20.91	23.91	29.68	37.55	44.83	59.77	74.72	89.66	104.60	119.55	149.44	179.33	209.21	224.16	239.10	269.00	298.88
OIL (180,000 BTU) GAL.	19.52	22.51	27.89	34.86	41.83	55.78	69.73	83.68	97.62	111.57	139.47	167.37	195.26	209.21	223.16	251.06	278.95

DATA:

HEATING SURFACE SQ. FT.	304	412	510	643	785	1022	1262	1525	1765	2019	2517	3017	3548	3783	4040	4541	5040
FURNACE VOLUME CU. FT. (M)	18.83	22.51	29.68	34.28	42.39	52.18	63.61	84.57	95.32	115.17	143.70	171.45	183.78	192.05	208.57	238.99	259.82
STEAM STORAGE VOL. CU. FT.	13.21	14.96	18.44	20.64	24.94	27.98	34.53	40.68	49.04	70.17	88.59	102.84	124.10	128.81	137.07	151.43	164.02
DISENGAGING AREA SQ. FT.	28.18	31.90	39.53	39.21	48.25	48.01	59.24	69.75	78.57	84.50	104.27	109.99	118.16	122.65	130.51	138.78	148.16
WATER CAPACITY MIN. GAL.	655	757	962	1047	1251	1381	1739	2074	2494	2783	3486	3607	4153	4269	4579	5245	5884
WATER WEIGHT MIN. LBS.	8447	6297	7998	8710	10408	11485	14482	17247	20747	23149	28998	30000	34545	35673	38090	43629	47111
WATER CAPACITY FULL GAL.	754	869	1100	1202	1433	1590	1997	2378	2861	3308	4134	4375	5081	5252	5605	6378	6891
WATER WEIGHT FULL LBS.	6269	7228	9148	8994	11921	13227	16811	19777	23799	27515	34385	36388	42268	43688	46618	53051	57316
SHIPPING WEIGHT 15 PSIG (M)	8400	9100	10400	11500	12900	17500	20300	23000	25800	29200	35300	39200	43100	44900	47200	51700	55800
SHIPPING WEIGHT 150 PSIG (M)	9300	10000	11300	12800	14200	19400	22300	24900	28700	33200	38500	42800	46600	48300	50700	60400	65200

STANDARD FEATURES:

- Units Designed And Fabricated To ASME Boiler And Pressure Vessel Code Requirements, Section IV-15 pdg, Section I-150 pdg Thru 250 pdg.
- Insulated With 2"-8 Lb. Density Mineral Fiber Insulation.
- Jacket Material 22 Gauge Galvanized-Phosphate Coated Steel.
- Devilbiss Doors Front / Rear-All Units.
- Flue Access Plug: 17" Dia., All Units.
- Manholes: 3" x 4" (5) All Units.
- Manway: 12" x 18" (1) All Units.
- Surface Blowdown Connections.
- Section I Boilers: Completed Furnace

STANDARD TRIM (BOILER)

- ASME Safety Valve(s).
- Water Column w/Water Level Gauge Glass, Try Cocks (As Req'd), Low Water Cutoff/Pump Control, Blowdown Valve.
- Operating Pressure Control
- High Limit Pressure Control (Manual Reset).
- Firing Rate Control (PH-Lo-Off Or Modulating Firing Only).
- Pressure Gauge w/Shutdown And Inspectors Gauge Cocks.
- Control Circuit Terminal Strips.
- Accoflow Low Water Cutoff, Probe In Shell.

Notes:

- All Units Manufactured To UL Listing Procedures.
- Steam Output Based On Steam From And At 212°F.
- Furnace Volume Is Furnace Only (Wet Backed Turnaround Not Included).
- Shipping Weights Are Based On Units With Natural Gas Burners-Weights Of Units For Air Atomized Oil Or Combination Gas/Oil Firing Will Be Higher.

ATTACHMENT D (continued)

**Information Used to Determine Emissions
for
Diesel Generators**

CATERPILLAR®

DIESEL GENERATOR SET

Attachment C (2/11)




Image shown may not reflect actual package.

STANDBY
1500 kW 1875 kVA
60 Hz 1800 rpm 480 Volts

Caterpillar is leading the power generation marketplace with Power Solutions engineered to deliver unmatched flexibility, expandability, reliability, and cost-effectiveness.

FEATURES

EMISSIONS

- EPA and CARB Emissions Certified for non-road mobile applications
UL 2200
- UL 2200 Listed configuration available
- FULL RANGE OF ATTACHMENTS**
- Wide range of bolt-on system expansion attachments, factory designed and tested
- ENCLOSURES (optional)**
- Weather protective and sound attenuated
- SINGLE-SOURCE SUPPLIER**
- Fully prototype tested with certified torsional vibration analysis available
- WORLDWIDE PRODUCT SUPPORT**
- Caterpillar® dealers provide extensive post sale support including maintenance and repair agreements
- Caterpillar dealers fill 99.7% of parts orders within 24 hours
- Caterpillar dealers have over 1,844 dealer branch stores operating in 166 countries
- The Cat Scheduled Oil Sampling (S-O-S™) program cost effectively detects internal engine component condition, even the presence of unwanted fluids and combustion by-products

CAT 3512B TA DIESEL ENGINE

- Reliable, rugged, durable design
- Field-proven in thousands of applications worldwide
- Four-stroke-cycle diesel engine combines consistent performance and excellent fuel economy with minimum weight
- UL 2200 Listed packages are available. Certain restrictions may apply. Consult with your Caterpillar dealer

CAT SR4B GENERATOR

- Matched to the performance and output characteristics of Caterpillar engines
- Optimum winding pitch for minimum total harmonic distortion and maximum efficiency
- Single point access to accessory connections
- UL 1446 recognized Class H insulation

CAT CONTROL PANELS

- Controls designed to meet individual customer needs:
 - EMCP II+ offers full-featured power metering and protective relaying
- UL 508A Listed

[Handwritten signature]



WHERE THE WORLD TURNS FOR POWER



Attachment c(3/11)

STANDBY 1500 eKW 1875 kVA

60 Hz 1800 rpm 480 Volts

FACTORY INSTALLED STANDARD & OPTIONAL EQUIPMENT

System	Standard	Optional
Air Inlet	<ul style="list-style-type: none"> • Single element canister type air cleaner • Service Indicator 	<ul style="list-style-type: none"> • Dual element & heavy duty air cleaners • Air Inlet adapters & shutoff
Cooling	<ul style="list-style-type: none"> • Radiator with guard (43°C) • Coolant drain line with valve • Fan and belt guards • Caterpillar Extended Life Coolant* *Not included with packages without radiators 	<ul style="list-style-type: none"> • Radiator with 60°C ambient capability • Radiator removal • Heat exchanger and expansion tank • Radiator duct flange • Coolant level switch gauge • Jacket water heater
Exhaust	<ul style="list-style-type: none"> • Dry exhaust manifold • Flanged faced outlets 	<ul style="list-style-type: none"> • Mufflers (15 dba) • Stainless steel exhaust flex fittings • Elbows, flanges, expanders & Y adapters
Fuel	<ul style="list-style-type: none"> • Secondary fuel filters • Fuel priming pump • Flexible fuel lines • Fuel cooler* *Not included with packages without radiators 	<ul style="list-style-type: none"> • Water separator • Duplex fuel filter
Generator	<ul style="list-style-type: none"> • Permanent magnet excited • Class H Insulation • Class F temperature (105°C prime/130°C standby) • Reactive droop • Digital Voltage Regulator, 3-phase sensing • Bus bar connections • Winding temperature detectors • Anti-condensation space heaters 	<ul style="list-style-type: none"> • Digital Voltage Regulator with KVAR/PF control • Bearing temperature detectors • Oversize, premium & self-excited generators • Cable access box • European bus bars • Circuit breakers, UL listed, 3 pole with shunt trip (low & medium voltage only) • Circuit breakers, IEC compliant, 3 pole with shunt trip (low & medium voltage only) • Space heater relay
Governing	<ul style="list-style-type: none"> • ADEM II 	<ul style="list-style-type: none"> • Load share module
Control Panels	<ul style="list-style-type: none"> • EMCP II+ (package mounted, rear facing) 	<ul style="list-style-type: none"> • Customer Communication Module • Local alarm modules • Remote annunciator modules • Auto starting aid & switch* *Cannot be used with UL LIST
Lube	<ul style="list-style-type: none"> • Lubricating oil and filter • Oil drain line with valves • Fumes disposal • Gear type lube oil pump 	<ul style="list-style-type: none"> • Oil level regulator • Deep sump oil pan • Electric & air prelube pumps • Manual prelube with sump pump • Duplex oil filter • Oil level regulator
Mounting	<ul style="list-style-type: none"> • 330 mm (13 in) structural steel rails • Spring-type, anti-vibration mounts (shipped loose) 	<ul style="list-style-type: none"> • Isolator removal
Starting/Charging	<ul style="list-style-type: none"> • 24 volt starting motor(s) • 45 amp charging alternator • Batteries with rack and cables • Battery disconnect switch 	<ul style="list-style-type: none"> • Battery chargers (10 Amp) • Oversize batteries • Ether starting aids • Heavy duty starting motors • Barring device (manual) • Air starting motor with control & silencer
General	<ul style="list-style-type: none"> • Right-hand service • Paint - Caterpillar Yellow except rails and radiators gloss black • SAE standard rotation • Flywheel and flywheel housing - SAE No. 00 	<ul style="list-style-type: none"> • Enclosures • Front stub shaft • CSA certification • EU Certificate of Conformance
Note	<p>Standard and optional equipment may vary for UL 2200 Listed Packages. UL 2200 Listed packages may have oversized generators with a different temperature rise and motor starting characteristics.</p>	



Attachment C (4/11)

STANDBY 1500 kW 1875 kVA

60 Hz 1800 rpm 480 Volts

SPECIFICATIONS

CAT GENERATOR

SR4B Generator

Frame size..... 697
 Excitation..... Permanent Magnet
 Pitch..... 0.7333
 Number of poles..... 4
 Number of bearings..... Single Bearing
 Insulation..... UL 1446 Recognized Class H with tropicalization and antiabrasion
 IP rating..... Drip Proof IP22
 Alignment..... Pilot Shaft
 Overspeed capability - % of rated..... 150
 Wave form..... Less than 5% deviation
 Paralleling kit/Droop transformer..... Standard
 Voltage regulator. 3 Phase sensing with selectable volts/Hz
 Voltage regulation..... Less than +/- 1/2% (steady state)
 Less than +/- 1% (no load to full load)
 Telephone influence Factor..... Less than 50
 Harmonic distortion..... Less than 5%

CAT DIESEL ENGINE

3512B TA, 4-stroke-cycle watercooled diesel

Bore - mm..... 170.00 mm (6.69 in)
 Stroke - mm..... 190.00 mm (7.48 in)
 Displacement - L..... 51.80 L (3160.84 cu. in)
 Compression ratio..... 14.0:1
 Aspiration..... TA
 Fuel system..... Electronic unit injection

CAT CONTROL PANELS

- EMCP II+
- 24 Volt DC Control
- NEMA 12, IP44 enclosure
- Electronically dead front
- Lockable hinged door
- Generator instruments meet ANSI C-39-1
- Generator terminal box mounted
- Single location for customer connection
- UL508A Listed
- Panel illuminating lights
- Auto start/stop control
- True RMS metering, 3-phase
- Digital indications for:
 - RPM
 - Operating hours
 - Oil pressure
 - Coolant temperature
 - System DC volts
 - L-L volts, L-N volts, Phase amps, Hz
 - kW, kVA, kVAR, kWhr, %kW, PF
- Shutdowns with indicating lights for:
 - Low oil pressure
 - High coolant temperature
 - Low coolant level
 - Overspeed
 - Emergency stop
 - Failure to start (overcrank)
- Programmable protective relaying functions:
 - Under and over voltage
 - Under and over frequency
 - Reverse power
 - Overcurrent (phase and total)
- Programmable kW level relay
- 3 spare indicator LED's (programmable)
- 4 spare alarm/shutdown inputs



Attachment C (S/N)

STANDBY 1500 kW 1875 kVA

60 Hz 1800 rpm 480 Volts

TECHNICAL DATA

Open Generator Set - - 1800 rpm/60 Hz/480 Volts	DM6610	
Package Performance Genset Power rating with fan Genset Power rating @ 0.8 pf	1500 kW 1875 kVA	
Fuel Consumption 100% load with fan 75% load with fan 60% load with fan	393.6 L/hr 306.8 L/hr 212.8 L/hr	40.50 Gal/hr 81.1 Gal/hr 56.2 Gal/hr
Cooling System Air flow restriction (system) Engine coolant capacity	0.12 kPa 156.8 L	0.48 in. water 41.4 Gal
Exhaust System Combustion air inlet flow rate Exhaust stack gas temperature Exhaust gas flow rate Exhaust flange size (internal diameter) Exhaust system backpressure (maximum allowable)	130.8 m ³ /min 455.2 Deg C 336.1 m ³ /min 203.2 mm 6.7 kPa	4619.2 cfm 851 Deg F 11869.3 cfm 8.0 in 28.9 in. water
Heat Rejection Heat rejection to coolant (total) Heat rejection to exhaust (total) Heat rejection to aftercooler Heat rejection to atmosphere from engine Heat rejection to atmosphere from generator	618 kW 1477 kW 355 kW 131 kW 65.32 kW	35146 Btu/min 83997 Btu/min 20189 Btu/min 7450 Btu/min 3714.74 Btu/min
Alternator Motor starting capability @ 30% voltage dip Frame Temperature Rise	2681 kVA 697 130 Deg C	266 Deg F
Lube System Sump refill with filter	310.4 L	82.0 Gal
Emissions Nox g/bhp-hr (not to exceed) CO g/bhp-hr (not to exceed) HC g/bhp-hr (not to exceed) PM g/bhp-hr (not to exceed)	8.42 g/bhp-hr .65 g/bhp-hr .20 g/bhp-hr .075 g/bhp-hr	

Ambient capability at 200 m (660 ft) above sea level. For ambient capability at other altitudes, consult your Caterpillar dealer.
 UL 2200 Listed packages may have oversized generators with a different temperature rise and motor starting characteristics. Generator temperature rise is based on a 40 degree C ambient per NEMA MG1-32.
 Emissions data measurements are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx. This engine's exhaust emissions are in compliance with the US EPA and California nonroad regulations as identified above. Data shown is based on steady state operating conditions of 77° F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,390 btu/lb.

*Attachment C (6/11)***STANDBY 1500 ekW 1875 kVA**

60 Hz 1800 rpm 480 Volts

RATING DEFINITIONS AND CONDITIONS

Meets or Exceeds International Specifications: ABGSM TM3, AS1359, AS2789, BS4999, BS5000, BS5514, DIN6271, DIN6280, EGSA101P, IEC34/1, ISO3046/1, ISO8528, JEM1359, NEMA MG 1-22, VDE0530, 89/392/EEC, 89/336/EEC

Standby - Output available with varying load for the duration of the interruption of the normal source power. Standby power in accordance with ISO8528. Fuel stop power in accordance with ISO3046/1, AS2789, DIN6271, and BS5514. Standby ambients shown indicate ambient temperature at 100 percent load which results in a coolant top tank temperature just below the shutdown temperature.

Ratings are based on SAE J1995 standard conditions. These ratings also apply at ISO3046/1, DIN6271, and BS5514 standard conditions.

Fuel Rates are based on fuel oil of 35° API (16° C or 60° F) gravity having an LHV of 42 780 kJ/kg (18,390 Btu/lb) when used at 29° C (85° F) and weighing 838.9 g/liter (7.001 lbs/U.S. gal.).

Additional Ratings may be available for specific customer requirements. Consult your Caterpillar representative for details.



Attachment c (7/11)

STANDBY 1500 kW 1875 kVA

60 Hz 1800 rpm 480 Volts

DIMENSIONS

Package Dimensions		
Length	6578.1 mm	219.61 in
Width	2644.9 mm	104.19 in
Height	3079.8 mm	121.25 in
Weight	11 090 kg	24,449 lb

Note: Do not use for installation design. See general dimension drawings for detail (Drawing #2001187).



Performance No.: DM6610

Feature Code: 512DE3B

Source: USA Sourced

3 March 2004

1928914

www.CAT ElectricPower.com

Caterpillar All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.



Attachment C (8/11)

Blanchard Machinery Company - Engine Systems Division
224 Neely Ferry Road Simpsonville, SC 29680
Phone (864) 963-3645 Fax (864) 963-2063

QUOTATION

Date: March 03, 2004

To: Mr. John Trammell - Lockwood Greene

From: Robert Raditz-Blanchard Machinery

RE: Your Customer

One Caterpillar 3512B Diesel Powered Generator Set rated at 1500kW Standby, 480 VAC, 60 Hz, 1800 rpm, 3 phase, 4 wire and equipped as follows:

AIR INLET SYSTEM

Air Cleaner, single element canister type with service indicator

CONTROL PANELS

Control Panel

EMCP II + control panel including:

24 Volt DC Control

NEMA 12, IP44 Dust Proof Enclosure

Lockable hinged door

Generator Terminal Box

Mounted (rear facing)

Single location customer connection

UL 508A Listed

Panel Illuminating lights

Auto start/stop control switch

Voltage adjustment potentiometer

True RMS AC metering, 3 phase

Digital indication for:

RPM

Operating hours

Oil pressure

Coolant temperature

DC Volts

L-L Volts, L-N Volts, Phase, Amps, Hz

kW, kVa, KVAR, kWhr, % kW, PF

Shutdowns with indicating lights for:

Low oil pressure

High coolant temperature

Overspeed

Emergency stop

Failure to start (overcrank)

Low coolant level

Programmable Protective Relaying Functions

Under and Over Voltage

Under and Over Frequency

Reverse Power

Over Current (Phase and Total)

3 Spare indicating LED's (Programmable)

4 Spare alarm/shutdown inputs

Attachment C (9/11)

COOLING SYSTEM

CVD Radiator sized for:
minimum 43C/110F @ 660 ft. at Standby rating
Radiator fan and fan drive
Fan and belt guards
Coolant drain line with valve
Coolant level sensors
Caterpillar Extended Life Coolant

ENCLOSURE

Weather protective

EXHAUST SYSTEM

Dry Exhaust Manifold
Flanged faced outlets
Critically rated exhaust silencer

FUEL SYSTEM

Secondary fuel filters
Fuel cooler
Flexible fuel lines
Fuel priming pump
2500 gallon sub-base fuel tank

GENERATORS AND GENERATOR ATTACHMENTS

3 Phase Brushless, Salient Pole
Permanent Magnet Excited
Digital Voltage Regulator (D.V.R.) 3- phase sensing
Reactive droop
Bus Bar connections
Winding Temperature detectors
Anti-condensation space heaters
(120/240 VAC, 2000 W)

GOVERNING SYSTEM

ADEM II Governor

LITERATURE

English

LUBE SYSTEM

Lubricating oil
Gear type lube oil pump
Integral lube oil cooler
Oil filter, filler and dipstick
Oil drain lines and valve
Fume disposal

MOUNTING SYSTEM

Rails - Engine/Generator/Radiator Mounting
330 mm (13 in) structural steel rails
Spring-type anti-vibration mounts

STARTING/CHARGING SYSTEM

45 amp charging alternator
24 Volt Electric Starting Motors
Battery rack w/cables
Battery disconnect switch
10 amp heavy duty battery charger
2500 amp, 3 pole circuit breaker

GENERAL**PAINT**

Caterpillar yellow, with high gloss black rails & radiator
RH Service
Flywheel and Flywheel housing-SAE No. 00
SAE Standard Rotation

Attachment C (10/11)

Total net Price (plus SC sales tax if applicable)

\$ 172,381

Notes:

1. Scope of supply is limited to the items listed in the quotation.
2. Offloading, setting, assembly and installation are not included.
3. Approximate delivery is 16-18 weeks at time of engineering submittal approval.

THIS QUOTATION INCLUDES AND IS SUBJECT TO ALL THE PROVISIONS ON THE REVERSE HEREOF. PRICES QUOTED ARE GUARANTEED FOR 30 DAYS FROM THE DATE OF THE PROPOSAL.

PLEASE REVIEW YOUR SPECIFICATIONS TO BE SURE THAT THE APPARATUS DESCRIBED ABOVE MEETS YOUR REQUIREMENTS. This quotation covers such apparatus as described herein and does not constitute a job proposal. Reference herein to a job name or a job number does not institute a representation or warranty that such apparatus meets any particular specification. Thank you for your request and for your consideration of this quotation. Plus all applicable state and local taxes. Telephone and verbal orders are to be confirmed in writing. We reserve the right to correct stenographic or clerical errors. Deliveries are subject to occurrences beyond our control.

ACCEPTANCE

BLANCHARD MACHINERY COMPANY

DATE

DATE

Terms & Conditions of Quotation

- 1) Written quotations are firm for 30 days unless written notice is given of change. Orders based on verbal quotations, published literature, or written quotations older than 30 days are subject to approval by an officer of Blanchard Machinery.
- 2) Delivery dates are the best estimates as of the date of issue and are subject to change.
- 3) Quotations are made in accordance with our interpretation of plans and specifications. Materials supplied under this quotation, which are in substantial compliance, shall be deemed to be acceptable. Only the materials itemized in our quotations will be supplied.
- 4) In the event that a quotation is not accepted in its entirety, we reserve the right to decline any part of the order based on such quotation.
- 5) All stenographic or clerical errors are subject to correction.
- 6) PRICES: All prices are FOB the manufacturer's locations, unless specified otherwise by written quotation. Prices and other published data are for reference purposes only and are subject to change without notice.
- 7) TAXES: Our prices do not include federal, state, or local sales, use, property or excise taxes. If any such taxes are imposed, the seller will bill them to the buyer as a separate item. In lieu of such taxes the purchaser shall provide with each order a tax exemption certificate, acceptable to the to the proper taxing authorities.
- 8) ACCEPTANCE OF ORDER: All orders must be bonafide commitments showing definite price, delivery date and information, together with complete specifications of the material ordered, and complete shipping instructions. The company's failure to object to any provisions contained in the purchaser's order or any other communication shall not constitute a waiver of their terms or conditions thereof, nor acceptance of such provisions. No order shall be considered accepted unless accepted in writing by an officer of the company.
- 9) TERMS OF PAYMENT: Payment is due in full when orders are shipped, or when ready to ship if shipment is deferred at customer request, unless quoted otherwise in writing. Other terms are subject to the approval of our accounting department. Title to all equipment shall remain with us until full consideration for such equipment is paid. We shall retain a purchase money security interest in the equipment until paid in full.
- 10) CANCELLATION: Upon acceptance by us, your order will be entered for production and will not thereafter be subject to cancellation or deferment of delivery schedule without our written consent. Any expense incurred by the company due to the cancellation of an order or the deferment of a delivery schedule will be billed to the purchaser and be immediately due and owing, together with all costs of cancellation including attorney's fees.
- 11) PACKING: Prices include our standard packing for domestic shipment within the continental United States. Special domestic packing or export crating charges will be paid by the purchaser. If the purchaser does not specify packing, or accepts material unpacked at our factory, no allowance will be made in lieu of packing.
- 12) SHIPPING WEIGHTS: We will not be responsible for the accuracy of shipping weights. Such weights are approximate and correct only within the limit necessary for estimating freight.
- 13) LIABILITY: We will not be liable for any delay in the performance of orders or contracts of in the delivery of shipment of goods or for any damages suffered by purchaser by reason of such delay.
- 14) Except for any written warranty, which may be issued by us in connection with the equipment covered hereby, there are no representations or guarantees by Blanchard. We shall not be liable for any lost profits or any special or consequential damages directly or indirectly arising out of the use of, or inability to use, the equipment covered hereby even if we are advised of the possibility of such damages. THERE IS NO WARRANTY EXPRESSED OR IMPLIED OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.
- 15) Blanchard Machinery does not supply fuel for exhaust piping other than what is shown in submittal bill of material. We do not supply fuel for in field tests or tank fill up regardless of specifications. This will be the responsibility of others.

Attachment c (11/11)

- 16) For initial start up and check out service/testing/personnel instructions, please allow ten (10) working days from time of notification. Only one service call for start up is included, additional service calls will be charged at customary service rates.
- 17) Blanchard Machinery will not be responsible for damages incurred during shipping of product(s) unless shipped directly to a Blanchard facility. If shipped directly to the job site, it will be the responsibility of others to inspect the product(s) for damage prior to signing the bill of lading and releasing the freight company.

Blanchard Engine Systems Division

Call Us For Your Prime & Stand-by Power Needs - 10 - 2000 KW Available · Sales & Rental
Trailer Mounted Units · Diesel & Natural Gas Industrial Engines Available For Prime Power (75 - 5000 HP)

Columbia/Rock Hill - Contact: Brady Porth (803) 791-7100
Charleston/Florence/Myrtle Beach - Contact: Chip Hill (843) 871-2000
Greenville/Spartanburg - Contact: Robert Raditz (864) 963-3645



AMERADA HESS CORPORATION

NFPA 704 (Section 16)

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil **MSDS No. 0088**

1. CHEMICAL PRODUCT and COMPANY INFORMATION (rev. Jan-98)

Amerada Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095-0961

EMERGENCY TELEPHONE NUMBER (24 hrs): CHEMTREC (800) 424-9300
COMPANY CONTACT (business hours): Corporate Safety (732) 750-6000
SYNONYMS: #2 Heating Oil; 2 Oil; Off-road Diesel Fuel

See Section 16 for abbreviations and acronyms.

2. COMPOSITION and INFORMATION ON INGREDIENTS (rev. Sep-98)

INGREDIENT NAME	EXPOSURE LIMITS	CONCENTRATION PERCENT BY WEIGHT
#2 Fuel Oil CAS NUMBER: 68476-30-2	OSHA PEL-TWA: 5 mg/m ³ as mineral oil mist ACGIH TLV-TWA: 1997 NOIC - 100 mg/m ³ , skin, A3	100
Naphthalene CAS NUMBER: 91-20-3	OSHA PEL-TWA: 10 ppm ACGIH TLV-TWA/STEL: 10 / 15 ppm, A4	Typically 0.1

A complex combination of hydrocarbons with carbon numbers in the range C9 and higher produced from the distillation of petroleum crude oil.

3. HAZARDS IDENTIFICATION (rev. Jan-98; Tox-98)

EMERGENCY OVERVIEW
CAUTION!

OSHA/NFPA COMBUSTIBLE LIQUID - SLIGHT TO MODERATE IRRITANT - EFFECTS CENTRAL NERVOUS SYSTEM - HARMFUL OR FATAL IF SWALLOWED

Moderate fire hazard. Avoid breathing vapors or mists. May cause dizziness and drowsiness. May cause moderate eye irritation and skin irritation. Long-term, repeated exposure may cause skin cancer.

If ingested, do NOT induce vomiting, as this may cause chemical pneumonia (fluid in the lungs).

EYES

Contact with eyes may cause mild irritation.

SKIN

Practically non-toxic if absorbed following acute (single) exposure. May cause skin irritation with prolonged or repeated contact. Liquid may be absorbed through the skin in toxic amounts if large areas of skin are repeatedly exposed.

INGESTION

The major health threat of ingestion occurs from the danger of aspiration (breathing) of liquid drops into the lungs, particularly from vomiting. Aspiration may result in chemical pneumonia (fluid in the lungs), severe lung damage, respiratory failure and even death.

Ingestion may cause gastrointestinal disturbances, including irritation, nausea, vomiting and diarrhea, and central nervous system (brain) effects similar to alcohol intoxication. In severe cases, tremors, convulsions, loss of consciousness, coma, respiratory arrest, and death may occur.

INHALATION

Excessive exposure may cause irritations to the nose, throat, lungs and respiratory tract. Central nervous system (brain) effects may include headache, dizziness, loss of balance and coordination, unconsciousness, coma, respiratory failure, and death.

AMERADA HESS CORPORATION

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil

MSDS No. 0088

WARNING: the burning of any hydrocarbon as a fuel in an area without adequate ventilation may result in hazardous levels of combustion products, including carbon monoxide, and inadequate oxygen levels, which may cause unconsciousness, suffocation, and death.

CHRONIC EFFECTS and CARCINOGENICITY

Similar products have produced skin cancer and systemic toxicity in laboratory animals following repeated applications. The significance of these results to human exposures has not been determined - see Section 11 Toxicological Information.

MEDICAL CONDITIONS AGGRAVATED BY EXPOSURE

Irritation from skin exposure may aggravate existing open wounds, skin disorders, and dermatitis (rash).

4. FIRST AID MEASURES (rev. Jan-98; Tox-98)

EYES

In case of contact with eyes, immediately flush with clean, low-pressure water for at least 15 min. Hold eyelids open to ensure adequate flushing. Seek medical attention.

SKIN

Remove contaminated clothing. Wash contaminated areas thoroughly with soap and water or with waterless hand cleanser. Obtain medical attention if irritation or redness develops.

INGESTION

DO NOT INDUCE VOMITING. Do not give liquids. Obtain immediate medical attention. If spontaneous vomiting occurs, lean victim forward to reduce the risk of aspiration. Monitor for breathing difficulties. Small amounts of material which enter the mouth should be rinsed out until the taste is dissipated.

INHALATION

Remove person to fresh air. If person is not breathing, provide artificial respiration. If necessary, provide additional oxygen once breathing is restored if trained to do so. Seek medical attention immediately.

5. FIRE FIGHTING MEASURES (rev. Sep-94)

FLAMMABLE PROPERTIES:

FLASH POINT:	100 °F (38 °C) minimum PMCC
AUTOIGNITION POINT:	494 °F (257 °C)
LOWER EXPLOSIVE LIMIT (%):	0.6
UPPER EXPLOSIVE LIMIT (%):	7.5

FIRE AND EXPLOSION HAZARDS

OSHA and NFPA Class 2 **COMBUSTIBLE LIQUID** (see Section 14 for transportation classification). Vapors may be ignited rapidly when exposed to heat, spark, open flame or other source of ignition. When mixed with air and exposed to an ignition source, flammable vapors can burn in the open or explode in confined spaces. Being heavier than air, vapors may travel long distances to an ignition source and flash back. Runoff to sewer may cause fire or explosion hazard.

EXTINGUISHING MEDIA

SMALL FIRES: Any extinguisher suitable for Class B fires, dry chemical, CO₂, water spray, fire fighting foam, or Halon.

LARGE FIRES: Water spray, fog or fire fighting foam. Water may be ineffective for fighting the fire, but may be used to cool fire-exposed containers.

FIRE FIGHTING INSTRUCTIONS

Small fires in the incipient (beginning) stage may typically be extinguished using handheld portable fire extinguishers and other fire fighting equipment.

AMERADA HESS CORPORATION

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil

MSDS No. 0088

Firefighting activities that may result in potential exposure to high heat, smoke or toxic by-products of combustion should require NIOSH/MSHA- approved pressure-demand self-contained breathing apparatus with full facepiece and full protective clothing.

Isolate area around container involved in fire. Cool tanks, shells, and containers exposed to fire and excessive heat with water. For massive fires the use of unmanned hose holders or monitor nozzles may be advantageous to further minimize personnel exposure. Major fires may require withdrawal, allowing the tank to burn. Large storage tank fires typically require specially trained personnel and equipment to extinguish the fire, often including the need for properly applied fire fighting foam.

See Section 16 for the NFPA 704 Hazard Rating.

6. ACCIDENTAL RELEASE MEASURES (rev. Jan-98)

ACTIVATE FACILITY'S SPILL CONTINGENCY OR EMERGENCY RESPONSE PLAN.

Evacuate nonessential personnel and remove or secure all ignition sources. Consider wind direction; stay upwind and uphill, if possible. Evaluate the direction of product travel, diking, sewers, etc. to confirm spill areas. Spills may infiltrate subsurface soil and groundwater; professional assistance may be necessary to determine the extent of subsurface impact.

Carefully contain and stop the source of the spill, if safe to do so. Protect bodies of water by diking, absorbents, or absorbent boom, if possible. Do not flush down sewer or drainage systems, unless system is designed and permitted to handle such material. The use of fire fighting foam may be useful in certain situations to reduce vapors. The proper use of water spray may effectively disperse product vapors or the liquid itself, preventing contact with ignition sources or areas/equipment that require protection.

Take up with sand or other oil absorbing materials. Carefully shovel, scoop or sweep up into a waste container for reclamation or disposal. Response and clean-up crews must be properly trained and must utilize proper protective equipment (see Section 8).

7. HANDLING and STORAGE (rev. Jan-98)

HANDLING PRECAUTIONS

Handle as a combustible liquid. Keep away from heat, sparks, excessive temperatures and open flame. No smoking or open flame in storage, use or handling areas. Bond and ground containers during product transfer to reduce the possibility of static-initiated fire or explosion.

Special slow load procedures for "switch loading" must be followed to avoid the static ignition hazard that can exist when this product is loaded into tanks previously containing low flash point products (such as gasoline) - see API Publication 2003, "Protection Against Ignitions Arising Out Of Static, Lightning and Stray Currents."

STORAGE PRECAUTIONS

Keep containers closed and clearly labeled. Use approved vented storage containers. Empty product containers or vessels may contain explosive vapors. Do not pressurize, cut, heat, weld or expose such containers to sources of ignition.

Store in a well-ventilated area. This storage area should comply with NFPA 30 "Flammable and Combustible Liquid Code". Avoid storage near incompatible materials. The cleaning of tanks previously containing this product should follow API Recommended Practice (RP) 2013 "Cleaning Mobile Tanks In Flammable and Combustible Liquid Service" and API RP 2015 "Cleaning Petroleum Storage Tanks."

WORK/HYGIENIC PRACTICES

Emergency eye wash capability should be available in the near proximity to operations presenting a potential splash exposure. Use good personal hygiene practices. Avoid repeated and/or prolonged skin exposure. Wash hands before eating, drinking, smoking, or using toilet facilities. Do not use as a cleaning solvent or harsh abrasive skin cleaners for washing this product from exposed skin areas. Waterless hand cleaners are effective. Promptly remove contaminated clothing and launder before reuse.

AMERAD HESS CORPORATION

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil

MSDS No. 0088

Use care when laundering to prevent the formation of flammable vapors which could ignite via washer or dryer. Consider the need to discard contaminated leather shoes and gloves.

8. EXPOSURE CONTROLS and PERSONAL PROTECTION (rev. Jan-98)

ENGINEERING CONTROLS

Use adequate ventilation to keep vapor concentrations of this product below occupational exposure and flammability limits, particularly in confined spaces.

EYE/FACE PROTECTION

Safety glasses or goggles are recommended where there is a possibility of splashing or spraying.

SKIN PROTECTION

Gloves constructed of nitrile, neoprene, or PVC are recommended. Chemical protective clothing such as of E.I. DuPont TyChem®, Saranex® or equivalent recommended based on degree of exposure. Note: The resistance of specific material may vary from product to product as well as with degree of exposure. Consult manufacturer specifications for further information.

RESPIRATORY PROTECTION

A NIOSH/MSHA-approved air-purifying respirator with organic vapor cartridges or canister may be permissible under certain circumstances where airborne concentrations are or may be expected to exceed exposure limits or for odor or irritation. Protection provided by air-purifying respirators is limited. Refer to OSHA 29 CFR 1910.134, ANSI Z88.2-1992, NIOSH Respirator Decision Logic, and the manufacturer for additional guidance on respiratory protection selection.

Use a positive pressure, air-supplied respirator if there is a potential for uncontrolled release, exposure levels are not known, in oxygen-deficient atmospheres, or any other circumstance where an air-purifying respirator may not provide adequate protection.

9. PHYSICAL and CHEMICAL PROPERTIES (rev. Jul-98)

APPEARANCE

Red or reddish/orange colored (dyed) liquid

ODOR

Mild, petroleum distillate odor

BASIC PHYSICAL PROPERTIES

BOILING RANGE: 340 to 700 °F (171 to 371 °C)
VAPOR PRESSURE: 0.009 psia @ 70 °F (21 °C)
VAPOR DENSITY (air = 1): > 1.0
SPECIFIC GRAVITY (H₂O = 1): AP 0.87
PERCENT VOLATILES: 100 %
EVAPORATION RATE: Slow; varies with conditions
SOLUBILITY (H₂O): Negligible

10. STABILITY and REACTIVITY (rev. Sep-94)

STABILITY: Stable. Hazardous polymerization will not occur

CONDITIONS TO AVOID and INCOMPATIBLE MATERIALS

Avoid high temperatures, open flames, sparks, welding, smoking and other ignition sources. Keep away from strong oxidizers; Viton ®; Fluorel ®

HAZARDOUS DECOMPOSITION PRODUCTS

Carbon monoxide, carbon dioxide and non-combusted hydrocarbons (smoke).

AMERAD HESS CORPORATION

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil

MSDS No. 0088

11. TOXICOLOGICAL PROPERTIES (rev. Jan-98; Tox-98)

ACUTE TOXICITY

Acute Oral LD50 (rat): 14.5 ml/kg

Acute Dermal LD50 (rabbit): > 5 ml/kg

Guinea Pig Sensitization: negative

Primary dermal irritation: moderately irritating (Draize mean irritation score - 3.98 rabbits)

Draize eye irritation: mildly irritating (Draize score, 48 hours, unwashed - 2.0 rabbits)

CHRONIC EFFECTS AND CARCINOGENICITY

Carcinogenic: IARC: NO NTP: NO OSHA: NO ACGIH: 1997 NOIC: A3

Dermal carcinogenicity: positive - mice

Studies have shown that similar products produce skin tumors in laboratory animals following repeated applications without washing or removal. The significance of this finding to human exposure has not been determined. Other studies with active skin carcinogens have shown that washing the animal's skin with soap and water between applications reduced tumor formation.

This product is similar to Diesel Fuel. IARC classifies whole diesel fuel exhaust particulates as probably carcinogenic to humans (Group 2A) and NIOSH regards it as a potential cause of occupational lung cancer based on animal studies and limited evidence in humans.

MUTAGENICITY (genetic effects)

Material of similar composition has been positive in a mutagenicity study.

12. ECOLOGICAL INFORMATION (rev. Jan-98)

Keep out of sewers, drainage areas and waterways. Report spills and releases, as applicable, under Federal and State regulations.

13. DISPOSAL CONSIDERATIONS (rev. Jan-98)

Consult federal, state and local waste regulations to determine appropriate disposal options.

14. TRANSPORTATION INFORMATION (rev. Jan-98)

PROPER SHIPPING NAME: FUEL OIL, NO. 2

HAZARD CLASS & PACKING GROUP: 3, PG III

DOT IDENTIFICATION NUMBER: NA 1993

DOT SHIPPING LABEL: FLAMMABLE LIQUID

May be reclassified for transportation as a COMBUSTIBLE LIQUID under conditions of DOT 49 CFR 173.120(b)(2).

15. REGULATORY INFORMATION (rev. Feb-01)

U.S. FEDERAL, STATE, and LOCAL REGULATORY INFORMATION

This product and its constituents listed herein are on the EPA TSCA Inventory. Any spill or uncontrolled release of this product, including any substantial threat of release, may be subject to federal, state and/or local reporting requirements. This product and/or its constituents may also be subject to other regulations at the state and/or local level. Consult those regulations applicable to your facility/operation.

CLEAN WATER ACT (OIL SPILLS)

Any spill or release of this product to "navigable waters" (essentially any surface water, including certain wetlands) or adjoining shorelines sufficient to cause a visible sheen or deposit of a sludge or emulsion must be reported immediately to the National Response Center (1-800-424-8802) or, if not practical, the U.S. Coast Guard with follow-up to the National Response Center, as required by U.S. Federal Law. Also contact appropriate state and local regulatory agencies as required.

AMERADA HESS CORPORATION

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil

MSDS No. 0088

CERCLA SECTION 103 and SARA SECTION 304 (RELEASE TO THE ENVIRONMENT)

The CERCLA definition of hazardous substances contains a "petroleum exclusion" clause which exempts crude oil, refined, and unrefined petroleum products and any indigenous components of such. However, other federal reporting requirements (e.g., SARA Section 304 as well as the Clean Water Act if the spill occurs on navigable waters) may still apply.

SARA SECTION 311/312 - HAZARD CLASSES

<u>ACUTE HEALTH</u>	<u>CHRONIC HEALTH</u>	<u>FIRE</u>	<u>SUDDEN RELEASE OF PRESSURE</u>	<u>REACTIVE</u>
X	X	X	-	-

SARA SECTION 313 - SUPPLIER NOTIFICATION

This product may contain listed chemicals below the *de minimis* levels which therefore are not subject to the supplier notification requirements of Section 313 of the Emergency Planning and Community Right-To-Know Act (EPCRA) of 1986 and of 40 CFR 372. If you may be required to report releases of chemicals listed in 40 CFR 372.28, you may contact Amerada Hess Corporate Safety if you require additional information regarding this product.

CANADIAN REGULATORY INFORMATION (WHMIS)

Class B, Division 3(Combustible Liquid); Class D, Division 2, Subdivision B (Toxic by other means)

16. OTHER INFORMATION (rev. Feb-01)

<u>NFPA® HAZARD RATING</u>	HEALTH:	0	Negligible
	FIRE:	2	Moderate
	REACTIVITY:	0	Negligible
<u>HMIS® HAZARD RATING</u>	HEALTH:	1*	Slight
	FIRE:	2	Moderate
	REACTIVITY:	0	Negligible
			* Chronic

SUPERSEDES MSDS DATED: 09/03/98

ABBREVIATIONS:

AP = Approximately < = Less than > = Greater than
N/A = Not Applicable N/D = Not Determined ppm = parts per million

ACRONYMS:

ACGIH	American Conference of Governmental Industrial Hygienists	NFPA	National Fire Protection Association (617) 770-3000
AIHA	American Industrial Hygiene Association	NIOSH	National Institute of Occupational Safety and Health
ANSI	American National Standards Institute (212) 642-4900	NOIC	Notice of Intended Change (proposed change to ACGIH TLV)
API	American Petroleum Institute (202) 682-8000	NTP	National Toxicology Program
CERCLA	Comprehensive Emergency Response, Compensation, and Liability Act	OPA	Oil Pollution Act of 1990
DOT	U.S. Department of Transportation [General info: (800) 467-4922]	OSHA	U.S. Occupational Safety & Health Administration
EPA	U.S. Environmental Protection Agency	PEL	Permissible Exposure Limit (OSHA)
HMIS	Hazardous Materials Information System	RCRA	Resource Conservation and Recovery Act
IARC	International Agency For Research On Cancer	REL	Recommended Exposure Limit (NIOSH)
MSHA	Mine Safety and Health Administration	SARA	Superfund Amendments and Reauthorization Act of 1986 Title III
		SCBA	Self-Contained Breathing Apparatus

AMERADA HESS CORPORATION

MATERIAL SAFETY DATA SHEET

No. 2 Fuel Oil

MSDS No. 0088

SPCC Spill Prevention, Control, and Countermeasures

STEL Short-Term Exposure Limit (generally 15 minutes)

TLV Threshold Limit Value (ACGIH)

TSCA Toxic Substances Control Act

TWA Time Weighted Average (8 hr.)

WEEL Workplace Environmental Exposure Level (AIHA)

WHMIS Canadian Workplace Hazardous Materials Information System

DISCLAIMER OF EXPRESSED AND IMPLIED WARRANTIES

Information presented herein has been compiled from sources considered to be dependable, and is accurate and reliable to the best of our knowledge and belief, but is not guaranteed to be so. Since conditions of use are beyond our control, we make no warranties, expressed or implied, except those that may be contained in our written contract of sale or acknowledgment.


Vendor assumes no responsibility for injury to vendee or third persons proximately caused by the material if reasonable safety procedures are not adhered to as stipulated in the data sheet. Additionally, vendor assumes no responsibility for injury to vendee or third persons proximately caused by abnormal use of the material, even if reasonable safety procedures are followed. Furthermore, vendee assumes the risk in their use of the material.

ATTACHMENT D (continued)

**Information Used to Determine Emissions
for
Fuel Tanks**



General Information Technical Information Local Distributors
GSA Purchasing News & Views Links Warranty Form



HOME
GENERAL INFO
TECHNICAL INFO
DISTRIBUTORS
GSA PURCHASING
NEWS & VIEWS
CHEMVAULT
LINKS
TERMS OF USE
MARKETING
MEMBERS
NETWORK MEMBERS
NEWS RELEASE
IN MEMORY

OWNER'S
INFORMATION

CONVERSION CHARTS

1-800-222-7099 or 209-632-7571

Fax: 209-632-4711


E-mail: info@convault.com

Click Here To Take

Copyright © CONVAULT, INC. TERMS OF USE



ConVault Storage Tanks are designed to store petroleum products including gasoline, diesel, jet fuel, oils, and other related products such as ethanol and methanol. They are UL2085 listed for protected aboveground storage of both combustible liquids and flammable liquids, and are designed with protection for both the primary tank and secondary containment. This makes them fire resistant, impact resistant, and bulletproof. As such, they are used widely across the United States and around the world, especially in environmentally sensitive areas or areas with the possibility of terrorist attack. The standard primary containment is a mild steel tank that can be internally coated for storage of many corrosive or hazardous chemical liquids. Stainless steel primary tanks are also available. All ConVault and ChemVault products are shop fabricated and shop tested and are ready for installation upon arrival. Use ConVault ASTs for all your protected above ground fuel storage tank needs.



PRODUCT DESCRIPTION

HOME | TECHNICAL INFO | PRODUCT DESCRIPTION | TANK SIZES | FINISHES | SPECIFICATIONS
WARRANTY | INSTALLATION INSTRUCTIONS | CYLINDRICAL OPTION | DRAWINGS

TABLE OF CONTENTS

A. THE BACKGROUND

B. ENGINEERED FOR SAFETY

C. THE MANUFACTURING PROCESS

- 1. The Steel Tank Construction
- 2. Secondary Containment
- 3. Concrete Vault
- 4. Coating and Finishing

D. ADDITIONAL FEATURES

- 1. Complying with Environmental and Fire Safety Requirements
- 2. UL/ULC Listed
- 3. Overfill Protection
- 4. Venting
- 5. Support Legs
- 6. Thermal and Corrosion Protection
- 7. Spill Containment
- 8. Vehicle Impact Resistance Bullet Resistance

E. TANK WEIGHTS AND DIMENSIONS

F. PERMITS AND APPROVALS

A. The Background

- 1. You are probably aware that underground fuel storage tanks are a main source of soil contamination in this country. Underground fuel storage tanks corrode and leak fuel oil and gas into the soil and cause soil contamination. The contamination may even reach the underground water streams and be carried into the drinking water systems. Decontamination of the underground fuel storage tanks' location is extremely costly and can have a devastating financial burden on tanks' owners and operators.
- 2. Regulatory agencies have enacted many guidelines requiring the owners and operators of the underground fuel storage tanks to install expensive leak detection and monitoring facilities to prevent costly contamination problems.

HOME
GENERAL I
TECHNICAL
DISTRIBUT
GSA PURCH
NEWS & VIE
CHEMVAUL
LINKS
TERMS OF I
MARKETING
MEMBERS
NETWORK I
NEWS RELE

OWNER'S
INFORMATI

CONVERSIC

3. There are also many regulations covering installation and operation of "unprotected" above ground steel storage tanks.
4. To solve the problems associated with the underground storage tanks and the unprotected aboveground steel storage tanks, ConVault® has come up with a breakthrough idea of constructing a tank that does not have the costly underground tank's leak monitoring system and contamination problem and at the same time has overcome the problems associated with the unprotected aboveground steel tanks. Because of its unique monolithic concrete construction feature, the ConVault® tank system provides a two (2) hour fire protection, vehicle impact resistance and bullets resistance proven by the tests carried out by the Underwriters Laboratories of USA (UL) and Canada (ULC).

B. Engineered for safety

1. The design and manufacturing concept of the ConVault® is simple and at the same time very practical. In a nut-shell, ConVault's® design concept consists of :
 - a. Constructing a welded steel tank to hold and store flammable and combustible liquid fuels.
 - b. Insulating the steel tank exterior by a minimum of 1/4" thick Styrofoam and wrapping it in a 30 mil high density polyethylene membrane to provide a secondary containment for fuel in case of a remote probability of any leaks from the steel tank.
 - c. Encasing both the poly and the steel tank in 6" thick monolithic reinforced concrete vault to provide two-hour fire protection, ballistic and vehicle impact protection.
2. ConVault® has even designed a leak detection system that enables checking the tank for leaks on a regular basis by simply inserting a stick in the leak detector chamber and find out if the tank has any leaks.
3. ConVault® is so confident of its superior design that it gives 20 to 30 years of warranty for its tanks. Provided that the tank is installed, operated and maintained in accordance with ConVault's® specifications, ConVault® will replace your tank without charge if it develops a leak. See your standard warranty for its actual number of years and its conditions.
4. Since you have purchased one of over 18,000 tanks, which remain in service since 1987, you may wish to understand the unique manufacturing process of ConVault tanks. The following paragraphs will explain the construction process of the ConVault® tanks.

C. The Manufacturing Process

ConVault® tanks construction process consists of four main steps, namely:

1. Steel tank construction
2. Secondary containment
3. Concrete Vault
4. Coating and Finishing

Figure No. 1 is an isometric view of a typical ConVault® tank with a cutaway section to show details of a ConVault® tank system.

1. Steel tank construction

- a. ConVault® steel tanks are made of 1/8" or 3/16" thick steel, depending on warranty and tank size. The steel tank contains and holds the liquid

fuel, which is the primary function of the tank. To make the steel tank systems fit for their function; the tanks are made in accordance with the UL standard 142 and ULC standard S601. The UL/ULC standards cover all the aspects of tank construction including material specification, fabrication, welding and testing. The tanks are listed in accordance with UL/ULC Standards and carry UL/ULC labels as such.


b. At the fabrication shop, the tanks undergo a number of quality control and test procedures including a 24 to 48 hour pressure test at five (5) psig.

2. Secondary Containment

a. The second stage of manufacturing consists of wrapping the steel tank with a minimum of 1/4" thick Styrofoam (foam) insulation and an impervious barrier of 30 Mil high density polyethylene membrane (poly). The 30 Mil poly provides containment for the remote probability of fuel leak through the steel tank. A leak detector pipe terminating in the secondary containment provides a positive-proof that the tank is not leaking.

b. Another advantage of the 30 Mil poly is that it shields and protects the steel tank exterior from coming in direct contact with concrete and thus minimizing the potential of tank external corrosion.

Figure No. 1



3. The Concrete Vault

The next step of manufacturing a ConVault® tank is to encase the tank in a six (6) inch thick reinforced concrete vault. Simply put, the six inches of concrete is poured on all sides bottom and top of the tank in one step and hence the phrase "monolithic". This process assures that there are no joints and no heat sinks in the concrete to carry heat from a fire into the primary containment.

The concrete pouring process also goes through a strenuous quality control procedure to make sure the ConVault® tank withstands its ultimate performance test, the two (2) hour fire test. ConVault® tanks are listed by UL 2085 standard and ULC/ORD 142.16 as fire resistant/insulated and protected tank.

4. Coating and Finishing

At the final stages of manufacturing, the concrete exterior of the tank is vacuum coated using a two-part water based epoxy paint to protect the tanks from the inclement weather conditions. Concrete exterior can also be produced in exposed aggregate with a clear coat of sealant or in STO finish. The entire pipe fittings and nipples on the tank are powder-coated to protect them from corrosion.

D. Additional features

The following is a list of some of the major features and advantages of the ConVault® tanks:

1. Complying with Environmental and Fire Safety Requirements

- a. ConVault® tanks meet applicable safety requirements for secondary containment, leak monitoring, and spill protection. ConVault® tanks are approved by fire officials in most local jurisdictions. They are currently in use nationwide.
- b. ConVault® tanks meet NFPA 30 and 30A , UFC, BOCA, SBCCI model fire codes safety standards. The units comply with the 1996 Uniform Fire Code Standard for the aboveground storage and dispensing of motor fuels.
- c. ConVault® tanks are certified by the California Air Resources Board for Balanced Phase 1 and phase 2 Vapor Recovery including methanol and ethanol.

2. UL/ULC Listed

- a. The ConVault® tanks have the following UL and ULC listings:
 1. **UL - 142**, aboveground tanks for flammable and combustible liquids.
 2. **UL - 2085**, two hour furnace fire test and two hour simulated pool fire test for insulated tank.
 3. **UL - 2085**, insulated and protected secondary containment aboveground tanks for flammable and combustible liquids
 4. **UL - 2085 and UFC SECTION (79-7)** ballistic and vehicle impact test for protected tank.
 5. **UL - 2085/UL CAN ORD-C 142.16** Non-Metallic Secondary Containment and Venting by Form of Construction.
 6. **UL - Subject 2244** Systems Listing for Motor Vehicle Fuel Dispensing.
 7. **UL CAN/ORD - C 142.16**, protected aboveground tank assemblies for flammable and combustible liquids.
 8. **UL CAN/ORD - C 142.5**, concrete encased aboveground tank assemblies for flammable and combustible liquids.
 9. **UL CAN/ORD - 142.16**, the furnace burn requirements for two hour fire rating.
 10. **UL CAN/ORD - 142.5**, the open (pool) fire testing for two hour flammable liquid fire test.

3. Overfill Protection

Tanks can be provided with two or more of the following methods to protect them against overfill: a) direct reading level gauge at the tank which is visible from fill pipe location; b) valve located within fill-pipe access to close automatically at a specified fill level; c) audible high level alarm activated by a float switch at a specified fill level.

4. Venting

The ConVault® tank systems are furnished with a 2 inch normal vent and an emergency pressure relief system. The standard emergency relief system furnished with the tank normally opens if the tank pressure exceeds 1/2 psig. The tank systems conform to model fire codes and UL/ULC Standards for venting.

5. Support Legs

Vaults have concrete support legs of unitized monolithic construction that provide visual inspection capability. Tanks do not require cathodic protection system as no steel part of the tanks comes in direct contact with the ground.

6. Thermal and Corrosion Protection

The tank construction includes thermal insulation to protect against temperature extremes and corrosion by separating the steel tank from the concrete. No part of the steel tank comes in direct contact with concrete or any other corrosive material.

7. Spill Containment

The tank system includes a 5 to 15 gallon, powder-coated UL-Listed and patented, spill containment surrounding the fill pipe. The spill container is equipped with a normally closed hand operated valve that can be actuated to drain the spilled fuel liquids into the steel tank.

8. Vehicle Impact resistance

ConVault® tanks are designed to have a low center of gravity that can withstand vehicle impact and tipping during earthquakes and other natural disasters. ConVault® tanks have withstood even phenomenon tests such as C-130 aircraft impact at Ft. Dobbins in Georgia, Hurricane Andrew and the 1989 Loma Prieta earthquake.

9. Bullet Resistance

ConVault® tanks withstand bullet resistance tests in compliance with UFC SECTION (79-7), APPENDIX # A-II-F-1.

10. Non-Metallic Secondary Containment and Venting by Form of Construction.

The UL 2085 Standard listing officially recognizes ConVault tank as having a secondary containment that is non-metallic and that vents by form of construction. This eliminates the need for an emergency-venting device on the secondary containment.

11. California Air Resources Board (CARB) Certified

ConVault AST's are CARB certifies for use with Phase I and Phase II vapor recovery systems under Executive Order G-70-116 and revisions A through F. California is recognized as the national air quality expert and, having passed all field examinations by CARB, ConVault AST's are generally regarded as having met the severest air quality compliance standards.

More information can be found at their website: <http://www.arb.ca.gov>.


- **.NOTICE:** Aboveground Storage Tanks (AST) should be evaluated to determine acceptability for continued use after fire exposure, physical damage, or misuse.

E. Tanks' Weights and Dimensions

Figures No. 2, 3 and 4 give nominal capacities, the outside dimensions, general fittings layout and approximate weights of some popular ConVault® systems. These figures can help you in your planning for the future fuel storage requirements. Contact your ConVault® distributor for accurate weight of tanks to help you in arranging for proper equipment for unloading and setting of tanks.

Figure No. 2

**Tank Weights and Dimensions *
Single Primary Tank**




SIZE	LENGTH	WIDTH	HEIGHT	WEIGHT
125	4' - 1"	4' - 1"	3' - 11"	6,000
250	7' - 8"	3' - 9"	3' - 3"	8,000
500	11' - 0"	4' - 6"	3' - 4"	12,000
1000	11' - 0"	5' - 8"	4' - 4"	18,000
2000	11' - 3"	8' - 0"	5' - 6"	30,000
3000 LP	11' - 3"	8' - 0"	7' - 3"	35,500
3000 HP	9' - 9"	8' - 0"	8' - 9"	37,500
4000 LP	17' - 7"	8' - 0"	6' - 5"	45,000
4000 HP	12' - 6"	8' - 0"	8' - 9"	40,000
5200 G	15' - 6"	8' - 0"	8' - 9"	47,000
6000	17' - 7"	8' - 0"	8' - 9"	59,000
8000	23' - 1"	8' - 0"	8' - 9"	72,000
10000	28' - 7"	8' - 0"	8' - 9"	87,500
12000	34' - 1"	8' - 0"	8' - 9"	101,000

- Double-wall steel tanks are optional and external dimensions are identical to single wall tank.
- Nipple layout and designs vary according to customer needs.

***NOTE:** These are nominal weights of the tanks. Check with your distributor/salesperson for accurate weights.

Figure No. 3

Multi-Compartment Tank Weights and Dimensions *
The "D" Design



SIZE	LENGTH	WIDTH	HEIGHT	WEIGHT
D250	11'-0"	4'-6"	3'-4"	12,000
D500	11'-0"	5'-8"	4'-4"	15,500
D1000	11'-3"	8'-0"	5'-6"	30,000
D1500 LP	11'-3"	8'-0"	7'-3"	30,000
D1500 HP	9'-9"	8'-0"	8'-9"	37,500
D2000 LP	17'-7"	8'-0"	6'-5"	45,500
D2000 HP	12'-6"	8'-0"	8'-9"	40,000
D2,600 G	15'-6"	8'-0"	8'-9"	47,000
D2600 W	13'-2"	11'-11"	6'-11"	53,000


D3000	17'-7"	8'-0"	8'-9"	59,000
D4000	23'-1"	8'-0"	8'-9"	72,000
D5000	28'-7"	8'-0"	8'-9"	87,500
D6000	34'-1"	8'-0"	8'-9"	101,000

- Nipple layout and design vary according to customer needs.

***NOTE:** These are nominal weights of the tanks. Check with your distributor/salesperson for accurate weights.

Figure No. 4

**Multi-Compartment Tank Weights and Dimensions *
The "E" Design**



SIZE	LENGTH	WIDTH	HEIGHT	WEIGHT
E250	11' - 0"	4' - 6"	3' - 4"	12,000
E500	11' - 0"	5' - 8"	4' - 4"	18,000
E1000	11' - 3"	8' - 0"	5' - 6"	30,000
E1500 LP	11' - 3"	8' - 0"	7' - 3"	35,500
E1500 HP	9' - 9"	8' - 0"	8' - 9"	37,500
E2000 LP	17' - 7"	8' - 0"	6' - 5"	45,000
E2000 HP	12' - 6"	8' - 0"	8' - 9"	40,000
E2600 G	15' - 6"	8' - 0"	8' - 9"	47,000
E2600 W	13' - 2"	11' - 11"	6' - 11"	53,000
E3000	17' - 7"	8' - 0"	8' - 9"	59,000
E4000	23' - 1"	8' - 0"	8' - 9"	72,000
E5000	28' - 7"	8' - 0"	8' - 9"	87,500
E6000	34' - 1"	8' - 0"	8' - 9"	101,000

- Nipple layout and design vary according to customer needs.

***NOTE:** These are nominal weights of the tanks. Check with your distributor/salesperson for accurate tank weight.

F. Permits and Approvals

Installation of fuel/oil storage systems requires approval process from various government agencies. Table 1 shows typical approval process and documents needed. Specific local or **AUTHORITIES HAVING JURISDICTION** requirements may slightly differ for different locations, but the list is a good reference and a guide for your permits requirements.

Table 1

PERMITS AND APPROVALS

--	--	--	--

A.	State and/or local application forms	F.	Prepare system detailed drawings to include:
B.	The ConVault® Site Review Form approved by the local Fire Marshall.	1.	Tank size, dimensions, and spacing between adjacent tanks.
C.	Site plan drawings.	2.	Base slab dimensions and bollard location and size.
D.	System detail drawings.	3.	Vent size and location. Height of standard vent and type of cap.
E.	Prepare the site plan as follows:	4.	Fill details including spill and overflow protection.
1.	Draw to scale.	5.	Piping details including shutoff valves and anti-siphon valves.
2.	Show property lines and indicate occupancy or use of adjacent property.	6.	Pumps and dispensing equipment including location, size, and type.
3.	Show streets, intersections, and railroads.	7.	Electrical details including shutoff switch location and grounding wire.
4.	Show buildings on the site and indicate type of construction. Show building openings on walls adjacent to tanks.	8.	Level gauges and leak detection equipment
5.	Show important utility lines, sewer, water, gas, and electric including fire hydrants and catch basins.	9.	Signs and decals.
6.	Show any nearby waterways streams, rivers, lakes, or retention basins.		
7.	Show any underground or aboveground tanks.		
8.	Show new tank location and indicate shortest distance to buildings and property lines.		

• **NOTICE:** It is advisable for the owners/operators to become familiar with the codes and regulations applicable to their operation. Table 2 lists some of the codes and regulations governing aboveground storage tanks.

Table No. 2

CODES, REGULATIONS, AND GUIDELINES

Aboveground fuel storage tanks fall under a variety of governmental jurisdictions; therefore the following reference is provided as a general outline. You may be subject to different legislation and governing bodies in your specific locale. A preliminary investigation must be conducted to thoroughly understand the controlling factors prior to the utilizing the product in your specific area.

FEDERAL REGULATIONS

40 CFR 112

US Coast Guard

Environmental Protection Agency (EPA)

Occupational Safety and Health Administration (OSHA)

STATE REGULATIONS

Federal regulations are referred to the governor of each state with the instructions that delegated duties to subordinate state agencies must provide a written plan on how the individual state will comply with the EPA's enforcement activities.

CODES AND STANDARDS

NFPA 30, 30A, and 31 Flammable and Combustible Liquid Code

ICBO Uniform Fire Code section 79 APPENDIX A - II - F (UFC)

Building Officials and Code Administration (BOCA)


Underwriters Laboratories (UL)

Underwriter's Laboratories Canada (UL CAN/ORD)

Southern Building Code Congress Institute (SBCCI)

ENVIRONMENTAL CAVEAT

Several regulatory agencies have been integrally involved in the development of the ConVault® aboveground storage tanks.



SPECIFICATIONS

1. The Insulated Secondary Containment Aboveground Storage Tank Systems for Flammable and Combustible Liquids, Protected Type: Vehicle Impact Protected, and Projectile Resistant shall be tested to and listed for the following:
 - A. **UL - 142**, aboveground steel tanks for flammable and combustible liquids..
 - B. **UL - 2085**, two-hour furnace fire test and two hour simulated pool fire test for insulated and protected tank.
 - C. **UL - 2085 and UFC Test Standard (Article 79 or APPENDIX #A-II-F-1)** for both Vehicle Impact Protection and Projectile Resistance.
 - D. **UL - 2085**, Protected aboveground tanks for flammable and combustible liquids.
 - E. **UL -2085 Non-Metallic Secondary Containment** protected tanks for flammable and combustible liquids with secondary containment Emergency Venting by "Form of Construction".
 - F. **CAN/ULC (ORD- 142.18)** Standard for shop fabricated steel aboveground horizontal tanks for flammable and combustible liquids.
 - G. **CAN/ULC- (ORD - C 142.16)** Standard for protected aboveground tank assemblies for flammable and combustible liquids
 - H. **CAN/ULC- (ORD - C 142.5)** Standard for concrete encased aboveground tank assemblies for flammable and combustible liquids.
 - I. **CAN/ULC- (ORD - C 142.16)** the furnace burn requirements for two hour fire rating.
 - J. **CAN/ULC- (ORD - C 142.25)** the open (pool) fire testing for two-hour flammable liquid fire test.
 - K. **CAN/ULC- (ORD - 142.23)** Standard for aboveground tanks for used oil.
 - L. The requirement for uniform fire code for two-hour (firewall) test. Specifications.
 - M. To be tested and certified by the California Air Resources Board (CARB) for Balanced Phase 1 and Phase 2 Vapor Recovery including methanol and ethanol.
2. The primary steel tank shall be rectangular or cylindrical in shape and have continuous welds on all exterior seams, manufactured in accordance with UL listing requirements and UL Standard 142.
3. The primary steel tank shall be pressure tested at 5 psig for 24 hours.
4. The primary steel tanks shall have "emergency vent" system as per NFPA'30 Code

HOME
 GENERAL INFO
 TECHNICAL INFO
 DISTRIBUTORS
 GSA PURCHASING
 NEWS & VIEWS
 CHEMVAULT
 LINKS
 TERMS OF USE
 MARKETING
 MEMBERS
 NETWORK MEMBERS
 NEWS RELEASE

OWNER'S
 INFORMATION

CONVERSION CHARTS

requirements.

5. The protected and insulated AST systems shall have a thru-tank leak detector tube to allow for physical checkup and monitoring capability between the primary and the secondary containment.
6. The primary steel tank shall be pressurized at 5 psig during concrete encasement.
7. The outer surface of the primary steel tank shall be covered by a minimum of 1/4" Thick (6.4 mm) Styrofoam insulation panels or equally acceptable thermal insulation.
8. The secondary containment shall consist of a 30 Mil thick (0.76 mm) High-Density Polyethylene membrane enclosing the steel tank and insulation material.
9. The primary steel tank and the secondary containment shall be encased in six inches of monolithic reinforced concrete, with minimum design strength of 4,000 and 5,000 psi at 28 days depending on the tank size. The concrete design shall include the following for long-term durability: air entrainment, water reducing admixture, and steel reinforcement. Concrete encasements with seams will not be approved.
10. The protected and insulated AST systems shall be of concrete exterior and a continuous and visually verifiable monolithic (seamless) pour on top, bottom, ends, and sides and contain no cold joints or heat sinks (heat transfer points). The AST must be shop fabricated and tested in accordance with the UL listings. Designs that use two layers of steel with insulation material between them will not be approved.
11. No steel or insulating material shall come in contact with the concrete or other corrosive material.
12. All openings shall be from the top only.
13. All exposed metal must be powder coated to inhibit corrosion.
14. The protected and insulated AST systems shall include a minimum 5-15 gallon powder coated UL listed spill containment, and shall include normally closed valve to release spilled product into the primary steel tank. Spill containment which route the spilled product into interstitial area will not be approved.
15. The protected and insulated AST systems shall have a coated concrete exterior to resist weather and reflect sunlight. Models with steel exteriors will not be approved.
16. 16. The protected and insulated AST systems shall have a warranty of 30 years for systems 2,000 Gallon capacity and larger and 20 years for systems 1,000 Gallon capacity and smaller with optional 30-year warranty.
17. The protected and insulated AST systems design shall have been in use for a minimum of thirteen (13) years. The manufacturer must stipulate no AST containment system failure in 24,000 units produced.
18. The protected and insulated AST systems shall have two (2) lugs for connecting grounding conductors for lightening protection in accordance with NFPA 780

ATTACHMENT D (continued)

**Information Used to Determine Emissions
for
TSB & SB GEVS**

Table 3.12-1 Estimated Annual Radiological and Mixed Wastes

Waste Type	Radiological Waste		Mixed Waste	
	Total Mass Kg (lb)	Uranium Content Kg (lb)	Total Mass Kg/lb	Uranium Content Kg/lb
→ Activated Carbon	300 (662)	25 (55)	-	-
→ Activated Alumina	2,160 (4,763)	2.2 (4.9)	-	-
Fomblin Oil Recovery Sludge	20 (44)	5 (11)	-	-
Liquid Waste Treatment Sludge	400 (882)	57 (126) ⁴	-	-
Activated Sodium Fluoride ¹	-	-	-	-
Assorted Materials (paper, packing, clothing, wipes, etc.)	2,100 (4,631)	30 (66)	-	-
→ Ventilation Filters	61,464 (135,506)	5.5 (12)	-	-
Non-Metallic Components	5,000 (11,025)	Trace ⁵	-	-
Miscellaneous Mixed Wastes (organic compounds) ^{2,3}			50 (110)	2 (4.4)
Combustible Waste	3,500 (7,718)	Trace ⁵	-	-
Scrap Metal	12,000(26,460)	Trace ⁵	-	-

¹ No NaF wastes are produced on an annual basis. The Contingency Dump System NaF traps are not expected to saturate over the life of the plant.

² A mixed waste is a low-activity radioactive waste containing listed or characteristic of hazardous wastes as specified in 40 CFR 261, subparts C and D (CFR, 2003p).

³ Representative organic compounds consist of acetone, toluene, ethanol, and petroleum ether

⁴ The value of 57 kg (126 lb) is comprised of uranium in the Decontamination System citric acid and degreaser tanks, precipitated aqueous solutions, uranium in precipitated laboratory/miscellaneous effluents, and uranium in sludge from the Decontamination System citric acid and degreaser tanks.

⁵ Trace is defined as not detectable above naturally-occurring background concentrations.

Table 3.12-3 Estimated Annual Gaseous Effluent

Page 1 of 1

Area	Quantity (yr ⁻¹)	Discharge Rate m ³ /yr. (SCF/yr. (STP))
Gaseous Effluent Vent Systems	NA	2.6 x 10 ⁸ (9.18 x 10 ⁸)
HVAC Systems	NA	
Radiological Areas	NA	1.5 x 10 ⁹ (max) (5.17 x 10 ¹⁰)
Non-Radiological Areas	NA	1.0 x 10 ⁹ (max) (3.54x10 ¹⁰)
Total Gaseous HVAC Discharge	NA	2.5 x 10 ⁹ (max) (8.71x10 ¹⁰)
Constituents:		
Helium	440 m ³ (STP) (15,540 ft ³)	NA
Nitrogen	52 m ³ (STP) (1,836 ft ³)	NA
Ethanol	40 L (10.6 gal)	NA
Laboratory Compounds	Traces (HF)	NA
Argon	190 m ³ (STP) (6,709 ft ³)	NA
→ Hydrogen Fluoride	<1.0 kg (<2.2 lb)	NA
→ Uranium	<10 g (<0.0221 lb)	NA
Methylene Chloride	610 L (161 gal)	NA
Thermal Waste:		
Summer Peak	3.2 x 10 ⁶ J/hr (3.1x10 ⁶ BTU/hr)	NA
Winter Peak	1.0 x 10 ⁷ J/hr (9.5x10 ⁶ BTU/hr)	NA

NA – Not Applicable

ATTACHMENT D (continued)

Information Used to Determine Fugitive Emissions

Table 3.12-3 Estimated Annual Gaseous Effluent

Page 1 of 1



Area	Quantity (yr ⁻¹)	Discharge Rate m ³ /yr. (SCF/yr. (STP))
Gaseous Effluent Vent Systems	NA	2.6 x 10 ⁸ (9.18 x 10 ⁹)
HVAC Systems	NA	
Radiological Areas	NA	1.5 x 10 ⁹ (max) (5.17 x 10 ¹⁰)
Non-Radiological Areas	NA	1.0 x 10 ⁹ (max) (3.54x10 ¹⁰)
Total Gaseous HVAC Discharge	NA	2.5 x 10 ⁹ (max) (8.71x10 ¹⁰)
Constituents:		
Helium	440 m ³ (STP) (15,540 ft ³)	NA
Nitrogen	52 m ³ (STP) (1,836 ft ³)	NA
→ Ethanol	40 L (10.6 gal)	NA
Laboratory Compounds	Traces (HF)	NA
Argon	190 m ³ (STP) (6,709 ft ³)	NA
Hydrogen Fluoride	<1.0 kg (<2.2 lb)	NA
Uranium	<10 g (<0.0221 lb)	NA
→ Methylene Chloride	610 L (161 gal)	NA
Thermal Waste:		
Summer Peak	3.2 x 10 ⁶ J/hr (3.1x10 ⁶ BTU/hr)	NA
Winter Peak	1.0 x 10 ⁷ J/hr (9.5x10 ⁶ BTU/hr)	NA

NA – Not Applicable

ATTACHMENT D (continued)

Information Related to Cooling Towers

ISO 9001
COMPLIANT



HXV CLOSED CIRCUIT HYBRID COOLING TOWERS



COOLING
TOWERS

CLOSED CIRCUIT
COOLING

THERMAL
STORAGE

REFRIGERATION




Baltimore Aircoil

HXV Closed Circuit Hybrid Cooling Tower

**Combined Operation Technology for Efficient Cooling, Plume Abatement,
and Maximum Water Savings**

The HXV can be a problem solver for your toughest projects. With its patented design, the HXV utilizes Combined Operation Technology to provide the best of both evaporative and dry cooling in a single, compact, energy-efficient, and water-conserving unit.



Industrial process facility installing multiple HXV cells.

Applications Include:

Plume sensitive jobs, such as airports or locations near highways or historic areas, where visible plume can be significantly reduced in wet modes and eliminated completely in dry mode.

Jobs in locales where water costs are high, as water consumption can be reduced by up to 70% over conventional evaporative products, yet still provide the low fluid temperatures critical for high system efficiency.

Projects where water supply is limited, but supply permits can be obtained thanks to the reduced water consumption of the HXV.

Critical use facilities, such as Internet data centers or hospitals, where cooling equipment must function even in the event of an interruption in the water supply.

High temperature (>180°F) cooling, where the incoming fluid needs to be tempered in the dry cooling section before entering the evaporative coil.

This unique product is the culmination of years of BAC research and development, as well as the trailblazing efforts of our BAC colleagues in Europe, where water costs can be up to ten times the rates here in North America.

This creative design has already garnered several patents and product innovation awards in both Europe and North America.

The installations pictured in this brochure are a sample of the many successful projects using the HXV for critical cooling duties.



HXV installation with optional flow control package for comfort cooling application.

Efficient Process Cooling with Plume Abatement and Maximum Water Savings

The HXV Provides:

Plume Reduction

Many installations are sensitive to the visible plume (saturated discharge air) that is emitted from evaporative cooling towers. For locations such as airports and vehicle passageways, plume can also create safety concerns. The HXV offers a combination of sensible, adiabatic, and evaporative heat transfer to significantly reduce any plume that may occur with conventional evaporative cooling equipment. During the coldest times of the year, when the potential for visible discharge is greatest, the HXV operates 100% dry, completely eliminating plume.

Closed Circuit Cooling


Closed circuit cooling protects the process fluid from contamination, reduces fouling potential, and ensures that maximum system efficiency is maintained over time.

Low Process Fluid Temperatures Even at Peak Load Conditions

The HXV concept incorporates the use of evaporative heat transfer during the summer peak. This results in much lower cooling temperatures than can be achieved with conventional air-cooled systems at a fraction of the fan horsepower and unit plan area.

Maximum Water Savings

Water savings are achieved throughout the year with each of three different operating modes of the HXV. At peak conditions in the "dry/wet" operating mode a significant amount of heat is removed by sensible heat transfer, providing reduced water consumption versus conventional evaporative cooling. When the heat load and/or ambient temperatures drop, water consumption is further reduced, particularly in the "adiabatic" operating mode, and is totally eliminated in the "dry" operating mode. In many areas, the water cost savings alone can pay for the equipment in as little as two years!



**HXV PLUME REDUCTION AND WATER CONSERVING TECHNOLOGY
...A UNIQUE APPROACH TO MEET TODAY'S DEMANDING ENVIRONMENTAL NEEDS.**

HXV Modes of Operation

Control Summary:

Operation Mode	Dry Finned Coil Fluid Flow	Wet Prime Surface Coil Fluid Flow	Spray Pump	Fan(s)
Combined Dry/Wet	100%	Modulating	On	On
Adiabatic	100%	0%	On	On
Dry	100%	100%	Off	On

Notes: 1) During dry mode, two-speed, variable frequency drive (VFD), or Energy-Miser® fan motor operation is also possible.



2) For both dry/wet and adiabatic operation modes, the use of an automatic blowdown system is recommended to minimize the water consumption.


Combined Dry/Wet Operation Mode

In this mode, the fluid to be cooled is fed first to the dry finned coil and then to the prime surface evaporative coil, where the cooled fluid exits the unit. Spray water is drawn from the cold-water sump and pumped to the water distribution system above the prime surface coil. Wetting the prime surface coil allows evaporative cooling to occur. The spray water falls from the prime surface coil over the wet deck surface, enhancing the evaporative heat transfer by sub-cooling the spray water. Air is drawn through both the prime surface coil and through the wet deck surface where it is saturated and picks up heat. The air is, however, still cold enough to achieve significant cooling within the finned coil which is installed at the

discharge above the fan(s). In the dry/wet mode, both sensible and evaporative heat transfer are used. Compared to a conventional evaporative unit the potential for plume is substantially reduced and significant water savings can be obtained, even at peak design conditions.


At reduced heat load and/or ambient temperatures the evaporative cooling portion, and hence water usage, are further reduced as the flow fed through the evaporative coil is gradually decreased. This is accomplished by a modulating flow control valve arrangement, which controls the outlet fluid temperature. This control arrangement automatically assures maximum use of sensible cooling in the finned coil and minimum use of evaporative cooling in the prime surface coil. Heat transfer method and flow control are arranged to achieve maximum water savings in the dry/wet mode. Plume is minimized by reducing the amount of evaporated water and the heating of the entire discharge air with the dry finned coil.






Adiabatic Mode

The adiabatic mode occurs when the fluid to be cooled completely bypasses the evaporative prime surface coil. No heat is rejected from this coil and the re-circulating spray water merely serves to saturate and adiabatically pre-cool the incoming outside air. In most climates, the ambient air still has considerable potential for absorbing moisture. Thus adiabatic cooling of the incoming air results in significantly lower air temperatures, which greatly increases the rate of sensible heat transfer. Compared to conventional evaporative cooling equipment, visible plume and water consumption are greatly reduced while maintaining the low fluid design temperatures required to maximize system efficiency.




Dry Mode

During the dry operation mode the spray water system is turned off, saving on pump energy. The fluid to be cooled is fed from the finned coil to the prime surface coil. The modulating flow control valve remains fully open to ensure both coils receive the full fluid flow in series; hence the maximum heat transfer surface is available. In this mode no water consumption occurs, and plume is completely eliminated. HXV units can be economically selected for dry bulb switchover points of 50°F (10°C) to 60°F (15°C) or higher, depending on the specific needs of the project. When the equipment operates in the dry mode for prolonged periods, draining the cold-water basin is recommended, eliminating the need for freeze protection and water treatment.




HXV Offers Economic Advantages



Dry bulb / wet bulb difference versus climate zone.

HXV First Cost Benefits

Heat rejection equipment must be selected for the maximum heat load at summer peak air temperatures. In most climates, peak wet bulb temperatures are significantly lower than peak dry bulb temperatures. Evaporative cooling equipment based on the ambient air wet bulb therefore has a greater temperature driving force, thus allowing the use of lower system design temperatures. This greater driving force also allows the use of less, and thus more cost-effective, heat transfer surface area. Because the HXV utilizes evaporative cooling during peak load operation, it inherently benefits from this advantage. Evaporatively cooled units such as the HXV have a plan area and fan horsepower advantage over the typical air-cooled arrangement, saving on support structures and electrical hook-ups. The HXV design also avoids the corrosion and scaling that can be associated with spraying of standard air-cooled equipment on design days for additional capacity. The lower process fluid temperatures that can be achieved compared to air-cooled systems, as well as the greatly reduced fouling factors of closed loop cooling, also result in lower first cost of process equipment such as




Closed Circuit Cooling Systems offer the lowest fluid temperatures.

chillers and refrigeration compressors. Finally, the costs associated with plume abatement are eliminated, as the design is inherently plume-free.


HXV Operating Cost Benefits

The water saving concept and Combined Flow design of the HXV offer significant operating cost benefits. Water consumption is minimized throughout the year. During peak summer operation a large amount of heat load is already transferred by the finned coil. As the ambient temperature and/or heat load drops, the amount of evaporative heat transfer is further reduced by controlling the flow through the wet coil. This reduces the evaporation loss and blow-down as well as water treatment requirements compared to conventional evaporative cooling equipment. In the "adiabatic" mode only a small amount of water is needed to saturate the air and the amount of blow-down is reduced even further. Finally, in the "dry" mode no water is used at all (while saving the energy associated with running the spray pump).



Typical annual distribution of ambient temperature with the three operating modes.

With HXV hybrid units water savings up to 70% or more are possible. Depending on local water costs and availability, this advantage alone can pay for the equipment in as little as two years through cost savings in water use, water treatment chemicals, sewage charges, and higher system efficiencies. In addition, fouling potential associated with open circuit cooling towers is eliminated through both the closed loop cooling system and the Advanced Coil Technology design of the HXV, assuring peak efficiency and energy savings over time. Finally, the induced draft propeller fan design results in low fan energy requirements compared to centrifugal fan units.



Optional HXV Accessories

Like the FXV product line of Closed Circuit Cooling Towers, all HXV units are available with a complete line of accessories for virtually every application need. These options include internal and external service platforms, sound attenuation, electric water level control, and the Energy-Miser[®] Fan System. The economical welded Type 304 stainless steel water-contact basin option also comes with a full five-year leak-free warranty.

Flow Control Package (optional)


Also available for the HXV is a completely engineered flow control package designed to provide maximum plume control and water savings. This package consists of a temperature sensor, a 3-way flow control valve arrangement with actuator, and all connecting piping. This option saves on the time required to select components and design the piping as well as reducing the cost of field installation. The package also provides single inlet and outlet connection points for field piping.

Five-Year Mechanical Equipment Warranty


The five-year warranty provided on BAC HXV Closed Circuit Hybrid Cooling Towers is the most comprehensive fan motor and mechanical equipment warranty available in the industry. Included in the five-year warranty are the mechanical equipment support(s), fan(s), fan shaft(s), bearings, sheaves, and fan motor(s).

ISO 9001 Certification

ISO 9001 Certification guarantees the consistently high quality of HXV Closed Circuit Hybrid Cooling Towers. It confirms BAC's commitment to quality assurance and reaffirms that BAC meets international standards set for management principles, designs, closed-loop corrective action, training, and documentation control in all of its engineering and manufacturing operations.



HXV with optional external service platform and flow control package.



Optional flow control package (shown in blue).

BAC Advanced Engineering Worldwide

Founded in 1938, Baltimore Aircoil Company specializes in the design and manufacture of evaporative cooling and heat transfer equipment. The superior performance advantages of BAC products are the result of a continuing research and development program and years of engineering experience. The design and construction innovations developed by BAC engineers offer more installation flexibility and easier maintenance plus longer, more reliable and cost-effective operation. Facilities and offices located worldwide can provide the Engineering support for all of your project needs.

BAC has pioneered the design and manufacture of closed-circuit cooling systems for water source heat pump loops, chiller loops, and many industrial processes, such as air compressor cooling, induction furnace cooling, and multiple heat exchanger loops. Recognizing the growing needs for plume abatement, water conservation, and low energy consumption, BAC has developed the HXV hybrid wet/dry technology to serve all these Markets.


Building on Combined Flow Technology

The HXV product line is based on the CTI Certified FXV line of closed circuit cooling towers, which utilizes patented Combined Flow Technology to provide high heat transfer rates at low fan horsepower in a compact footprint.


Both the FXV and HXV product lines utilize Advanced Coil Technology, which sustains high thermal performance and extends the life of the evaporative coil through the following features:

- Air and spray water flow in a parallel path
- Increased spray water flowrate over the coil
- Evaporative cooling occurs primarily in the wet deck section, not the coil section
- Colder spray water reduces scale potential

Both products feature heavy-duty construction, excellent access and maintenance features, and a wide variety of optional accessories.



BAC Research and Development Laboratory.



FXV closed circuit cooling tower installation.




Baltimore Aircoil

P.O. Box 7322, Baltimore, MD 21227
Phone: 410-799-6200 • Fax: 410-799-6416
Web site: <http://www.baltimoreaircoil.com>

ATTACHMENT E


**NEF 5-Kilometer Radius Map
7.5 Minute Topographic Quadrangle**



* DISTANCES MEASURED FROM CENTER OF THE TECHNICAL SERVICES BUILDING (TSB)

** FACILITY PROPERTY BOUNDARY ALSO DEFINES THE AREA THAT WILL BE RESTRICTED TO PUBLIC ACCESS.

USGS 7.5 MINUTE
MAP INDEX



MAP SOURCE:
USGS 7.5 MINUTE
EUNICE NE QUADRANGLE
EUNICE SE QUADRANGLE
TEX.-N. MEX. 1:24000



LOCKWOOD GREENE
ENGINEERS & GEOTECHNICAL
CONSULTANTS
REFERENCE NUMBER
7.5Min Figure.dwg



ATTACHMENT E
7.5 MINUTE TOPOGRAPHIC QUADRANGLE

ATTACHMENT F

**NEF is applying for a Notice of Intent and therefore,
a Public Notice is not applicable
as per NMAC 20.2.73.200.B**

ATTACHMENT G

Description of Facility Operations

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

Description of NEF Operations and Systems

The NEF is designed to separate a feed stream containing the naturally occurring proportions of uranium isotopes into a product stream enriched in ^{235}U and a stream depleted in the ^{235}U isotope. The feed material for the enrichment process is uranium hexafluoride (UF_6) with a natural composition of isotopes ^{234}U , ^{235}U , and ^{238}U . The enrichment process involves the mechanical separation of isotopes using a fast-rotating cylinder (centrifuge) which is based on a difference in centrifugal forces due to differences in molecular weight of the uranic isotopes. No chemical or nuclear reactions take place. The feed, product, and depleted UF_6 streams are all in the form of UF_6 . The UF_6 is delivered to the plant in standard Type 48X or 48Y international transit cylinders, which are connected to the plant in feed stations joined to a common manifold. Heat is then applied electrically to sublime UF_6 from solid to vapor. The gas is flow controlled through a pressure control system for distribution to individual cascades at sub-atmospheric pressure.

Individual centrifuges are not able to produce the desired product and depleted UF_6 concentration in a single step. They are therefore grouped together in series and parallel to form arrays known as cascades. A typical cascade hall comprises many hundreds of centrifuges. A cascade hall is made up of eight cascades. UF_6 is drawn through cascades with vacuum pumps and moved to the transport cylinders located in product and tails take-off stations where it can desublime. Highly reliable UF_6 resistant pumps have been developed for transferring the process gas.

Depleted uranium material is desublimed at the Tails Low-Temperature Take-Off Station into chilled Uranium Byproduct Cylinders (UBCs), Type 48Y. The product is desublimed into 30B cylinders for shipping or Type 48Y for internal use.

The entire plant process gas system operates at sub-atmospheric pressure. This provides a high degree of safety but also means that the system is susceptible to in-leakage of air. Any in-leakage of air passes through the cascades and is preferentially directed into the product stream. A gaseous effluent vent system is provided to remove uranium and hydrogen fluoride prior to discharge to atmosphere via an exhaust stack.

Each Plant Module – consisting of two Cascade Halls - is provided with a cooling water system to remove excess heat at key positions on the centrifuges in order to maintain optimum temperatures within the centrifuges. The centrifuges are driven by a medium frequency Alternating Current (AC) supply system. A converter produces the medium frequency supply from the AC main supply using high efficiency switching devices for both run-up and continuous operation.

Major Facility Areas and Structures

The major structures and areas of the NEF are described below and shown in Figure G-1 of this Attachment

The Security Building serves as the primary access control point for the facility. It also contains the necessary space and provisions for an alternate Emergency Operations Center (EOC) should the primary facility become unusable.

ATTACHMENT G State of New Mexico Air Quality Notice of Intent

The Separations Building houses three, essentially identical, plant process units. Each Separations Building Module is comprised of a UF₆ Handling Area, two Cascade Halls, and a Process Services Area. UF₆ is fed into the Cascade Halls and enriched UF₆ and depleted UF₆ are removed. The Cylinder Receipt and Dispatch Building (CRDB) is located between Separations Building Modules.

The Centrifuge Assembly Building (CAB) is used to assemble centrifuges before the centrifuges are moved to the Separations Building and installed in the cascades. The Technical Services Building (TSB) contains various laboratories and maintenance facilities necessary to safely operate and maintain the facility. The TSB also includes a Medical Room and the Control Room. In an emergency, the Control Room serves as the primary Emergency Operations Center (EOC) for the facility. Most site infrastructure facilities (i.e., laboratories for sample analysis) are located in the TSB.

The Central Utilities Building (CUB) provides a central location for the utility services for the process buildings. The CUB also contains the two standby diesel powered electric generators that provide power to protect selected equipment in the unlikely event of loss of offsite supplied power. The building also contains electrical rooms, an air compression room, a boiler room, and cooling water facility.

The Cylinder Receipt and Dispatch Building (CRDB) is used to receive, inspect, weigh and temporarily store cylinders of natural UF₆ sent to the plant and dispatch cylinders of enriched UF₆ to customers. Additionally, clean, empty product and UBC are received, inspected, weighed, and temporarily stored prior to their being filled in the Separations Building.

The UBC Storage Pad is a series of concrete pads designed to store UBCs, which contain UF₆ that is depleted in ²³⁵U. The depleted uranium is stored under vacuum in corrosion resistant type 48Y cylinders.

A single-lined UBC Storage Pad Stormwater Retention Basin will be used specifically to retain runoff from the UBC Storage Pad during heavy rainfalls. This basin will also receive cooling tower and heating boiler blowdown. The unlined Site Stormwater Detention basin will receive rainfall runoff from the balance of the developed plant site. Liquid effluent from plant process systems will be discharged to the double-lined Treated Effluent Evaporative Basin provided with a leak detection system.

Air Emission Systems

Technical Services Building Confinement Ventilation System (Stack #1)

The TSB Confinement Ventilation System maintains the room temperature in the clean areas, potentially contaminated areas, laboratories, locker rooms, link corridors, general offices, break room, storage areas and the Control Room. The potentially contaminated areas include those areas where uranium is stored or analyzed. A process flow diagram for this system is shown in Attachment A, Sheets #1 and #2.

The potentially contaminated rooms include the Decontamination Workshop, Cylinder Preparation Room and Ventilated Room. The HVAC system for these rooms consists of two, 50% capacity AHUs. Airflow from the potentially contaminated rooms is exhausted through two, 50% capacity Bag-In/Bag-Out high efficiency particulate air (HEPA) filters

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

by one of two, 100% capacity filtration exhaust fans. The exhaust air is then discharged to the exhaust stack and monitored for alpha radiation and hydrogen fluoride (HF). Some potentially contaminated areas have fume hoods, which are connected to the TSB GEVS.

The noncontaminated areas include the TSB GEVS Room, Laundry, Mechanical/Electrical & Instrumentation (ME&I) Workshop, Solid Waste Collection Room (SWCR), Vacuum Pump Rebuild Workshop, and Liquid Effluent Collection and Treatment Room. The HVAC system consists of two 50% capacity AHUs. Airflow from the clean areas is returned/exhausted by two 50% capacity return/exhaust fans. A majority of the ventilation air from the clean areas is recirculated, and the remaining air is discharged through the exhaust stack. The Vacuum Pump Rebuild Workshop and ME&I Workshop are provided with a general exhaust system and discharged to the atmosphere.

The locker rooms, access corridors, first and second floor offices, break room, and storage rooms HVAC system consists of one 100% capacity AHU with two 50% capacity supply air fans, and two 50% capacity return/exhaust fans. The Control Room HVAC system consists of two 100% capacity computer room AC units.

The Chemical, Mass Spectrometry, and Environmental Monitoring Laboratory HVAC systems consists of one, 100% capacity AHU with two, 100% capacity supply air fans, and two, 100% capacity exhaust fans. The ventilation air is discharged to an exhaust stack. The Environmental Laboratory is designed to be at a positive pressure to the surrounding rooms while the Mass Spectrometry and Chemical Laboratories are maintained at a negative pressure with respect to the surrounding rooms. Any potentially contaminated fume hoods in the Chemical and Mass Spectrometry Laboratories are connected to the TSB GEVS. Non-contaminated fume hoods and the HVAC for these three laboratories are exhausted to the atmosphere.

The confinement function of the HVAC in the TSB is designed to maintain the clean areas at positive room pressure and the potentially contaminated areas at slightly negative room pressure. This ensures that the airflow direction is from areas of little or no potential for contamination to areas of higher potential for contamination. Pressure zones are controlled by adjusting the filtered exhaust airflow rate and the supply airflow rate accordingly. Also, appropriate access controls are provided to maintain proper airflow patterns.

Exhaust flow from the potentially contaminated rooms (i.e., Ventilated Room, Cylinder Preparation Room and Decontamination Workshop) of the TSB is filtered by a pre-filter, activated carbon filter and HEPA filter and is then released through an exhaust stack. The exhaust stack flow is continuously monitored for alpha and HF. The stack exhaust is periodically sampled. The continuous monitoring and periodic sampling is in accordance with the guidance in Regulatory Guide 4.16.

Plant Hot Water Boilers (Stacks #2 & #3)

The constructed plant will have two 300 Horsepower hot water boilers that will be used to provide comfort and industrial space heating for all the site facilities. Although there are two boilers at NEF, only one boiler will be used at any one time. The other boiler is a back-up or standby boiler. The boilers are identical and use natural gas as fuel. Emission data was provided by the manufacturer.

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

Standby Diesel Generator System (Stacks #4 & #5)

The Standby Diesel Generator System provides backup 480 volt power to the NEF during a loss of normal power. The Standby Diesel Generator System is not a requirement for safe operation of the plant and is installed to provide protection of investment only.

The Standby Diesel Generator System is comprised of two, 100% rated generators that supply the total backup power required. The Standby Diesel Generator System is installed in the Central Utilities Building. In the event of normal power failure, the Standby Diesel Generator System maintains plant services that protect the capital investment.

Although there are two generators, annual testing will be performed at only one generator at a time. The annual test operational time for each boiler is less than 300 hours. For emission estimation purposes, it was assumed that each generator was operated a total of 300 hours in one year, but not simultaneously. Both generators would be required to operate if a site emergency were to occur that knocked out all incoming electrical service.

The functional requirement of the Standby Diesel Generator System is to provide backup power within approximately 10 seconds after a normal power interruption. There is sufficient fuel storage capacity to operate the system at rated capacity until the process equipment is run to standstill.

The addition of other smaller standby diesel generators is presently being evaluated. The site and number of these additional standby diesel generators is not known at this time.

Cooling Towers (Stacks #6, #7, #8 and #9)

NEF will employ four cooling tower units; two to support the cascade halls and two to support the comfort HVAC systems. The towers will be of closed circuit hybrid type that can provide both evaporative and dry cooling in a compact, energy efficient and water-conserving unit. Visible plumes are significantly reduced in the wet (evaporative) modes and completely eliminated in the dry mode. Water consumption can be reduced by up to 70% over conventional evaporative coolers.

Diesel Generator Storage Tanks (Stack #10)

NEF will utilize two, 6000-gallon above ground storage tanks to store the #2 Diesel Fuel required to operate the site's two 3500 Horsepower emergency generators. The tanks selected will meet all NMAC requirements. The tanks will have steel construction with secondary containment and concrete vault. The secondary containment consists of wrapping the steel tank with a minimum ¼ inch thick Styrofoam insulation and an impervious barrier of 30 mil high density polyethylene membrane. The maximum temperature of the tank contents never exceeds 70°F. The reinforced concrete vault is six (6) inches thick and poured in a monolithic fashion so there are no joints and no heat sinks in the concrete. There are two tank pressure vents, one normal mode that opens at a tank pressure of 2.0 oz/in² and the other an emergency release vent that full opens at 0.5 psig.

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

Centrifuge Test and Centrifuge Post Mortem Processes (Stack #11)

This section describes the basic components, functional requirements, and utilities required for operation of the Centrifuge Test Facility (CTF) and Centrifuge Post Mortem Facility (CPMF). The CTF and CPMF are located in the Centrifuge Assembly Building (CAB). These two facilities are segregated within the CAB for two reasons; the presence of uranium hexafluoride results in the areas being classified as process areas and the sensitive operations undertaken within the facilities require personnel access control.

Centrifuge Test Facility

Functional Description

The principal functions of the Centrifuge Test Facility (CTF) are to provide a means of functionally testing the performance of production centrifuges to ensure compliance with design parameters and to investigate production and operational problems. The facility consists of two test positions.

Testing in the CTF is performed by feeding a stream of gaseous UF₆ into the centrifuge and removing enriched and depleted streams, Product and Tails, respectively. The enriched UF₆ stream is referred to as the Product Stream. The depleted UF₆ stream is referred to as the Tails Stream. During this process, the centrifuge is maintained at the required operating frequency, temperature, and pressure, and samples are taken from the Product and Tails streams to enable determination of the separative capacity of the centrifuge under test. The discharge line from the mobile vacuum pump set and flexible exhaust hose is provided to the Centrifuge Test and Post Mortem Facilities Exhaust Filtration System.

Centrifuge Test and Post Mortem Facilities Exhaust Filtration System (Stack #11)

The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System provides exhaust of potentially hazardous contaminants from the Centrifuge Test and Post Mortem Facilities. The system also ensures the Centrifuge Post Mortem Facility is maintained at a negative pressure with respect to adjacent areas. The system is shown on Attachment A, Sheets 1 & 3, NEF Process Block Diagram and Flow Diagram Centrifuge Storage & Miscellaneous Areas (CAB). The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System is located in the Centrifuge Assembly Building and is monitored from the Control Room.

Functional Description

Potentially contaminated exhaust air comes from the Centrifuge Test and Post Mortem Facilities. The total airflow to be handled by the Centrifuge Test and Post Mortem Facilities Exhaust Filtration System is 9,345 m³/hr (5,500 cfm). Flow rates and capacities are preliminary and are subject to change during final design.

The design requirements for the facility provide a large safety margin between normal and accident conditions so that no single failure could result in the release of significant hazardous material. The amounts of UF₆ in the system also preclude the release of significant quantities of hazardous material from a single failure or multiple failures. Instrumentation is provided to detect abnormal process conditions so that the process can be returned to normal by operator actions.

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

These requirements and operating conditions also assure "as low as reasonably achievable" personnel exposure to hazardous materials and compliance with environmental and safety criteria.

Major Components

The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System consists of the following major components.

1. Duct system
2. Prefilter
3. Impregnated carbon filter (impregnated with potassium carbonate)
4. High Efficiency Particulate Air Filter (HEPA)
5. Two exhaust filtration fans
6. Exhaust stack
7. Stack alpha monitor
8. Stack HF monitor.

Design Description

The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System consists of a duct network that serves the Centrifuge Test and Post Mortem Facilities and operates at negative pressure. The ductwork is connected to one filter station and vents through either of two 100% fans. Both the filter station and either of the fans can handle 100% of the effluent. One of the fans will normally be in standby. Operations that require the Centrifuge Test and Post Mortem Facilities Exhaust Filtration System to be operational are manually shut down if the system shuts down. The system capacity is estimated to be 9,345 m³/hr (5,500 cfm).

Gases from the associated areas pass through the 85% efficient prefilter which removes dust and protects the carbon filter, then through the 99.9% efficient activated carbon (potassium carbonate impregnated) filter that captures HF. Remaining uranic particles (mainly UO₂F₂ particles) will be filtered by the 99.97% efficient HEPA filter. The remaining clean gases pass through a fan, which maintains the negative pressure upstream of the filter station. The clean gases are then discharged through the stack on the Centrifuge Assembly Building.

Specifications for filter efficiency testing will be provided during the design phase. A minimum velocity is maintained in the duct system in order to ensure that particulate contaminants are conveyed through the ductwork without settling. Each section also has a damper to balance the individual flows in the system. Flexible exhaust hoses are provided in both the Centrifuge Test Facility and the Centrifuge Post Mortem Facility. A hood is also provided in the Centrifuge Post Mortem Facility.

The materials of construction, corrosion allowances, and fabrication specifications for the equipment and ductwork used in the GEVS are compatible with UF₆ and HF and are noncombustible.

Design and Safety Features

The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System is designed to protect plant personnel against uranium and HF exposure. The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System is designed to meet all applicable NRC -

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

requirements for public and plant personnel safety and effluent control and monitoring. The system design also complies with applicable standards of OSHA, EPA, and state and local agencies.

The Centrifuge Test and Post Mortem Facilities Exhaust Filtration System provides for continuous monitoring and periodic sampling of the gaseous effluent in the exhaust stack in accordance with the guidance in Regulatory Guide 4.16. The system filters contaminated gases, and continuously monitoring exhaust gas flow to the atmosphere. The system also provides primary confinement for the Centrifuge Post Mortem Facility by maintaining the Centrifuge Post Mortem Facility at a negative pressure relative to adjacent areas. An HF monitor and associated alarm and an alpha radiation monitor and associated alarm are installed immediately upstream of the exhaust stack to avoid the release of hazardous materials to the environment. The frequency of filter replacement will be determined during the design phase.

Instrumentation

The process variables, pressure, fan speed, and damper positioning are all controlled automatically. The fan speed is automatically controlled to maintain negative pressure in the system. The differential pressure across the filters is monitored to provide indication of when filter replacement is required. An HF monitor measures the concentration of the gas in the air stream. Also, a radiation detector is used to measure the level of radiological contamination (alpha only) present in the air stream located in the stack. Deviations from specified values for HF and alpha radiation are indicated by alarms. The HF and alpha radiation monitoring devices have non-interruptible power supplies in order to continue to function during a general power failure.

Gaseous Effluent Vent Systems (GEVS)

The function of the GEVS is to remove particulates containing uranium, and HF from potentially contaminated process gas streams. Prefilters and absolute filters (HEPA) remove particulates and potassium carbonate impregnated activated carbon filters are used for the removal of any HF. Electrostatic filters remove oil vapor from the gaseous effluent associated with exhaust from vacuum pump/chemical trap set outlets wherever necessary.

The systems produce solid wastes from the periodic replacement of prefilters, absolute filters, and chemical filters. The systems produce no gaseous effluents of their own, but discharge effluents from other systems after treatment to remove hazardous materials. There are two GEVSs for the plant. The Separations Building GEVS and the TSB GEVS.

Technical Services Building GEVS (Stack #12)

The TSB GEVS provides exhaust of potentially hazardous contaminants. The system is shown on Attachment A, Sheets 1, 4 and 5, NEF Process Block Diagram, PFD GEVS Technical Services Building, and P&ID GEVS Technical Services Building. The GEVS servicing the TSB is located on the first floor of the TSB and is monitored from the Control Room.

Functional Description

Potentially contaminated exhaust air comes from the following rooms and services within the TSB:

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

1. Ventilated Room 2,700 m³/hr (1,589 cfm)
2. Laundry 1,000 m³/hr (589 cfm)
3. Fomblin Oil Recovery System 2,000 m³/hr (1,177 cfm)
4. Decontamination Workshop 12,300 m³/hr (7,240 cfm)
5. Chemical Laboratories 1,000 m³/hr (589 cfm)
6. Cylinder Preparation Room 1,000 m³/hr (589 cfm)
7. Solid Waste Collection Room 700 m³/hr (412 cfm)
8. Air from the Fomblin Oil Recovery System is part of the Decontamination Workshop discharge.

Thus, the total airflow to be handled by the TSB GEVS is 18,700 m³/hr (11,000 cfm). Flow rates and capacities are preliminary and are subject to change during final design. The design requirements for the facility provide a large safety margin between normal and accident conditions so that no single failure could result in the release of significant hazardous material. The amounts of UF₆ in the system also preclude the release of significant quantities of hazardous material from a single failure or multiple failures. Instrumentation is provided to detect abnormal process conditions so that the process can be returned to normal by operator actions.

These requirements and operating conditions also assure "as low as reasonably achievable" personnel exposure to hazardous materials and compliance with environmental and safety criteria.

Major Components

The TSB GEVS consists of the following major components:

1. Duct system
2. Prefilter
3. Impregnated carbon filter (impregnated with potassium carbonate)
4. Centrifugal Fan
5. Monitoring and controls (HF) before and after filters
6. Automatically controlled inlet and outlet isolation dampers
7. Exhaust stack
8. Gamma monitor and controls (prefilter and HEPA filter)
9. Monitoring and controls (alpha and HF) in exhaust stack
10. Stack Sampling system.

Design Description

The GEVS serving the TSB consists of a duct network that serves all of the uranium processing systems and operates at negative pressure. The ductwork is connected to one filter station and vents through one fan. Both the filter station and the fan can handle 100% of the effluent. There is no standby filter station or fan. Operations that require the GEVS to be operational are shut down if the system shuts down. The system capacity is estimated to be 18,700 m³/hr (11,000 cfm). A differential pressure controller controls the fan speed and maintains negative pressure in front of the filter station.

Gases from the UF₆ processing systems pass through the 85% efficient prefilter which removes dust and protects the HEPA filter, then through the 99.97% efficient HEPA filter which removes uranium aerosols (mainly UO₂F₂ particles). Finally the air passes through the 99.9% efficient activated carbon (potassium carbonate impregnated) filter which

ATTACHMENT G

State of New Mexico Air Quality Notice of Intent

captures HF. The remaining clean gases pass through the fan, which maintains the negative pressure upstream of the filter stations. The clean gases are then discharged through the exhaust stack on the TSB. Specifications for filter efficiency testing will be provided during the design phase.

A minimum velocity of 12.7 m/s (2,500 ft/min) is maintained in the duct system in order to ensure that particulate contaminants are conveyed through the ductwork without settling. Each section of the duct system has an orifice plate to maintain a minimum air velocity. Each section also has a damper to balance the individual flows in the system. Flexible exhaust hoses have a capture velocity of 0.75 m/s (150 ft/min). Fume hoods shall have a capture velocity of 0.5 m/s (100 ft/min).

The TSB GEVS provides ventilation and removal of uranium and hydrogen fluoride for the TSB through ductwork, via hoods vented by booster fans to the technical services area, the chemical laboratory, and the vacuum pump rebuild workshop.

The materials of construction, corrosion allowances, and fabrication specifications for the equipment and ductwork used in the GEVS are compatible with UF₆ and HF and are noncombustible.

Design and Safety Features

The TSB GEVS is designed to protect plant personnel against uranium and HF exposure. The TSB GEVS is designed to meet all applicable NRC requirements for public and plant personnel safety and effluent control and monitoring. The system design also complies with applicable standards of OSHA, EPA, and state and local agencies. The system filters contaminated gases, and continuously monitoring exhaust gas flow to the atmosphere. HF monitors and alarms are installed upstream of the filtration systems and immediately upstream of the exhaust stack to avoid the release of hazardous materials to the environment. The alarms are monitored in the Separation Plant Control Room.

The TSB GEVS provides for continuous monitoring and periodic sampling of the gaseous effluent in the exhaust stack in accordance with the guidance in Regulatory Guide 4.16. Gamma monitors measure the build-up of ²³⁵U on prefilters and HEPA filter. The unit is located in a dedicated room in the TSB with the GEVS for the Separation Plant. The filters are bag-in/bag-out. The frequency of filter replacement will be determined during the design phase and the SAR revised accordingly. If the TSB GEVS stops operating, material within the duct will not be released into the building because each of the TSB GEVS connections has a P-trap to catch entrained material that could otherwise fall back into the building from the ductwork during system failure.

Instrumentation

The process variables, pressure, fan speed, and damper positioning are all controlled automatically. The fan speed is automatically controlled to maintain negative pressure in the system. The differential pressure across the filters is monitored and the fan speed is adjusted to maintain the design airflow rates. When a high pressure drop is detected across the filters, an alarm alerts the personnel that a filter change may be necessary. HF monitors measure the concentration of the gas in the air stream. Also, devices are used to measure the level of radiological contamination (alpha only) present in the air stream located in the stack. Deviations from specified values are indicated by alarms. HF and alpha monitors and alarms are installed upstream of the filtration system and

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

Immediately upstream of the exhaust stack to avoid the release of hazardous materials. The HF and radiological monitoring devices have noninterruptible power supplies in order to continue to function during a general power failure.

Each area has an alarm that is activated in the event that the TSB GEVS or the fan fails. The TSB GEVS control system is mounted in a Local Control Center (LCC). This is a stand-alone system that does not generate alarms during normal operation. The LCC provides automatic control of the fan and dampers and provides local control via a Local Operator Interface (LOI) that is mounted in the LCC.

The Central Control System (CCS) has no supervisory control over the TSB GEVS control system. However, the TSB GEVS LCC communicates with the CCS via the dual redundant process network so that comprehensive monitoring of the TSB GEVS status exists. Data that is monitored is fan status, filter and duct pressure measurements, and damper status.

The TSB GEVS LCC has one PLC that provides all automatic control and protection required for the system and also the communication interface to the PCS. All equipment related to the TSB GEVS is directly wired to the LCC.

The radiological activity and HF monitoring instruments are stand-alone and powered separately. These instruments interface with the TSB GEVS LCC via hardwired signals that indicate when alarm limits have been exceeded. Any shutdown device for the filter train and fan is latched and requires local operator action to reset. High-level environmental alarms will shut down the TSB GEVS.

Separations Building Gaseous Effluent Vent System (SB GEVS) (Stack #13)

The GEVS for the Separations Building provides exhaust of potentially hazardous contaminants. The system is shown on Attachment A, Sheets 1, 6 and 7, NEF Process Block Diagram, PFD GEVS – Separations/Blend & Sample, and P&ID GEVS-Separation/Blend & Sample. The GEVS system serving the Separations Building is located in the TSB on the first floor. The system is operated from the Control Room.

Functional Description

The Separations Building GEVS interfaces with the following systems, auxiliary activities, and utilities:

1. UF₆ Feed System
2. Product Take-off System
3. Tails Take-off System
4. Product Blending System
5. Product Liquid Sampling System
6. Contingency Dump System
7. Compressed Air System
8. Electrical System
9. Control Room

The design requirements provide a large safety margin between normal and accident conditions so that no single failure could result in the release of significant hazardous material. The amounts of UF₆ in the system also preclude the release of significant quantities of hazardous material from a single failure or multiple failures. Instrumentation

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

is provided to detect abnormal process conditions so that the process can be returned to normal by operator actions.

Major Components

The Separation Building GEVS consists of the following major components.

1. Duct system
2. Electrostatic filter
3. Prefilters
4. High Efficiency Particulate Air (HEPA) Filters
5. Activated carbon filters
6. Centrifugal Fans
7. Monitoring and controls (HF) before and after filters
8. Automatically controlled inlet and outlet isolation dampers
9. Exhaust stack
10. Gamma monitors and controls (prefilters, HEPA Filters, and electrostatic precipitator)
11. Monitoring and controls (alpha and HF) in exhaust stack
12. Stack sampling system.

Design Description

One Separation Building GEVS serves the entire Separations Building. It consists of a duct network that serves all of the uranium processing systems and operates at negative pressure. It is sized to handle the flow from all permanently ducted process locations, as well as up to 13 flexible exhaust hose exhaust points at one time. The flexible exhaust hoses are used for cylinder connection/disconnection or maintenance procedures. A minimum velocity of 12.7 m/s (2500 ft/min) is maintained in the duct system in order to ensure that particulate contaminants are conveyed through the ductwork without settling. Each section of the duct system has an orifice plate to maintain a minimum air velocity. Each section also has a damper to balance the individual flows in the system. The flexible exhaust hoses will have a capture velocity of 0.75 m/s (148 ft/min).

The ductwork is connected to two parallel filter stations. Each is capable of handling 100% of the effluent. One is online and the other is a standby. Each station consists of an 85% efficient prefilter, a 99.97% efficient HEPA filter, and a 99.9% efficient activated carbon filter for removal of HF. Electrostatic filters have an efficiency of 97%. Specifications for filter efficiency testing will be provided during the design phase. The filter stations vent through one of two fans. Each fan is capable of handling 100% of the effluent. One fan is online, and the other is a standby. A switch between the operational and standby systems can be made using automatically controlled dampers. The system capacity is estimated to be 11,000 m³/hr (6,474 cfm). A differential pressure controller controls the fan speed and maintains negative pressure upstream of the filter station. Flow rates and capacity are preliminary and are subject to change during final design. Gases from the UF₆ processing systems pass through the prefilter which removes dust and protects the HEPA filter, then through the HEPA filter which removes uranium aerosols (mainly UO₂F₂ particles), then through the potassium carbonate impregnated activated carbon filters which captures HF. The remaining clean gases pass through the fan, which maintains the negative pressure upstream of the filter stations. Finally, the clean gases are discharged through a roof top exhaust stack on the TSB. One exhaust stack is common to the operational system and the standby system.

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

The materials of construction, corrosion allowances, and fabrication specifications for the equipment and ductwork used in the GEVS are compatible with UF₆ and HF and are noncombustible.

The Separations Building GEVS provides the ventilation and hazardous contaminant removal for the following systems, equipment, and areas. It is connected via permanently ducted locations to:

1. The UF₆ Feed System, The Product Take-off System, the Tails Take-off System, Product Blending and Sampling Vent Subsystem and Contingency Dump System.
2. All Liquid Sampling System autoclaves.
3. All discharge lines from mobile vacuum pump sets.

It is connected via flexible exhaust hoses to places where piping is normally disconnected or equipment is opened, such as:

1. The Product Take-off System and Tails Take-off System pumping trains and the UF₆ Feed Purification Subsystem, Product Vent Subsystem, Tails Evacuation Subsystem and Product Blending and Sampling Vent Subsystem vacuum pump/chemical trap sets.
2. The Liquid Sampling System autoclaves. The lines for the flexible duct are run to a point within approximately 0.9 m (3 ft) of each door opening. Approximately 1.8 m (6 ft) of flexible duct is connected to this point to enable access to all places where the autoclave UF₆ pipework is connected/disconnected.
3. The Product and Tails Low Temperature Take-off Stations.
4. The Solid Feed Stations and Feed Purification Low Temperature Take-off Stations.
5. The Blending Donor Stations and Blending Receiver Stations.

If the Separations Building GEVS stops operating, material within the duct will not be released into the building because each of the Separations Building GEVS connections has a P-trap to catch entrained material that could otherwise fall back into the building from the ductwork during system failure.

Mobile vacuum pump units that vent to the Separations Building GEVS are available in the UF₆ Handling Areas and the Product Blending and Liquid Sampling Area.

Design and Safety Features

The Separations Building GEVS is designed to protect plant personnel against uranium and HF exposure. Potential hazards include the release of UF₆ and HF to the building and/or environment, contaminated filters, and contaminated oil.

The system filters contaminated gases, and continuously monitoring exhaust gas flow to the atmosphere. HF monitors and alarms are installed upstream of the filtration systems and immediately upstream of the exhaust stack to avoid the release of hazardous materials to the environment. A fault alarm is generated, in the event of a fault occurring within any of the monitors. The alarms are monitored in the Control Room. Gamma monitors measure the build up of ²³⁵U on prefilters, HEPA filters and on the electrostatic filter.

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

The Separations Building GEVS unit is located in a dedicated room with the GEVS from the TSB. The filters are bag-in/bag-out. The frequency of filter replacement will be determined during the design phase. The Separations Building GEVS provides for continuous monitoring and periodic sampling of the gaseous effluent in the exhaust stack in accordance with the guidance in Regulatory Guide 4.16.

The Separations Building GEVS is designed to meet all applicable NRC requirements for public and plant personnel safety and effluent control and monitoring. The system designs also comply with applicable standards of OSHA, EPA, and state and local agencies.

Instrumentation

The process variables, pressure, fan speed, and damper positioning are all controlled automatically. The fan speed is automatically controlled to maintain negative pressure in the system. HF monitors measure the concentration of the gas in the air stream. Also, devices are used to measure the level of radiological contamination (alpha only) present in the air stream located in the exhaust stack. Deviations from specified values are indicated by alarms. HF monitors and alarms are installed upstream of the filtration system and immediately upstream of the exhaust stack to avoid the release of hazardous materials. The HF and radiological monitoring devices have non-interruptible power supplies in order to continue to function during a general power failure. HF monitors and alarms are installed upstream of the filtration systems and immediately upstream of the exhaust stack to prevent the release of hazardous materials. The differential pressure across the prefilter and HEPA filter is monitored to indicate required filter changes.

The GEVS control system is mounted in a Local Control Center (LCC). This is a stand-alone system that does not generate alarms during normal operation. The LCC provides automatic control of the fans and dampers and provides local control via a Local Operator Interface (LOI) that is mounted in the LCC.

The Central Control System (CCS) has no supervisory control over the Separations Building GEVS control system. However, the Separations Building GEVS LCC communicates with the CCS via the dual redundant process network so that comprehensive monitoring of the GEVS status exists. Data that is monitored is fans status, filter and duct pressure measurements, damper status, and electrostatic precipitator status. System alarms are relayed to the CCS.

The Separations Building GEVS LCC has one PLC that provides all automatic control and protection required for the system, and also the communication interface to the PCS. All equipment related to the Separations Building GEVS is directly wired to the LCC. The radiological activity and HF monitoring instruments are stand-alone and powered separately. These instruments interface with the Separations Building GEVS LCC via hardwired signals that indicate when alarm limits have been exceeded. These alarms are overridden during calibration.

ATTACHMENT G
State of New Mexico Air Quality Notice of Intent

Site Basins

Uranium Byproduct Cylinder (UBC) Storage Pad Storm Water Retention Basin (Unit No. B-1)


The UBC Storage Pad Storm Water Retention Basin is used to collect and contain water discharges from three sources: (1) cooling tower blowdown, (2) storm water runoff from the UBC Storage Pad, and (3) heating boiler blowdown. The ultimate disposal of basin water will be through evaporation of water and impoundment of the residual dry solids after evaporation. The basin is designed to contain runoff for a volume equal to twice that for the 24-hour, 100-year return frequency storm, a 6-inch rainfall plus an allowance for cooling tower and heating boiler blowdown water. The UBC Storage Pad Storm Water Retention Basin is designed to contain a volume of approximately 20,528,340 gallons. Area served by the basin includes 22.8 acres, the total area of the UBC Storage Pad. This basin is designed with a membrane lining to minimize any infiltration into the ground.

Treated Effluent Evaporative Basin (Unit No. B-2)

The Treated Effluent Evaporative Basin is used to collect and contain liquid effluent discharge from the Liquid Effluent Collection and Treatment System. The ultimate disposal of liquid effluent will be through evaporation of water and impoundment of the residual dry solids byproduct of evaporation. Total annual discharge to the basin will be approximately 669,844 gallons per year, but it is designed to contain a volume of approximately 985,306 gallons. Evaporation will provide the only means of liquid disposal from this basin. The basin will include a double membrane liner and a leak detection system.

Site Storm Water Detention Basin (Unit No. B-3)

The Site Storm Water Detention Basin will collect runoff from various developed parts of the site, including roads, parking areas, and building roofs. It is unlined and will have an outlet structure to control discharges above the design level. The normal discharge will be through evaporation and infiltration into the ground. The basin is designed to contain runoff for a volume equal to that for the 24-hour, 100-year return frequency storm, a 6-inch rainfall. The basin will have approximately 6,169,070 gallons of storage capacity. Area served includes about 96 acres with the majority of that area being the developed portion of the 543 acres NEF site. Effluent is not treated prior to release.



HATCHED AREAS INDICATE HAZARDOUS WASTE STORAGE AREAS.

LEGEND:

- | | | |
|--|---|-----------------------------------|
| 1. URANIUM BYPRODUCT CYLINDERS (UBC) STORAGE PAD | 10. URANIUM HEXAFLUORIDE (UF ₆) HANDLING AREA | 19. ADMINISTRATION BUILDING |
| 2. LIQUID NITROGEN (N ₂) TANK NO. 4 | 11. LIQUID N ₂ TANK NO. 3 | 20. VISITOR CENTER |
| 3. CENTRIFUGE ASSEMBLY BLDG. | 12. LIQUID N ₂ TANK NO. 2 | 21. EMPLOYEE PARKING |
| 4. CASCADE HALLS 1&2 | 13. UBC STORAGE PAD STORMWATER RETENTION BASIN | 22. SECURITY BLDG. |
| 5. CASCADE HALLS 3&4 | 14. SITE STORMWATER DETENTION BASIN | 23. GUARD HOUSE |
| 6. CASCADE HALLS 5&6 | 15. TREATED EFFLUENT EVAPORATIVE BASIN | 24. CENTRAL UTILITIES BLDG. (CUB) |
| 7. CYLINDER RECEIPT & DISPATCH BLDG. | 16. LIQUID N ₂ TANK NO. 1 | 25. METEOROLOGICAL TOWER |
| 8. BLENDING & LIQUID SAMPLING AREA | 17. COOLING TOWER | |
| 9. TECHNICAL SERVICES BLDG. (TSB) | 18. ELECTRICAL SWITCH GEAR | |



REFERENCE NUMBER
e00002.dwg



FIGURE G-1
NEF SITE BUILDING

ATTACHMENT H

**Prevention of Significant Deterioration (PSD)
Determination is not applicable for a Notice of Intent
per NMAC 20.2.73.200.B**

ATTACHMENT I

**State & Federal Compliance Status
is not applicable for a Notice of Intent
as per NMAC 210.2.73.200.B**

ATTACHMENT J

**Operational Mitigation Plan is not applicable for
a Notice of Intent as per NMAC 210.2.73.200.B**

ATTACHMENT K

**NEF is applying for a Notice of Intent and therefore,
Air Quality Dispersion Demonstration is not applicable
as per NMAC 20.2.73.200.B**

ATTACHMENT 3

**Letter dated May 17, 2004,
from J. Schoeppner (New Mexico Environment Department)
to Louisiana Energy Services, L. P.,
Regarding "Administrative Completeness Determination and Applicant's Public Notice
Requirements, DP-1481, National Enrichment Facility"**

REC'D MAY 24 2004



BILL RICHARDSON
GOVERNOR

State of New Mexico
ENVIRONMENT DEPARTMENT

Ground Water Quality Bureau
Harold Runnels Building
1190 St. Francis Drive, P.O. Box 26110
Santa Fe, New Mexico 87502-6110
Telephone (505) 827-2918
Fax (505) 827-2965



RON CURRY
SECRETARY

DERRITH WATCHMAN-MOORE
DEPUTY SECRETARY

May 17, 2004

RE: Administrative Completeness Determination and Applicant's Public Notice Requirements, DP-1481, National Enrichment Facility

Dear Discharge Permit Applicant:

The New Mexico Environment Department (NMED) received a Ground Water Discharge Permit Application from you on April 28, 2004. Pursuant to Section 20.6.2.3106 NMAC of the New Mexico Water Quality Control Commission Regulations (2016.2 NMAC), NMED determined on May 6, 2004 that your application is administratively complete.

Within 30 days of the submission of an administratively complete Discharge Permit Application, you must provide public notice using one of the 3 options listed in Section 20.6.2.3108 NMAC. You selected public notice options #1, 2 & 3. The instructions and materials needed to complete this option are enclosed.

If you have any questions, please call the Ground Water Quality Bureau at (505) 827-2900.

Sincerely,

A handwritten signature in cursive script that reads "Diana D. Sandoval".

for! Jerry Schoeppner, Chief
Ground Water Quality Bureau

Attachments: Public Notice 1 (mail to property owner)
Public Notice Synopsis (for newspaper display ad)
Instructions for Option #2
Affidavit (return to NMED)
Invoice (\$15 fee for poster – please submit payment to NMED)
Poster

ATTACHMENT 4

Letter dated May 27, 2004,
from B. D. Taylor (New Mexico Environment Department)
to R. M. Krich (Louisiana Energy Services, L. P.)
Regarding "Notice of Intent No. 3062 - National Enrichment Facility (NEF)"



State of New Mexico
ENVIRONMENT DEPARTMENT

Air Quality Bureau
2048 Galisteo St.
Santa Fe, NM 87505
Phone (505) 827-1494
Fax (505) 827-1523
www.nmenv.state.nm.us



BILL RICHARDSON
Governor

RON CURRY
Secretary

DERRITH WATCHMAN-MOORE
Deputy Secretary

May 27, 2004

CERTIFIED MAIL NO. 7001 2510 0000 8015 5465
RETURN RECEIPT REQUESTED

R. M. Krich
Vice President of Licensing, Safety
and Nuclear Engineering
Louisiana Energy Services, LP
100 Sun Lane NE, Suite 204
Albuquerque, New Mexico 87109

Notice of Intent No. 3062
IDEA ID No. 20321 – PRN20040001
National Enrichment Facility (NEF)
AIRS NO. 35-025-0356

Dear Mr. Krich:

This letter acknowledges the receipt of your Notice of Intent application dated April 20, 2004 to construct and operate the National Enrichment Facility (NEF) in Township 21S, Range 38E, Section 32 in Lea County, near Eunice, New Mexico. The application was received by the Department on April 27, 2004.

Operations affecting air emissions at the facility shall consist of:

Technical Services Building Confinement Ventilation System, two (2) natural gas fired Hot Water Heaters (one of the two will be used as back-up), two (2) Emergency Diesel Generators (Cat 3512B TA Diesel Engine with a CAT SR4B Generator DM6610), four (4) Closed Circuit Hybrid Cooling Towers, two (2) 6,000 gallon each #2 Diesel Fuel Tanks, CAB Centrifuge Test and Post Mortem Facilities Exhaust Filtration System, Technical Services Building Gaseous Effluent Vent System (TSB GEVS), Separations Building Gaseous Effluent Vent System (SB GEVS), UBC Storage Pad Stormwater Retention Basin, Treated Effluent Evaporative Basin and a Stormwater Detention Basin.

Based on the information provided in the submitted application, the Department has determined that an air quality permit under 20.2.72 NMAC is not required. Because the potential emission rate is greater than ten (10) tons per year, this facility is subject to 20 NMAC 2.73. The submitted

Louisiana Energy Services, LP
NOI No. 3062 – National Enrichment Facility (NEF)
May 27, 2004
Page 2 of 2

application will serve as the Notice of Intent in accordance with 20 NMAC 2.73. The two emergency diesel generator sets are exempt pursuant to 20 NMAC 2.72.202.B (3), provided all requirements specified by 20 NMAC 2.72.202 B (3) are met. Surface coating activities at this facility are exempt provided all requirements specified by 20 NMAC 2.72.202 B (6) are met.


The Department has also determined that new source performance standards (NSPS) and national emission standards for hazardous air pollutants (NESHAPS) do not apply to this source. During any asbestos demolition or renovation work the Code of Federal Regulations (CFR), Title 40, Part 61, Subpart M would apply.

Any changes in the method of operation or addition of more units at the site may constitute a modification, which requires the Department's prior approval for construction and/or operation.

In the event of any change in ownership or operator of this facility, the new owner or operator shall notify the Department in writing within thirty (30) days of that change.

If you have any questions about this Notice of Intent, please call me in Santa Fe at (505) 827-1494, Extension 8042.

Sincerely,



Bruce D. Taylor
New Source Review Unit
Air Quality Bureau

cc: Section Chief, Compliance and Enforcement Section, AQB, Santa Fe
Hobbs NMED Field Office

Enclosure: Industry/Consultant Feedback Questionnaire with envelope