



**Nebraska Public Power District**

*Always there when you need us*

NLS2004087

July 8, 2004

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555-0001

Subject: Monthly Operating Report for June 2004, Docket 50-298

The purpose of this letter is to provide the Cooper Nuclear Station Monthly Operating Report for June 2004. In accordance with the guidance provided by Generic Letter 97-02, this report includes an Operating Data Report and Unit Shutdown Report for the month of June. In accordance with Technical Specification 5.6.4, this report also includes documentation of challenges to the safety/relief valves.

Should you have any comments or require additional information regarding this report, please contact Paul Fleming at (402) 825-2774.

Sincerely,

Paul Fleming  
Licensing Manager

/cb  
Enclosure

cc:	NRC Regional Administrator	W. J. Fehrman
	NRC Senior Resident Inspector	W. D. Shanks
	ANI Library	R. K. Edington
	C. C. Warren	J. M. Cline
	B. Lewis	A. L. Dostal
	G. W. Griffith	J. C. Roberts
	J. W. Dutton	S. Moffitt
	R. L. Gumm	INPO Records Center
	Records	

JE24

**APPENDIX A  
OPERATING DATA REPORT**

DOCKET NO. 050-0298  
 UNIT NAME Cooper Nuclear Station  
 DATE 7/8/2004  
 COMPLETED BY Rodrick Wilson  
 TELEPHONE (402) 825-5135

Reporting Period: June 2004

	This Month	Yr.-to-Date	Cumulative
1. Design Electrical Rating (Net MWe). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	<u>778.0</u>	<u>N/A</u>	<u>N/A</u>
2. Maximum Dependable Capacity (Net MWe): The gross electrical output as measured at the output terminals of the turbine-generator during the most restrictive seasonal conditions minus the normal station service loads.	<u>764.0</u>	<u>N/A</u>	<u>N/A</u>
3. Number of Hours the Reactor Was Critical. The total number of hours during the gross hours of the reporting period that the reactor was critical.	<u>720.0</u>	<u>4,367.0</u>	<u>203383.3</u>
4. Number of Hours the Generator Was On Line. (Also called Service Hours). The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	<u>720.0</u>	<u>4367.0</u>	<u>200473.3</u>
5. Unit Reserve Shutdown Hours. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
6. Net Electrical Energy (MWh). The gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	<u>537,929.0</u>	<u>3,280,602.0</u>	<u>13,643,460.7.0</u>

**APPENDIX B  
UNIT SHUTDOWNS**

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	7/8/2004
COMPLETED BY	Rodrick Wilson
TELEPHONE	(402) 825-5135

REPORT MONTH June 2004

No.	Date	Type F: FORCED S: SCHEDULED	Duration (Hours)	Reason (1)	Method Of Shutting Down (2)	CAUSE/CORRECTIVE ACTIONS	COMMENTS

SUMMARY: None

- (1) Reason:
- A - Equipment Failure (Explain)
  - B - Maintenance or Test
  - C - Refueling
  - D - Regulatory Restriction
  - E - Operator Training/License Examination
  - F - Administrative
  - G - Operational Error (Explain)
  - H - Other (Explain)

- (2) Method:
- 1 - Manual
  - 2 - Manual Trip/Scram
  - 3 - Automatic Trip/Scram
  - 4 - Continuation
  - 5 - Other (Explain)

**APPENDIX C**  
**SAFETY/RELIEF VALVE CHALLENGES**  
**JUNE 2004**

There were no challenges to the safety/relief valves during the month of June.

