

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

July 1, 2004

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 04-122A
NL&OS/ETS R0
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
NORTH ANNA POWER STATION UNITS 1 AND 2
WITHDRAWAL OF PROPOSED TECHNICAL SPECIFICATION CHANGES
DELETION OF NOTE FOR PERFORMANCE OF COT

In a March 4, 2004 letter (Serial No. 04-122), Dominion requested a change to the Technical Specifications to Facility Operating Licenses Numbers NPF-4 and NPF-7 for North Anna Power Station Units 1 and 2, respectively. The proposed change would have deleted the Note from Surveillance Requirement (SR) 3.4.12.7 for the power-operated relief valves. Based on a telephone conference call with Mr. Stephen Monarque and Ms. Kerri Kavanagh of your staff, Dominion is withdrawing the proposed Technical Specification change from consideration. The Note, which permits entering a Mode where the PORVs are required to be operable for low temperature overpressure protection prior to performing the channel operational test (COT) will be maintained. However, the associated Bases will be changed to clarify that the COT can be performed either prior to entry or within 12 hours of entry into a Mode where the PORVs are required for low temperature overpressure protection. The bases changes will be processed in accordance with the Technical Specification Bases Control Program and 10 CFR 50.59.

If you have any further questions or require additional information, please contact Mr. Thomas Shaub at (804) 273-2763.

Very truly yours,


W. R. Matthews
Senior Vice President – Nuclear Operations

Commitments made in this letter: None

A 001

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

Mr. J. E. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center
4201 Dominion Blvd.
Suite 300
Glen Allen, Virginia 23060

Commissioner
Bureau of Radiological Health
1500 East Main Street
Suite 240
Richmond, VA 23218

Mr. M. T. Widmann
NRC Senior Resident Inspector
North Anna Power Station

Mr. S. R. Monarque
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 8-H12
Rockville, MD 20852