

Mr. Robert H. Leyse
P.O. Box 2850
Sun Valley, ID 83353

Dear Mr. Leyse:

I am responding to your letter of September 2, 2002, which submitted a petition for rulemaking (PRM) to amend regulations and guidance documents pertaining to the performance of heat transfer surfaces in nuclear power plants (NPPs).

Your letter contended that existing regulations, guidance documents, test procedures, computer codes, and licensing and compliance inspection programs do not adequately address the impact of fouling on the performance of all heat transfer surfaces in NPPs.

The Nuclear Regulatory Commission (NRC) published a notice of receipt of PRM-50-78 on October 31, 2002. Four letters of public comment were received on the petition. Two of the letters were from you and the other two opposed the PRM. The commenters noted that current reporting requirements in 10 CFR 50.72 and 50.73 require reporting of any event or condition that would interfere with a safety function needed to shutdown that plant and maintain it in a safe condition, remove residual heat, control radiological material, or mitigate accident consequences. The commenters also noted that these same concerns had been addressed by industry in opposition to two prior PRMs from you: PRM-50-73 and PRM-50-73A. The commenters stated that this new petition (PRM-50-78) provided no additional basis for revising any NRC regulations.

The Commission is denying your petition for rulemaking, (PRM-50-78) for the following reasons.

The petition provided no evidence, and the staff could not find any data or reports, to indicate that fouling of safety-significant heat exchanger surfaces had degraded performance to the extent that a significant safety problem existed.

The NRC regulation and oversight of nuclear power plants includes the establishment of regulations, the issuance of operating licenses and technical specifications, and continuous inspections and technical reviews of licensee programs and plant performance. When viewed in total, this regulatory program provides confidence in the safety of operating nuclear power plants. The NRC staff's finding that no rulemaking is required, even though no specific regulation explicitly addresses the performance of heat exchangers, is based on the determination that the existing structure of regulations, technical specifications, and licensee programs subject to NRC inspection provides confidence that plant safety features, including heat exchangers, are properly designed and maintained.

Robert H. Leyse

-2-

The NRC staff evaluated your request for rulemaking with respect to the four performance goals of the Commission. The requested action would not contribute to maintaining safety, would not enhance public confidence, would not improve regulatory efficiency and effectiveness, and would increase unnecessary regulatory burden.

The integration of the various requirements and related NRC oversight functions provides the necessary confidence that systems important to safety such as heat exchangers will perform their intended functions. The addition of specific requirements to a regulation to address heat exchanger performance is not necessary. Further details are discussed in the enclosed notice of Denial of Petition for Rulemaking, which will be published in the *Federal Register*.

Sincerely,

Annette Vietti-Cook
Secretary of the Commission

Enclosure: *Federal Register* Notice of Denial of
Petition for Rulemaking

Robert H. Leyse

-2-

The NRC staff evaluated your request for rulemaking with respect to the four performance goals of the Commission. Your requested action would not contribute to maintaining safety, would not enhance public confidence, would not improve regulatory efficiency and effectiveness, and would increase unnecessary regulatory burden.

The integration of the various requirements and related NRC oversight functions provides the necessary confidence that systems important to safety such as heat exchangers will perform their intended functions. The addition of specific requirements to a regulation to address heat exchanger performance is not necessary. Further details are discussed in the enclosed notice of Denial of Petition for Rulemaking, which will be published in the *Federal Register*.

Sincerely,

Annette Vietti-Cook
Secretary of the Commission

Enclosure: *Federal Register* Notice of Denial of
Petition for Rulemaking

Distribution:

ADAMS GMizuno
RPRP r/f SCollins

C:\ORPCheckout\FileNET\ML041960041.wpd

ADAMS Accession No.: **ML041960041**

OFFICE	RPRP	TECH EDITOR	RPRP:SC	RPRP:PD	OGC	RES	DSSA	ADM
NAME	ARoecklein	PKleene	DSkeen	CHaney	STreby	JRosenthal	JWermiel	MLesar
DATE	3/9/04		3/9/04	3/19/04	6/09/04	3/22/04	3/16/04	3/16/04
OFFICE	DSSA	DRIP:D	NRR:	NRR:D	EDO	SECY		
NAME	SBlack	Dmatthews (FGillespie for)	BSheron	JDyer	LReyes	AVietti-Cook		
DATE	07/06/04	6/14/04	7/14/04	7/15/04				

OFFICIAL RECORD COPY