Bill Eaton, BWRVIP Chairman Entergy Operations, Inc. Echelon One 1340 Echelon Parkway Jackson, MS 39213-8202

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - REVIEW OF THE BOILING

WATER REACTOR VESSEL AND INTERNALS PROJECT REPORT.

BWRVIP-76, "BOILING WATER REACTOR CORE SHROUD INSPECTION &

FLAW EVALUATION GUIDELINES"

Dear Mr. Eaton:

By letter dated September 23, 2002, you submitted for NRC staff review, Electric Power Research Institute (EPRI) proprietary report, BWRVIP-76, "Boiling Water Reactor Core Shroud Inspection & Flaw Evaluation Guidelines." The purpose of this report is to provide generic acceptance standards and inspection intervals for horizontal and vertical welds in repaired and unrepaired core shrouds, and procedures for determining plant-specific inspection intervals when the generic acceptance standards are not applicable. The report also includes generic inspection intervals and acceptance standards for radial ring welds, repair hardware and repair anchorages in repaired core shrouds.

The NRC staff has completed its initial review of the BWRVIP-76 report. As indicated in the attached request for additional information, the NRC staff has determined that additional information is needed to complete the review. If you have any questions, please contact Meena Khanna at (301) 415-2150.

Sincerely,

/RA/

Matthew A. Mitchell, Acting Chief Vessels & Internals Integrity and Welding Section Materials and Chemical Engineering Branch Division of Engineering Office of Nuclear Reactor Regulation

Project No. 704

Enclosure: As stated

cc: BWRVIP Service List

Bill Eaton, BWRVIP Chairman Entergy Operations, Inc. Echelon One 1340 Echelon Parkway Jackson, MS 39213-8202

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - REVIEW OF BWR VESSEL

AND INTERNALS PROJECT REPORT, BWRVIP-76, "BOILING WATER REACTOR CORE SHROUD INSPECTION & FLAW EVALUATION

**GUIDELINES**"

Dear Mr. Eaton:

By letter dated September 23, 2002, you submitted for NRC staff review, Electric Power Research Institute (EPRI) proprietary report, BWRVIP-76, "Boiling Water Reactor Core Shroud Inspection & Flaw Evaluation Guidelines." The purpose of this report is to provide generic acceptance standards and inspection intervals for horizontal and vertical welds in repaired and unrepaired core shrouds, and procedures for determining plant-specific inspection intervals when the generic acceptance standards are not applicable. The report also includes generic inspection intervals and acceptance standards for radial ring welds, repair hardware and repair anchorages in repaired core shrouds.

The NRC staff has completed its initial review of the BWRVIP-76 report. As indicated in the attached request for additional information, the NRC staff has determined that additional information is needed to complete the review. If you have any questions, please contact Meena Khanna at (301) 415-2150.

Sincerely,

/RA/

Matthew A. Mitchell, Acting Chief Vessels & Internals Integrity and Welding Section Materials and Chemical Engineering Branch Division of Engineering Office of Nuclear Reactor Regulation

Project No. 704

Enclosure: As stated

cc: BWRVIP Service List

**DISTRIBUTION**:

EMCB R/F AHiser WCullen

JRajan CEMoyer

ADAMS Accession No.: ML041960104

INDICATE IN BOX: "C"=COPY W/O ATTACHMENT/ENCLOSURE, "E"=COPY W/ATT/ENCL, "N"=NO COPY EMCB:DE

OFFICE	EMCB:DE	Е	EMCB:DE	Е	EMCB:DE		EMCB:DE	
NAME	MKhanna		EReichelt		TChan WKoo for		MMitchell	
DATE	07/06/2004		07/07/2004		07/07/2004		07/09/2004	

## REQUEST FOR ADDITIONAL INFORMATION OF THE BWRVIP VESSEL AND INTERNALS PROJECT REPORT BWRVIP-76

The staff has completed its initial review of the topical report BWRVIP-76, "Boiling Water Reactor Core Shroud Inspection & Flaw Evaluation Guidelines," dated November 1999. In order to complete the review, the staff needs additional information from the Boiling Water Reactor Vessels and Internals Program (BWRVIP). The staff's request for additional information (RAI) is provided below. The RAIs have been discussed with the BWRVIP during the meeting that was held on July 1, 2004, at NRC Headquarters in Rockville, Maryland.

## BWRVIP-76-1

In paragraph 2.3.2 of the BWRVIP-76 report, surface examinations are identified in several places as including visual examinations. To be consistent with Section XI of the American Society of Mechanical Engineers (ASME) Code, surface examinations are identified as magnetic particle, liquid penetrant and eddy current examinations. Visual examinations (VT-1, VT-2, and VT-3) are identified in a separate category. Therefore, the staff requests that the BWRVIP revise the inspection categories, as identified above, in a future supplement to the BWRVIP-76 report.

## BWRVIP-76-2

Section 2.3.1 of the BWRVIP-76 report states that end of intervals (EOIs) will be determined for any cracks found in vertical welds in the un-repaired Category C shrouds by using "an acceptable crack growth rate." The staff requests that the BWRVIP provide more detail regarding "an acceptable crack growth rate (i.e., is the crack growth rate going to be in accordance with a BWRVIP, Materials Reliability Program, Westinghouse Commercial Atomic Power topical report?).

## BWRVIP-76-3

Section 3.2 of the BWRVIP-76 report states that inspections are not required for horizontal or vertical welds that are structurally replaced by a repair. The staff requests that the BWRVIP provide a definition of "structurally replaced." The staff also requests that the BWRVIP provide examples and sketches of how horizontal and vertical welds would be structurally replaced by a repair that would not require any future inspections. Please provide a list of BWR plants that have structurally replaced horizontal welds and structurally replaced vertical welds.

CC:

Tom Mulford, EPRI BWRVIP
Integration Manager
Raj Pathania, EPRI BWRVIP
Mitigation Manager
Ken Wolfe, EPRI BWRVIP
Repair Manager
Larry Steinert, EPRI BWRVIP
Electric Power Research Institute
P.O. Box 10412
3412 Hillview Ave.
Palo Alto, CA 94303

Robin Dyle, Technical Chairman BWRVIP Integration Committee Southern Nuclear Operating Co. 42 Inverness Center Parkway (M/S B234) Birmingham, AL 35242-4809

George Inch, Technical Chairman BWRVIP Assessment Committee Constellation Nuclear Nine Mile Point Nuclear Station (M/S ESB-1) 348 Lake Road Lycoming, NY 13093

William C. Holston, Executive Chairman BWRVIP Integration Committee Constellation Generation Group Nine Mile Point Nuclear Station P. O. Box 63 Lycoming, NY 13093

Jim Meister, BWRVIP Vice-Chairman Exelon Corp. Cornerstone II at Cantera 4300 Winfield Rd. Warrenville, IL 60555-4012

Al Wrape, Executive Chairman BWRVIP Assessment Committee PPL Susquehanna, LLC 2 N. 9<sup>th</sup> St. Allentown, PA 18101-1139

H. Lewis Sumner, Executive Chairman BWRVIP Mitigation Committee Vice President, Hatch Project Southern Nuclear Operating Co. M/S BIN B051, P.O. BOX 1295 40 Inverness Center Parkway Birmingham, AL 35242-4809 Denver Atwood, Technical Chairman BWRVIP Repair Focus Group Southern Nuclear Operating Co. Post Office Box 1295 40 Inverness Center Parkway (M/S B031) Birmingham, AL 35242-4809

Jeff Goldstein, Technical Chairman BWRVIP Mitigation Committee Entergy Nuclear NE 440 Hamilton Ave. (M/S K-WPO-11c) White Plains, NY 10601

Dale Atkinson, BWRVIP Liason to EPRI Nuclear Power Council Energy Northwest Columbia Generating Station (M/S PEO8) P. O. Box 968 Snake River Complex North Power Plant Loop Richland, WA 99352-0968

Richard Ciemiewicz, Technical Vice Chairman BWRVIP Assessment Committee Exelon Corp. Peach Bottom Atomic Power Station M/S SMB3-6 1848 Lay Road Delta, PA 17314-9032

Gary Park, Chairman BWRVIP Inspection Focus Group Nuclear Management Co. Monticello Nuclear Plant 2807 W. Country Road 75 Monticello, MN 55362-9635 Robert Carter, EPRI BWRVIP Assessment Manager Greg Selby, EPRI BWRVIP Inspection Manager EPRI NDE Center P.O. Box 217097 1300 W. T. Harris Blvd. Charlotte, NC 28221