

From: Sunil Weerakkody
To: Alex, MARION,; INTERNET: fae@nei.org
Date: Wednesday, July 14, 2004 4:53PM
Subject: Re: CO2 Response

Alex:

We plan to provide our response to your letter before 8/31. In the mean time, we appreciate the initiative that you have taken to prepare a white paper on this issue for our review. Dan Frumkin remains my lead on the Issue Management Protocol. However, Naeem Iqbal (NXI@nrc.gov) will be the responsible staff person assigned to prepare the response to this letter.

Sunil Weerakkody
Chief, Fire Protection
NRC\NRR\DSSA\SPLB
Tel: 301-415-2870
Mail Stop: O-11 A-11
Office: O-11 D-22

>>> "MARION, Alex" <am@nei.org> 07/02/04 01:19PM >>>
July 2, 2004

Mr. Sunil Weerakkody
Fire Protection Section Chief, DSSA
U.S. Nuclear Regulatory Commission
Mail Stop O11-A11
Washington, DC 20555-0001

PROJECT NUMBER: 689

As discussed during our meeting with you on June 22, 2004, we have evaluated the NRC concern related to manual lockout of automatic CO2 systems. We conducted a survey of licensee plans to change current CO2 system designs and found that such lockouts are of low risk significance. Adequate defense-in-depth is maintained if appropriate compensatory actions are taken and adequate suppression capability is assured.

Alex Marion

Senior Director, Engineering

Nuclear Generation Division

202-739-8080

am@nei.org

This electronic message transmission contains information from the Nuclear Energy Institute, Inc. The information is intended solely for the use of the addressee and its use by any other person is not authorized. If you are not the intended recipient, you have received this communication in error, and any review, use, disclosure, copying or distribution of the contents of this communication is strictly prohibited. If you have received this electronic transmission in error, please notify the sender immediately by telephone or by electronic mail and permanently delete the original message.

CC: Brown, Eva; Frumkin, Daniel; Hannon, John; IQBAL, Naeem