

Research Reactor Center

University of Missouri-Columbia

Research Park Columbia, MO 65211

PHONE (573) 882-4211 FAX (573) 882-6360

July 13, 2004

Mr. Alexander Adams, Jr. U.S. Nuclear Regulatory Commission Mail Stop O12-G13 Washington, DC 20555-0001

SUBJECT: University of Missouri Research Reactor Facility Docket No. 50-186 Monthly Operations Summary

Dear Mr. Adams:

Enclosed is a copy of MURR's Monthly Operations Summary for June 2004. If you have any questions, please contact me at (573) 882-5276.

Sincerely,

Leslie Foyto

Reactor Manager

LM/sm cc. Craig Bassett Enclosure: June Operation Summary – 4 pages

JEQU

UNIVERSITY OF MISSOURI RESEARCH REACTOR

OPERATIONS MONTHLY SUMMARY

June 2004

Prepared by: Operations Staff

INTRODUCTION

The reactor operated continuously in June with the following exceptions: 4 shutdowns for scheduled maintenance and refueling; 2 unscheduled shutdowns.

٤

٦.

1

MAINTENANCE ACTIVITIES

6/3/04	Refueled - removed core 04-25, loaded core 04-26.
6/7/04	Refueled - removed core 04-26, loaded core 04-27. Reinstalled refurbished Secondary Coolant System Distribution Valve S-19. Replaced cooling water lines to Primary Coolant Pumps 501A/B.
6/14/04	Refueled - removed core 04-27, loaded core 04-28.
6/16/04	Refueled – removed core 04-28, loaded core 04-29.
6/17/04	Shipped eight spent fuel elements to Savannah River Site.
6/21/04	Refueled – removed core 04-29, loaded core 04-30. Removed the 20 element X fuel storage basket for inspection.
6/28/04	Refueled – removed core 04-30, loaded core 04-31. Placed an epoxy patch on the secondary side of Primary Heat Exchanger 503A.
6/29/04	Loaded new pool de-ionization bed 'F'.

UNSCHEDULED SHUTDOWNS

Date	<u>No.</u>	Type	<u>Cause</u>
6/3/04	NA	Manual Scram	Sample scheduling error

On June 3, the reactor was shutdown due to a sample scheduling error which resulted in the incorrect sample being removed on the previous maintenance day. After the shutdown, the correct sample was pulled. The reactor was subsequently returned to 10 MW operation.

6/16/04

NA

Manual Scram Inner Airlock Door Positioning Chain

On June 16, the reactor was shutdown when it was discovered that the inner airlock door positioning chain had come off it's sprocket due to a loose set screw. Containment integrity was never lost since the outer airlock door remained closed and the seal inflated. The reactor was secured, and the inner airlock door set screw was replaced with a locking style set screw. The reactor was subsequently returned to 10 MW operation.

]		
	OPERATION SUMMARY FOR MONTH OF Jun-04 University of Missour Research Reactor Center (MURR)	
	HOURS OPERATED THIS PERIOD 644.02	
	TOTAL HOURS OPERATED, REACTOR 259,209.49	
	HOURS OPERATED AT FULL POWER, THIS PERIOD 641.69	
	TOTAL HOURS AT FULL POWER, REACTOR 255,883.97	
	INTEGRATED POWER THIS PERIOD 267.53 MWD	
	TOTAL INTEGRATED POWER, REACTOR 100,818.82 MWD	
	Submitted by: K	
	MWD Custodian/Reactor Physicist	
	Date:7/1/04	

.