



FPL

JUL 15 2004
L-2004-165
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - June 2004

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the June 2004 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

Michael Navin

for Terry O. Jones
Vice President
Turkey Point Plant

RLE

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250
 UNIT: Turkey Point Unit 3
 DATE: 07/14/2004
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period June, 2004

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	720	4367	206900.2
No. of hours generator was on line (service hours)	647.6	4294.6	204435.1
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	427384	3012738	133817383

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20040009	6/17/2004	F	20.7	A	1	Turbine Oil Leak Repairs Required
20040012	6/26/2004	F	51.6	A	1	Turbine Control Valve Repairs Required

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G -Operational Error (Explain)
- H -Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% power until June 17, 2004 when the unit was reduced to about 60% power and then shut down to repair a turbine oil leak. Return to full power was delayed until June 21, 2004 due to various secondary side problems. The unit then operated at essentially 100% power until June 25, 2004, when the unit was reduced to about 60% power and then shutdown June 26, 2004 for turbine control valve, stop valve, and other secondary side repairs. Unit 3 returned to 100% power on June 29, 2004.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 07/14/2004
 COMPLETED BY: Ronald Everett
 TELEPHONE: (305) 246-6190

Reporting Period June, 2004

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	720	4325.9	203745.7
No. of hours generator was on line (service hours)	720	4272.5	199250.9
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	500536	3002459	131524027

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power for the month of June.