

1 **6 ALTERNATE EVALUATION**

2  
3 **6.1 INTRODUCTION**

4  
5 This section describes an alternate evaluation methodology for demonstrating acceptable  
6 containment sump performance relative to the requirements identified in Section 2.  
7

8 **6.1.1 BACKGROUND**

9  
10 In SECY-02-0057 (Reference 1), the NRC staff recommended the development of risk-  
11 informed approaches to the technical requirements specified in 10 CFR 50.46 (Reference  
12 2), and related provisions, concerning LOCA acceptance criteria and evaluation models.  
13 In its March 31, 2003 SRM (Reference 5), the NRC Commissioners directed the staff to  
14 undertake rulemakings, one of which would develop a proposed rule to allow, as a  
15 voluntary alternative, a redefinition of design basis maximum break size. In a March 4,  
16 2004 letter to NEI (Reference 3), the NRC staff opened the possibility for risk-informing  
17 portions of the evaluation process for addressing GSI-191 concerns:  
18

19 "...the NRC staff plans to discuss, in public meetings, the use of current or planned work to risk-inform  
20 Title 10, *Code of Federal Regulations* Section 50.46, "Acceptance criteria for emergency core cooling  
21 system for light-water nuclear power reactors," as a suitable technical basis for defining a spectrum of  
22 break sizes for debris generation and containment sump strainer performance."  
23

24 Most recently in SRM SECY-04-037 (Reference 4), the NRC Commissioners directed  
25 the staff to develop a rulemaking package to risk-inform the requirements addressing  
26 large break loss-of-coolant accidents (LOCA). The Commission directed the staff to use  
27 the initiating event frequencies from the expert elicitation process, supported by historical  
28 data and fracture mechanics analysis and other relevant information, to guide the  
29 determination of an appropriate alternative break size.  
30

31 An alternate evaluation methodology for GSI-191 resolution is discussed in this section  
32 that builds on applicable risk insights from the preparatory work that supports risk  
33 informing the large break LOCA requirements.  
34

35 **6.1.2 OVERVIEW OF ALTERNATE EVALUATION METHODOLOGY**

36  
37 The alternate evaluation methodology (Option B of Figure 2-1) allows for use of an  
38 alternate break size in analyses of containment recirculation performance.

1 Implementation of the alternate evaluation methodology involves two separate analysis  
2 steps:

- 3
- 4 1) Region I – For pipe breaks up to an alternate break size, analyses of the  
5 containment sump performance use highly conservative analysis methodologies  
6 as described in Section 6.3.
- 7 2) Region II – For pipe breaks larger than the alternate break sizes, analyses of the  
8 containment sump performance use risk insights and more realistic analysis  
9 methodologies as described in Section 6.4.

10

11 The Region I and Region II nomenclature was chosen to provide a clean definition of the  
12 two analyses that would not be misinterpreted with other regulatory terminology and has  
13 no other significance.

14

15 The analysis for Region I is performed in the same manner as that described in Sections  
16 3, 4 and 5 of this document with the exception that the maximum break size considered in  
17 the recirculation performance analysis is limited to an alternate break size that is less than  
18 the double-ended rupture of the largest pipe in the reactor coolant system. Section 6.3  
19 provides additional guidance on the Region I analyses.

20

21 In implementing the alternate evaluation approach, it is necessary to demonstrate that  
22 reasonable assurance of mitigation capability is retained for break sizes between the  
23 alternate break size and the double-ended guillotine break of the largest pipe in the  
24 reactor coolant system. This is termed Region II and Section 6.4 provides guidance on  
25 appropriate analysis methods and assumptions. This Region II recirculation performance  
26 analysis is performed using more realistic analysis methods and assumptions.

27

28 The alternate methodology calls for a risk impact calculation to be performed when  
29 changes to the existing facility design are necessary to meet the acceptance criteria using  
30 the alternate methodologies described in this section. The risk impact calculation is used  
31 to assure that the changes to the facility design have sufficient reliability to provide  
32 reasonable assurance that they will perform their intended function. This risk calculation  
33 only applies for cases where active components and/or operator actions are considered  
34 and reliability can be measured. The risk impact is not calculated for passive components  
35 since they typically can be assumed to perform their function with a high degree of  
36 reliability based on design margins, etc. In cases where a measurable and inspectable  
37 reliability can be ascribed to a passive component, the risk assessment may be applicable.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38

**6.2 ALTERNATE BREAK SIZE**

In SRM-SECY-04-0037, the NRC Commissioners directed the NRC staff to use the initiating event frequencies from the expert elicitation process, supported by historical data and fracture mechanics analysis and other relevant information, to guide the determination of an appropriate alternative break size for the proposed large Break LOCA re-definition (also known as the proposed 50.46 rulemaking).

The preliminary results of the NRC’s break size frequency expert elicitation process, as documented in SECY-04-0060 (Reference 6), has provided a new estimate of the probability of break flows over a wide range of possible pipe configurations. This expert elicitation process includes both probabilistic fracture mechanics considerations as well as margins for uncertainties concerning aging mechanisms and their impact on piping integrity. Of particular importance for PWRs, the expert elicitation gave strong weight to reactor vessel penetration integrity for the large break sizes and to steam generator tube failures for small break sizes. They also gave strong weighting to breaks in locations that have Alloy 600 welds based on operating experience. These locations are considered to be more probable than a circumferential break in a smooth piping segment. For these reasons, consideration of piping break size and break location will ideally be considered together in defining the Alternate Break Size. For example, considerations that led to the preliminary expert elicitation results indicate that the large break frequencies are dominated by reactor vessel penetration failures. Consideration of the debris generation and transport features of reactor vessel insulation indicates that these breaks do not generate significant debris that can be transported to the containment sump. Thus, the use of the expert elicitation in defining the alternate break size for sump performance assessments contains an inherent bias that provides added margin to the sump performance assessments.

The NRC Commissioners also provided clarification to the NRC staff with respect to the break size designation for the large break LOCA redefinition:

“For example, a frequency of 1 occurrence in 100,000 reactor years is an appropriate mean value for the LOCA frequency guideline for selecting the maximum design-basis LOCA since it is complemented by the requirement that appropriate mitigation capabilities, including effective severe accident mitigation strategies, must be retained for the beyond design-basis LOCA category.”

1 Based on the preliminary break frequencies from the expert elicitation, this corresponds  
2 to about a 4 inch diameter break size.

3  
4 To reflect the preliminary nature of the expert elicitation results and the need to resolve  
5 GSI-191 in a time frame that is much shorter than the proposed 50.46 rulemaking, a more  
6 deterministic alternate break size is used that will, with a high degree of certainty, bound  
7 the eventual break size that is specified in the post-rulemaking 50.46. In other words, the  
8 alternate break size uses insights from the proposed risk informed large break redefinition  
9 effort. In using this GSI-191 alternate break size, it is recognized that when the 50.46  
10 rule is finalized, licensees can re-perform the sump performance evaluations with the  
11 final break size specified in 50.46 and modify the plant design and operation. This would  
12 assure coherence in the implementation of 50.46.

13  
14 The alternate break size for the alternate evaluation of sump performance is defined as:

- 15  
16 ■ A complete guillotine break of the largest line connected to the reactor coolant system  
17 loop piping. If sufficient energy for debris generation exists on both sides of the  
18 break, a double ended break will be used. For example the guillotine break of the  
19 pressurizer surge line would result in high pressure blowdown from both sides of the  
20 guillotine break location. However, in the case of a safety injection discharge line,  
21 amount of high pressure fluid in the pipe between the main loop piping and the first  
22 isolation valve is very limited and would not be expected to result in significant  
23 debris generation from the discharge from that side of the break.

24  
25 A criteria to be used to determine if a pipe has sufficient energy on both sides of the  
26 break to cause significant debris generation is 10 pipe inside diameters for large bore  
27 piping (i.e., greater than 2 inch diameter) and 20 pipe diameters for small bore piping.  
28 For example, consider a 14 inch diameter schedule 160 pipe (11.18 inch I.D.)  
29 connected to the main loop piping. If a normally closed isolation valve is within 9.3  
30 feet (10 pipe diameters based on I.D.), then only a single ended break needs to be  
31 considered. This is based on the low stored energy in the pipe section between the  
32 break and isolation valve with respect to significant debris generation.

- 33  
34 ■ For main loop piping, a break size will be assumed to be that equivalent to a  
35 guillotine break of a 14 inch schedule 160 line. A guillotine break of this pipe, with  
36 an ID of 11.19 inches, gives an effective break area of 196.6 square inches (assuming

1 both sides of the break are pressurized). This is roughly equivalent to a single sided  
2 break of a 20 inch schedule 160 pipe with an ID of 16.06 inches.

3  
4 In defining these break sizes, the alternate break size to be considered by each licensee  
5 for lines connected to the main loop piping is plant dependent, while the alternate break  
6 size to be applied to the main loop piping is identical for each licensee.

### 7 8 **6.3 Region I Analysis**

9  
10 The analysis of recirculation system performance under the alternate evaluation process  
11 is performed in the same manner as described in Sections 3, 4 and 5 of this document,  
12 except that the maximum size of reactor coolant system (RCS) breaks to be considered is  
13 set by the "Alternate Break Size." The range of secondary side break sizes (e.g., steam  
14 line and feed line breaks) that will be considered is unchanged under the alternate  
15 evaluation methodology.

#### 16 17 **6.3.1 Break Size**

18  
19 For the Region I analysis a break size equal to or smaller than the alternate break size will  
20 be used as described in Section 6.2.

#### 21 22 **6.3.2 Break Location**

23  
24 The use of an alternate break size has no impact on the range of break locations to be  
25 considered. As discussed in Section 3, a full range of break locations will be assessed to  
26 determine the limiting location considering both debris generation and debris transport.  
27 However, Section 4 identifies that Branch Technical Position MEB 3-1 (Reference 7)  
28 may be used to limit the break locations considered. The use of an alternate break size  
29 could impact the limiting location of the break compared to analyses performed under  
30 Option A. Under Option A, the limiting break location considers the location of  
31 maximum debris generation / transport from a double ended guillotine break of the  
32 largest loop piping. When assessing the more limited alternate break size under Option  
33 B, the break location that results in the maximum debris generation / transport may be  
34 different from that of a double ended guillotine break.

35

1 **6.3.3 Break Configuration**

2  
3 The maximum break size to be considered for a given primary-side piping location is the  
4 minimum of either the alternate break size established in section 6.2 or the maximum  
5 attainable effective break area, as discussed below. Circumferential breaks will be  
6 assumed to result in pipe severance and separation amounting to at least one-diameter  
7 lateral displacement of the ruptured piping sections unless physically limited by piping  
8 restraints and supports, or other plant structural members that can be shown through  
9 analysis to limit pipe movement to less than one diameter lateral displacement. For pipes  
10 with a larger diameter than the maximum break size, the maximum attainable break area  
11 would be modeled as a partial pipe break with an area equivalent to the double ended  
12 rupture of a pipe with the same diameter as the alternate break size. The worst location  
13 of the break in terms of orientation around the break location must be considered.

14  
15 For example, the transverse internal area of a 14” schedule 160 pipe is 98.32 sq. in. The  
16 maximum attainable effective break area for this pipe is 2 times this value, or 196.65 sq.  
17 in (assuming a source high-energy flow from both directions). This break area would be  
18 applied to all main coolant loop piping.

19  
20 **6.3.4 Zone of Influence**

21  
22 The guidance in Section 3.4.2 on determination of the zone of influence for debris  
23 generation presumes a DEG break. For DEG breaks, a spherical Zone of Influence (ZOI)  
24 is conservatively postulated. This is appropriate for use in the alternate evaluation for  
25 breaks smaller than the alternate break size for piping connected to the main loop piping  
26 since a guillotine break of this piping is postulated. However for main loop piping,  
27 postulation of a break size less than the DEG break area would indicate a limited-  
28 displacement circumferential break or a longitudinal break, i.e., “split break”. This  
29 difference can be accounted for in one of the following ways:

- 30  
31 ■ ZOI Based on a Hemisphere. The zone of influence for longitudinal, or split breaks,  
32 can be simulated as a hemisphere with radius determined by the destruction pressure  
33 of the insulation that would be affected by the postulated break. As described in  
34 Section 3.4.2.2, the ZOI value used in a plant specific calculation depends upon the  
35 destruction pressure of the insulation in the region of the break. To use the  
36 hemispherical ZOI modeling, the break orientation needs to be simulated at various  
37 angles around the loop piping to determine maximum debris generation.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37

- ZOI Based on a Sphere. Because a worst-case break orientation can be difficult to determine, an alternative to assuming a hemispherical ZOI is to translate the hemispherical volume into an equivalent volume sphere.

Additional guidance is also provided in Section 4 for the use of the following refinements to the guidance given above:

1. The use of debris specific zones of influence, and,
2. The use of directed jets to evaluate damage to insulation and coatings

These refinements may be applied at the option of the user to reduce the zone of influence for consideration of debris generation. In particular, for coolant loop piping and a postulated break size less than the DEG break area, the use of a directed jet for debris generation may require the determination of a worst-case break orientation.

**6.3.5 Debris Generation, Transport and Accumulation**

The guidance in Sections 3 and 4 is to be used to determine the debris generation (except for ZOI as discussed above), transport and accumulation on the containment sump screens for breaks smaller than the alternate break size.

**6.3.6 Acceptance Criteria**

The acceptance criteria for containment sump screen performance continues to be core cooling based on available NPSH equal to, or greater than, the required NPSH for all pumps required to operate for long term core cooling. The calculation of the required and available NPSH is based on the models and assumptions currently used in design basis analyses of sump and core cooling recirculation performance. In addition, if containment spray is credited in the design basis analyses (containment pressure, radiological consequence, etc.), the containment sump screen performance also includes NPSH margin for the operation of the minimum required containment spray.

**6.3.7 Modifications to Event Timings and Conditions**

Consideration will be given to the potential impact of the alternate break size on event timings, thermal/hydraulic conditions and NPSH requirements. Use of the alternate

1 break size on either piping connected to the main loop piping or the main loop piping  
2 itself, in lieu of a full DEG break on the main loop piping, will affect key scenario events  
3 such as (but not limited to):

- 4
- 5     ▪ the timing of transfer to recirculation from RWST injection,
- 6     ▪ the containment sump water properties (e.g., temperature), and
- 7     ▪ containment back-pressure (if credited in design basis analyses).

8

9 The evaluation will consider these revised timings as appropriate.

### 10

### 11 **6.3.8 Operator Actions**

12

13 The use of break sizes smaller than a full double-ended rupture may result in significant  
14 differences in the time at which core cooling recirculation would be initiated. The impact  
15 of operator actions to mitigate containment sump blockage may be considered for these  
16 scenarios provided that the operator actions meet the criterion for consideration in design  
17 basis analyses. These considerations would include adequate time for operator action per  
18 design basis “rules”, proceduralized guidance, job-task-analysis, etc.

### 19

### 20 **6.4 Region II Analysis**

21

22 In implementing the alternate evaluation methodology (Option B) approach, reasonable  
23 assurance must be provided that mitigation capability is retained for break sizes between  
24 the alternate break size and a guillotine break of the largest main coolant loop pipe. This  
25 evaluation is performed using more realistic analysis methods and assumptions and credit  
26 can be taken for operation of non-safety systems, structures and components, as well as  
27 expected operator actions. In addition, modification of the acceptance criteria (i.e.,  
28 NPSH considerations) applicable to design basis analyses is permitted. The list of  
29 potential modifications to the set of conservative methods and assumptions used in the  
30 design basis analysis can be large. To simplify the Region II analysis process the  
31 following sections identify a recommended set of modifications to methods and  
32 assumptions described in Section 3 through 5. These modifications were selected based  
33 on the potential for the largest benefits in terms of the use of more realistic models and  
34 assumptions that affect the analyzed containment sump performance (as opposed to the  
35 actual sump performance).

36



1 **6.4.1 Break Size**

2  
3 Break sizes that need to be considered in the Region II analysis cover the range from  
4 “Alternate Break Size” identified in Section 6.2 up to a guillotine break of the loop  
5 piping.  
6

7 **6.4.2 Break Location**

8  
9 Primary side piping whose attainable break area is less than or equal to the “Alternate  
10 Break Size” will have already been addressed as part of the design basis analysis  
11 described in Section 6.3 and can be excluded from further consideration as part of the  
12 Region II analysis. Any postulated secondary side break locations will also have been  
13 addressed as part of the Region I analysis and can be excluded from the Region II  
14 analysis. Consequently, all high energy piping locations except for main loop piping are  
15 fully addressed as part of the design basis analysis. If a licensee chooses to use an  
16 alternate break size smaller than the largest connected piping to the main coolant loop, as  
17 discussed in Section 6.2, then connected piping larger than the alternate break size would  
18 be addressed as part of the Region II evaluation.  
19

20 For the remaining break locations, guidance provided in Generic Letter 87-11, *Relaxation*  
21 *in Arbitrary Intermediate Pipe Rupture Requirements* (Reference 8) and the associated  
22 Branch Technical Position MEB 3-1, *Postulated Rupture Locations in Fluid System*  
23 *Piping Inside and Outside Containment*, should be used to identify postulated primary  
24 side break locations. The use of MEB 3-1 to identify the break locations is within the  
25 design basis as discussed in the Background of that document:  
26

27 “This position on pipe rupture postulation is intended to comply with the requirements of General Design  
28 Criteria 4 of Appendix A to 10 CFR Part 50 for the design of nuclear power plant structures and  
29 components...The rules of this position are intended to utilize the available piping design information by  
30 postulating pipe ruptures at locations having relatively higher potential for failure, such that an adequate  
31 and practical level of protection may be achieved (emphasis added).”  
32

33 As discussed in Section 6.2 and SECY-04-0060, the NRC’s Option 3 expert elicitation  
34 gave strong weight to reactor vessel penetration integrity for the large break sizes and  
35 steam generator tube failures for small break sizes. They also gave strong weighting to  
36 breaks in locations that have Alloy 600 welds based on operating experience. These  
37 locations are considered to be more probable than a circumferential break in a smooth  
38 piping segment. For these reasons, consideration of piping break locations as defined in

1 MEB 3-1 are considered for breaks larger than the alternate break size. In the  
2 development of MEB 3-1, it was recognized that some pipe break locations were of  
3 sufficiently low probability that these locations did not require additional design  
4 considerations to limit their consequences. Consequently, MEB 3-1 identifies that the  
5 dynamic effects of pipe breaks need only be considered for high stress and fatigue pipe  
6 locations, such as at the terminal ends of a piping system at its connection to the  
7 nozzles of a component. Breaks at locations other than those prescribed by MEB 3-1  
8 have been determined by the NRC staff to be of sufficiently low probability that the  
9 design need not accommodate their dynamic effects. The position taken in MEB 3-1 is  
10 confirmed by the NRC's Option 3 expert panel. Therefore, consideration of breaks in  
11 loop piping at locations identified in MEB 3-1 provides confidence that an adequate and  
12 practical level of protection is achieved.

### 13 14 **6.4.3 Break Configuration**

15  
16 All breaks considered in the Region II evaluation are main coolant loop piping, except in  
17 the case where the licensee has defined the alternate break size as less than the largest  
18 pipe connected to the main coolant loop piping, as discussed in Section 6.2. In any case,  
19 the Region II evaluation does not consider partial breaks of piping. Partial breaks of  
20 main coolant loop piping (and other connected piping) have already been considered as  
21 part of the Region I evaluation, as discussed in Section 6.3. Partial breaks larger than the  
22 alternate break size are not considered in the Region II evaluation because the Region II  
23 evaluation already considers guillotine breaks in these pipes. Therefore, the Region II  
24 evaluation is limited to guillotine pipe breaks.

25  
26 These circumferential breaks are assumed to result in pipe severance and separation  
27 amounting to at least one-diameter lateral displacement of the ruptured piping sections  
28 unless physically limited by piping restraints and supports, other plant structural  
29 members, or piping stiffness as may be demonstrated by analysis. Existing plant-specific  
30 dynamic loads analyses for postulated primary side breaks are utilized to assist the  
31 determination of the break configuration for the Region II analysis.

### 32 33 **6.4.4 Zone of Influence**

34  
35 The guidance in Sections 3 and 4 and in Section 6.3.4 is used to determine the ZOI.  
36 There are a number of known conservatisms in the ZOI model presented in Sections 3  
37 and 4. However, development of a technically sound model to more realistically model

1 the ZOI, based on existing experimental and analytical data, is quite complex and has not  
2 been initiated due to the time constraints for development of the Region II guidance.  
3 Therefore, use of the ZOI evaluation methods in Sections 3 and 4 will be used for the  
4 Region II evaluation.

#### 6 6.4.5 Debris Generation, Transport and Accumulation

7  
8 The guidance in Sections 3 and 4 is used to determine the debris generation, transport and  
9 accumulation on the containment sump screens for Region II evaluations.

10  
11 The current experimental and analytical basis for the generation, transport and  
12 accumulation does not easily lend itself to the quantification of more realistic models.  
13 The evaluations models presented in Sections 3 and 4 are considered to be bounding  
14 models to assure that the debris generation, transport and accumulation is not under-  
15 predicted. Thus, there are known conservatisms in each portion of the model evaluation  
16 models presented in Sections 3 and 4. However, development of more realistic models is  
17 difficult due to the limited amount of experimental and analytical information available  
18 for any single aspect of the model. This development work has not been initiated due to  
19 the time constraints for completion of the Region II guidance.

#### 21 6.4.6 Acceptance Criteria

22  
23 The acceptance criterion for containment sump screen performance is continued core and  
24 containment cooling. The applicable criteria to demonstrate retained mitigation  
25 capability for long-term cooling capability in the Region II analysis are:

- 26  
27 1. Positive NPSH margin is maintained for the minimum number of ECCS pumps  
28 necessary to demonstrate adequate core cooling flow, and  
29 2. Demonstration of adequate containment cooling capability to provide assurance that  
30 the containment boundary remains intact.

31  
32 The first criterion (positive NPSH margin is maintained for the minimum number of  
33 ECCS pumps) can be met by ensuring NPSH margin is maintained for one or more  
34 moderate to high-capacity ECCS injection pumps (e.g., low-head RHR pumps for W-  
35 NSSS plants or either high-head or low-head SI pumps for CE NSSS plants. The  
36 calculation of the required and available NPSH is discussed below in Section 6.4.7.

1 For the Region II evaluation, limited operation without NPSH margin is acceptable if it  
2 can be shown that the pumps can reasonably be expected to survive during the time  
3 period of inadequate available NPSH. For example, if vendor information for a pump  
4 identifies that operation in a cavitation model for a limited period of time would not be  
5 expected to harm the long term pump performance, this may be considered in the Region  
6 II evaluation. In crediting pump operation under inadequate available NPSH conditions,  
7 it is recognized that both the time of operation with inadequate available NPSH and the  
8 magnitude of the inadequate available NPSH need to be considered. Vendor information  
9 may be used to justify continued pump operation under episodes of inadequate available  
10 NPSH. The vendor information may be test data or engineering judgment derived from  
11 tests and/or operational events.

12  
13 For plants relying on decay heat removal via modes other than the minimum ECC  
14 recirculation pathway that meets the first criterion would also have to assure that the heat  
15 removal pathway is also available. For example, some plants require containment spray  
16 recirculation for decay heat removal (e.g., subatmospheric containment plants and some  
17 CE NSSS plants). In this case, some containment spray flow would have to be  
18 maintained as discussed in Criterion 2.

19  
20 The second criterion (demonstration of adequate containment cooling capability) can be  
21 met through credit taken for minimal heat-removal pathways, including containment fan  
22 coolers, permitted by emergency procedures. Subatmospheric containment plants would  
23 not have to demonstrate that the containment remains below atmospheric pressure for the  
24 duration of the accident, if permitted by the emergency procedures.

25  
26 In addition, exceeding nominal transient containment design pressure/temperature and  
27 EQ envelopes is allowed for Region II analysis, if reasonable assurance is provided that  
28 containment pressure boundary failure or vital equipment failure would not be expected  
29 to occur.

#### 30 31 **6.4.7 Net Positive Suction Head Calculation**

32  
33 Use of an alternate NPSH calculation, in lieu of the conservative calculation method  
34 prescribed by Regulatory Guide 1.1, “Net Positive Suction Head for Emergency Core  
35 Cooling and Containment Heat Removal System Pumps” (Reference 9), and Regulatory  
36 Guide 1.82, Rev. 3, “Water Sources for Long-Term Recirculation Cooling Following a  
37 Loss-Of-Coolant Accident”(Reference 10), is recommended for the evaluation of break

1 sizes larger than the alternate break size. The conservative factors involved in the  
2 calculation of NPSH, including event timings, thermal/hydraulic conditions and plant  
3 physical configurations, may be evaluated to provide a more realistic calculation of  
4 NPSH available. This section discusses the potential impact of factors that have a  
5 positive impact on more realistic analysis of available net positive suction head (NPSH).

6  
7 In applying a more realistic NPSH calculation to the Region II evaluation, which is still  
8 within the plant design basis, it is recognized that operability assessments, for example,  
9 such as those identified in Generic Letter 91-18 (Reference 11), do not need to be  
10 undertaken when nominal parameters used in the assessment are exceeded for a short  
11 period of time (e.g., less than 30 days). The NPSH margin still available, even using  
12 these more realistic analysis models, combined with the short time period of exceedance  
13 of the values used in this analysis and the low probability of a break larger than the  
14 alternate break size support continued operation without an operability assessment under  
15 these conditions.

#### 16 17 **6.4.7.1 NPSH Available**

18  
19 The Hydraulic Institute Standard ANSI/HI 1.1-1.5-1994 (Reference 12), defines NPSH as  
20 the total suction head in feet absolute, determined at the suction nozzle and corrected to  
21 datum, less the vapor pressure of the liquid in feet absolute. It is an analysis of energy  
22 conditions on the suction side of a pump to determine if the liquid will vaporize at the  
23 lowest pressure point in the pump. The typical equation governing the calculation of  
24 available NPSH is given as:

$$25 \quad \text{NPSH}_A = H_P + H_{EI} - H_{VP} - H_F$$

26  
27  
28 Where:

29  
30  $H_P$  = absolute pressure head at the pump suction pressure

$$31 \quad = (P_{\text{gage}}) \times \rho / 144 \text{in}^2/\text{ft}^2$$

32  $\rho$  = fluid density (lbs/ft<sup>3</sup>)

33  $H_{EI}$  = Elevation head

34  $H_{VP}$  = Vapor pressure at prevailing water temperature converted to head

$$35 \quad = (P_{\text{vapor}}) \rho / 144 \text{in}^2/\text{ft}^2$$

36  $H_F$  = form and frictional head losses including through the sump screen,  
37 entrance losses and piping losses

1  
2 Each of the contributing factors to the available NPSH are typically calculated based on  
3 conservative assumptions to assure that adequate NPSH is available under all a wide  
4 range of possible conditions. Calculation of available NPSH based on more realistic  
5 basis may be used to demonstrate that adequate margin exists between available and  
6 required NPSH. The following discussion evaluates each of the above contributors, plant  
7 status and thermal hydraulic conditions that will effect the calculation of available NPSH  
8 and to a lesser extent the NPSH required.

#### 9 10 Suction Elevation Head

11  
12 This parameter is the flooded level within containment above the pump suction  
13 centerline. Historically the value has been calculated based on absolute minimum values  
14 of water delivered to the containment sump. Considerations to provide a more accurate  
15 estimate of sump levels should include the following:

- 16  
17 ■ The nominal operating volume in the RWST and the accumulators are to be utilized  
18 rather than the Technical Specification minimum values,.
- 19 ■ RWST and accumulator volume delivered to the containment do not include  
20 instrument error volumes that are typically considered in determining a conservative  
21 delivered sump volume.
- 22 ■ The volume of water estimated to be delivered to the containment as the switchover  
23 of safety injection and containment spray pumps are manually (or automatically)  
24 completed are to be used rather than the RWST volume delivered at the ECC  
25 switchover setpoint based on RWST level
- 26 ■ Containment sump inventory is to include RCS volumes that will be in the  
27 containment sump post accident. Since only breaks larger than the alternate break  
28 size are considered in this portion of the alternate evaluation methodology, it is not  
29 expected that the RCS would be refilled. Analyses performed for W-NSSS plants to  
30 determine the minimum break size for consideration of switchover to hot leg  
31 recirculation to prevent boron buildup in the reactor vessel concluded that the RCS  
32 could not be refilled for breaks larger than 10 inches equivalent diameter. Therefore  
33 it is appropriate to include the primary side of the steam generators, the pressurizer  
34 and surge line, and the vessel head volumes in the containment sump water inventory  
35 available at the beginning of ECC recirculation.
- 36 ■ Best estimate holdup volumes within the containment are to be used.

1 Absolute Pressure Head and Vapor Pressure Head

2  
3 This parameter is the head that can be attributed to the pressure exerted on the fluid in the  
4 sump by external forces. Typically for PWRs that do not credit containment overpressure  
5 in the design basis analyses, the basic assumption is to conservatively assume that  
6 containment pressure equals the vapor pressure of the liquid in the sump. In reality, this  
7 assumes that there is no air partial pressure in containment prior to the event, or that the  
8 air pressure is non-mechanistically lost during the event. A more realistic assumption is  
9 that at the time of safety injection recirculation the containment partial steam pressure is  
10 equal to sump fluid vapor pressure plus an air partial pressure equal to the containment  
11 air pressure prior to the event. The air pressure prior to the event is to be calculated  
12 assuming 100% relative humidity at a containment temperature corresponding to the  
13 maximum normal temperature experienced at the plant. Alternatively, the pre-event  
14 minimum containment pressure minus the partial steam pressure at the dew point  
15 temperature for the cooling water temperature can be assumed for the air pressure. The  
16 recognition of the pre-event air pressure acknowledges the thermal-hydraulic condition of  
17 containment prior to the event without crediting containment overpressure based on the  
18 accident scenario.

19  
20 Regulatory Guide 1.82 specifies that ECC and containment heat removal systems should  
21 be designed so that sufficient available NPSH is provided to the system pumps, assuming  
22 the maximum expected temperature of pumped fluid and no increase in containment  
23 pressure from that present prior to the postulated LOCA. Further, RG 1.82 acknowledges  
24 that for cases where the design cannot be practicably altered, conformance with the above  
25 regulatory position may not be possible. In these cases, additional containment pressure  
26 may be included in the determination of available NPSH, but only to the extent that is  
27 necessary to preclude calculated pump cavitation. This allowance acknowledges that the  
28 calculation of available containment pressure and sump water temperature as a function  
29 of time will underestimate the expected containment pressure and overestimate the sump  
30 water temperature when determining available NPSH for this situation. Elevated  
31 containment pressure is to be credited in the alternate evaluation methodology only after  
32 full consideration has been given to other possible use of more realistic models and  
33 assumptions in the analysis.

34  
35 When credit for containment pressure above atmospheric pressure is included in the  
36 NPSH available evaluation, a new containment analysis is likely to be required since the  
37 calculation for ECC backpressure typically only considers the first few minutes of the

1 accident scenario. The following considerations will be assessed to assure that a  
2 conservatively low containment overpressure is credited:

- 3
- 4     ▪ The use of the nominal RWST temperature and nominal containment pressure and  
5       temperature based on operating experience.
- 6     ▪ A slower rate of release of stored thermal energy from the steam generators to the  
7       containment environment may be considered. For example, a steam generator  
8       stored thermal energy release rate over the first two hours of the postulated event  
9       may be considered.
- 10    ▪ Realistic containment heat removal, both active and passive, may be assumed.
- 11    ▪ Other input parameters to the LOCA mass & energy containment integrity  
12      analysis should be reviewed to identify those parameters that may be changed to  
13      calculate a nominal containment overpressure.
- 14

#### 15 Friction and Form Head Loss

16

17 This parameter is the sum of the head losses through the containment sump screen,  
18 containment sump and suction piping. The head losses through the sump screen are the  
19 subject of Sections 3.2.5 and 4.2.5. The guidance of those sections is to be followed in  
20 the head loss determination. A refinement to this approach may be considered based on  
21 realistic conditions for the fluid approach velocity in the sump screen head loss  
22 calculations. Two examples of more realistic conditions are:

- 23
- 24     ▪ At switchover to ECC recirculation, the containment spray pumps typically  
25       remain aligned to the RWST until the entire usable RWST inventory is drained to  
26       the containment. Thus, the fluid approach velocity at the beginning of ECC  
27       recirculation will only consider the pumps taking suction from the containment  
28       sump at that time. A second calculation may be required to determine the head  
29       loss with containment spray pumps taking suction from the containment sump, if  
30       applicable (see Section 6.4.9 on Operator Actions). However, that second  
31       calculation may also consider the increased elevation head available due to  
32       draining the entire usable RWST to the containment sump.
- 33     ▪ In response to NRC Bulletin 2003-1 (Reference 13), a set of compensatory  
34       measures were identified and additional generic Emergency Response Guideline  
35       procedures and/or procedure steps were developed. Credit for these operator  
36       actions to reduce the approach velocity may be taken where those procedures



1 have been implemented. More information on credit for operator actions can be  
2 found in Section 6.4.9.

3  
4 Friction and form losses calculated for entrance losses into the sump (exclusive of the  
5 screen) and in the pump suction piping are normally calculated using standardized loss  
6 factors from generally accepted handbook sources such as Crane Technical Paper 410,  
7 “Flow of Fluids” (Reference 14). Experience has shown that these calculations are  
8 typically conservative (higher projected frictional and form losses) than field experience  
9 has shown. The magnitude of the conservatism for these handbooks is normally in the  
10 range of 15 to 25 percent. If handbook sources have been used to calculate the head  
11 losses input into the NPSH evaluation, then the values may be reduced to be more  
12 realistic, based on either engineering judgment or test results that provide evidence of the  
13 losses.

#### 14 15 **6.4.7.2 NPSH Required**

16  
17 The Hydraulics Institute defines NPSH required as “the amount of suction head, over  
18 vapor pressure, required to prevent more than 3% loss in total head from the first stage of  
19 the pump at a specific rate of flow”. Therefore, this value is indicative of when head loss  
20 begins to occur rather than when incipient pump damage occurs. In the containment  
21 sump recirculation mode, pump developed head is not necessarily a critical parameter  
22 and thus the pump vendor may be able to provide relief in the amount of NPSH required to  
23 avoid pump damage rather than the established formal definition of required NPSH.  
24 However, tests have shown that there is typically very little margin between the NPSH at  
25 which 3% loss in total head occurs and the NPSH at which pump impeller damage  
26 occurs. While the margin is dependent on the pump design, it is generally quite small.  
27 This aspect of NPSH is not recommended for further investigation unless vendor  
28 information, derived from tests or operating experience, indicates that there are atypical  
29 margins available.

30  
31 ANSI/ HI 1.1-1.5-1994 also specifies a method of accounting for the decrease in required  
32 NPSH with an increase in temperature of the pumped fluid. This method is subject to  
33 restrictions specified in the standard dealing with experience with the specific pump, the  
34 amount of air dissolved in the fluid, and the transient nature of the pressure and  
35 temperature of the pumped fluid. Therefore, it is recommended that credit not be taken  
36 for the reduction in required NPSH due to the temperature of the pumped fluid, because  
37 of the uncertainty in these factors.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

### 6.4.7.3 Calculational Method

Credit for more realistic calculation of the available and required NPSH requires careful examination of the integrated time dependent changes in the parameters that can impact the available and required NPSH over the range of possible break sizes considered for the Region II evaluation methodology. The impact of the break size, from the alternate break size to a guillotine break, on the parameters that impact the available and required NPSH also need to be considered. The containment and sump responses (sump water level, sump screen approach velocity, sump water temperature and containment pressure) used in the NPSH assessments need to be carefully assessed to assure that the available NPSH is not underestimated and the required NPSH is not overestimated.

The single failure assumption used for design basis ECC performance analyses is generally not appropriate for containment sump performance calculations since the maximum sump approach velocities and minimum containment conditions will typically control the results.

The following assumptions are generally acceptable for the calculation of more realistic available and required NPSH:

- Containment water level consistent with nominal RWST and RCS volumes that would be expected to be in the containment sump for the break size under consideration and realistic assessment of holdup volumes.
- Containment sump temperatures based on realistic decay heat rates, as defined in ANSI 5.1 1979 (Reference 15) and nominal heat removal using maximum service water / component cooling water temperatures that represent at least the 95<sup>th</sup> percentile from operating experience.
- Containment pressure head based on absolute pressure rather than vapor pressure.
- If additional credit is taken for containment overpressure, an analysis that minimizes the containment pressure is to be performed to assure that the containment overpressure is not overestimated. Credit for containment overpressure should only be taken as a last resort where a design difference would be mandated without credit for overpressure.
- The sump screen approach velocity for the head loss calculation is to realistically consider the maximum pumps drawing from the sump as a function of time, including credit for appropriate operator actions to terminate operation of certain pumps.

- 1   ▪ More realistic factors for head loss in the sump entrance (exclusive of the sump  
2    screens) and the suction piping may be used based on engineering judgment or test  
3    results.  
4

#### 5   **6.4.8 Timing of Events** 6

7   More realistic modeling of debris generation, transport and accumulation on sump  
8   screens can be considered based on the timing of debris generation, transport, and  
9   accumulation in relation to the timing of the available and required NPSH. The design  
10  basis analyses described in Sections 3 and 4 assume that the maximum debris is available  
11  on the sump screens and available NPSH requirements are the minimum that occur over  
12  the entire accident scenario. A more realistic assessment would take into account that:

- 13  
14  ▪ debris generation, transport and accumulation is time dependent,  
15  ▪ available NPSH is time dependent, and  
16  ▪ the maximum debris accumulation and the minimum required NPSH may not occur  
17  simultaneously.  
18

19  Therefore, a time dependent treatment of debris accumulation and NPSH requirements  
20  will use the following guidelines:

- 21  
22  ▪ for the debris generation as a result of the pipe break, the debris is available for  
23  transport at the initiation of the accident,  
24  ▪ for debris generation as a result of containment spray and other latent sources, an  
25  arbitrary linear debris generation over a period of one hour will be assumed,  
26  ▪ for debris transport to the sump screens, the time is to be based on sump velocities as  
27  discussed in Sections 3 and 4,  
28  ▪ for the assessment of head loss at the sump screen, the time dependent flow through  
29  the screen is to be considered, including credit for operator actions to terminate one or  
30  more pumps taking suction from the sump, and  
31  ▪ for assessment of available NPSH, time dependent sump water properties (e.g.,  
32  temperature, depth) are to be used.  
33

#### 34  **6.4.9 Operator Actions** 35

36  An important allowance in the Region II analysis is credit for operator actions and the  
37  operation of non-safety equipment.

1  
2 The operator actions that can be credited include those directed by emergency  
3 procedures. In applying operator actions, an assessment of the accident sequences and  
4 procedures is necessary to assure that there is reasonable confidence that the operator  
5 actions can be effective. The operator actions may include some of the compensatory  
6 actions identified in licensee response to NRC Bulletin 2003-1, including:

- 7
- 8 - Termination or reduction of containment spray recirculation when it is not needed for  
9 containment cooling,
  - 10 - Termination of excess ECC recirculation capability when it is not needed to long  
11 term core cooling,
  - 12 - RCS cooldown and depressurization to use shutdown cooling in place of ECC  
13 recirculation, which may also involve establishing an alternate means of RCS (i.e.,  
14 after the initial RWST volume is used).

15  
16 The operations that can be credited will be plant-specific, but could include:

- 17
- 18 • Credit for non-safety active screens, screen backwash systems or similar  
19 modifications to containment sump screen design
  - 20 • Credit for shutdown cooling and alternate methods of RWST makeup.

21  
22 **6.5 Risk Insights**

23  
24 In the event that plant specific changes to the plant design / operation are made to address  
25 the sump blockage issue, risk insights can be used to assure that the changes can  
26 reasonably be expected to provide adequate protection for a wide range of accidents. In  
27 particular, risk tools can be used to determine the targeted reliability of the changes.  
28 These risk insights need only be applied to plant modifications involving active  
29 components and /or operator actions that are made solely to show compliance with the  
30 acceptance criteria for alternate evaluations described in Section 6. The risk calculation  
31 does not apply to passive components (e.g., enlarged sump screen area) since they  
32 typically can be assumed to perform their function with a high degree of reliability based  
33 on design margins, etc. In cases where a measurable and inspectable reliability can be  
34 ascribed to a passive component (e.g., passive screen cleaning), the risk assessment may  
35 be applicable.

36

1 The minimum reliability for active components and operator actions is to be determined  
2 from the maximum acceptable change in risk (e.g., core damage frequency, or CDF) for a  
3 baseline risk value. A simplified generic risk assessment can be developed that provides  
4 a bounding targeted reliability of the modifications to provide reasonable assurance of  
5 adequate containment sump performance.

6  
7 As a bounding assessment, the change in core damage frequency is modeled to be the  
8 product of the large break LOCA frequency and the probability that the mitigation feature  
9 fails:

10  
11 
$$\text{Delta CDF} = \text{LBLOCA IEF} * \text{Mitigation FP}$$

12  
13 Where:           Delta CDF is the change in CDF as a result of implementing the  
14                   mitigation system  
15                   LBLOCA IEF is the large break LOCA initiating event frequency  
16                   Mitigation FP is the Mitigation System Failure Probability

17  
18 This simplified calculation assumes:

- 19  
20     ▪ An idealized base case condition in which the sump does not clog if the mitigation  
21       operates  
22     ▪ A bounding alternate case where the sump will clog and core damage occurs if the  
23       mitigation system fails (e.g., CDF probability is 1.0)  
24     ▪ There is no credit for successful recovery actions if the mitigation system fails.

25  
26 For the LBLOCA initiating event frequency, the value of 5.0 E-04 per reactor year that  
27 was used in NUREG-1150 (Reference 16) represents a generic bound that may be used in  
28 the assessment in place of plant specific values from the licensees PRA. The generic  
29 bounding value is not likely to be exceeded in future considerations of break size vs.  
30 frequency for the Option 3 large break LOCA redefinition effort. This assures that  
31 updates to this risk assessment will be unaffected by the final break frequency  
32 considerations used in Option 3.

33  
34 The acceptable Delta CDF is derived from Regulatory Guide 1.174 (Reference 17).  
35 From Regulatory Guide 1.174, when the calculated increase in CDF is in the range of 1.0  
36 E-06 per reactor year to 1.0 E-05 per reactor year, changes in the licensing basis are to be  
37 considered only if it can be reasonably shown that the total CDF is less than 1.0 E-04 per

1 reactor year (Region II of Figure 3 of the Regulatory Guide). The CDF of less than 1.0  
2 E-04 bounds the population of PWRs.

3  
4 A simple bounding PRA logic can be defined where the failure of ECC recirculation is  
5 dominated by the failure of the modification considered for sump blockage mitigation.  
6 This would then be dominated by the mitigation equipment reliability, or the operator  
7 action credited for mitigation.

8  
9 Using a bounding generic value for LBLOCA initiating event frequency of 5.0 E-04 per  
10 year as identified in NUREG-1150 and a minimum change in CDF as a result of the  
11 modification of 1.0 E-05 per year from Regulatory Guide 1.174, yields a required  
12 unreliability of 2.0 E-02 per demand. This can be translated to a targeted reliability of  
13 98% per demand for operator actions and or active components.

14  
15 This generic risk calculation does not need to be repeated for plant specific assessments.  
16 Plant specific assessments of proposed changes would only have to assure that a target  
17 reliability of 98% per demand could reasonably be met.

18  
19 Establishing a combination of extremely low probability of needing containment sump  
20 recirculation and challenging the containment sump performance will provide suitable  
21 redundancy for the regulatory intent to be met by not assuming single failures of active  
22 components. Thus, the defense in depth and safety margin considerations in Regulatory  
23 Guide 1.174 can be implicitly assured by the low probabilities of the events.

## 24 25 **6.6 REFERENCES**

- 26  
27
- 28 1. SECY-02-0057, "Update to SECY-01-0133, 'Fourth Status Report on Study of  
29 Risk Informed Changes to the Technical Requirements of 10 CFR Part 50 (Option  
30 3) and Recommendation on Risk-Informed Changes to 10 CFR 50.46 (ECCS  
31 Acceptance Criteria)".
  - 32  
33 2. 10 CFR 50.46, "Acceptance Criteria for Emergency Core Cooling Systems for  
34 Light Water Nuclear Power Reactors".
  - 35  
36 3. Letter from Suzanne C. Black, NRC, to Anthony Pietrangelo, NEI, "Nuclear  
37 Energy Institute's Proposals for Determining Limiting Pipe Break Size Used in

- 1           Assessing Debris Generation Following a Design Basis LOCA (TAC NO.  
2           MC1154,” March 4, 2004.  
3
- 4           4. SRM-SECY-04-0037, “Staff Requirements - SECY-04-0037 – Issues Related to  
5           Proposed Rulemaking to Risk-Inform Requirements Related to Large Break Loss-  
6           of-Coolant Accident (LOCA) Break Size and Plans for Rulemaking on LOCA  
7           with Coincident Loss-of-Offsite Power.  
8
  - 9           5. SRM-SECY-02-0057, “Staff Requirements - SECY-02-0057 – Update to SECY-  
10           01-0133, "Fourth Status Report on Study of Risk-Informed Changes to the  
11           Technical Requirements of 10 CFR PART 50 (Option 3) and Recommendations  
12           on Risk-Informed Changes to 10 CFR 50.46 (ECCS Acceptance Criteria)".  
13
  - 14           6. SECY-04-0060, “Loss-of Coolant Accident Break Frequencies for the Option III  
15           Risk-Informed Reevaluation of 10 CFR 50.46, Appendix K to 10 CFR Part 50,  
16           and General Design Criteria (GDC) 35.  
17
  - 18           7. Branch Technical Position MEB 3-1, Revision 2, “Postulated Rupture Locations  
19           in Fluid System Piping Inside and Outside Containment”.  
20
  - 21           8. Generic Letter 87-11, “Relaxation in Arbitrary Intermediate Pipe Rupture  
22           Requirements”.  
23
  - 24           9. Regulatory Guide 1.1, “Net Positive Suction Head for Emergency Core Cooling  
25           and Containment Heat Removal System Pumps”.  
26
  - 27           10. Regulatory Guide 1.82, Rev. 3, “Water Sources for Long-Term Recirculation  
28           Cooling Following a Loss-Of-Coolant Accident”.  
29
  - 30           11. Generic Letter 91-18, Revision 1, “Information to Licensees Regarding NRC  
31           Inspection Manual on Resolution of Degraded and Nonconforming Conditions”.  
32
  - 33           12. ANSI/HI 1.1-1.5 -1994, “Centrifugal Pumps - Nomenclature, Definitions,  
34           Applications And Operation”.  
35
  - 36           13. NRC Bulletin 2003-01, “Potential Impact of Debris Blockage on Emergency  
37           Sump Recirculation at Pressurized-Water Reactors,” June 9, 2003.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12

14. Crane Technical Paper 410, “Flow of Fluids”.

15. ANSI/ANS 5.1-1979, “American National Standard for Decay Heat Power in Light Water Reactors”.

16. NUREG-1150, Volumes 1 and 2, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants”.

17. Regulatory Guide 1.174, “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis”.