


George Vanderheyden
Vice President
Calvert Cliffs Nuclear Power Plant
Constellation Generation Group, LLC

1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410.495.4455
410.495.3500 Fax



Constellation Energy

July 19, 2004

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Resolution of Generic Letter 96-06 Issues

REFERENCES:

- (a) Letter from Mr. P. E. Katz (CCNPP) to Document Control Desk (NRC), dated December 3, 2002, "Response to Request for Additional Information, Generic Letter 96-06"
- (b) Letter from Mr. G. S. Vissing (NRC) to Mr. P. E. Katz (CCNPP) dated March 25, 2003, "Response to Generic Letter 96-06, Assurance of Equipment Operability and Containment Integrity During Design-Basis Accident Conditions, dated September 30, 1996 (TAC Nos. M96792 and M96793)"

In Reference (a), we made a regulatory commitment to prevent waterhammer in the Service Water System by placing the service water pumps on step "0" in the loading sequence of the emergency diesel generator. In Reference (b), the Nuclear Regulatory Commission concurred with this decision. Reference (b) also requested that we advise the Nuclear Regulatory Commission when the modification has been fully implemented.

We have now completed this modification on both units and consider our response to Generic Letter 96-06 closed.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

GV/EMT/bjd

cc: J. Petro, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
R. V. Guzman, NRC

H. J. Miller, NRC
Resident Inspector, NRC
R. I. McLean, DNR

1072