July 22, 2004

Mr. Gordon Bischoff, Manager Owners Group Program Management Office Westinghouse Electric Company P.O. Box 355 Pittsburgh, PA 15230-0355

#### SUBJECT: DRAFT SAFETY EVALUATION FOR TOPICAL REPORT WCAP-15872, REV. 00, "USE OF ALTERNATE DECAY HEAT REMOVAL IN MODE 6 REFUELING" (TAC NO. MB9020)

Dear Mr. Bischoff:

On May 12, 2003, the Westinghouse Owners Group (WOG) submitted Topical Report (TR) WCAP-15872, Rev. 00, "Use of Alternative Decay Heat Removal in Mode 6 Refueling" to the staff for review. Enclosed for the WOG's review and comment is a copy of the staff's draft safety evaluation (SE) for the TR WCAP-15872, Rev. 00.

Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Girija Shukla at 301-415-8439.

Sincerely,

#### /RA/

Stephen Dembek, Chief, Section 2 Project Directorate IV Division of Licensing Project Management Office of Nuclear Reactor Regulation

Project No. 694

Enclosure: Draft Safety Evaluation

cc w/encl: See next page

Mr. Gordon Bischoff, Manager Owners Group Program Management Office Westinghouse Electric Company P.O. Box 355 Pittsburgh, PA 15230-0355

### SUBJECT: DRAFT SAFETY EVALUATION FOR TOPICAL REPORT WCAP-15872, REV. 00, "USE OF ALTERNATE DECAY HEAT REMOVAL IN MODE 6 REFUELING" (TAC NO. MB9020)

Dear Mr. Bischoff:

On May 12, 2003, the Westinghouse Owners Group (WOG) submitted Topical Report (TR) WCAP-15872, Rev. 00, "Use of Alternative Decay Heat Removal in Mode 6 Refueling" to the staff for review. Enclosed for the WOG's review and comment is a copy of the staff's draft safety evaluation (SE) for the TR WCAP-15872, Rev. 00.

Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Girija Shukla at 301-415-8439.

Sincerely, /RA/ Stephen Dembek, Chief, Section 2 Project Directorate IV Division of Licensing Project Management Office of Nuclear Reactor Regulation

Project No. 694

Enclosure: Draft Safety Evaluation

cc w/encl: See next page

#### DISTRIBUTION:

PUBLIC	JUhle
PDIV-2 Reading	JWermiel
RidsNrrDlpmLpdiv (Hberkow)	YOrechwa
RidsNrrPMGShukla	
RidsNrrLAEPeyton	
RidsOgcRp	
RidsAcrsAcnwMailCenter	

NRR-106

#### ADAMS Accession No.: ML042050169

OFFI CE	PDIV-2/I	PDIV-2/PM	PDIV-2/LA	SRXB/DSSA	PDIV-2/SC
NAME	GTaylor:mp	GShukla	EPeyton	JUhle	SDembek
DATE	7/8/04	7/8/04	7/7/04	5/27/04*	7/22/04

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML042050169.wpd OFFICIAL RECORD COPY

## DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

## WCAP-15872, REV. 00, "USE OF ALTERNATE DECAY HEAT REMOVAL

# IN MODE 6 REFUELING"

### WESTINGHOUSE OWNERS GROUP

### PROJECT NO. 694

### 1 1.0 INTRODUCTION

By letter dated May 12, 2003, the Westinghouse Owners Group (WOG) submitted Topical 2 Report (TR) WCAP-15872, Rev. 00, "Use of Alternative Decay Heat Removal in Mode 6 3 Refueling," for staff review and approval of an alternate method for the shutdown cooling during 4 Mode 6 plant operations as specified in the current technical specifications (TSs) for the plant. 5 The alternate decay heat removal method may be used to supplement or to substitute for the 6 shutdown decay heat removal system during refueling operations. The TR describes a 7 computational methodology for assessing the necessary conditions for entry into and operation 8 under the alternate heat removal alignment. These conditions are governed by a combination 9 of factors such as decay heat generation rate, heat removal capabilities, temperature of the 10 refueling pool, and the heat sink temperatures. The computational model of the alternate heat 11 removal alignment is formulated as a series of one-dimensional control volumes within which 12 the fluid mass, momentum, and energy are conserved. The model describes the transfer, by 13 natural convection, of the decay heat from the reactor cavity to the refueling pool, and then by 14 forced convection into the cooling system aligned via the alternate cooling method. 15

- The validity of the one-dimensional formulation is dependent on the estimation of the values of two parameters:
  - mixing coefficient for the fluid from the reactor cavity, and
    - bypass coefficient for the fluid in the refueling pool.
- These values are plant and alternate decay heat removal alignment dependent. The values for
  these coefficients are computed via multi-dimensional computational fluid dynamics
- calculations.

18

19

- <sup>23</sup> The methodology has been validated through a comparison of predicted to recorded data at the
- 24 Calvert Cliffs Nuclear Power Plant (CCNPP) Unit 2 during the March 2001 refueling outage.
- The applicability of the methodology in general is predicated on a plant-specific validation
- similar to the one given in WCAP-15872, Rev. 00 for the CCNPP Unit 2.

#### 1 2.0 <u>REGULATORY EVALUATION</u>

The methodology presented in WCAP-15872, Rev. 00, "Use of Alternate Decay Heat Removal 2 in Mode 6 Refueling," addresses the computational issues associated with demonstrating 3 compliance with the requirements for a residual decay heat removal system set forth in General 4 Design Criterion (GDC) 34. In particular, the numerical values computed with this methodology 5 may be used to support the demonstration that the transfer of fission product decay heat and 6 other residual heat from the reactor core is at a rate such that specified acceptable fuel design 7 limits are not exceeded. The approval of the computational methodology in WCAP-15872, 8 Rev. 00 is consistent with the requirements set forth in Appendix B to Part 50 of Title 10 of the 9 Code of Federal Regulations (10 CFR Part 50) "Quality Assurance Criteria for Nuclear Power 10 Plants and Fuel Reprocessing Plants." WCAP-15872 describes actions necessary to provide 11 adequate confidence that an alternate heat removal system will perform satisfactorily in service. 12

#### 13 3.0 <u>SUMMARY OF WCAP-15872, REV. 00</u>

The TR discusses the operational and technical issues associated with the introduction of an 14 alternate decay heat removal system which takes suction from and discharges to the refueling 15 pool while in Mode 6, with the refueling pool fully flooded. Standard decay heat removal in 16 Mode 6 is provided by the shutdown cooling system. In this system, suction is taken from the 17 hot leg, and the flow is fed to the shutdown cooling pump, and passed through a shutdown 18 cooling heat exchanger. Cooled water is then returned to the reactor coolant system through a 19 nozzle located in the cold leg. The alternate heat removal alignment is a specific alignment of 20 existing plant systems as a substitute for conventional decay heat removal by the shutdown 21 cooling system. In the alternate heat removal alignment, the core decay heat circulates from 22 the open reactor vessel by natural circulation into the flooded refueling pool. The refueling pool 23 is then cooled by an alternate cooling system. In the alternate cooling alignment, a pump takes 24 suction from the refueling pool, then after passing through a heat exchanger, the flow is 25 directed back into the refueling pool. The specific locations of the suction pipe from the 26 refueling pool and the refill pipe to the refueling pool can be optimized depending on the 27 specific plant design. In the case of CCNPP Unit 2, the alternate heat removal alignment 28 consists of the spent fuel pool pump that takes suction from the refueling pool, then after 29 passing through the spent fuel pool heat exchanger, the flow is directed back into the refueling 30 pool. This flow is directed into the refueling pool through piping near the bottom of the pool. 31 The suction from the refueling pool to the spent fuel pool cooling line is through a drain in the 32 bottom of the refueling pool, at the side of the pool opposite the inlet point. This arrangement 33 results in cooled water inventory drawn across the pool region directly above the open vessel. 34

Activation of the alternate heat removal alignment is dependent on the ability of the decay heat to circulate from the open reactor vessel (upper guide structure removed) by natural circulation and constrained by the water level in the refueling pool, the pool temperature, and the residual decay heat of the reactor core. Factors influencing the performance of the alternate heat removal alignment include the heat transfer ability of the spent fuel pool cooling system when aligned to the refueling pool, the pumped flow rates, and the ultimate heat sink temperature.

#### 1 3.1 Computational Method

The computational methodology described in WCAP-15872, Rev. 00 addresses the 2 requirements for a residual decay heat removal system set forth in GDC 34. The computation 3 in particular evaluates the capability of an alternate decay heat removal system to transfer 4 decay heat and other residual heat from the reactor such that fuel design limits are not 5 exceeded. The computational methodology consists of two interrelated models. A 6 one-dimensional, time-dependent, lumped-parameter model of the core coupled to the refueling 7 pool, and a three-dimensional, steady-state, computational fluid dynamics (CFD) model of the 8 refueling pool. 9

### 10 3.1.1 <u>One-Dimensional Model</u>

The one-dimensional model divides the refueling pool and the reactor vessel internals into a 11 series of control volumes that describe the upper guide structure, core and refueling pool. Ten 12 state points that represent natural boundaries between the control volumes are defined in the 13 model. These are consistent with the set of assumptions used to reduce the refueling pool and 14 core coupled circulation problem to a mathematically tractable form. Conservation of mass, 15 momentum, and energy are solved for these control volumes to predict the mass flow rate 16 between the reactor vessel and the refueling pool. Temperatures of the refueling pool, the 17 suction and discharge are calculated. The flow rate through the alternate decay heat removal 18 system is also calculated. The model also considers the heat lost at the pool surface due to 19 natural convection and evaporation from the free surface. 20

### 21 3.1.2 <u>Computational Fluid Dynamics Model</u>

The one-dimensional model cannot account for the geometric effects of the pool regions where 22 the cooler fluid near the bottom of the pool does not fully mix with the hot plume rising from the 23 core. Thus, two empirical coefficients, a mixing and a bypass coefficient, are introduced. The 24 mixing coefficient accounts for the portion of the reactor cavity fluid that does not mix with the 25 core flow. The bypass coefficient accounts for the alternate decay heat removal train flow that 26 does not mix with the core exit flow. The values of these coefficients are specific to the 27 geometry of the refueling pool and the alternate heat removal alignment. A three-dimensional 28 CFD model of the refueling pool and boundary conditions consistent with the one-dimensional 29 nodal model of the refueling pool and reactor cavity, are used to compute these coefficients. 30

### 31 4.0 <u>TECHNICAL EVALUATION</u>

Key elements of the methodology described in the TR, such as the mixing and bypass 32 coefficients, are plant and alternate heat removal alignment specific. The model validation 33 presented in the TR is based on a comparison of model predictions with data recorded at 34 CCNPP Unit 2 during the March 2001 refueling outage. Under limited conditions, CCNPP units 35 are permitted to use an alternate refueling pool cooling system during Mode 6 with the refueling 36 pool flooded and with the shutdown cooling secured. Test data were recorded for two days 37 during which the alternate pool cooling alignment was in use. Fluid temperatures in the 38 refueling pool were recorded by thermocouples located at the reactor vessel flange level, at 39 mid-level in the pool and close to the pool surface. The temperatures and shutdown cooling 40 flow rates were recorded as a function of time. Switching from the conventional shutdown 41

1 cooling decay heat removal, both before and after the head is removed, followed by switching

- to the alternate decay heat removal are taken into account via the following sequence of
  operations:
- 4 1. reduce shutdown cooling flow for vessel head removal
- 5 2. restore full shutdown cooling flow
- 6 3. initiate alternate heat removal cooling flow, continue shutdown cooling flow
- 7 4. secure shutdown cooling flow, continue alternate heat removal cooling flow
- 8 5. secure alternate heat removal flow, restore shutdown cooling flow
- 9 4.1 Validation of the Computational Method

During the alternate heat removal alignment the refueling pool temperature data, at different elevations above the reactor vessel flange, indicate that the pool temperature decreases with elevation. This suggests that the hot plume from the core thermally mixes with the colder refueling pool water and cools as it rises to the top of the pool. The CFD predictions of the refueling pool water temperatures at locations corresponding to the measurement points compare favorably with the measured temperatures.

The variation with time of the computed and measured temperatures (shutdown cooling outlet, 16 spent fuel pool outlet, and refueling pool average) and flow rates, over the sequence of 17 operations that define entrance into steady-state operation and exit from the alternate decay 18 heat removal alignment during the CCNPP Unit 2 March 2001 refueling outage, agree well. 19 Some of the differences can be explained as due to the uncertainties in decay heat values and 20 initial refueling pool temperatures at the time the head is removed. Thus, the mixing and 21 bypass coefficients based on the CFD calculations account well for the non-uniform dynamic 22 effects in the refueling pool in the one-dimensional analysis. 23

24 4.2 Alternate Heat Removal System Entry Conditions

The key factors that govern entry into the alternate heat removal alignment are decay heat 25 generation rate, heat removal capability, the temperature of the refueling pool, and the heat 26 sink temperature. The limiting time for entry into alternate heat removal is when the decay heat 27 is first low enough to satisfy the refueling pool temperature limit given by the TS for a given heat 28 sink temperature. At CCNPP the calculational methodology, described above and in 29 WCAP-15872, Rev. 00 has been employed with plant specific data to determine the minimum 30 time after shutdown for entry into the alternate heat removal alignment corresponding to the 31 limiting refueling pool temperature versus ultimate heat sink temperature and other variables. 32 The good agreement between predictions and measurements of the average refueling pool 33 temperatures during the March 2001 refueling outage at CCNPP Unit 2 demonstrate the 34 efficacy of the methodology for computing the conditions for entry into the alternate heat 35 removal alignment at CCNPP. 36

1 4.3 Estimation of Time-to-Boiling and Boron Dilution

Following a loss of normal shutdown cooling, the computed time to boil when the refueling pool 2 is flooded varies from approximately 16 hours at 15 days after shutdown to nearly 20 hours at 3 25 days after shutdown. Following a loss of alternate decay heat removal, the computed time 4 to boil when the refueling pool is flooded varies from approximately 13 hours at 15 days after 5 shutdown to 17 hours at 25 days after shutdown. The alternate heat removal alignment results 6 in a somewhat shorter time to boil due to the higher predicted refueling pool temperature under 7 the alternate decay heat removal alignment than under the normal shutdown cooling system. 8 Given that the time to uncover the core due to boiling is on the order of days for both the 9 alternate decay heat removal system and the normal decay heat removal system, the difference 10 in the time to boil between the two systems is not significant, and is acceptable. 11

The safety analysis of a boron dilution event assumes an inadvertent injection of un-borated water into the reactor coolant system via the charging system. This implies the availability of the charging pumps. Since the charging pumps are not in service during Mode 6 refueling, the boron dilution event is not considered credible.

16 4.4 Effect of Pool Fluid Velocity on Fuel Movement

Due to thermal convection between the core and refueling pool and the subsequent mixing with 17 the pool circulation flow, a fuel assembly can become tilted and difficult to insert into the core. 18 Limiting values of tilt angle as a function of time after shutdown are computed based on the 19 predicted one-dimensional model flow rates due to natural convection between the core and the 20 refueling pool. The allowable window for the initiation of the alternate heat removal alignment is 21 computed consistent with temperature limits. The allowable window may require further 22 refinement based on the computed tilt angles so as to preclude problems with the insertion of 23 fuel assemblies. The specific limiting values of tilt angle depend on plant-specific experience 24 with fuel assembly insertion. 25

# 26 5.0 <u>CONCLUSIONS</u>

The staff has reviewed WCAP-15872, Rev.00 and the supporting documentation submitted in response to its request for additional information. On the basis of this review, the staff approves the methodology, together with its verification, described in WCAP-15872, Rev. 00 for referencing in licensing actions with regard to implementing an alternate method for shutdown cooling during routine Mode 6 operations at CCNPP. Application of the methodology for referencing in licensing actions to other plants is conditional on the verification of the methodology on a plant-specific basis and a review by the staff.

- This verification for each plant-specific alternate decay heat removal system and refueling pool flow configuration entails:
- A quantitative verification of the CFD model of the refueling pool with respect to measurements comparable to those described in Appendix C of WCAP-15872, Rev. 00.
- A quantitative comparison of the results of the computational model (as described in Appendix A of WCAP-15872, Rev. 00) to measurements comparable to those described in Appendix B of WCAP-15872, Rev. 00.

- An estimate of the sensitivity of the bypass and mixing coefficients of the computational 2 model to model assumptions and the effects of this sensitivity on the computed results.
- Estimates of time-to-boiling and boron dilution are computed under the assumption of
  fission product saturation and demonstrate conformance with General Design
  Criteria 34.
- 6 Principal Contributor: Yuri Orechwa
- 7 Date: July 22, 2004

Project No. 694

Westinghouse Owners Group

cc: Mr. James A. Gresham, Manager Regulatory Compliance and Plant Licensing Westinghouse Electric Company P.O. Box 355 Pittsburgh, PA 15230-0355