PSEG Nuclear LLC P.O. Box 236, Hancocks Bridge, New Jersey 08038-0236

JUL 0 9 2004



LR-N04-0299

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555-0001

INSERVICE INSPECTION PROGRAM RELIEF REQUESTS S1-RR-04-V01 and V02 SALEM GENERATING STATION UNIT 1 FACILITY OPERATING LICENSES NO. DPR-70 DOCKET NO. 50-272

**References:** 

PSEG Letter LR-N96437, Dated December 26, 1996, "Inservice Testing Program Relief Request Salem Generating Station Unit Nos. 1 and 2".

NRC Letter dated March 12, 1999, "Relief Requests V-24 and V-25 Regarding Inservice Testing of Accumulator Check Valves at Salem Nuclear Generating Station, Units 1 and 2 (TAC NOS. M98259 and M98260)".

NRC Letter dated January 2, 2004, "Relief Requests S2-RR-03-V01 and S2-RR-03-V02 Regarding Testing of Accumulator Check Valves Salem Nuclear Generating Station Unit 2 (TAC NO. MC1102)".

Pursuant to 10CFR50.55a(f)(5)(iii), PSEG Nuclear is submitting, in Attachment 1 to this letter, Inservice Testing (IST) Relief Requests S1-RR-04-V01 and V02 for NRC approval. These requests address Salem Unit 1 and are revisions to the engineering basis for the previously approved Relief Requests V-24 and V-25. The earlier requests were sought based on the impracticality of performing testing in accordance with the Code requirements and in consideration of the burden on the Licensee if the Code requirements were imposed on the facility.

Specifically, relief requests V-24 and V-25 sought approval for the use of an alternate testing methodology to the testing specified in IWV-3522 (b) in order to allow the use of a partial accumulator dump test to verify that safety injection (SI) Accumulator Outlet Check Valves 11SJ55, 12SJ55, 13SJ55, 14SJ55, 11SJ56, 12SJ56, 13SJ56 and, 14SJ56 could perform their safety function.

95-2168 REV. 7/99

On March 12, 1999 the NRC approved Relief Requests V-24 and V-25 that imposed an acceptance criterion of 27.0 seconds for alternate testing. In addition, relief requests S2-RR-03-V01 and S2-RR-03-V02 sought to increase the acceptance criteria from 27 to 28.1 seconds to reflect new system dynamics due to modifications of the safety injection (SI) Accumulator Isolation Valves 21SJ54, 22SJ54, 23SJ54, 24SJ54 valves. These relief requests were approved in a letter dated January 2, 2004 (TAC No. MC1102).

The same modifications for Salem Unit 1 Accumulator Isolation Valves 13SJ54 and 14SJ54 were made during 1R16. Similar changes are planned for 11SJ54 and 12SJ54 during 1R17. The modification increases the valve stroke time to address a maintenance issue and results in an increase in the acceptance criteria from 27 to 28.1 seconds for the SJ55 and SJ56 valves. With the SJ54 valves opening more slowly the system dynamics have changed and accordingly the measured time for the partial accumulator dump test has lengthened. This change does not invalidate the conclusions made in the original relief request. The engineering calculations for Relief Requests S1-RR-04-V01 and V02 change the acceptance criterion to 28.1 seconds due to physical plant changes, which altered the original testing acceptance criterion basis.

Accumulator Isolation Valve testing is performed during shutdown prior to entering refueling. Since, Accumulator Isolation Valves 13SJ54 and 14SJ54 have been modified, this relief request allows valves 13SJ55, 56 and 14SJ55, 56 to be tested to the 28.1 second acceptance criteria. Accumulator Isolation Valves 11SJ54 and 12SJ54 are being modified during 1R17, valves 11SJ55, 56 and 12SJ55, 56 will be tested to the current 27 second acceptance criteria for 1R17 and the 28.1 second acceptance criteria in subsequent refueling outages.

Attachment 1 to this letter contains the specific relief requests, S1-RR-04-V01 and V02. Attachment 2 to this letter provides the General Approach Proposed For Full Open Testing Of Accumulator Check Valves. Attachment 3 to this letter is calculation S-1-SJ-MDC-1539 Rev 1, "Accumulator Pressure Decay Time During Discharge Test", which is used to determine the acceptance criteria associated with the Alternate Testing. This calculation has been revised based on the revised opening time of the SJ54 valves.

This relief request is applicable to PSEG Nuclear Salem Generating Station Unit 1. PSEG Nuclear requests that the NRC approve this request by August 31, 2005 in order to support Salem Unit 1 refueling outage 1R17.

Document Control Desk LR-N04-0299

Should you have any questions regarding this request, please contact Mr. Michael Mosier at 856-339-5434.

Sincerely, Steven R. Mannøn

Manager – Nuclear Safety and Licensing

Attachments

C: Regional Administrator – NRC Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

> Mr. D. Collins, Project Manager – Salem U.S. Nuclear Regulatory Commission Mail Stop 08C2 Washington, DC 20555-0001

USNRC Senior Resident Inspector - Salem (X24)

Mr. K. Tosch, Manager IV Bureau of Nuclear Engineering PO Box 415 Trenton, New Jersey 08625

## Attachment 1

### INSERVICE INSPECTION PROGRAM RELIEF REQUESTS S1-RR-04-V01 and V02 SALEM GENERATING STATION UNIT 1

FACILITY OPERATING LICENSE NO. DPR-70 DOCKET NO. 50-272

#### COMPONENTS: 11SJ55, 12SJ55, 13SJ55 and, 14SJ55

#### FUNCTION:

These check valves are located in the discharge lines from the respective safety injection accumulators. The valves perform an active safety function in the open and closed positions. The valves must be capable of opening during a large break Loss of Coolant Accident (LOCA) to provide a flow path for Safety Injection (SI) accumulator discharge to the Reactor Coolant System (RCS) cold legs when reactor pressure drops below accumulator pressure. The valve must be capable of closure to prevent divergence of safety injection and recirculation flow subsequent to the accumulators dumping their contents. This valve also functions as an RCS pressure isolation valve. This function prevents exposing the SI accumulators to RCS pressure that would compromise accumulator pressure boundary integrity.

CATEGORY: AC

CLASS: 1

**TEST REQUIREMENTS:** 

Open & Closed Position - Check valves shall be exercised at least once every 3 months in accordance with the requirements of OMa-1988, Part 10-4.3.2.1.

#### BASIS FOR RELIEF:

During power operation, these valves are maintained in the closed position by RCS pressure on the downstream side of the valve disk. Quarterly exercising these valves to the full or partially open position during power operation is impracticable because the only flow path is into the RCS. The operating accumulator pressure cannot overcome normal operating RCS pressure to establish flow. Full stroke exercising these valves at cold shutdown is impracticable because of the potential for low temperature over pressurization due to insufficient expansion volume in the RCS to accept required flow. This testing could also result in the intrusion of nitrogen into the core, which could interrupt the normal circulation of cooling water flow. The associated motoroperated isolation valve (one per accumulator) cannot be partially stroked, but must complete a full stroke before changing direction. This could cause a complete discharge of the water volume in the accumulator and possibly inject nitrogen into the reactor coolant system, causing gas binding of the residual heat removal pumps and a subsequent loss of shutdown cooling. These valves are also verified to close by leak testing per plant technical specifications for

Pressure Isolation Valves (PIV's). Reverse exercising these check valves at any time other than refueling is burdensome without a commensurate increase in the level of quality and safety. The valves are normally in the closed position. Accumulator pressure is continuously monitored to ensure that an adequate nitrogen blanket is maintained and to verify the lack of RCS inleakage.

#### ALTERNATE TESTING:

These check valves shall be full stroke exercised to the open position during refueling utilizing a reduced pressure, partial accident flow test method. This controlled method is performed with the reactor vessel head removed. The test method establishes accumulator pressure of 70 psig, accumulator level between 96 and 100% and refueling cavity level between 125.5 and 126.5 feet. After establishment of the fixed parameters, the test then measures the time interval required for the pressure in the associated safety injection accumulator to drop from an initial pressure to 35 psig. Engineering calculation S-1-SJ-MDC-1539 Rev. 1, "Accumulator Pressure Decay Time During Discharge Test" establishes the test conditions and acceptance criterion and concludes that this methodology is adequate in determining the associated check valve disk moves to the full open position. Information from other nuclear stations was reviewed regarding partial flow, full stroke exercising using a calculational method. The testing performed at Salem provides a valid methodology for verifying the open function even though the test method differs from the various methods reviewed.

In attempting to utilize the guidance of NUREG 1482, Section 4.1.2 - "Exercising Check Valves with Flow and Nonintrusive Techniques", nonintrusive equipment was used during informational testing. These valves are Darling Valve & Manufacturing Co. "Clear Waterway" swing checks that are fabricated without a backstop. The valve design permits the disk to move sufficiently out of the flow path without contacting the valve body. Nonintrusive testing using acoustic and magnetic technology provides sufficient data for monitoring degradation on a periodic basis; however, full open acoustic indication is not detected nor is expected to show on the test trace. Nonintrusive testing does not verify full stroke exercising, however occasional use of this equipment during the pressure decay test provides useful condition monitoring information.

This method of forward flow check valve testing complies with the guidance provided in Generic Letter 89-04, Attachment 1, Position 1.

Regarding reverse flow exercise testing, these valves shall be verified in the closed position during the process of performing seat leakage testing at the

frequency specified in Unit I Technical Specification (TS) 4.4.6.3 and Unit 2 TS 4.4.7.2.2.

The open stroke frequency change was previously approved in NRC Safety Evaluation April 15, 1994 (TAC Nos. M88144 and M881451)

The use of the alternate testing methodology was previously approved in NRC Safety Evaluation March 12, 1999 (TAC Nos M98259 and M98260)

#### COMPONENTS: 11SJ56, 12SJ56, 13SJ56 and, 14SJ56

#### FUNCTION:

These check valves are located in the discharge lines from the respective safety injection accumulators downstream of the branch connection from Residual Heat Removal System (RHR). The valves perform an active safety function in the open position. The valves must be capable of opening during, a large break Loss of Coolant Accident (LOCA) to provide a flow path for Safety Injection (SI) accumulator discharge to the Reactor Coolant System (RCS) cold legs when reactor pressure drops below accumulator pressure. The valve must also be capable of opening to provide a path for low head safety injection and cold leg recirculation flow. This valve also functions as an RCS pressure isolation valve. This function prevents exposing the SI accumulators and RHR system piping to RCS pressure.

CATEGORY: AC

CLASS: 1

**TEST REQUIREMENTS:** 

Open & Closed Position - Check valves shall be exercised at least once every 3 months, in accordance with the requirements of OMa-1988, Part 10-4.3.2.1.

#### **BASIS FOR RELIEF:**

During power operation, these valves are maintained in the closed position by RCS pressure on the downstream side of the valve disk. Quarterly exercising these values to the full or partially open position during power operation is impracticable because the only flow path is into the RCS. The operating accumulator pressure cannot overcome normal operating RCS pressure to establish flow. Full stroke exercising these valves at cold shutdown is impracticable because of the potential for low temperature over pressurization due to insufficient expansion volume in the RCS to accept required flow. This testing could also result in the intrusion of nitrogen into the core, which could interrupt the normal circulation of cooling water flow. The associated motoroperated isolation valve (one per accumulator) cannot be partially stroked, but must complete a full stroke before changing direction. This could cause a complete discharge of the water volume in the accumulator and possibly inject nitrogen into the reactor coolant system, causing gas binding of the residual heat removal pumps and a subsequent loss of shutdown cooling. These valves are also verified to close by leak testing per plant technical specifications for

Pressure Isolation Valves (PIV's). Reverse exercising these check valves at any time other than refueling is burdensome without a commensurate increase in the level of quality and safety.

#### ALTERNATE TESTING:

These check valves shall be full stroke exercised to the open position during refueling utilizing a reduced pressure, partial accident flow test method. This controlled method is performed with the reactor vessel head removed. The test method establishes accumulator pressure between 67 and 70 psig, accumulator level between 96 and 100% and refueling cavity level between 125.5 and 126.5 feet. After establishment of the fixed parameters the test then measures the time interval required for the pressure in the associated safety injection accumulator to drop from an initial pressure to 35 psig. Engineering calculation S-1-SJ-MDC-1539 Rev. 1, "Accumulator Pressure Decay Time During Discharge Test" establishes the test conditions and acceptance criterion and concludes that this methodology is adequate in determining that the associated check valve disk moves to the full open position. Information from other nuclear stations was reviewed regarding partial flow, full stroke exercising using a calculational method. The testing performed at Salem provides a valid methodology for verifying the open function even though the test method differs from the various methods reviewed.

In attempting to utilize the guidance of NUREG 1482, Section 4.1.2 - "Exercising Check Valves with Flow and Nonintrusive Techniques", nonintrusive equipment was used during informational testing. These valves are Darling Valve & Manufacturing Co. "Clear Waterway" swing checks that are fabricated without a backstop. The valve design permits the disk to move sufficiently out of the flow path without contacting the valve body. Nonintrusive testing using acoustic and magnetic technology provides sufficient data for monitoring degradation on a periodic basis; however, full open acoustic indication is not detected nor is expected to show on the test trace. Nonintrusive testing does not verify full stroke exercising however occasional use of this equipment during the pressure decay test provides useful condition monitoring information.

The valves shall be partial stroke exercised at cold shutdown during normal RHR shutdown cooling operations.

This method of forward flow check valve testing complies with the guidance provided in Generic Letter 89-04, Attachment 1, Position 1.

Regarding reverse flow exercise testing, these valves shall be verified in the closed position during the process of performing seat leakage testing at the

frequency specified in Unit 1 Technical Specification (TS) 4.4.6.3 and Unit 2 TS 4.4.7.2.2

The open stroke frequency change was previously approved in NRC Safety Evaluation April 15, 1994 (TAC Nos. M88144 and M88145).

The use of the alternate testing methodology was previously approved in NRC Safety Evaluation March 12, 1999 (TAC Nos M98259 and M98260)

## Attachment 2

#### INSERVICE INSPECTION PROGRAM RELIEF REQUESTS S1-RR-04-V01 and V02 SALEM GENERATING STATION UNIT 1

FACILITY OPERATING LICENSE NO. DPR-70 DOCKET NO. 50-272

General Approach Proposed For Full Open Testing Of Accumulator Check Valves

#### General Approach Proposed For Full Open Testing Of Accumulator Check Valves

PSEG procedure S1.OP-ST.SJ-0006 (Q), Inservice Testing Safety Injection Valves Mode 6, provides instructions necessary to perform Inservice Inspection and Testing IAW Technical Specification 4.0.5 for the following Safety Injection (Accumulator) check valves:

- o 11SJ55 and 11SJ56 13 Accumulator Discharge to Cold Leg
- o 12SJ55 and 12SJ56 14 Accumulator Discharge to Cold Leg
- o 13SJ55 and 13SJ56 13 Accumulator Discharge to Cold Leg
- o 14SJ55 and 14SJ56 14 Accumulator Discharge to Cold Leg

The testing procedure involves open-stroke testing each tank's discharge check valves with the reactor depressurized and the vessel head removed. The initial tank liquid volume is set to 96 - 100%, and initial tank pressure is set at 70 psig. Flow is initiated by opening the tank motor operated valve (MOV). Per the procedure, the valve is to be stroked fully open, left in the open position until the Accumulator reaches a pressure of 35 psig, and then closed. Tank pressure is set low enough to prevent injection of nitrogen gas into the reactor coolant system (RCS). Velocities achieved should also be sufficient to fully stroke the valves, according to calculation.

The bases for the testing are captured in Calculation No. S-1-SJ-MDC-1539 Rev.1, Accumulator Pressure Decay Time During Discharge Test. The purpose of this calculation is to establish a mathematical model of test conditions to develop acceptance criterion for establishing the valves tested go full open. The description below describes the calculation with reactor head removed as is currently performed during testing.

The following parameters are fixed by procedure:

- The Unit is in Mode 6 (Defueled) with the Upper Internals installed.
- o Safety Injection Accumulators are at a fixed and defined pressure.
- Safety Injection Accumulators are at a fixed and defined level.
- o Refueling Cavity is at a fixed and defined level.
- o Acceptance criteria Maximum blowdown time in seconds.
- o Failure of testing to result in corrective action for both SJ55 and 56.

During valve stroking, Accumulator pressure and level measurements, which are acquired from inputs from normal plant instrumentation, are recorded. Based on the measured level and pressure change with time, the relationship between the check valve disc angle, flow rate and pressure difference are calculated using information supplied by Westinghouse Letter PSE-90- 530 for full lift velocity for the valves being tested. The loss factor for the MOV isolation valve as well as friction losses associated with the piping system are calculated. Equations of motion are then solved simultaneously.

#### General Approach Proposed For Full Open Testing Of Accumulator Check Valves

The calculation solves six unknown variables simultaneously using a FORTRAN computer program. The following are calculated to determine flow and pressure at a point in time under a variety of disc angles:

- o Accumulator level elevation
- o Accumulator gas pressure
- o MOV loss factor
- o Check valve Delta P
- o Derivatives
- o Values at new time step

### Attachment 3

### INSERVICE INSPECTION PROGRAM RELIEF REQUESTS S1-RR-04-V01 and V02 SALEM GENERATING STATION UNIT 1

#### FACILITY OPERATING LICENSE NO. DPR-70 DOCKET NO. 50-272

Calculation S-1-SJ-MDC-1539 (Rev 1)

NC.DE-AP.ZZ-0002(Q)

CALC NO.: S-1 REVISION: 1	-SJ-MDC-1	539	CAI	CULATION COVER	SHEET	Page 1 of 26	
CALC. TITLE:	Accu	mulator Pressur	e Decay Tim	e During Discharge 7	est	•••••••	
# SHTS (CALC)	: 26	# ATT / # SH	rs: 0/0	# IDV/50.59 SHTS	4 #	TOTAL SHTS:	30
		A (Proposed Pla	int Change)	🗌 FINAL (Futu	ire Confirma	tion Req'd) [	
SALEM OR HO		⊠ Q–LIS ]Q □Qs	T ⊠ IM ⊡Qsh	IPORTANT TO SAFE		ON-SAFETY RELA	TED
HOPE CREEK							

FORM 1

#### DESCRIPTION OF CALCULATION REVISION (IF APPL.):

The calculation was revised because the opening stroke times of 13SJ54 and 14SJ54 valves will be increased. The opening times of 11SJ54 and 12 SJ54 valves will remain the same. The change will be done under DCP's 80017350 and 80017351.

#### PURPOSE:

The purpose of this calculation is to determine the acceptance criterion for the pressure decay time of the accumulator discharge test in support of the testing of SJ55 and SJ56 check valves.

#### **CONCLUSIONS:**

- 1. The acceptance criterion for the pressure decay time for the 11 and 12 loops that have SJ54 opening stroke time of 12.5 seconds is 27 seconds.
- 2. The acceptance criterion for the pressure decay time for the 13 and 14 loops that have SJ54 opening stroke time of 22 seconds is 28.1 seconds (reactor head is off).

	Printed Name / Signature	Date
ORIGINATOR/COMPANY NAME:	Vijay Chandra/PSEG Vyaj chandra.	May 13, 2004
REVIEWER/COMPANY NAME:	James Murphy N/A	May 13, 2004
VERIFIER/COMPANY NAME:	James Murphy	May 13, 2004
PSEG SUPERVISOR APPROVAL:	Paul Lindsay 99	5/24/04

Revision 9

l e	<b>PSEG</b>	TITLE ACCUMULATOR PRESSURE DECAY DURING DISCHARGE	ID NO. S-1-SJ-MDC- 1539	-
CC	CALCULATION ONTINUATION SHEET	TEST ORIGINATOR V.CHANDLA O DATE 24 JAN1996 PEER REVIEW ART GARCIA DATE CARCIA	V-CIIANDRA	
	TABLE	OF CONTENTS		P
		ON		
	3. ANALYSIS			
	3.1 Accum	ILATORS		
	3.2 PRESS 3.2 CHECK	VALVES SJ55 M	D SJ56	
	3 4 GATE	VALVE SJ54		
	3.5 FRICT 3.6 EQUAT	ION LOSS FACTORS	AND INERTIA LENGTH	1
	4 RESULTS			2
	5. CONCLUSIC	N		2
	6. KETEKENCE	s		2
				; ; ; ;
		: : :		
				••
				: : :
		• •	• • • • •	

.

NC.DE-AP.ZZ-0002(Q)

### FORM 2

			CAL	CULATION CONT	NUATION	SHEET	SHE	ет: З			
ALC.	NO.: S-1-	-SJ-MDC-1	539	<u> </u>	REFE	RENCE:	<b>I</b>				
ORIGINATOR,DATE REV:				V. Chandra Feb. 25, 2004	1						
REVIEWER/VERIFIER,DATE				JM 3/18/04							
				Revisi	on History						
	Revision No.	E	Date Description								
1	0	Feb 1	ruary 5, 996	Original issue				<u></u>			
	1	Fel 25	bruary , 2004	Added analysis for increased to 22 sec	the loops w conds.	hose SJ54 v	valve open	ing stroke	a time v	vas	
-				Page Re	vision Inde	ex					-
-  -	Page	Revision	Pag	e Revision	Pag	<u>0 R</u>	evision	Pag	8	Revisio	n
-							0	2	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		
	۲.	1 1		0		<u></u>			<u>0</u>		
r	2	1	1 1	1 1 1	1 1	2 1	0				
-	3	1		$\frac{1}{2}$	- 2	0	0		•		
-	3			$\begin{array}{c c c c c c c c c c c c c c c c c c c $	2	0	0 0 1		<u> </u>		
-	345			1 2 3 4 0	2	0 1 22	0 0 1 1				
-	3456			1 2 3 4 5 0 5		0 1 2 2 3	0 0 1 1 1				
-	345			$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$		0 1 22 23 24	0 1 1 1 0		·		
-	3 4 5 6 7 8			1 2 3 3 4 5 6 1 			0 1 1 1 0				 
	3 4 5 6 7 8			1 1 2 0 3 0 4 0 5 0 6 1			0 0 1 1 1 0				
	3 4 5			1 2 3 4 5 6 1 							· · · ·
	3 4 5			1 1 2 0 3 0 4 0 5 0 6 1							
	3 4 5 6 7 8			1 1 2 0 3 0 4 0 5 0 6 1							· · · · · · · · · · · · · · · · · · ·
	3 4 5			1 1 2 0 3 0 4 0 5 0 6 1							· · ·

Nuclear Common

Revision 9

M DSEC	TITLE ACCUMUL PRESSURE I DURING DIS	ATOR DECAY CHARGE TEST	ID NO. 5-1-	SJ-MDC-	1539	sне 4
			REFERENCE	rr	·····	0
CALCULATION CONTINUATION SHEET	ORIGINATOR DATE PEER REVIEW DATE	V.CHANDRA 0 23JAN1996 _Cass G _Z=1=96	V-CHANDPA 1 03mph2004 141 8/18/08			2
1. INTRODUCTION	-		•			
ACCUMULATOR	DUMP TES	T IS DO	NE IN MO	DEG USI	NG	
PROCEDURE S1.	OPST.S.	5-0006(6	?) fer 5	FOR SALE	M-UNIT 1.	
THE PURPOSE O	T THE LE	ST IS T	O DEMON	STRATE	OPERABILIT	לא
OF DISCHARGE					5056.	· ·
FAR A COUMIL AT	OR PRESSI	DE CRITI	KION WA	S ESTABL	LISHED	•
ALSO THE PRI	SSURE DE	CAY TIME	WAS CAL	CULATED	FOR	• •
- A SITUATION U	vhen the	REACTOR	L HEAD	IS ON AND	THE	••
REACTOR WATE	R IS DIRE	CTED TO	D THE PR	ESSURIZ	ER.	•
IN THE PRE	SENT CALC	WL ATION	AN ACCEL	PTANCE	CRITERION	•
FOR PRESSURE	DECAY T	IME WIL	L BE GEN	ERATED	FOR UNIT	Ľ, :
BOTH SITUATION	IS (REACT	OR HEAD C	IN AND R	ENC TOR 1	IEAD OFF ]	)
WILL BE CON	SIDERED	AS THEY	NERE IN	REF[1]		
THE FLOW I	INE UP IS	FROMITH	le Aiccumi	ULATOR	TOTHE	. !
KEACTOR NIA	NALVE S	154, S	.255, And	0 S J 56.	INITIACLY	
THE OAC DRACE	RE IN M		in Arran i	C 7 A 100 1	A I I NIMIA /	_
THE GAS PRESS	URE IN TH	IE ACCUM	WLATOR I	S 70 PSI	g. DURING	
THE GAS PRESS THE TEST S PRESSURE DI	URE IN TI 154 IS 0 ЕСЛУЗ. Т	IE ACCOM DENED A HE TIME	WD THE FOR TH	S 70 PS ACCUMULA VE PRES	g. DURING TOR SSURE	· · ·
THE GAS PRESS THE TEST S PRESSURE DI TO DECAY FR	URE IN TH 154 15 01 CAYS. T 1000 70 0	IE ACCOM DENED A HE TIME Snig TO	WLATOR I MO THE FOR TH 35 psng	S 70 PS ACCUMULA IE PRE IS RE	g. DVRING FTOR SSURE CORDED	· · ·
THE GAS PRESS THE TEST S PRESSURE DI TO DECAY FR	URE IN TH J54 IS OF ECAYS. T IOM 70 P ULATION	IE ACCUM DENED A HE TIME Snig To AN A	WEATOR I MO THE FOR TH 35 psng CCEPTAT	S 70 PS ACCUMULA IE PRE IS RE IS RE	g. DVRING FTOR SSURE CORDED TERIOTN	
THE GAS PRESS THE TEST S PRESSURE DI TO DECAY FR IN THIS CALC FOR THIS	URE IN TH J54 IS OF CAYS. T CM 70 P ULATION PRESSURE	HE ACCOM DENED A HE TIME Snig To AN A DECAY	IULATOR I MO THE FOR TH 35 psng CCEPTAT TIME H	S 70 PS ACCUMULA IE PRE IS RE IS RE ICE CRI AS BEE	g. DVRING SSURE CORDED TERIOTN N CALCUL	A77
THE GAS PRESS THE TEST S PRESSURE DI TO DECAY FR IN THIS CALC FOR THIS SEE REF[1]	URE IN TH J54 IS OF CAYS. T CM 70 P ULATION PRESSURE FOR DETI	HE ACCOM DENED A HE TIME Saig To AN A DECAY HUS	IULATOR I MD THE FOR TH 35 psng CCEPTAT TIME H	S 70 PS ACCUMULA IE PRE IS RE NCE CRI AS BEE	g. DVRING SSURE CORDED TERION N CALCUL	A77
THE GAS PRESS THE TEST S PRESSURE DI TO DECAY FO IN THIS CALC FOR THIS SEE REF[1]	URE IN TH J54 IS ON CAYS. T COM 70 P ULATION PRESSURE FOR DETI	HE ACCUM DENED A HE TIME Shig To AN A DECAY	IULATOR I MD THE FOR TH 35 psng CCEPTAT TIME H	S 70 PS ACCUMULA IE PRE IS RE IS RE NCE CRI AS BEE	g. DVRING SSURE CORDED TERIOTN N CALCUL	A77

NC.DE-AP.ZZ-0002(Q)

\_\_\_\_.

FORM 2

	CA	LCULATION CONT	INUATION	SHEET	SHE	ET: 5		
CALC. NO.: S-1-SJ-MDC-	1539		REFE	RENCE:	_l			
ORIGINATOR,DATE	REV:	V. Chandra Feb. 25, 2004	1					
REVIEWER/VERIFIER,DA	TE						<u> </u>	
Originally, the Rev. 0 of this applies for those loops that actuators of valves 13SJ54 Unit 2 SJ54 valves have be and the Rev. 2 is the curren Unit 2 calculation and have time is not available. For ur opening stroke time will be of valves (opening stroke time This calculation has two set 1. The original acceptance 2. Since the exact stroke was chosen to be 22 set time for units 1 is the si acceptance criterion for [8], the Unit 1 pressure criterion calculated in F The following note was added After the replacement of act The opening stroke time of The opening stroke time of Therefore, the original estin	calculation v still have SJ3 and 14SJ54 en replaced at calculation not been rep nit 2, the larg used for the 12.5 second is of results: e criterion of time of valve ec. As show ame as the v r Units 1 and decay time of Ref. [8]. I after the Ins tuators of 13S 13SJ54 valv 14SJ54 valv nate of 22 se	was done with the ope 54 valve opening strok of Salem Unit 1 are bo by longer opening valv . This fact is mentione weated here. Since the est opening stroke tim replacement valves of is) are unaffected by th 27 seconds [Ref. 8] ap s 13SJ54 and 14SJ54 n in the results section alue calculated for Unit 21 s same. Therefore criterion will be kept ect tallation of the DCP's: SJ54 and 14SJ54 valve e is 20.5 sec [Ref. notit e is 21.3 sec [Ref. notit cond was quite good a	ning stroke i e time of 12 eing replace es. The Sa d here beca o Unit 1 valve e for SJ543 the unit 1. I nis revision i oplies to tho is not know , for the strok t 2 in Ref. [ for the Incre pual to press as, the open fication 2013 ind the calcu	time of valve S 2.5 seconds (11 d with a longer lem Unit 2 calc ause the details es have not be valves is 21.9 Please note the to the calculation se loops that have a this time, ske time of 22 at 1. According to assed SJ54 vac sure decay time asset SJ54 vac sure decay time ass8810] 88884] ulation need not	J54 = 1 ISJ54 a r openir culation s of ana second at the lo on. have SJ a reaso second to Ref [4 Ive stro e criterio es of the	12.5 seco and 12SJ ng stroke S-2-SJ-I lylical me aced yet ls. There oops that 54 stroke mable va s for Unit 3], the pri ke time, t on for Unit ase valve	nds. Therefore, 54 valves). The time. All the Sa VIDC-1394 was r athod is presente there exact operation of the exact operation still have the ork a time = 12.5 sec lue for the stroke 1, the pressure assure decay following the split it 2 pressure decay s were measure	Rev. 0 lem evised ad in the ning s ginal conds. time decay dt of Ref cay d.
Nuclear Common			<u> </u>				Revision	9

•

PSEG	TITLE ACCUMUL ATOR PRESSURE DECAY DURING DISCHARGE TEST.	ID NO. S-1- SJ-MDC- 1539 REFERENCE
CALCULATION CONTINUATION SHEET	ORIGINATOR V <u>CHANDRA</u> DATE 2 <u>3 JA4199</u> 6 PEER REVIEW <u>QAAG</u> DATE <u>Z-1-9</u> 6	
2. DESCRIPTIO	N OF CONFIGURA	TION
CONFIGURA WILL NOT BE	TION IS DESCRI REPEATED HERI	BED IN REF [1] AND
3. ANALYSIS		TICAL MODEL OF Accumulat
DUMP-PROCESS	HAS BEEN DEVE	LOPED. THE DETAILS ARE
DESCRIBED IN	CF.L.T.T.	

\_\_\_\_•

OUTSTAN	DING CHANGES MUST BE ATTACHED FOR WORKING COPY
	<b>PSEG</b> URING DISCHARGE TEST TITLE ACCUMULATOR PRESSURE DECAY DURING DISCHARGE REFERENCE DISCHARGE REFERENCE DISCHARGE
•	CALCULATION CONTINUATION SHEET ORIGINATOR U.CHIANDRA D 23 JAN1996 PEER REVIEW DATE 24 JAN1996 26
	3.1 ACCUMULATORS
	ELE VATIONS. [Ref 2,3,4]
	AT 100% LEVEL, ELEVATION = 91.4 ft, WATER VOL = 7116 GAL = 9513 ft
	AT 0% LEVEL, ELEVATION = 88.9 ft, WATER VOL = 5325 GAL = 711.9 ft 3
	LE I $Z_A = ELEVATION OF WATER LEVEL IN THE ACCUMULATOR(ft) V_{WA} = NOLUME OF WATER IN THE ACCUMULATOR (-ft3)$
	THEREFORE,
	$V_{WA} = 95.76 Z_A - 1801.2$ ; 85.65 ft 4 Z 4 91.4 ft
	$V_{WA, INIT} = 941.7 \text{ ft}^3$
	TOTAL VOLUME OF ACCUMULATOR = 1350 ft 3 [Ref 5]
	= 408.3 + 133.4
	DE-AP.ZZ-0002(Q) ATTACHMENT 2



Desec	TITLE ACCUMULA TOR PRESSURE DECAY DURING DISCHARGE TEST.	ID NO. 5-1- SJ-MDC- 1539 REFERENCE	_
CALCULATION CONTINUATION SHEE	ORIGINATOR V.CIINNDRA DATE 23.JANJ96 PEER REVIEW 016 DATE 2-1-95		
3.2 PRESSUR	ZER		
PRESSURIZE	R LEVEL ELEVATIONS	VS. VOLUME RELATIONSHIP	•
CBD - DE - CB	RC = 0042(Q) WAS	CORRENT, HOWEVER,	
A CBD CHA	NGE NOTICE FOR FI	GURE FIT-1 WAS OUTSTAN	)/,
CHANGE NO.	TICE WOULD BE INC	T WAS EXPECTED THAT THE TR PORATED IN REVIL. HOWEVI	R
AT PRESENT	THE DMS SYSTEM	HAS REV 1. BUT THE CBD	
CHANGE NO	TICE IS NOT INCORPORT	ATED INIT. TO AVOID THE FEIGURE FIT-1 15	
ATTACHED H	IERE.		:
			•
			• •
			• •
			: 
			•
			•
			:

95-0327 REV 3/03



OUTSTANDING CHANGES	S MUST BE AT	TACHED FOR	WORKING (	OPY			
© P	SEG	TITLE ACCUMUL PRESSURE I DURING DIS TEST.	ATOR Decny Charge	ID NO. S-I- REFERENCE	SJ-MDC-15	39	SHEET
	JLATION TION SHEET	ORIGINATOR DATE PEER REVIEW DATE	v. CHANDRA 0 24 Jin 1996 0214 2-2-96	V. CHOOPA 1 25 FEB 2004 JM 3/18/04			26
3.3 THES THES NOT B 3.4 NOT B 3.4 THIS BE U STROK THIS 3.5	CHECK VAL PRESSURE E CHECK VI E CHECK VI E LOSS FACT F[1] AND TABLE ST IT VALVE SED TO C E TIME OF IS BASET RICTION L F A COUMU TABLE 2	DATE VES SJ 5 DROP VE NLVES W/ D HERE. E SJ 54 OR VS. STI WILL NOT ROKE TIM IS 12.5 ALCULAT F REPLAC ON THU OSS FAC LATOR DI C 1.22 C	5 AND 5 E RSUS FLOW S DEVEL S DEVEL S DEVEL S E REPE S E C. [] E PRESSI E MENT N E UNIT S TORS AND SCHARGE 2 2 2 6	JIGION STELATIO OPED IN ATED HET J54, 125 REJ 6] RE DE CA TALVES I LATERTIA PIPING 2 4002	LE WAS REF[1] REF[1] E. THE SE. THE IS4, 13SJ THIS VAL INF SEL LENGTHS	AND WILL AND WILL AND WILL MI MUM 54, AND JE WILL THE OND S.	
FRI A.C.C Effic CS DE-AP.ZZ-0002	CTION LOSS UMULNTOR. H TABLE FFECTIVE L = AI EE REF 1 (0)	FACTOR THE EF L = 2 A LENGTH FLOW A D. 26 FOR	S OF DISC FECTIVE A A F EACH P REA OF E ITS USE)	CHARGE PI L A IPE SEGM FACH PIPE	PING OF E SHOWN UN ENT SEGMENT	ACH DERNEPTH	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
DE-AP.ZZ-0002	(Q)					ATTACHN	IENI 2

95-0327 REV 3/93

0UTSTANE 20040706	DING CHANGES MUST BE AT	TACHED FOR WORKING C	OPY .	
• •	PSEG	TITLE ACCUMULATOR PRESSURE DECAY DURING DISCHARGE TEST.	ID NO. S-1- SJ-MDC - 1539 REFERENCE	SHEET 12
•	CALCULATION CONTINUATION SHEET	ORIGINATOR U.CHANDRA O DATE 24 JAN 1996 PEER REVIEW CANG DATE Z-Z-GC		26
	<u>JI ACCO</u> NALVES	TABLE 3.5.1 IMULATOR DISCHARG ARE NOT INCLUDED.	E LINE FITTINGS REF. STRESS 150 2672	41 [kq.9]
			26724	+6 [ <u>k</u> el·[0]
	DESCRIPTION		$\begin{array}{ccc} RE F. & LOSS \\ AREA, & FACTOR \\ A & K = \frac{\Delta R}{JPV^2} \\ (ft^2) & \end{array}$	$\frac{k}{A^2}$ (fi <sup>-1</sup> )
	- 29.7 ft LONG PIPE? J.D = 0.835 ft	$\frac{fl}{d} = \frac{0.0146 + 29.7}{0.835} = 0.519$	0.548 0.519	1.73
	1 SR ELBOW 1 2. LR ELBOW 1	<=1* 0.27 <=2* 0.18	0·548 0·27 0·548 0·36	1.2
	79 1 ft LONG PIPE ID = 0.7083 ft 21 R ELBOWS	$\begin{cases} -1 & = 0 & -1 & -1 & -1 \\ -1 & 0 & -7 & -0 & -3 \\ -1 & -1 & -6 & -3 \\ -3 & -3 & -3 & -3 & -3 \\ -3 & -3 &$	0.394 1.63	9·28
	I SRELBOW! K	=1×0.27	0.394 0.27	1'74
	2 TEE RUNS K	:2*.0.05	0.394 0.1	0.64
	I EXI T K	= 1·0	0.394 1.0	644
	29.7 An 10:54	$3 + \frac{79.1}{0.394}$ $ft^{-1}$	≥ <mark>∦</mark> 2	= 3565 ft 1
8	255	o.ft'		
	DE-AP.ZZ-0002(Q)			ATTACHMENT 2
_				

. .

CALCULATION CONTINUATION SHEET	RING DISCHARGE EST. RIGINATOR V.CHANDRA D DATE 24 JAN1996 ER REVIEW CMA DATE 2-2-96	ID NO. S -1 - S REFERENCE	s J- mDc-153	SHEET
CALCULATION CONTINUATION SHEET PE	RIGINATOR V.CHANDRA O DATE 24 JAN1996 ER REVIEW CMC DATE 2-2-96			
<u>12 A</u>	TABLE 3.5.2 CCUMULATOR 1	DISCHARGE L	ΙΝΕ ΕΙΤΤΙΝΙ	<u>95</u>
VALVE	S ARE NOT INCL	.UDED; Ref S	57RESS 150. 2	67241C [11] 67242 [12]
DESCRIPTION		REF. AREA, A (f1?)	LOSS FACTOR, K = <u>DP</u> Zev2	<u>k</u> (-(+ <sup>-1</sup> )
$2 3 \cdot 9 ft Low G PIPE ? flID = 0.835 ft fa$	0.0146×23.9 0.835	0.548	0.418	1.39
2 LR ELBOWS K= 21 SRELBOW K= 1	€ 0·18 € 0·27	0·548 0·548	0,36	1·2. 0:9
81.5 ft LONG PIPE ? f ID = 0.783 ft } Z	- 0.0146* 81.5 0.783 - 1.52	o· 394	1.52	9.79
7 LR ELBOWS ; K= 7 2 SR ELBOWS ; K= 2	* 0·18 * 0·27	0:394 0:394	1·26 0·54	8·12 3 4 8
2 TEE RUNS, K= 2+ ENTRANCE K= 0	co 05 5	0·394 0·394	0-1	0.644
1 EXIT K=1	0	0.394	1.0	6.44
$\sum \frac{L_i}{A_i} = \frac{23 \cdot 9}{0.548}$ $= 250 \cdot$	$+\frac{81.5}{0.394}$ ft 5 ft		Σ <mark>k</mark>	= 35·18/17 4
DE-AP.ZZ-0002(Q)				ATTACHMENT 2

95-0327 REV 3/93

OUTSTAN	DING CHANGES MUST BE AT	TACHED FOR WC	RKING C	OPY		
2004070		TITLE ACCUMULAT PRESSURE DECA	OR	ID NO. 5-1- 5	5J-mDC-1539	SHEET
,	PSEG	DURING DISCHARGE		REFERENCE	- 14	
•	CALCULATION CONTINUATION SHEET	ORIGINATOR V.CH DATE 24 JA PEER REVIEW Q DATE 2-	ANDRA 0 N1996 NG -2-96	L		_ 0₽ _ 26
į	<u>/3 A</u>	TABLE 3.5 CCUMULATOR ALVES ARE NO	. З <u>Dischi</u> т імал	HRGE LINE IDED , REF	FITTINGS STREE ISO: 26724 267240	3 [13] [10]
. '	DESCRIPTION		REF AREA, A (f1 <sup>2</sup> )	$LOSS FACTORK = \frac{\Delta P}{\frac{\Delta P}{\frac{1}{2}ev2}}$	$\frac{\frac{K}{A^2}}{(ft^{-4})}$	
	13.8 ft LONG PIPE? ff ID=0.835 ft; J 3. SRELBOW, K= 1-LRELBOW, K=	0.0146*13:8 0.835 0.241 3*0.27 1×0.18	0 548 0 548 0 548	0.241 0.81 0.18	0-803 2.697 0.599	
	$B0.4 ft LONG PIPE 24JD = 0 7083 ft \int C5 LR ELBOW K =$	$f = \frac{0.014 G + 80.4}{0.708 S}$ $= 1.457$ $5 * 0.18$	0-394 0-394 0-394	1.657 0.9 0.54	10:67 4 5 · 798 3 · 479	
	2 TEE RUNS, K IENTRANCE K IEXTRANCE K	2 * 1.05 0.5 1.0	0 394 0 394 0 394	0-10 0.5 1.0	0·644 3 221 6·442	
8	$\sum_{i=1}^{n} \frac{13.8}{A_i} = 229$	$\frac{80.4}{0.394}$ > 2 $ft^{-1}$	ft	Σ	<u>k</u> = 34.357 - 1	<b>4</b>
, ·	DE-AP.ZZ-0002(Q)	<u></u>		· · · · · · · · · · · · · · · · · · ·	ATTA	CHMENT 2
	<u></u>			•		95-0327 REV 3/90

OUTSTAND 20040706	TSTANDING CHANGES MUST BE ATTACHED FOR WORKING COPY 04070 <u>6</u>						
	PSEG	TITLE ACCUMULATOR. PRESSURE DECAY DURING DISCHARGE TEST	ID NO. S-I- S	J-MDC-153	SHEET		
	CALCULATION CONTINUATION SHEET	ORIGINATOR DATE PEER REVIEW DATE DATE V.CHAMDRA 24JAM1996 QMG Z-Z-QC			26		
	<u>14 ACcur</u>	TABLE 3.5.4 NULATOR DISCHARC	GE LINE FI	TTINGS			
	VALVES	ARE NOT INCLUDE	D, KEF. 57R	ESS ISO. 267	7.244 [Kej·1]		
	DESCRIPTION		$REF$ $AREA, A$ $(-ft^{2})$	$LOSS FACTOR K = \frac{SP}{5PV^2}$	$\frac{k}{A^2}$		
	23.9 ft LONG PIPE ( ID = 0.835 ft J I SRELBOWS K = 2 LRELBOWS K=	$\frac{fl}{d} = \frac{0.0146 \times 23.9}{0.835}$ $= 0.42$ $1 \times 0.27$ $2 \times 0.18$	0·548 0·548 0·548	0.42 0.27 0.36	1·4 0·9 1·2		
•	68.77 LONG PIPE 7 ID=07083.77	$\frac{f!}{a} = \frac{0.0146 \times 68}{0.7083} = 1.40$	0:394	1.40	9.03 644		
	2 SR ELBONS 2 TEE RUNS 1 ENTRANCE	K = 6 + 0.10 K = 2 × 0.27 K = 2 × 0.05 K = 0.5	0·394 0·394 0·394	0.54 0.1 0.5	3·5 0·64 3·22		
	1 EXI T	K = 1.0	0 394	10	6.44		
	$\sum \frac{L_{1}}{A_{i}} = \frac{23}{0.5}$ $= 216$	$\frac{9}{48} + \frac{68}{0.394} \text{ ft}^{-1}$ $2 \text{ ft}^{-1}$	•	E KA2	= 32·8 ft <sup>4</sup>		
			· · ·				
	DE-AP.ZZ-0002(Q)				ATTACHMENT 2		

OUTSTANDING CHANGES MUST BE AT	TACHED FOR WORKING	COPY	
· PSEG	THE ACCUMULATOR PRESSURE DECAY DURING DISCHARGE TEST.	ID NO. S-I- SJ-MDC-1539 REFERENCE	SHEET
CALCULATION CONTINUATION SHEET	ORIGINATOR V.CHANDRA O DATE 24,JANPOG PEER REVIEW OMG DATE Z-Z-QG	<u>v-CHMORA</u> <u>1</u> <u>05 MBR 2004</u> <u>JM</u> <u>3/(8/04</u>	- 26
CONTINUATION SHEET 11 ACCUMULATOR D $2 \frac{L}{A}$ AND Z THE $\frac{L}{A}$ OF PR COMBINED $\frac{L}{A}$ OF $4 \frac{L}{1NE} = 2.55 \pm 92$ $2 \frac{C}{A} + \frac{C}{A} = -92$ $\frac{C}{A} + \frac{C}{A} = -92$	PEER REVIEW DATE $2-2-96$ DISCHARGE LINE HA $A^2$ . RESSURIZER SURGE SURGE LINE AND A 20.7 = 275.7 + 275.7 = 534.8 $\times 1.94 \times (35.65$ $\times 1.94 \times (35.65$ $4.88 \frac{SLUG}{ft7}$ HEAD IS OFF $1.94 \times 255 \frac{S}{5}$ $= \frac{1}{2} \times 1.94 \times 35.6$ $1.94 \times 255 \frac{S}{5}$	STHE HIGHEST VALUES OF LINE IS $\frac{65}{3.144}$ = 20:7 $ft^{-1}$ CCUMULATOR DISCHARGE $ft^{-1}$ [REACTORHEAD ON] $\frac{SLUG}{ft^{4}}$ [REACTORHEAD ON] $\frac{SLUG}{ft^{4}}$ [REACTORHEAD ON] $\frac{SLUG}{ft^{7}}$ [REACTOR HEAD ON] SLUG	
DE-AP.ZZ-0002(Q)	· · · · · · · · · · · · · · · · · · ·	ATTAC	HMENT 2

95-0327 REV 3/93



\_\_\_\_\_

OUTSTANDING	CHANGES MUST BE AT	TACHED FOR WORKING C	COPY	
	PSEG	TITLE ACCUMULATOR PRESSURE DECAY DURING DISCHARGE TEST.	ID NO. SI- SJ-MDC-1539 REFERENCE	SHEET 18 OF
	CALCULATION CONTINUATION SHEET	ORIGINATOR V.CHANDRA O DATE 24 JAN19% PEER REVIEW QAAG DATE 779.6	V.CHANDAN 1	26
	EQUATIONS (G) THE LISTING OF FOLLOWING PAG THE REN. O WHEN THE STR INCE THE ST INCE THE ST INCE THE ST INCT BEING ILOOPS IN ATTO BY REVISION DECAY TIME A OF 22 SECO THE ACTUAL IS SJ54 VE THE ACTUAL M 14 SJ54 VE THESE VAL THESE VAL THESE VAL	THROUGH (12) WERE COMPUTER PROGRA ES. OFITHIS CALCULATIO OKE TIME OF SJ ROKE TIME OF SJ ROKE TIME OF SJ ROKE TIME OF SJ LOF THIS CALCU NAC YSIS FOR ND HAS BEEN A MEASURED OPENING ILVE = 20.5 S ENSURED OPENING NLVE = 21.3 Soc VES ARE CLOSE ORIGINALLY S ALLATION.	SOLVED NUMERICALLY SOLVED NUMERICALLY M IS SHOWN IN THE N DEALT WITH THE SITUM 54 NALVE IS 12.5 SEC. SJ54 AND 12 SJ54 IS CCEPTANCE CRITERION FOR AINS 2.7 Sec. SJ54 STROKE TIME DDED. JING STROKE TIME OF [Ref. NOTIFICATION 20188810] STROKE TIME OF [Ref. NOTIFICATION 2018884] E ENOUGH TO 22-Sec. ELECTED BEFORE	TION
DE-	AP.ZZ-0002(Q)		ATTACHI	MENT 2
•				

.

•

95-0327 REV 3/93

OUTSTANDING CHANGES MUST BE ATTACHED FOR WORKING COPY 20040706 S-1-SJ-MDC-1539 P 19 . type acchon.for RAN.O DIMENSION VVOF(12), CVCV(12) . . DATA VVOF/0.,.05,.1,.2,.3,.4,.5,.6,.7,.8,.9,1./ DATA CVCV/0., 0.0194, 0.055, 0.1, 0.146, 0.204, # 0.277,0.3536,0.4613,0.6086,0.767,1./ PARAMETERS COMPOTER PROGRAM LISTING GAM=1.3 G=32.174 REACTOR HEAD IS ON RHO=1.94 AREA=0.394 DT=0.01 SJ54 STROKE TIME PPRES=14.7\*144 INITIAL CONDITIONS C = 12.5 Sec. TIME=0.1 NSTEP=-1 VNAZ=408.3 VNA=VNAZ PAZ=84.7\*144. PA=PAZ Q=.001 VWP=758. WRITE(\*,101) 101 FORMAT (T19'TIME', T28'ACCUMULATOR PRESSURE FLOW RATE') 103 FORMAT(T19'(SEC.)',T28' WRITE(\*,103) (GPM) ' ',//) (PSIG) 31 NSTEP=NSTEP+1 TIME=TIME+DT CALCULATE ACCUMULATOR LEVEL ELEVATION С VWA=1350.-VNA ZA=(VWA+7801.2)/95.76 С CALCULATE PRESSURIZER LEVEL ELEVATION ZP=(VWP+4092.3)/38.34 CALCULATE ACCUMULATOR GAS PRESSURE PA=PAZ\*(VNAZ/VNA)\*\*GAM С CALCULATE SJ54 LOSS FACTOR VOT1=12.5 GVKZ=.15 IF (TIME .LT. VOT1) THEN VOF=TIME/VOT1 CALL INTER (VOF, CVND, 12, VVOF, CVCV) GVK=GVKZ/(CVND\*CVND) ELSE GVK=GVKZ ENDIF С CALCULATE CHECK VALVE DP VEL=Q/AREA AV2=38.3/(VEL\*VEL) SINPHI=0.5\*(SQRT(AV2\*\*2+4.)-AV2) IF (SINPHI .GE. 0.9532) SINPHI=0.9532 DPCHK=2.\*8.98\*RHO\*VEL\*VEL\*(1.-SINPHI) CALCULATE DERIVATIVES С DQDT = (PA+RHO\*G\*ZA-PPRES-RHO\*G\*ZP-34.88\*Q\*ABS(Q))-0.5\*GVK\*1.94\*Q\*ABS(Q)/AREA\*\*2 - DPCHK)/534.8 # DVNADT=Q DVWPDT=Q CALCULATE VALUES AT NEW TIME STEP С QQ=O+DQDT\*DT VVNA=VNA+DVNADT\*DT VVWP=VWP+DVWPDT\*DT IF (TIME .LE. 2.) THEN IF(MOD(NSTEP,10) .EQ. 0)WRITE(\*,102) TIME,+(PA/144.-14.7), Q\*7.48\*60. ELSE IF(MOD((NSTEP+10),100) .EQ. 0)WRITE(\*,102) TIME,+(PA/144.-14.7), Q\*7.48\*60. # ENDIF

102 FORMAT(F23.3,8F17.2) 5-1- SJ- MDC- 1539 P 20 C UPDATE THE OLD VARIABLES Revio a > 4Q = QQVNA=VVNA REACTOR HEAD ISON VWP=VVWP SJ 54 STROKE TIME IF(TIME .GT. 100.) STOP GO TO 31 END = 12.5 Sec. SUBROUTINE INTER(X,Y,N,XX,YY) DIMENSION XX(N), YY(N) IF(X .LT. XX(1) .OR. X .GT. XX(N)) GO TO 3 DO 2 J=2,N IF(X .GE. XX(J-1) .AND. X .LE. XX(J)) GO TO 101 GO TO 2  $\frac{101 Y = YY (J-1) + (YY (J) - YY (J-1)) * (X-XX (J-1))}{1 (XX (J) - XX (J-1))}$ RETURN **2 CONTINUE** 3 WRITE(6,1) X,(XX(I),I=1,N) 1 FORMAT(' BEYOND RANGE',G10.4,5X,20G10.4) RETURN END ·

C:\SALEM\REACTOR\ECCS>

.

•

```
OUTSTANDING CHANGES MUST BE ATTACHED FOR WORKING COPY
20040706ENSION VVOF(12), CVCV(12)
                                                                                       P.21
      OPEN(1,FILE='slAcchon free.out', STATUS='old')
      DATA VVOF/0.,.05,.1,.2,.3,.4,.5,.6,.7,.8,.9,1./
                                                              5-1-51-mDC-1539, Revil
      DATA CVCV/0., 0.0194, 0.055, 0.1, 0.146, 0.204,
     Ħ
             0.277,0.3536,0.4613,0.6086,0.767,1./
C
   PARAMETERS
                                                             COMPUTER PROGRAM LISTING
      GAM=1.3
      G=32.174
                                                              REACTOR HEAD IS ON
      RHO=1.94
      AREA=0.394
      DT=0.01
                                                                SJ 54 STROKE TIME
      PPRES=14.7*144.
  INITIAL CONDITIONS
C
                                                                  = 22 Sec.
      TIME=0.1
      NSTEP=-1
                                                               CHECK VALVE IS FREE
      VNAZ=408.3
      VNA=VNAZ
      PAZ=84.7*144.
      PA=PAZ
      Q=.001
      VWP=758.
      WRITE(1,101)
  101 FORMAT (T19'TIME', T28'ACCUMULATOR PRESSURE FLOW RATE')
  103 FORMAT (T19' (SEC.)', T28'
                                    (PSIG)
                                                       (GPM) ',//)
      WRITE(1,103)
   31 NSTEP-NSTEP+1
      TIME=TIME+DT
   CALCULATE ACCUMULATOR LEVEL ELEVATION
С
      VWA=1350.-VNA
      ZA= (VWA+7801.2)/95.76
С
  CALCULATE PRESSURIZER LEVEL ELEVATION
      ZP= (VWP+4092.3) /38.34
С
   CALCULATE ACCUMULATOR GAS PRESSURE
      PA=PAZ* (VNAZ/VNA) **GAM
   CALCULATE SJ54 LOSS FACTOR
C
      VOT1=22.
      GVKZ=.15
      IF (TIME .LT. VOT1) THEN
          VOF=TIME/VOT1
          CALL INTER (VOF, CVND, 12, VVOF, CVCV)
          GVK=GVKZ/(CVND*CVND)
        ELSE
          GVK=GVKZ
      ENDIF
C CALCULATE CHECK VALVE DP
      VEL=Q/AREA
      AV2=38.3/(VEL*VEL)
      SINPHI=0.5*(SQRT(AV2**2+4.)-AV2)
      IF (SINPHI .GE. 0.9532) SINPHI=0.9532
      DPCHK=2.*8.98*RHO*VEL*VEL*(1.-SINPHI)
C CALCULATE DERIVATIVES
      DQDT= (PA+RHO*G*ZA-PPRES-RHO*G*ZP-34.88*Q*ABS(Q)
     #
             -0.5*GVK*1.94*Q*ABS(Q)/AREA**2 - DPCHK)/534.8
      DVNADT=Q
      DVWPDT=Q
C CALCULATE VALUES AT NEW TIME STEP
      QQ=Q+DQDT+DT
      VVNA=VNA+DVNADT*DT
      VVWP=VWP+DVWPDT*DT
      IF (TIME :. LE. 2.) THEN
      IF (MOD (NSTEP, 10) .EQ. 0) WRITE (1, 102) TIME, + (PA/144.-14.7),
     #
        Q*7.48*60.
      ELSE
      IF(MOD((NSTEP+10),100) .EQ. 0)WRITE(1,102) TIME,+(PA/144.-14.7),
     Ħ
         Q*7.48*60.
      ENDIF
  102 FORMAT (F23.3,8F17.2)
C UPDATE THE OLD VARIABLES
         0-00
         VNA=VVNA
         VWP=VVWP
      IF(TIME .GT. 40.) STOP
```

OUTSTANDING CHANGES MUST BE ATTACHED FOR WORKING COPY C- 153 & Por. P. 22 20040706 SUBROUTINE INTER (X,Y,N,XX,YY) DIMENSION XX (N), YY (N) IF(X .LT. XX(1) .OR. X .GT. XX(N)) GO TO 3 DO 2 J=2,N REACTOR HEAD ISON IF(X .GE. XX(J-1) .AND. X .LE. XX(J)) GO TO 101 GO TO 2 SJ54 STROKE TIME 101 Y=YY(J-1)+(YY(J)-YY(J-1))\*(X-XX(J-1))/1 (XX(J) - XX(J-1))RETURN = 22 Sec. 2 CONTINUE 3 WRITE(6,1) X, (XX(I), I=1,N) 1 FORMAT(' BEYOND RANGE', G10.4, 5X, 20G10.4) RETURN END

•

۰.

NC.DE-AP.ZZ-0002(Q)

FORMZ	)
-------	---

	CA	LCULATION CONTINUATION SHEET			SHEET:	23	
CALC. NO.: S-1-SJ-MDC-1539		REFERENCE:				 	
ORIGINATOR,DATE	REV:	V. Chandra Feb. 25, 2004	1				
REVIEWER/VERIFIER,D	DATE						 , <u>,,,,</u>

#### 4. RESULTS

Table 4.1 shows the time histories of the accumulator pressure and the discharge flow rate when the SJ54 valve opening stroke time is 12.5 seconds. As suggested by Ref. [8], the acceptance criterion for the pressure decay time was set to 27 seconds. This value was obtained by subtracting 1.5 seconds from the pressure decay time obtained for 60 degree maximum open angle case.

Table 4.2 shows the accumulator pressure and discharge flow rate time histories for the situation when the reactor head is on, check valve is free, and the SJ54 valve stroke time is 22 sec. The 22 second stroke time was selected to reasonable bound the data collected for Unit 2. The pressure decay time for this situation for Unit 1 is nearly the same as it was calculated in Ref. [1] for Unit 2. NRC approved the acceptance criterion for the pressure decay time for Unit 2 on Jan 2, 2004 through relief requests S2-RR-03-V01 and S2-RR-03-V02 (TAC No. MC1102). Following the spirit of Ref. [8], the Unit 1 pressure decay time criterion will be made equal to Unit 1 pressure decay time criterion of 28.1 sec. Please note that the pressure decay time is a relatively weak function of SJ54 stroke time. It is emphasized, that in order to provide some flexibility in data collection, the actual acceptance criterion needs to be slightly greater than the calculated value for the free check valve case.

The following note was added after the installation of the DCP's

After the replacement of actuators of 13SJ54 and 14SJ54 valves, the opening stroke times of these valves were measured. The opening stroke time of 13SJ54 valve is 20.5 sec [Ref. notification 20188810] The opening stroke time of 14SJ54 valve is 21.3 sec [Ref. notification 20188884]

Therefore, the original estimate of 22 second was quite good and the calculation need not be redone.

#### 5. CONCLUSION

As suggested by Ref. [8], the acceptance criterion for pressure decay time should be made equal to 27 seconds for the situation when the SJ54 opening stroke time is 12.5 seconds. This criterion applies to loops 11 and 12.

Following the rationale provided in Ref [1], the Unit 1 pressure decay time acceptance criterion for 13 and 14 loops will be set equal to 28.1 seconds.

This calculation revision is in support of DCP's 80017350 and 80017351. Therefore, a 50.59 Safety Evaluation is not required.

Nuclear Common

**Revision 9** 

, accnon	TIME	ACCUMULATOR PRESSURE	FLOW RATE	- Pr 24.
	(SEC.)	(PSIG)	(GPM)	; · · ·
	. 110	70.00	. 45	SI-SJ-MDC-1539, Rav.0
	.210	69.99	242.54	,
	.310	69.97	356,39	
	.410	69.95	468,61	
	.510	69.88	688.20	
· . · ·	.710	69.84	824,00	
	.810	69.78	993.71	
	.910	69.72 69.64	1168.00	
	1.110	69.56	1512.76	
	1.210	69.46	1681.01	
	1.310	69.36	1841.72	REACTOR HENDON
	1.410	69.25 69.13	1979.86	CHECK VALVE IS
	1.610	69.00	2216.12	FREE
	1.710	68.87	2323.05	SI54 STROKE
	1.810	68.73	2425.24	
	2.010	68.43	2618.72	m E =  2, 2 260
	3.010	66.70	3426.55	
	4.010	64.66	3977.46	
	5.010	62.48 60.25	4357.61	
	7.010	58.05	4707.43	
	8.010	55.94	4733.72	
	9.010	53.93	4717.87	
	11.010	52.03	4669,58	
	12.010	48.58	4500.25	
	13.010	47.02	4398.37	
	14.010 15 010	45.56	4284.26	
	16.010	42.92	4060.25	· ·
	17.010	41.73	3953.51	
	18.010	40.60	3850.18	
		39.55	3/50.05	
	21.010	37.61	3558.44	
	22.010	36.73	3460.78	
	23.010	35.89	3353.02	
	25.010	34.37	3134.53	
	26.010	33.67	3027.76	
	27.011	33.02	2923.22	
		32.40	2820.90	
•	30.011	31.26	2622.67	
	31.011	30.74	2526.59	
	32.011	30.25	2432.44	
	33.010	29.79	2249.66	
	35.010	28.94	2160.95	
	36.010	28.55	2074.00	
	37.010	28.18	1988.81	
	38.010	27.50	1823.80	
	40.009	27.19	1744.07	
	41.009	26.90	1666.29	
	42.009	26.62	1590.57	
	43.009	20.30	TOT1.05	

OUISTANDING	CHANGES MUST	BE ATTACHED	FOR	WORKING	COPY P 25
20040706	(SEC.)	(PSIG)		(GPM)	1.20.
					5-1-51-MDC-1529 P.
	. 0.110	70.00		0.45	
	0.210	69.99		144.06	
	0.310	69.98		212.26	TABLE 4.2
	0.410	69.97		280.02	
	0.510	69.95		347.25	ACCUMULATOR PRESSURE
	0.610	69.93		413.89	ACCONDENT FOR FLAND RATE
	0.710	69.90		479.92	AND DISCHMAGE FLOW MARC
	0.810	69.87		545.36	TIME HISTORIES.
	. 0.910	69.84		610.22	
	1,010	69.80		674.55	OTACTOR HEAD IS ON
	1 210	69.76		738.40	N ETTC TOIL MOTOR
	1 210	69.71		829.26	CHECK VALVE IS FREE
	1.310	69.66		935.34	
	1 610	69.60		1043.40	SJ 54 STROKE TIME
	1,510	09.53		1151.27	
	1 710	07.40 CD 70		1258.18	- 22 Sec.
	1 910	69.30		1364.00	
	1 010	69.30		1671 04	
	2 010	69 12		1271.04	
	3 010	67 90		2406 16	
	4.010	66 40		2400.13	
	5.010	64 69		2220 02	
	6.010	62 85		3329.03	
	7.010	60 96		3031.47	
	8.010	59 04		1066 AE	
	9.010	57 16		4000.45	
	10.010	55 29		4100.74	
	11.010	53 49		4273.33	
	12.010	51 76		4312.01	
•	13.010	50.11		4313.30	
	14.010	48.55		4207.20	
	15.010	47.07		4198.90	
	16.010	45.66		4138.37	
	17.010	44.34		4071.83	
	18.010	43.08		3996.36	
	19.010	41.89		3915.35	
	20.010	40.77		3830.78	
	21.010	39.71		3746.64	
	22.010	38.71		3661.49	
	23.010	37.77		3572.18	
	24.010	36.87		3477.56	
	25.010	36.03		3371.12	
	26.010	35.23		3261.53	
	27.011	34.49		3152.57	
	28.011	33.79		3045.47	
	29.011	33.12		2940.55	
	30.011	32.50		2837.87	
	31.011	31.91		2737.36	
	32.011	31.35		2638.94	
	33.010	30.83		2542.54	
	34.010	30.33		2448.06	
	35.010	29.87		2355.46	
	36.010	29.43		2264.68	
	37.010	29.01		2175.67	
	38.010	28.61		2088.43	
	39.009	28.24		2002.95	
	40.009	27.89		1919.24	

.....