



July 23, 2004

U. S. Nuclear Regulatory Commission Attn: Document Control Desk

Washington, DC 20555

Subject:

San Onofre Nuclear Generating Station Units 2 and 3

Docket Nos. 50-361 and 50-362

Proposed Change Number (PCN) 545

Request To Revise Technical Specifications 3.3.1 and 3.3.5

References: 1)

Letter from D. E. Nunn (SCE) to the Document Control Desk (NRC) dated July 28, 2003; Subject: San Onofre Nuclear Generating Station Units 2 and 3, Docket Nos. 50-361 and 50-362, Proposed Change Number (PCN) 545, Request To Revise Technical Specifications 3.3.1 and 3.3.5

Letter from B. M. Pham (NRC) to H. B. Ray (SCE) dated October 22, 2003; Subject: San Onofre Nuclear Generating Station,

Units 2 And 3 – Request For Additional Information Regarding Steam Generator Pressure-Low Allowable Value (TAC NOS. MC0200 and

MC0201)


Dear Sir or Madam:

2)

Reference (1) was a request by Southern California Edison (SCE) to change the Technical Specification Steam Generator Pressure-Low allowable value from its current value of 729 psia to a revised value of 717 psia. The request was identified as Proposed Change Number (PCN) 545.

By Reference (2), NRC staff requested additional information regarding PCN-545 needed for the staff to continue its review of the proposed change.

SCE is preparing a response to Reference (2) and will be submitting it by December 31, 2004. The response will replace Reference (1) in its entirety, and SCE, therefore, requests that it be withdrawn.



7

If you have any questions or require any additional information, please contact Mr. Jack Rainsberry at (949) 368-7420.

Sincerely,

Alfekur

cc: B. S. Mallett, NRC Region IV, Regional Administrator

B. M. Pham, NRC Project Manager, San Onofre Units 2 and 3

C. C. Osterholtz, NRC Senior Resident Inspector, San Onofre Units 2 and 3

S. Y. Hsu, Department of Health Services, Radiologic Health Branch