

August 13, 2004

Mr. Christopher M. Crane  
President and Chief Nuclear Officer  
Exelon Nuclear  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING PEACH BOTTOM  
ATOMIC POWER STATION, UNITS 2 AND 3, REQUEST FOR ACTIVATION  
OF OSCILLATION POWER RANGE MONITOR (TAC NOS. MC2219 AND  
MC2220)

Dear Mr. Crane:

By letter dated February 27, 2004, you requested amendments to the Technical Specifications for the Peach Bottom Atomic Power Station, Units 2 and 3. The proposed amendments would support the activation of the oscillation power range monitor. In order to complete our review of your amendment request we will need answers to the questions in the enclosed Request for Additional Information (RAI). I forwarded an electronic copy of these questions to Mr. Glenn Stewart of your staff and the questions were discussed with your staff in a telephone call on August 4, 2004. As a result of this call, the term "period based algorithm allowable value and confirmation counts" in Question 2. was replaced with the term "period based algorithm setpoint and confirmation counts." I understand that you plan to respond to this RAI by September 14, 2004.

Sincerely,

*/RA/*

George F. Wunder, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-277 and 50-278

Enclosure: RAI

cc w/encl: See next page

Mr. Christopher M. Crane  
President and Chief Nuclear Officer  
Exelon Nuclear  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING PEACH BOTTOM  
ATOMIC POWER STATION, UNITS 2 AND 3, REQUEST FOR ACTIVATION  
OF OSCILLATION POWER RANGE MONITOR (TAC NOS. MC2219 AND  
MC2220)

Dear Mr. Crane:

By letter dated February 27, 2004, you requested amendments to the Technical Specifications for the Peach Bottom Atomic Power Station, Units 2 and 3. The proposed amendments would support the activation of the oscillation power range monitor. In order to complete our review of your amendment request we will need answers to the questions in the enclosed Request for Additional Information (RAI). I forwarded an electronic copy of these questions to Mr. Glenn Stewart of your staff and the questions were discussed with your staff in a telephone call on August 4, 2004. As a result of this call, the term "period based algorithm allowable value and confirmation counts" in Question 2. was replaced with the term "period based algorithm setpoint and confirmation counts." I understand that you plan to respond to this RAI by September 14, 2004.

Sincerely,  
*/RA/*

George F. Wunder, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-277 and 50-278  
Enclosure: RAI  
cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDI-2 R/F JClifford GWunder HGarg OGC  
MO'Brien GMatakas, RGN-I FAKstulewicz THuang ACRS

ADAMS ACCESSION NUMBER: ML042100423

|        |          |          |           |
|--------|----------|----------|-----------|
| OFFICE | PM/PD1-2 | LA/PD1-2 | SC/PD1-2  |
| NAME   | GWunder  | MO'Brien | JClifford |
| DATE   | 8/11/04  | 8/12/04  | 8/12/04   |

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION  
BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
EXELON GENERATION COMPANY, LLC  
PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3  
DOCKET NOS. 50-277/278

The Nuclear Regulatory Commission staff has reviewed the February 27, 2004, amendment request and has identified the following questions to be addressed by the licensee in order to complete our evaluation.

1. Please provide the detailed procedures to verify the accuracy of trip setpoints for the new oscillation power range monitor (OPRM) instrumentation based on available data of the system calibration tests during normal operation as well as the shutdown and subsequent start-up from refueling outage.
2. Please provide a detailed description of the methodology for calculation of the plant-specific Delta CPR/Initial CPR Vs. Oscillation Magnitude (DIVOM) correlation and the OPRM setpoints for Technical Specification (TS) 3.3.1.1. Also, provide a detailed description of the procedure to generate the OPRM period based algorithm setpoint and confirmation counts for future cycles. Please identify any plant-specific differences from the generic values specified in NEDO-32465-A such as period based detection algorithm (PBDA) period confirmation setpoints in Table 3-1, PBDA trip setpoints in Table 3-2, and generic DIVOM curve slope. Provide specific values for OPRM scram setpoints and the DIVOM correlation for the next cycle.
3. Please provide a detailed description of the alternate method to detect and suppress thermal hydraulic instability oscillation stated in TS 3.3.1.1, Action I.1, including its functional relationship with Required Action I.1 stated in TS 3.3.1.1 for OPRM. Also, Provide the rationale to delete Figure 3.4.1-1 from the TSs and identify any role of Figure 3.4.1-1 in the reactor operating manual.
4. Please provide an example of the new core operating limit report format for the next cycle as shown in Table 3.3.1.1-1, Function 2.f, and justify allowable value is NA as stated in footnote d to the table.

Enclosure

Peach Bottom Atomic Power Station, Unit Nos. 2 and 3

cc:

Site Vice President  
Peach Bottom Atomic Power Station  
Exelon Generation Company, LLC  
1848 Lay Road  
Delta, PA 17314

Associate General Counsel  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Plant Manager  
Peach Bottom Atomic Power Station  
Exelon Generation Company, LLC  
1848 Lay Road  
Delta, PA 17314

Regulatory Assurance Manager  
Peach Bottom Atomic Power Station  
Exelon Generation Company, LLC  
1848 Lay Road  
Delta, PA 17314

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Peach Bottom Atomic Power Station  
P.O. Box 399  
Delta, PA 17314

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Roland Fletcher  
Department of Environment  
Radiological Health Program  
2400 Broening Highway  
Baltimore, MD 21224

Correspondence Control Desk  
Exelon Generation Company, LLC  
P. O. Box 160  
Kennett Square, PA 19348

Rich Janati, Chief  
Division of Nuclear Safety  
Bureau of Radiation Protection  
Department of Environmental Protection  
Rachel Carson State Office Building  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Board of Supervisors  
Peach Bottom Township  
545 Broad Street Ext.  
Delta, PA 17314-9203

Mr. Richard McLean  
Power Plant and Environmental  
Review Division  
Department of Natural Resources  
B-3, Tawes State Office Building  
Annapolis, MD 21401

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Manager-Financial Control & Co-Owner  
Affairs  
Public Service Electric and Gas Company  
P.O. Box 236  
Hancocks Bridge, NJ 08038-0236

Manager Licensing-Peach Bottom  
Atomic Power Station  
Exelon Generation Company, LLC  
200 Exelon Way, KSA -3E  
Kennett Square, PA 19348

Peach Bottom Atomic Power Station, Unit Nos. 2 and 3

cc:

Vice President - Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Vice President-Operations Mid-Atlantic  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-N  
Kennett Square, PA 19348

Senior Vice President, Nuclear Services  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Director-Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348