



FirstEnergy Nuclear Operating Company

5501 North State Route 2
Oak Harbor, Ohio 43449

Mark B. Bezilla
Vice President - Nuclear

419-321-7676
Fax: 419-321-7582

Docket Number 50-346
License Number NPF-3
Serial Number 1-1381

July 27, 2004

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Subject: Request for Extension of Commitment to a Notice of Violation from Davis-Besse
Nuclear Power Station NRC Inspection Report No. 50-346/03-010

Ladies and Gentlemen:

On June 30, 2004 the FirstEnergy Nuclear Operating Company (FENOC) requested a verbal extension of an NRC Inspection Report 2003-010 Notice of Violation commitment to provide documentation establishing flow requirements (e.g., to demonstrate full open position) for check valves SW17, SW18, and SW19 due by June 30, 2004. This commitment was originally documented in Davis-Besse Nuclear Power Station (DBNPS) letter Serial 1-1357, dated April 5, 2004. The extension will permit completion of the formal documentation. This extension request is necessary due to an apparent work coordination issue between work groups and was entered into our Corrective Action program for further evaluation. Verbal approval was granted to extend the due date to October 15, 2004, by Mr. Passehl, NRC Project Engineer and the DBNPS Corrective Action Program Focus Area NRC lead inspector.

The NRC identified Violation was of very low safety significance. The revised commitment date identified in this submittal is listed in Attachment 1.

If there are any questions concerning this matter, please contact Mr. Gregory A. Dunn, Manager - Regulatory Affairs at 419-321-8450.

Very truly yours,

JCS/s

Attachment 1: Commitment Listing

cc: NRC Regional Administrator, Region III
DB-1 Senior NRC/NRR Project Manager
DB-1 Senior NRC Resident Inspector
C. A. Lipa, Chief, Branch 4, Division of Reactor Projects
D. Passehl, Project Engineer, Division of Reactor Projects
Utility Radiological Safety Board

IEO1

Docket Number 50-346
License Number NPF-3
Serial Number 1-1381
Attachment 1, Page 1 of 1

COMMITMENT LIST

The following list identifies those revised actions committed to by the Davis-Besse Nuclear Power Station (DBNPS) in this document. Any other actions discussed in the submittal represent intended or planned actions by the DBNPS. They are described only as information and are not regulatory commitments. Please notify the Manager - Regulatory Affairs (419-321-8450) of any questions regarding this document or associated regulatory commitments.

COMMITMENTS

DUE DATE

Documentation will be provided establishing flow requirements (e.g., to demonstrate full open) for check valves in the Check Valve program, including Service Water (SW) 17, SW18, and SW19.

October 15, 2004