

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.3 Safety and Relief Valves

LCO 3.4.3 The safety function of 9 safety valves shall be OPERABLE. |

AND

The relief function of 5 relief valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One relief valve inoperable.	A.1 Restore the relief valve to OPERABLE status.	14 days
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Two or more relief valves inoperable. <u>OR</u> One or more safety valves inoperable.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4.	12 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.3.1	Verify the safety function lift setpoints of the safety valves are as follows:	In accordance with the Inservice Testing Program
	<u>Number of Safety Valves</u>	
	<u>Setpoint (psig)</u>	
	1	
	2	
SR 3.4.3.2	-----NOTE----- Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. -----	24 months
	Verify each relief valve opens when manually actuated.	
SR 3.4.3.3	-----NOTE----- Valve actuation may be excluded. -----	24 months
	Verify each relief valve actuates on an actual or simulated automatic initiation signal.	