

**From:** "Daflucas, Ronda" <rdafluc@entergy.com>  
**To:** "Rick Ennis" <RXE@nrc.gov>  
**Date:** 6/3/04 10:11AM  
**Subject:** RE: Additional RAI

Thanks

Ronda Daflucas  
802-258-4232

-----Original Message-----

**From:** Rick Ennis [mailto:RXE@nrc.gov]  
**Sent:** Thursday, June 03, 2004 10:02 AM  
**To:** Daflucas, Ronda  
**Cc:** Harold Walker; Richard Lobel  
**Subject:** Additional RAI

Ronda,

Here's an additional RAI from SPSB-C (Harold Walker). For tracking purposes let's call it question 28 (add after Rich Lobels' 27 questions):

28. Provide additional information regarding the potential impact of the CPPU on those HVAC systems discussed in the Standard Review Plan sections 6.4, 6.5.1, 9.4.1, 9.4.2, 9.4.3, 9.4.4 and 9.4.5. This should include a discussion of the impact, if any, during both normal and post-accident operations resulting from increases in heat loads due to CPPU and the bases for your determination of system acceptability post-CPPU.

Please let me know if you would like to discuss this afternoon or on Monday's call.

Thanks,

Rick

B-40