

```

*****
*****
* FILE NAME:      CLINATMB.INP
*
* GENERAL DESCRIPTIVE TITLE DESCRIBING THIS "ATMOS" INPUT
*
RIATNAM1001 'ATMOS INPUT FOR CLINTON ABWR MODEL 1 PLUME'
*
*   BASE CASE
*
* G.A.TEAGARDEN (ERIN ENGINEERING) 6/16/2004
*
*****
*****
* GEOMETRY DATA BLOCK
*****
* NUMBER OF RADIAL SPATIAL ELEMENTS
*
GENUMRAD001  9
*
* SPATIAL ENDPOINT DISTANCES IN MILES      (MATCHES SITE FILE)
*
*           END001  1.2    2.5    3.7    5.0    6.2
*           END002  10     25     37     50
*
* SPATIAL ENDPOINT DISTANCES IN KILOMETERS
*
GESPAEND001    2.0      4.0      6.0      8.0      10.0
GESPAEND002   16.0     40.0     60.0     80.0
*****
*****
* NUCLIDE DATA BLOCK
*****
* Number of pseudo-stable nuclides (used to truncate the decay chains)
* User's Guide p. 5-7
ISNUMSTB001    27
*
* List of pseudo-stable nuclides, User's Guide p. 5-7
*
ISNAMSTB001    I-129    (daughter of Te-129 and Te-129m)
ISNAMSTB002    Xe-131m  (daughter of I-131)
ISNAMSTB003    Xe-133m  (daughter of I-133)
ISNAMSTB004    Xe-135m  (daughter of I-135)
ISNAMSTB005    Cs-135   (daughter of Xe-135 and Xe-135m)
ISNAMSTB006    Sm-147   (daughter of Pm-147)
ISNAMSTB007    U-234    (daughter of Pu-238)
ISNAMSTB008    U-235    (daughter of Pu-239)
ISNAMSTB009    U-236    (daughter of Pu-240)
ISNAMSTB010    U-237    (daughter of Pu-241)
ISNAMSTB011    Np-237   (daughter of Am-241)
ISNAMSTB012    Rb-87    (daughter of Kr-87)
ISNAMSTB013    Ba-137m  (daughter of Cs-137)
ISNAMSTB014    Rb-88    (daughter of Kr-88)
ISNAMSTB015    Y-91m    (daughter of Sr-91)
ISNAMSTB016    Zr-93    (daughter of Y-93)
ISNAMSTB017    Nb-93m   (daughter of Zr-93)
ISNAMSTB018    Nb-95m   (daughter of Zr-95)
ISNAMSTB019    Nb-97    (daughter of Zr-97 and Nb-97m)
ISNAMSTB020    Nb-97m   (daughter of Zr-97)
ISNAMSTB021    Tc-99    (daughter of Mo-99)

```

```

ISNAMSTB022      Rh-103m  (daughter of Ru-103)
ISNAMSTB023      Rh-106   (daughter of Ru-106)
ISNAMSTB024      Te-131   (daughter of Te-131m)
ISNAMSTB025      Pr-144   (daughter of Ce-144 and Pr-144m)
ISNAMSTB026      Pr-144m  (daughter of Ce-144)
ISNAMSTB027      Pm-147   (daughter of Nd-147)
*
* Number of radioactive nuclides to be considered
*
ISNUMISO001 60
*
* NUMBER OF NUCLIDE GROUPS
*
ISMAXGRP001 9
*
* WET AND DRY DEPOSITION FLAGS FOR EACH NUCLIDE GROUP
* ALL NUCLIDE GROUPS EXCEPT NOBLE GAS ARE ASSUMED SUBJECT
* TO BOTH WET AND DRY DEPOSITION. (CONSISTENT WITH USERS GUIDE)
*
*           WETDEP      DRYDEP
*
ISDEPFLA001      .FALSE.  .FALSE.
ISDEPFLA002      .TRUE.   .TRUE.
ISDEPFLA003      .TRUE.   .TRUE.
ISDEPFLA004      .TRUE.   .TRUE.
ISDEPFLA005      .TRUE.   .TRUE.
ISDEPFLA006      .TRUE.   .TRUE.
ISDEPFLA007      .TRUE.   .TRUE.
ISDEPFLA008      .TRUE.   .TRUE.
ISDEPFLA009      .TRUE.   .TRUE.
*
* NUCLIDE GROUP DATA FOR 9 NUCLIDE GROUPS
* (SAME AS 1150 EXCEPT LOWER CASE NUCNAM, NO PARENT OR HALFLIFE)
* (User's Guide p. 5-8)
*           NUCNAM      IGROUP
*
ISOTPGRP001      Co-58      6
ISOTPGRP002      Co-60      6
ISOTPGRP003      Kr-85      1
ISOTPGRP004      Kr-85m     1
ISOTPGRP005      Kr-87      1
ISOTPGRP006      Kr-88      1
ISOTPGRP007      Rb-86      3
ISOTPGRP008      Sr-89      5
ISOTPGRP009      Sr-90      5
ISOTPGRP010      Sr-91      5
ISOTPGRP011      Sr-92      5
ISOTPGRP012      Y-90       7
ISOTPGRP013      Y-91       7
ISOTPGRP014      Y-92       7
ISOTPGRP015      Y-93       7
ISOTPGRP016      Zr-95      7
ISOTPGRP017      Zr-97      7
ISOTPGRP018      Nb-95      7
ISOTPGRP019      Mo-99      6
ISOTPGRP020      Tc-99m     6
ISOTPGRP021      Ru-103     6
ISOTPGRP022      Ru-105     6
ISOTPGRP023      Ru-106     6
ISOTPGRP024      Rh-105     6

```

ISOTPGRP025	Sb-127	4
ISOTPGRP026	Sb-129	4
ISOTPGRP027	Te-127	4
ISOTPGRP028	Te-127m	4
ISOTPGRP029	Te-129	4
ISOTPGRP030	Te-129m	4
ISOTPGRP031	Te-131m	4
ISOTPGRP032	Te-132	4
ISOTPGRP033	I-131	2
ISOTPGRP034	I-132	2
ISOTPGRP035	I-133	2
ISOTPGRP036	I-134	2
ISOTPGRP037	I-135	2
ISOTPGRP038	Xe-133	1
ISOTPGRP039	Xe-135	1
ISOTPGRP040	Cs-134	3
ISOTPGRP041	Cs-136	3
ISOTPGRP042	Cs-137	3
ISOTPGRP043	Ba-139	9
ISOTPGRP044	Ba-140	9
ISOTPGRP045	La-140	7
ISOTPGRP046	La-141	7
ISOTPGRP047	La-142	7
ISOTPGRP048	Ce-141	8
ISOTPGRP049	Ce-143	8
ISOTPGRP050	Ce-144	8
ISOTPGRP051	Pr-143	7
ISOTPGRP052	Nd-147	7
ISOTPGRP053	Np-239	8
ISOTPGRP054	Pu-238	8
ISOTPGRP055	Pu-239	8
ISOTPGRP056	Pu-240	8
ISOTPGRP057	Pu-241	8
ISOTPGRP058	Am-241	7
ISOTPGRP059	Cm-242	7
ISOTPGRP060	Cm-244	7

\*\*\*\*\*  
\*\*\*\*\*

\* WET DEPOSITION DATA BLOCK

\*\*\*\*\*

\* WASHOUT COEFFICIENT NUMBER ONE, LINEAR FACTOR

\*

WDCWASH1001 9.5E-5 (JON HELTON AFTER JONES, 1986)

\*

\* WASHOUT COEFFICIENT NUMBER TWO, EXPONENTIAL FACTOR

\*

WDCWASH2001 0.8 (JON HELTON AFTER JONES, 1986)

\*

\* ABOVE VALUES SAME AS USERS GUIDE.

\*

\*\*\*\*\*  
\*\*\*\*\*

\* DRY DEPOSITION DATA BLOCK

\*\*\*\*\*

\* NUMBER OF PARTICLE SIZE GROUPS

\*

DDNPSGRP001 1

\*

\* DEPOSITION VELOCITY OF EACH PARTICLE SIZE GROUP (M/S)

\* (SEE LETTER M. A. CUNNINGHAM TO F.T. HARPER AUG 7 1990 NRC PDR)

```

DDVDEPOS001  0.01  (VALUE SELECTED BY S. ACHARYA, NRC)
*
*****
* DISPERSION PARAMETER DATA BLOCK
*****
* THE POWER-LAW MODEL IS USED, THEREFORE NUM_DIST IS SET TO ZERO
* OR DELETE THE FOLLOWING CARD.
*
NUM_DIST001  0
*
* POWER-LAW FUNCTION IS OF FORM:  SIGMA = A * X ** B
*
* Tadmor and Gur Parameterization for Distance Range 0.5 to 5.0 km
* as taken from Atmospheric Motion and Air Pollution (Dobbins 1979).
* (User's Guide p. 5-11, Same as NUREG-1150 only in different spacing)
* P-G CLASS:          A          B          C          D
E          F
DPCYSIGA001          0.3658          0.2751          0.2089          0.1474
0.1046          0.0722
DPCYSIGB001          0.9031          0.9031          0.9031          0.9031
0.9031          0.9031
DPCZSIGA001          2.5E-4          1.9E-3          0.2          0.3
0.4          0.2
DPCZSIGB001          2.125          1.6021          0.8543          0.6532
0.6021          0.6020
*
* LINEAR SCALING FACTOR FOR SIGMA-Y FUNCTION, NORMALLY 1
*
DPYSCALE001  1.
*
* LINEAR SCALING FACTOR FOR SIGMA-Z FUNCTION,
* NORMALLY USED FOR SURFACE ROUGHNESS LENGTH CORRECTION.
* (Z1 / Z0) ** 0.2, FROM CRAC2 WE HAVE (10 CM / 3 CM) ** 0.2 = 1.27
*
DPZSCALE001  1.27 (VALUE INTENDED TO BE USED WITH TADMOR AND GUR
PARAMATERS)
*
* ABOVE VALUES CONSISTENT WITH USERS'GUIDE.
*
*****
***** *
* PLUME MEANDER EXPANSION FACTOR DATA BLOCK
*****
* TIME BASE FOR EXPANSION FACTOR (SECONDS)
*
PMTIMBAS001  600. (10 MINUTES)
*
* BREAK POINT FOR FORMULA CHANGE (SECONDS)
*
PMBRKPNT001  3600. (1 HOUR, NUREG/CR-4551)
*
* EXPONENTIAL EXPANSION FACTOR NUMBER 1
*
PMXPFAC1001  0.2 (NUREG/CR-4551)
*
* EXPONENTIAL EXPANSION FACTOR NUMBER 2
*
PMXPFAC2001  0.25 (NUREG/CR-4551)
*

```

```

* ABOVE FACTORS FROM USERS' GUIDE.
*
*****
* PLUME RISE DATA BLOCK
*****
* THE FOLLOWING SCALING FACTORS COULD BE USED TO MODIFY THE MACCS
METHOD OF
* PERFORMING PLUME RISE CALCS.
*
* SCALING FACTOR FOR THE CRITICAL WIND SPEED FOR ENTRAINMENT OF A
BOUYANT PLUME
* (USED BY FUNCTION CAUGHT)
*
PRSCLCRW001 1. (NUREG/CR-4551)
*
* SCALING FACTOR FOR THE A-D STABILITY PLUME RISE FORMULA
* (USED BY FUNCTION PLMRIS)
*
PRSCLDAP001 1. (NUREG/CR-4551)
*
* SCALING FACTOR FOR THE E-F STABILITY PLUME RISE FORMULA
* (USED BY FUNCTION PLMRIS)
*
PRSCLEFP001 1. (NUREG/CR-4551)
*
* ABOVE VALUES CONSISTENT WITH USERS' GUIDE.
*
*****
* WAKE EFFECTS DATA BLOCK
*****
*
* ESP CONTAINMENT STRUCTURE
* CB height = 76.1 m (ESP SSAR,Table 1.4-1 Plant Parameter Envelope,
234 feet)
* CB cross sectional area = 2069 m x m (ESP SSAR,Section 2.3.4.3)
* CB width = 45.5 m (Assumed building to be a square, normally
average width and length))
*
* Initial value of sigma-y for each plume
*
SIGYINIT001 10.6 *(initial sigma-y = W/4.3 = 45.5/4.3 [User's Guide p.
5-22])
*
* Initial value of sigma-z for each plume
*
SIGZINIT001 35.4 *(initial sigma-z = H/2.15=76.1/2.15 [User's Guide p.
5-22])
*
* Building height (meters)
*
WEBUILDH001 76.1 *(Height of CB, from ESP)
*
*****
* RELEASE DATA BLOCK
*****
* PARTICLE SIZE DISTRIBUTION OF EACH NUCLIDE GROUP
* YOU MUST SPECIFY A COLUMN OF DATA FOR EACH OF THE PARTICLE SIZE GROUPS

```

\*

RDPSDIST001 1.  
RDPSDIST002 1.  
RDPSDIST003 1.  
RDPSDIST004 1.  
RDPSDIST005 1.  
RDPSDIST006 1.  
RDPSDIST007 1.  
RDPSDIST008 1.  
RDPSDIST009 1.

\*

\* core concentration at end of cycle

\* based on GE14, exposure 35 GWd/MT, 4.6% enrich, 128kg U

\*

\*                   NUCNAM                   CORINV (Bq/MWt)

\*

RDCORINV001	Co-58	5.10E+12
RDCORINV002	Co-60	4.92E+12
RDCORINV003	Kr-85	1.23E+13
RDCORINV004	Kr-85m	2.73E+14
RDCORINV005	Kr-87	5.27E+14
RDCORINV006	Kr-88	7.42E+14
RDCORINV007	Rb-86	2.35E+12
RDCORINV008	Sr-89	9.93E+14
RDCORINV009	Sr-90	9.76E+13
RDCORINV010	Sr-91	1.25E+15
RDCORINV011	Sr-92	1.34E+15
RDCORINV012	Y-90	1.01E+14
RDCORINV013	Y-91	1.27E+15
RDCORINV014	Y-92	1.34E+15
RDCORINV015	Y-93	1.55E+15
RDCORINV016	Zr-95	1.70E+15
RDCORINV017	Zr-97	1.69E+15
RDCORINV018	Nb-95	1.71E+15
RDCORINV019	Mo-99	1.89E+15
RDCORINV020	Tc-99m	1.68E+15
RDCORINV021	Ru-103	1.50E+15
RDCORINV022	Ru-105	1.00E+15
RDCORINV023	Ru-106	5.21E+14
RDCORINV024	Rh-105	9.10E+14
RDCORINV025	Sb-127	1.03E+14
RDCORINV026	Sb-129	3.15E+14
RDCORINV027	Te-127	1.05E+14
RDCORINV028	Te-127m	1.37E+13
RDCORINV029	Te-129	3.10E+14
RDCORINV030	Te-129m	4.60E+13
RDCORINV031	Te-131m	1.42E+14
RDCORINV032	Te-132	1.41E+15
RDCORINV033	I-131	9.90E+14
RDCORINV034	I-132	1.44E+15
RDCORINV035	I-133	2.04E+15
RDCORINV036	I-134	2.25E+15
RDCORINV037	I-135	1.91E+15
RDCORINV038	Xe-133	2.03E+15
RDCORINV039	Xe-135	2.72E+14
RDCORINV040	Cs-134	1.98E+14
RDCORINV041	Cs-136	6.89E+13
RDCORINV042	Cs-137	1.28E+14
RDCORINV043	Ba-139	1.84E+15
RDCORINV044	Ba-140	1.77E+15

```

RDCORINV045    La-140      1.82E+15
RDCORINV046    La-141      1.68E+15
RDCORINV047    La-142      1.62E+15
RDCORINV048    Ce-141      1.68E+15
RDCORINV049    Ce-143      1.56E+15
RDCORINV050    Ce-144      1.36E+15
RDCORINV051    Pr-143      1.53E+15
RDCORINV052    Nd-147      6.69E+14
RDCORINV053    Np-239      1.93E+16
RDCORINV054    Pu-238      3.34E+12
RDCORINV055    Pu-239      4.02E+11
RDCORINV056    Pu-240      5.21E+11
RDCORINV057    Pu-241      1.51E+14
RDCORINV058    Am-241      1.70E+11
RDCORINV059    Cm-242      4.01E+13
RDCORINV060    Cm-244      1.94E+12

```

\*

\* SCALING FACTOR TO ADJUST THE CORE INVENTORY FOR POWER LEVEL

\*

\* SCALING FACTOR TO CONVERT INVENTORY FROM Bq/MWt TO Bq

\*

*	REACTOR	GE BASE	CLINTON ESP SSAR, Section 1.3.1
*	TYPE	ABWR	ABWR
*	POWER LEVEL (MWTH)	3926	3926
*	SCALING FACTOR	3926	3926

\*

RDCORSCA001 3926. \* BASE ABWR POWER LEVEL = 3926

\*

RDAPLFR001 PARENT (apply rel fracs the same as prior versions)

\*

\*\*\*\*\*

\* OUTPUT CONTROL DATA BLOCK

\*\*\*\*\*

\*

\* FLAG TO INDICATE THAT THIS IS THE LAST PROGRAM IN THE SERIES TO BE RUN

\*

OCENDAT1001 .FALSE. (SET THIS VALUE TO .TRUE. TO SKIP EARLY AND CHRONC)

\*

OCIDEBUG001 0

\*

\* NAME OF THE NUCLIDE TO BE LISTED ON THE DISPERSION LISTINGS

\*

\* OCNUCOUT001 Cs-137 (NOT USED IF DEBUG=0)

\*

\* NUM0 NO TABLES OUTPUT=0

TYPE0NUMBER 0

\*

\* INDREL INDRAD

\* TYPE0OUT001 1 4

\* TYPE0OUT002 1 9 XCCDF

\*\*\*\*\*

\* METEOROLOGICAL SAMPLING DATA BLOCK

\*\*\*\*\*

\* METEOROLOGICAL SAMPLING OPTION CODE:

\*

\* METCOD = 1, USER SPECIFIED DAY AND HOUR IN THE YEAR (FROM MET FILE),

\*

2, WEATHER CATEGORY BIN SAMPLING,

\*

3, 120 HOURS OF WEATHER SPECIFIED ON THE ATMOS USER INPUT

```

FILE,
*           4, CONSTANT MET (BOUNDARY WEATHER USED FROM THE START),
*           5, STRATIFIED RANDOM SAMPLES FOR EACH DAY OF THE YEAR.
*
M1METCOD001  2
*
* LAST SPATIAL INTERVAL FOR MEASURED WEATHER
*
M2LIMSPA001  9          (ADJUSTED FOR SL RADIAL INTVL)
*
* BOUNDARY WEATHER MIXING LAYER HEIGHT
*
M2BNDMXH001 1000.      (METERS, NUREG-1150)
*
* BOUNDARY WEATHER STABILITY CLASS INDEX
*
M2IBDSTB001  4          (D-STABILITY)
*
* BOUNDARY WEATHER RAIN RATE
*
M2BNDRAN001  0.         (MM/HR, NUREG-1150)
*
* BOUNDARY WEATHER WIND SPEED
*
M2BNDWND001  5.0        (M/S)
*
* NUMBER OF RAIN DISTANCE INTERVALS FOR BINNING
*
M4NRNINT001  5
*
* ENDPOINTS OF THE RAIN DISTANCE INTERVALS (KILOMETERS)
*
* NOTE:  THESE MUST BE CHOSEN TO MATCH THE SPATIAL ENDPOINT DISTANCES
* SPECIFIED FOR ARRAY SPAEND (10 % ERROR IS ALLOWED).
*
*           1.2    5.0    10.0    25.0    50.0    MILES
*
M4RNDSTS001  2.0    8.0    16.0    40.0    80.0    KM
*
* NUMBER OF RAIN INTENSITIY BREAKPOINTS
*
M4NRINTN001  3
*
* RAIN INTENSITY BREAKPOINTS FOR WEATHER BINNING (MILLIMETERS PER HOUR)
*
M4RNRATE001  2.  4.  6.
*
* NUMBER OF WEATHER SAMPLES PER BIN
* (NUREG-4551 used 4, more samples are preferred, but increase
* computing time. 12 judged a good compromise for current PCs)
*
M4NSMPLS001 12 (4 MINIMUM, 24 MAXIMUM)
*
* INITIAL SEED FOR RANDOM NUMBER GENERATOR FOR WEATHER SAMPLING
*
M4IRSEED001  79
***** RELEASE DATA BLOCK *****
*
* MACCS Categories  Xe/Kr  I    Cs    Te    Sr    Ru    La    Ce
Ba

```



```

*
*****
***** RELEASE DATA BLOCK *****
*
* Source term data is taken from Dominion Model for ABWR 1 plume,
4/14/2004
*
* SOURCE TERM NUMBER 0
*
RDATNAM2001      'ABWR CASE 0 Specific data used from GE SSAR'
RDOALARM001      6120.      *time of site general emergency declaration=
1.7 hours
RDNUMREL001      1          *one plume segment
RDMAXRIS001      1          *first plume segment carries greatest risk
RDREFTIM001      0.0        *plume segment decay based on leading edge
RDPLHEAT001      1.38E+6    *buoyant plume rise heat rate, watts
RDPLHITE001      37.7       *Release height of each plume
RDPLUDUR001      36000.     *Plume duration =10 hours
RDPDELAY001      9720.     *plume segments start at 2.7 hours after
scram
*
*
*          Xe/Kr      I          Cs          Te          Sr          Ru          La
Ce          Ba
RDRELFRC001      4.4E-2    2.3E-5    2.3E-5    5.3E-6    0.0E+0    0.0E+0    0.0E+0
0.0E+0    0.0E+0
.
***** RELEASE DATA BLOCK *****
* SOURCE TERM NUMBER 1
*
RDATNAM2001      'ABWR CASE 1'
RDOALARM001      69120.     *time of site general emergency declaration=
19.2 hours
RDNUMREL001      1          *one plume segment
RDMAXRIS001      1          *first plume segment carries greatest risk
RDREFTIM001      0.0        *plume segment decay based on leading edge
RDPLHEAT001      1.38E+6    *buoyant plume rise heat rate, watts
RDPLHITE001      37.7       *Release height of each plume
RDPLUDUR001      3600.     *Plume duration =1 hours
RDPDELAY001      72000.     *plume segments start at 20 hours after
scram
*
*
*          Xe/Kr      I-Br      Cs-Rb      Te-Sb      Sr          Co-Mo      La
Ce          Ba
RDRELFRC001      1.0E+0    1.5E-7    1.3E-5    3.1E-4    6.3E-6    2.4E-11    7.9E-8
7.9E-8    6.3E-6
.
***** RELEASE DATA BLOCK *****
* SOURCE TERM NUMBER 2
*
RDATNAM2001      'ABWR CASE 2'
RDOALARM001      65520.     *time of site general emergency declaration=
18.2 hours
RDNUMREL001      1          *one plume segment
RDMAXRIS001      1          *first plume segment carries greatest risk
RDREFTIM001      0.0        *plume segment decay based on leading edge
RDPLHEAT001      1.38E+6    *buoyant plume rise heat rate, watts
RDPLHITE001      37.7       *Release height of each plume
RDPLUDUR001      3600.     *Plume duration =1 hours
RDPDELAY001      68400.     *plume segments start at 19 hours after
scram

```

```

*
*           Xe/Kr   I-Br   Cs-Rb   Te-Sb   Sr     Co-Mo   La
Ce       Ba
RDRELFRC001  1.0E+0  5.0E-6  5.0E-6  0.0E+0  0.0E+0  0.0E+0  0.0E+0
0.0E+0  0.0E+0
.
***** RELEASE DATA BLOCK *****
* SOURCE TERM NUMBER 3
*
RDATNAM2001  'ABWR CASE 3'
RDOALARM001  177120.    *time of site general emergency declaration=
49.2 hours
RDNUMREL001  1           *one plume segment
RDMAXRIS001  1           *first plume segment carries greatest risk
RDREFTIM001  0.0         *plume segment decay based on leading edge
RDPLHEAT001  1.38E+6      *buoyant plume rise heat rate, watts
RDPLHITE001  37.7        *Release height of each plume
RDPLUDUR001  36000.      *Plume duration =10 hours
RDPDELAY001  180000.    *plume segments start at 50 hours after
scram
*
*           Xe/Kr   I-Br   Cs-Rb   Te-Sb   Sr     Co-Mo   La
Ce       Ba
RDRELFRC001  1.0E+0  2.8E-4  2.2E-3  0.0E+0  0.0E+0  0.0E+0  0.0E+0
0.0E+0  0.0E+0
.
***** RELEASE DATA BLOCK *****
* SOURCE TERM NUMBER 4
*
RDATNAM2001  'ABWR CASE 4'
RDOALARM001  69120.    *time of site general emergency declaration=
19.2 hours
RDNUMREL001  1           *one plume segment
RDMAXRIS001  1           *first plume segment carries greatest risk
RDREFTIM001  0.0         *plume segment decay based on leading edge
RDPLHEAT001  1.38E+6      *buoyant plume rise heat rate, watts
RDPLHITE001  37.7        *Release height of each plume
RDPLUDUR001  3600.      *Plume duration =1 hour
RDPDELAY001  72000.    *plume segments start at 20 hours after
scram
*
*           Xe/Kr   I-Br   Cs-Rb   Te-Sb   Sr     Co-Mo   La
Ce       Ba
RDRELFRC001  1.0E+0  1.6E-3  1.6E-3  0.0E+0  0.0E+0  0.0E+0  0.0E+0
0.0E+0  0.0E+0
.
***** RELEASE DATA BLOCK *****
* SOURCE TERM NUMBER 5
*
RDATNAM2001  'ABWR CASE 5'
RDOALARM001  65520.    *time of site general emergency declaration=
18.2 hours
RDNUMREL001  1           *one plume segment
RDMAXRIS001  1           *first plume segment carries greatest risk
RDREFTIM001  0.0         *plume segment decay based on leading edge
RDPLHEAT001  1.38E+6      *buoyant plume rise heat rate, watts
RDPLHITE001  37.7        *Release height of each plume
RDPLUDUR001  3600.      *Plume duration =1 hour
RDPDELAY001  68400.    *plume segments start at 19 hours after
scram

```

\*  
 \*  
 \*                   Xe/Kr    I-Br      Cs-Rb    Te-Sb      Sr        Co-Mo    La  
 Ce            Ba  
 RDRELFRC001    1.0E+0   6.0E-3   5.3E-4   0.0E+0   0.0E+0   0.0E+0   0.0E+0  
 0.0E+0   0.0E+0

.  
 \*\*\*\*\* RELEASE DATA BLOCK \*\*\*\*\*

\* SOURCE TERM NUMBER 6  
 \*

RDATNAM2001        'ABWR CASE 6'  
 RDOALARM001       65520.       \*time of site general emergency declaration=  
 18.2 hours  
 RDNUMREL001       1               \*one plume segment  
 RDMAXRIS001       1               \*first plume segment carries greatest risk  
 RDREFTIM001       0.0             \*plume segment decay based on leading edge  
 RDPLHEAT001       1.38E+6       \*buoyant plume rise heat rate, watts  
 RDPLHITE001       37.7            \*Release height of each plume  
 RDPLUDUR001       36000.        \*Plume duration =10 hours  
 RDPDELAY001       68400.        \*plume segments start at 19 hours after  
 scram

\*  
 \*                   Xe/Kr    I-Br      Cs-Rb    Te-Sb      Sr        Co-Mo    La  
 Ce            Ba  
 RDRELFRC001    1.0E+0   3.1E-2   7.7E-2   0.0E+0   0.0E+0   0.0E+0   0.0E+0  
 0.0E+0   0.0E+0

.  
 \*\*\*\*\* RELEASE DATA BLOCK \*\*\*\*\*

\* SOURCE TERM NUMBER 7  
 \*

RDATNAM2001        'ABWR CASE 7'  
 RDOALARM001       69120.       \*time of site general emergency declaration=  
 19.2 hours  
 RDNUMREL001       1               \*one plume segment  
 RDMAXRIS001       1               \*first plume segment carries greatest risk  
 RDREFTIM001       0.0             \*plume segment decay based on leading edge  
 RDPLHEAT001       1.38E+6       \*buoyant plume rise heat rate, watts  
 RDPLHITE001       37.7            \*Release height of each plume  
 RDPLUDUR001       36000.        \*Plume duration =10 hours  
 RDPDELAY001       72000.        \*plume segments start at 16, 18, and 26  
 hours after scram

\*  
 \*                   Xe/Kr    I-Br      Cs-Rb    Te-Sb      Sr        Co-Mo    La  
 Ce            Ba  
 RDRELFRC001    1.0E+0   8.9E-2   9.9E-2   0.0E+0   0.0E+0   0.0E+0   0.0E+0  
 0.0E+0   0.0E+0

.  
 \*\*\*\*\* RELEASE DATA BLOCK \*\*\*\*\*

\* SOURCE TERM NUMBER 8  
 \*

RDATNAM2001        'ABWR CASE 8'  
 RDOALARM001       4320.       \*time of site general emergency declaration=  
 1.2 hours  
 RDNUMREL001       1               \*one plume segment  
 RDMAXRIS001       1               \*first plume segment carries greatest risk  
 RDREFTIM001       0.0             \*plume segment decay based on leading edge  
 RDPLHEAT001       4.19E+6       \*buoyant plume rise heat rate, watts  
 RDPLHITE001       37.7            \*Release height of each plume  
 RDPLUDUR001       36000.        \*Plume duration =10 hours  
 RDPDELAY001       7200.        \*plume segments start at 2 hours after scram

\*  
 \*

	Xe/Kr	I-Br	Cs-Rb	Te-Sb	Sr	Co-Mo	La
Ce Ba							
RDRELFRC001	1.0E+0	1.9E-1	2.5E-1	0.0E+0	0.0E+0	0.0E+0	0.0E+0
	0.0E+0	0.0E+0					

.  
 \*\*\*\*\* RELEASE DATA BLOCK \*\*\*\*\*  
 \* SOURCE TERM NUMBER 9

\*  
 RDATNAM2001 'ABWR CASE 9'  
 RDOALARM001 43920. \*time of site general emergency declaration=  
 12.2 hours  
 RDNUMREL001 1 \*one plume segment  
 RDMAXRIS001 1 \*first plume segment carries greatest risk  
 RDREFTIM001 0.0 \*plume segment decay based on leading edge  
 RDPLHEAT001 1.38E+6 \*buoyant plume rise heat rate, watts  
 RDPLHITE001 37.7 \*Release height of each plume  
 RDPLUDUR001 36000. \*Plume duration =10 hours  
 RDPDELAY001 84960. \*plume segments start at 23.6 hours after  
 scram

	Xe/Kr	I-Br	Cs-Rb	Te-Sb	Sr	Co-Mo	La
Ce Ba							
RDRELFRC001	1.0E+0	3.7E-1	3.6E-1	1.1E-3	9.3E-3	9.2E-8	2.8E-3
	2.8E-3	9.3E-3					

.