

### 3.6 CONTAINMENT SYSTEMS

#### 3.6.6 Containment Spray and Cooling Systems

LCO 3.6.6 The containment fan cooling unit (CFCU) system and two containment spray trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One containment spray train inoperable.	A.1 Restore containment spray train to OPERABLE status.	<p>-----NOTE----- The Condition A Completion Times may be extended to 14 days for Unit 2 cycle 12 for containment spray pump 2-2 control circuit cable maintenance.</p> <p>72 hours <u>AND</u> 10 days from discovery of failure to meet the LCO</p>
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	84 hours
C. One required CFCU system inoperable such that a minimum of two CFCUs remain OPERABLE.	C.1 Restore required CFCU system to OPERABLE status.	<p>7 days <u>AND</u> 10 days from discovery of failure to meet the LCO</p>

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. One required containment spray train inoperable and one required CFCU system inoperable such that a minimum of two CFCUs remain OPERABLE.	D.1 Restore one required containment spray system to OPERABLE status,	72 hours
	<u>OR</u> D.2 Restore one CFCU system to OPERABLE status such that four CFCUs or three CFCUs, each supplied by a different vital bus, are OPERABLE.	72 hours
E. Required Action and associated Completion Time of Condition C or D not met.	E.1 Be in MODE 3.	6 hours
	<u>AND</u> E.2 Be in MODE 5.	36 hours
F. Two containment spray trains inoperable. <u>OR</u> One containment spray train inoperable and two CFCU systems inoperable such that one or less CFCUs remain OPERABLE. <u>OR</u> One or less CFCUs OPERABLE.	F.1 Enter LCO 3.0.3.	Immediately