



444 South 16th Street Mall
Omaha NE 68102-2247

August 12, 2004
LIC-04-0025

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: July 2004 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for July 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

J. B. Herman
Manager – Nuclear Licensing

JBH/EPM/epm

Attachment

- c: B. S. Mallett, NRC Regional Administrator, Region IV
- A. B. Wang, NRC Project Manager
- J. G. Kramer, NRC Senior Resident Inspector
- INPO Records Center

OPERATING DATA REPORT

DOCKET NO. 50-285
 UNIT NAME Fort Calhoun Station
 DATE August 2, 2004
 COMPLETED BY E. P. Matzke
 TELEPHONE (402) 533-6855

REPORT PERIOD: July 2004

Design Electrical Rating (MWe-Net): 478
 Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO- DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	744	4847	219715
Number of Hours Generator was On-line:	744	4830	218355
Unit Reserve Shutdown Hours:	0	0	0
Net Electrical Energy Generated (MWh):	349079	2304937	94831040

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the month of July 2004.