

August 13, 2004

Mr. Gordon Bischoff, Manager  
Owners Group Program Management Office  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

SUBJECT: REVISION TO DRAFT SAFETY EVALUATION FOR TOPICAL REPORT  
WCAP-15872, REV. 00, "USE OF ALTERNATE DECAY HEAT REMOVAL IN  
MODE 6 REFUELING" (TAC NO. MB9020)

Dear Mr. Bischoff:

On May 12, 2003, and its supplement dated November 18, 2003, the Westinghouse Owners Group (WOG) submitted Topical Report (TR) WCAP-15872, Rev. 00, "Use of Alternative Decay Heat Removal in Mode 6 Refueling" to the staff for review. On July 22, 2004, the NRC provided the WOG a copy of the staff's draft safety evaluation (SE). Subsequently, the staff has discovered some misrepresentations in the draft SE and a revision to the draft SE is being provided again for the WOG's review and comment.

Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Girija Shukla at 301-415-8439.

Sincerely,

**/RA/**

Stephen Dembek, Chief, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Project No. 694

Enclosure: Draft Safety Evaluation

cc w/encl: See next page

August 13, 2004

Mr. Gordon Bischoff, Manager  
Owners Group Program Management Office  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

SUBJECT: REVISION TO DRAFT SAFETY EVALUATION FOR TOPICAL REPORT  
WCAP-15872, REV. 00, "USE OF ALTERNATE DECAY HEAT REMOVAL IN  
MODE 6 REFUELING" (TAC NO. MB9020)

Dear Mr. Bischoff:

On May 12, 2003, and its supplement dated November 18, 2003, the Westinghouse Owners Group (WOG) submitted Topical Report (TR) WCAP-15872, Rev. 00, "Use of Alternative Decay Heat Removal in Mode 6 Refueling" to the staff for review. On July 22, 2004, the NRC provided the WOG a copy of the staff's draft safety evaluation (SE). Subsequently, the staff has discovered some misrepresentations in the draft SE and a revision to the draft SE is being provided again for the WOG's review and comment.

Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Girija Shukla at 301-415-8439.

Sincerely,

*/RA/*

Stephen Dembek, Chief, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Project No. 694

Enclosure: Draft Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsNrrDipmLpdiv (Hberkow)

RidsNrrPMGShukla

RidsNrrLAEPeyton

RidsOgcRp

RidsAcrsAcnwMailCenter

JUhle

JWermiel

YOrechwa

**ADAMS Accession No.: ML042260509**

NRR-106

OFFICE	PDIV-2/PM	PDIV-2/LA	SRXB/DSSA	PDIV-2/SC
NAME	GShukla	EPeyton	JUhle	SDembek
DATE	8/11/04	8/11/04	5/27/04*	8/11/04

DOCUMENT NAME: C:\MYFILES\Copies\WCAP-15872 Draft SE Letter Rev 1.wpd

OFFICIAL RECORD COPY

DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

WCAP-15872, REV. 00, "USE OF ALTERNATE DECAY HEAT REMOVAL

IN MODE 6 REFUELING"

WESTINGHOUSE OWNERS GROUP

PROJECT NO. 694

1     1.0     INTRODUCTION

2     By letter dated May 12, 2003, and its supplement dated November 18, 2003, the Westinghouse  
3     Owners Group (WOG) submitted Topical Report (TR) WCAP-15872, Rev. 00, "Use of  
4     Alternative Decay Heat Removal in Mode 6 Refueling," for staff review and approval of an  
5     alternate method for the shutdown cooling during Mode 6 plant operations as specified in the  
6     current technical specifications (TSs) for the plant. The alternate decay heat removal method  
7     may be used to supplement or to substitute for the shutdown decay heat removal system during  
8     refueling operations. The TR describes a computational methodology for assessing the  
9     necessary conditions for entry into and operation under the alternate heat removal alignment.  
10    These conditions are governed by a combination of factors such as decay heat generation rate,  
11    heat removal capabilities, temperature of the refueling pool, and the heat sink temperatures.  
12    The computational model of the alternate heat removal alignment is formulated as a series of  
13    one-dimensional control volumes within which the fluid mass, momentum, and energy are  
14    conserved. The model describes the transfer, by natural convection, of the decay heat from the  
15    reactor cavity to the refueling pool, and then by forced convection into the cooling system  
16    aligned via the alternate cooling method.

17    The validity of the one-dimensional formulation is dependent on the estimation of the values of  
18    two parameters:

- 19         •     mixing coefficient for the fluid from the reactor cavity, and  
20         •     bypass coefficient for the fluid in the refueling pool.

21    These values are plant and alternate decay heat removal alignment dependent. The values for  
22    these coefficients are computed via multi-dimensional computational fluid dynamics  
23    calculations.

24    The methodology has been validated through a comparison of predicted to recorded data at the  
25    Calvert Cliffs Nuclear Power Plant (CCNPP) Unit 2 during the March 2001 refueling outage.  
26    The applicability of the methodology in general is predicated on a plant-specific validation  
27    similar to the one given in WCAP-15872, Rev. 00 for the CCNPP Unit 2.

1     2.0     REGULATORY EVALUATION

2     The methodology presented in WCAP-15872, Rev. 00, "Use of Alternate Decay Heat Removal  
3     in Mode 6 Refueling," addresses the computational issues associated with demonstrating  
4     compliance with the requirements for a residual decay heat removal system set forth in General  
5     Design Criterion (GDC) 34. In particular, the numerical values computed with this methodology  
6     may be used to support the demonstration that the transfer of fission product decay heat and  
7     other residual heat from the reactor core is at a rate such that specified acceptable fuel design  
8     limits are not exceeded. The approval of the computational methodology in WCAP-15872,  
9     Rev. 00 is consistent with the requirements set forth in Appendix B to Part 50 of Title 10 of the  
10    Code of Federal Regulations (10 CFR Part 50) "Quality Assurance Criteria for Nuclear Power  
11    Plants and Fuel Reprocessing Plants." WCAP-15872 describes actions necessary to provide  
12    adequate confidence that an alternate heat removal system will perform satisfactorily in service.

13    3.0     SUMMARY OF WCAP-15872, REV. 00

14    The TR discusses the operational and technical issues associated with the introduction of an  
15    alternate decay heat removal system which takes suction from and discharges to the refueling  
16    pool while in Mode 6, with the refueling pool fully flooded. Standard decay heat removal in  
17    Mode 6 is provided by the shutdown cooling system. In this system, suction is taken from the  
18    hot leg, and the flow is fed to the shutdown cooling pump, and passed through a shutdown  
19    cooling heat exchanger. Cooled water is then returned to the reactor coolant system through a  
20    nozzle located in the cold leg. The alternate heat removal alignment is a specific alignment of  
21    existing plant systems as a substitute for conventional decay heat removal by the shutdown  
22    cooling system. In the alternate heat removal alignment, the core decay heat circulates from  
23    the open reactor vessel by natural circulation into the flooded refueling pool. The refueling pool  
24    is then cooled by an alternate cooling system. In the alternate cooling alignment, a pump takes  
25    suction from the refueling pool, then after passing through a heat exchanger, the flow is  
26    directed back into the refueling pool. The specific locations of the suction pipe from the  
27    refueling pool and the refill pipe to the refueling pool can be optimized depending on the  
28    specific plant design. In the case of CCNPP Unit 2, the alternate heat removal alignment  
29    consists of the spent fuel pool pump that takes suction from the refueling pool, then after  
30    passing through the spent fuel pool heat exchanger, the flow is directed back into the refueling  
31    pool. This flow is directed into the refueling pool through piping near the bottom of the pool.  
32    The suction from the refueling pool to the spent fuel pool cooling line is through a drain in the  
33    bottom of the refueling pool, at the side of the pool opposite the inlet point. This arrangement  
34    results in cooled water inventory drawn across the pool region directly above the open vessel.

35    Activation of the alternate heat removal alignment is dependent on the ability of the decay heat  
36    to circulate from the open reactor vessel (upper guide structure removed) by natural circulation  
37    and constrained by the water level in the refueling pool, the pool temperature, and the residual  
38    decay heat of the reactor core. Factors influencing the performance of the alternate heat  
39    removal alignment include the heat transfer ability of the spent fuel pool cooling system when  
40    aligned to the refueling pool, the pumped flow rates, and the ultimate heat sink temperature.

### 3.1 Computational Method

The computational methodology described in WCAP-15872, Rev. 00 addresses the requirements for a residual decay heat removal system set forth in GDC 34. The computation in particular evaluates the capability of an alternate decay heat removal system to transfer decay heat and other residual heat from the reactor such that fuel design limits are not exceeded. The computational methodology consists of two interrelated models. A one-dimensional, time-dependent, lumped-parameter model of the core coupled to the refueling pool, and a three-dimensional, steady-state, computational fluid dynamics (CFD) model of the refueling pool.

#### 3.1.1 One-Dimensional Model

The one-dimensional model divides the refueling pool and the reactor vessel internals into a series of control volumes that describe the upper guide structure, core and refueling pool. Ten state points that represent natural boundaries between the control volumes are defined in the model. These are consistent with the set of assumptions used to reduce the refueling pool and core coupled circulation problem to a mathematically tractable form. Conservation of mass, momentum, and energy are solved for these control volumes to predict the mass flow rate between the reactor vessel and the refueling pool. Temperatures of the refueling pool, the suction and discharge are calculated. The flow rate through the alternate decay heat removal system is also calculated. The model also considers the heat lost at the pool surface due to natural convection and evaporation from the free surface.

#### 3.1.2 Computational Fluid Dynamics Model

The one-dimensional model cannot account for the geometric effects of the pool regions where the cooler fluid near the bottom of the pool does not fully mix with the hot plume rising from the core. Thus, two empirical coefficients, a mixing and a bypass coefficient, are introduced. The mixing coefficient accounts for the portion of the reactor cavity fluid that does not mix with the core flow. The bypass coefficient accounts for the alternate decay heat removal train flow that does not mix with the core exit flow. The values of these coefficients are specific to the geometry of the refueling pool and the alternate heat removal alignment. A three-dimensional CFD model of the refueling pool and boundary conditions consistent with the one-dimensional nodal model of the refueling pool and reactor cavity, are used to compute these coefficients.

## 4.0 TECHNICAL EVALUATION

Key elements of the methodology described in the TR, such as the mixing and bypass coefficients, are plant and alternate heat removal alignment specific. The model validation presented in the TR is based on a comparison of model predictions with data recorded at CCNPP Unit 2 during the March 2001 refueling outage. Under limited conditions, CCNPP units are permitted to use an alternate refueling pool cooling system during Mode 6 with the refueling pool flooded and with the shutdown cooling secured. Test data were recorded for two days during which the alternate pool cooling alignment was in use. Fluid temperatures in the refueling pool were recorded by thermocouples located at the reactor vessel flange level, at mid-level in the pool and close to the pool surface. The temperatures and shutdown cooling flow rates were recorded as a function of time. Switching from the conventional shutdown

1 cooling decay heat removal, both before and after the head is removed, followed by switching  
2 to the alternate decay heat removal are taken into account via the following sequence of  
3 operations:

- 4 1. reduce shutdown cooling flow for vessel head removal
- 5 2. restore full shutdown cooling flow
- 6 3. initiate alternate heat removal cooling flow, continue shutdown cooling flow
- 7 4. secure shutdown cooling flow, continue alternate heat removal cooling flow
- 8 5. secure alternate heat removal flow, restore shutdown cooling flow

#### 9 4.1 Validation of the Computational Method

10 During the alternate heat removal alignment the refueling pool temperature data, at different  
11 elevations above the reactor vessel flange, indicate that the pool temperature decreases with  
12 elevation. This suggests that the hot plume from the core thermally mixes with the colder  
13 refueling pool water and cools as it rises to the top of the pool. The CFD predictions of the  
14 refueling pool water temperatures at locations corresponding to the measurement points  
15 compare favorably with the measured temperatures.

16 The variation with time of the computed and measured temperatures (shutdown cooling outlet,  
17 spent fuel pool outlet, and refueling pool average) and flow rates, over the sequence of  
18 operations that define entrance into steady-state operation and exit from the alternate decay  
19 heat removal alignment during the CCNPP Unit 2 March 2001 refueling outage, agree well.  
20 Some of the differences can be explained as due to the uncertainties in decay heat values and  
21 initial refueling pool temperatures at the time the head is removed. Thus, the mixing and  
22 bypass coefficients based on the CFD calculations account well for the non-uniform dynamic  
23 effects in the refueling pool in the one-dimensional analysis.

#### 24 4.2 Alternate Heat Removal System Entry Conditions

25 The key factors that govern entry into the alternate heat removal alignment are decay heat  
26 generation rate, heat removal capability, the temperature of the refueling pool, and the heat  
27 sink temperature. The limiting time for entry into alternate heat removal is when the decay heat  
28 is first low enough to satisfy the refueling pool temperature limit given by the TS for a given heat  
29 sink temperature. At CCNPP the calculational methodology, described above and in  
30 WCAP-15872, Rev. 00 has been employed with plant specific data to determine the minimum  
31 time after shutdown for entry into the alternate heat removal alignment corresponding to the  
32 limiting refueling pool temperature versus ultimate heat sink temperature and other variables.  
33 The good agreement between predictions and measurements of the average refueling pool  
34 temperatures during the March 2001 refueling outage at CCNPP Unit 2 demonstrate the  
35 efficacy of the methodology for computing the conditions for entry into the alternate heat  
36 removal alignment at CCNPP.

1 4.3 Effect of Pool Fluid Velocity on Fuel Movement

2 Due to thermal convection between the core and refueling pool and the subsequent mixing with  
3 the pool circulation flow, a fuel assembly can become tilted and difficult to insert into the core.  
4 Limiting values of tilt angle as a function of time after shutdown are computed based on the  
5 predicted one-dimensional model flow rates due to natural convection between the core and the  
6 refueling pool. The allowable window for the initiation of the alternate heat removal alignment is  
7 computed consistent with temperature limits. The allowable window may require further  
8 refinement based on the computed tilt angles so as to preclude problems with the insertion of  
9 fuel assemblies. The specific limiting values of tilt angle depend on plant-specific experience  
10 with fuel assembly insertion.

11 5.0 CONCLUSIONS

12 The staff has reviewed WCAP-15872, Rev. 00 and the supporting documentation submitted in  
13 response to its request for additional information. On the basis of this review, the staff only  
14 approves the computational methodology, together with its verification, as described in  
15 WCAP-15872, Rev. 00 for referencing in licensing actions with regard to implementing an  
16 alternate method for shutdown cooling during routine Mode 6 operations at CCNPP.  
17 Application of the methodology for referencing in licensing actions to other plants is conditional  
18 on the verification of the methodology on a plant-specific basis and a review by the staff.

19 This verification for each plant-specific alternate decay heat removal system and refueling pool  
20 flow configuration entails:

- 21 ● A quantitative verification of the CFD model of the refueling pool with respect to  
22 measurements comparable to those described in Appendix C of WCAP-15872, Rev. 00.
- 23 ● A quantitative comparison of the results of the computational model (as described in  
24 Appendix A of WCAP-15872, Rev. 00) to measurements comparable to those described  
25 in Appendix B of WCAP-15872, Rev. 00.
- 26 ● An estimate of the sensitivity of the bypass and mixing coefficients of the computational  
27 model to model assumptions and the effects of this sensitivity on the computed results.

28 Principal Contributor: Yuri Orechwa

29 Date: August 13, 2004

Westinghouse Owners Group

Project No. 694

cc:

Mr. James A. Gresham, Manager  
Regulatory Compliance and Plant Licensing  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355