

August 16, 2004

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - REQUEST FOR ADDITIONAL INFORMATION
RE: ONE TIME EXTENSION OF DIESEL GENERATOR ALLOWED OUTAGE
TIME (TAC NO. MC3770)

Dear Mr. Edington:

Nebraska Public Power District (the licensee) requested the Nuclear Regulatory Commission (NRC) staff approve one time extension of diesel generator allowed outage time.

The NRC staff has reviewed the information provided in the July 15, 2004, submittal and determined that additional information is required in order to complete the review of the changes. As agreed upon in telephone call with Ed McCutchen on August 12, 2004, the licensee will respond to the request for additional information (RAI) within 45 days. The RAI is enclosed.

Sincerely,

/RAI

Michelle C. Honcharik, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: RAI

cc w/encl: See next page

August 16, 2004

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - REQUEST FOR ADDITIONAL INFORMATION
RE: ONE TIME EXTENSION OF DIESEL GENERATOR ALLOWED OUTAGE
TIME (TAC NO. MC3770)

Dear Mr. Edington:

Nebraska Public Power District (the licensee) requested the Nuclear Regulatory Commission (NRC) staff approve one time extension of diesel generator allowed outage time.

The NRC staff has reviewed the information provided in the July 15, 2004, submittal and determined that additional information is required in order to complete the review of the changes. As agreed upon in telephone call with Ed McCutchen on August 12, 2004, the licensee will respond to the request for additional information (RAI) within 45 days. The RAI is enclosed.

Sincerely,
/RAI
Michelle C. Honcharik, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	PDIV-1 r/f
RidsNrrDlpmLpdiv (HBerkow)	RidsNrrDlpmLpdiv1 (RGramm)
RidsNrrPMMHoncharik	RidsNrrLADBaxley
RidsAcrcAcnwMailCenter	RidsOgcRp
RidsRgn4MailCenter (KKennedy)	RidsNrrDlpmDpr (SWall)
RidsNrrDeDpr	Jai Rajan
Thomas Koshy	David Terao

ACCESSION NO: ML042300347
Nrr-088

*See Tad Marsh Deferral Memo
**RAI input via e-mail dated

OFFICE	PDIV-1/PM	PDIV-1/LA	EMEB/SC	PDIV-1/SC
NAME	MHoncharik	DBaxley	DTerao	WReckley for RGramm
DATE	8/16/04	N/A*	8/10/04*	8/16/04

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML042300347.wpd

cc:

Mr. William J. Fehrman
President and Chief Executive Officer
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. Clay C. Warren
Vice President of Strategic Programs
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. John R. McPhail, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Mr. Paul V. Fleming
Licensing Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Cheryl K. Rogers, Program Manager
Nebraska Health & Human Services
System
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P. O. Box 95007
Lincoln, NE 68509-5007

Mr. Ronald A. Kucera, Director
of Intergovernmental Cooperation
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Jerry Uhlmann, Director
State Emergency Management Agency
P. O. Box 116
Jefferson City, MO 65101

Chief, Radiation and Asbestos
Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
401 SW 7th Street
Suite D
Des Moines, IA 50309

Mr. Scott Clardy, Director
Section for Environmental Public Health
P.O. Box 570
Jefferson City, MO 65102-0570

Cooper Nuclear Station

-2-

Jerry C. Roberts, Director of Nuclear
Safety Assurance
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

REQUEST FOR ADDITIONAL INFORMATION

ISSUES RELATED TO ONE TIME EXTENSION OF DIESEL GENERATOR

ALLOWED OUTAGE TIME

COOPER NUCLEAR STATION

DOCKET NO. 50-298

(1) In Section 4.3 of the amendment request the licensee states that the temporary equipment required to perform diesel fuel movement will be located on an area of engineered fill, which is resistant to damage caused by seismic events. The licensee is requested to provide the basis for this statement, including a discussion of the level of earthquake ground motion and the load transfer between the tank and the engineered fill. The licensee is also requested to discuss the basis for the statement that the temporary equipment will remain functional during seismic events at this location, including a description of the evaluation of the ability of temporary piping and above-ground tank anchorages to withstand seismic loadings.

(2) The licensee is requested to provide bearing pressure and soil settlement data that might have been taken at the engineered fill location to assure that differential settlement is not occurring at this time and the soil bearing pressure is adequate to support the temporary equipment in a stable manner.

ENCLOSURE