

Kevin J. Nietmann
Plant General Manager
Calvert Cliffs Nuclear Power Plant
Constellation Generation Group, LLC

1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101
410 495-4787 Fax



August 13, 2004

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
July 2004 Operating Data Reports

The subject reports are being sent to you as required by Technical Specification 5.6.4.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

A handwritten signature in black ink, appearing to be "KJN", written over a horizontal line.

for
Kevin J. Nietmann
Plant General Manager

KJN/CAN/bjd

Attachments

cc: J. Petro, Esquire
J. E. Silberg, Esquire
R. V. Guzman, NRC
H. J. Miller, NRC

Resident Inspector, NRC
R. I. McLean, DNR
S. Mainieri, INPO
K. N. Larson, ANI

IE24

UNIT SHUTDOWNS

DOCKET NO.	50-317
UNIT NAME	Calvert Cliffs - U1
DATE	August 3, 2004
COMPLETED BY	Herman O. Olsen
TELEPHONE	(410) 495-6734

REPORTING MONTH July 2004

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

¹ Reason:

- A - Equipment Failure
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error
- H - Other

² Method:

- 1 - Manual
- 2 - Manual Scram.
- 3 - Automatic Scram.
- 4 - Continued
- 5 - Other

DOCKET NO. 50-317
CALVERT CLIFFS - UNIT 1
August 3, 2004

SUMMARY OF OPERATING EXPERIENCE

July 2004

The unit operated at 100% power for the entire month.

UNIT SHUTDOWNS

DOCKET NO. 50-318
 UNIT NAME Calvert Cliffs-U2
 DATE August 3, 2004
 COMPLETED BY Herman O. Olsen
 TELEPHONE (410) 495-6734

REPORT MONTH July 2004

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

¹ Reason:

- A - Equipment Failure
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error
- H - Other

² Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Continued
- 5 - Other

DOCKET NO. 50-318
CALVERT CLIFFS - UNIT 2
August 3, 2004

SUMMARY OF OPERATING EXPERIENCE

July 2004

The unit began the month at 100% power.

On 07/18/04 at 0808 power was reduced to 97% for moderator coefficient testing (PSTP-4). Testing was completed at 1115 and power was returned to 100% at 1230.

The unit operated at 100% power for the remainder of the month.