

8/17/04
RDB reviewed
Hpm

8/3/04
GFR 46597

(1)

DG-1125, Table 2

Case N-498-4 - This entry should be highlighted, as the limitations have been revised from R.G. 1.147, Rev. 13. The limitation has been eliminated for noninsulated Class 2 and 3 systems that operate during normal plant operation and have been in operation for 10 min to 4 hr. This reduced limitation is consistent with the current IWA-5213(a)(3).

DG-1126, Table 1

Case N-595-3 - The reason for the lack of acceptability contains inaccurate statements. ASME has not approved incorporation of Case N-595-3 into Section III, Division 3. That proposal failed to gain approval of the BPVSC. Instead, the BPVSC agreed to publish a new Case N-717 that will contain those same provisions. This proposal has not yet been approved by the BNCS. A proposal to incorporate Case N-717 has not yet been considered by the ASME Committees.

DG-1126, Table 2

Case N-595-3 - The reason for the lack of acceptability contains an inaccurate statement. Concern (1) is inaccurate because IWA-6350 was added in the 2003 Addenda. Concern (2) is unclear. Perhaps some discussion between the NRC and SC XI members could resolve the staff's difficulty with the footnote and the table.

Rick Swayne
Reedy Engineering, 3425 S Bascom Ave, Ste E
Campbell CA 95008-7300
rswayne@reedyeng.com

E-RFDs = ADU-03

Adm = W. Martin (WEN)

Template = ADM-013