

SURVEILLANCE REQUIREMENTS (continued)		
SURVEILLANCE		FREQUENCY
SR 3.8.4.6	Verify each battery charger supplies $\geq 300$ amps for chargers 1A and 1B and $\geq 50$ amps for charger 1C at $\geq 130.2$ V for $\geq 8$ hours.	18 months
SR 3.8.4.7	<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> <li>1. SR 3.8.4.8 may be performed in lieu of SR 3.8.4.7 once per 60 months.</li> <li>2. This Surveillance shall not be performed in MODE 1, 2, or 3 (not applicable to Division III). However, credit may be taken for unplanned events that satisfy this SR.</li> </ol> <p>-----</p> <p>Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test.</p>	18 months

(continued)

**SURVEILLANCE REQUIREMENTS (continued)**

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.8</p> <p>-----NOTE-----            This Surveillance shall not be performed in MODE 1, 2, or 3 (not applicable to Division III). However, credit may be taken for unplanned events that satisfy this SR.</p> <p>-----</p> <p>Verify battery capacity is <math>\geq 80\%</math> of the manufacturer's rating when subjected to a performance discharge test.</p>	<p>60 months</p> <p><u>AND</u></p> <p>-----NOTE-----            Only applicable when battery shows degradation or has reached 85% of expected life.</p> <p>-----</p> <p>18 months</p>

**SURVEILLANCE REQUIREMENTS (continued)**

<b>SURVEILLANCE</b>		<b>FREQUENCY</b>
<b>SR 3.8.4.6</b>	Verify each battery charger supplies $\geq 300$ amps for chargers 1A and 1B and $\geq 50$ amps for charger 1C at $\geq 130.2$ V for $\geq 8$ hours.	18 months
<b>SR 3.8.4.7</b>	<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> <li>1. SR 3.8.4.8 may be performed in lieu of SR 3.8.4.7 once per 60 months.</li> <li>2. This Surveillance shall not be performed in MODE 1, 2, or 3 (not applicable to Division III). However, credit may be taken for unplanned events that satisfy this SR.</li> </ol> <p style="text-align: center;">-----</p> <p>Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test.</p>	18 months

(continued)

**SURVEILLANCE REQUIREMENTS (continued)**

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.8</p> <p style="text-align: center;">-----NOTE-----</p> <p>This Surveillance shall not be performed in MODE 1, 2, or 3 (not applicable to Division III). However, credit may be taken for unplanned events that satisfy this SR.</p> <p style="text-align: center;">-----</p> <p>Verify battery capacity is <math>\geq 80\%</math> of the manufacturer's rating when subjected to a performance discharge test.</p>	<p>60 months</p> <p><u>AND</u></p> <p style="text-align: center;">-----NOTE-----</p> <p>Only applicable when battery shows degradation or has reached 85% of expected life.</p> <p style="text-align: center;">-----</p> <p>18 months</p>