



GARY R. PETERSON
Vice President
McGuire Nuclear Station

Duke Power
MG01VP / 12700 Hagers Ferry Road
Huntersville, NC 28078-9340

704 875 5333
704 875 4809 fax
grpeters@duke-energy.com

August 9, 2004

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: Duke Energy Corporation (Duke)
McGuire Nuclear Station Units 1 and 2
Docket Nos. 50-369 and 50-370
Relief Requests (RR) 04-MN-02, 04-MN-03,
and 04-MN-04

Pursuant to 10 CFR 50.55a(a)(3), Duke requests approval to use alternatives to Section XI of the ASME Boiler and Pressure Vessel Code (Code). Compliance with the specified requirements of this section would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety. However, the proposed alternatives will provide an acceptable level of quality and safety. Specific details are described in the attached relief requests.

Questions on this matter should be directed to Norman T. Simms, McGuire Regulatory Compliance, at (704) 875-4685.

Sincerely,

G.R. Peterson

Attachments

A047

U.S. Nuclear Regulatory Commission

August 9, 2004

Page 2

cc w/attachments:

Mr. W.D. Travers
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303

Mr. J.J. Shea, Project Manager (addressee only)
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 08 H12
11555 Rockville Pike
Rockville, MD 20852-2738

Mr. J.B. Brady
Senior NRC Resident Inspector
McGuire Nuclear Station

bxc w/o attachments:

N.T. Simms
R. Branch (MG01WC)
G.J. Underwood (EC05A)
D.E. Caldwell (MG01WC)
R.K. Rhyne (EC05A)
J.J. Mc Ardle (EC05A)
J.F. Swan (MG01WC)
K.L. Crane

bxc w/attachments:

NRIA File/ELL
Master File # 1.3.2.13

ATTACHMENT 1

Relief Request 04-MN-002

**Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality**

Duke Energy Corporation

McGuire Nuclear Station – Unit 1 (EOC-15), Examination Dates April 18, 2001 To October 10, 2002

Third 10-Year Interval – Inservice Inspection Plan

Interval Start Date December 1, 2001. Interval End Date December 1, 2011

ASME Section XI Code – 1995 Edition with 1996 Addenda and * Westinghouse Owner’s Group (WCAP-14572)

Limitation I.D. Number	I. System / Component for Which Relief is Requested: Area or Weld to be Examined	II. & III. Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage	IV. Basis for Relief	V. Alternate Examinations or Testing	VI. Justification for the Granting of Relief	VII. Implementation Schedule
ICCPUMP-1A-LEG	1A Centrifugal Charging Pump Support Legs (Integrally Welded Attachment)	Exam Category C-C Item No. C03.030.001 Fig. IWC-2500-5 (a) 77.74% Surface Area Coverage	See Paragraph “A” also (See Attachment 1 Pages 1-5)	None	See Paragraph “C” also (See Attachment 1 Pages 1-5)	The examination requirements for this interval were met; no additional exams are planned.
IRPV1-462C-SE	NI Safety Injection System Reactor Vessel Head to Upper Head Injection Tube Weld	Exam Category R-A (RI-ISI Program) Item No.R01.011.026 Fig. IWB-2500-8(c) Appendix III,III-4420 and III-4430 74.62% Volume Coverage	See Paragraph “B” also (See Attachment 2 Pages 1-5)	None	See Paragraph “D” also (See Attachment 2 Pages 1-5)	The examination requirements for this interval were met; no additional exams are planned.

*** Piping welds examined under the RI-ISI program developed in accordance with methodology contained in the Westinghouse Owner’s Group (WOG) Topical Report, WCAP-14572, Revision 1-NPA and Request for Relief 01-005 approved by SER dated June 12, 2002.**

Note: Item Number C03.030.001 was examined on 09/10/2002 and R01.011.026 was examined on 09/23/2002.

Basis for Relief

Paragraph: A

(The 1A Centrifugal Charging Pump Support Leg material is stainless steel.)

During the liquid penetrant examination of the welds, 100% coverage of the required surface examination area could not be obtained. The examination coverage was limited to 77.74%. The limitations were caused by the geometric configuration of the support legs restricting access for complete examination coverage. No recordable indications were found during the surface examination of this weld.

Paragraph: B

(The Upper Head Injection Tube Weld material is carbon steel and inconel. The weld has a diameter of 6.250" and a wall thickness of .625".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 74.62%. This percentage represents the aggregate coverage from all scans. A 45 degree longitudinal wave axial scan from the pipe side covered 92.31% of the examination volume from one direction. Two opposing circumferential scans using 45 degree shear waves covered 73.85% and a 45 degree longitudinal wave axial scan from the vessel side covered 58.46% of the required volume from one direction. In order to achieve greater than 90% coverage from two beam path directions, axially and circumferentially, the weld would have to be re-designed to allow scanning from both sides which is impractical. No recordable indications were found during the volumetric examination of this weld.

Justification for Relief

Paragraph: C

Although the examination surface area as defined in ASME Section XI 1995 Edition with 1996 Addenda, Figure IWC-2500-5 (a) could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. The code required surface (PT) examination was the only examination performed for this item. The liquid penetrant examination was performed in accordance with ASME Section V Article 6, 1989 Edition with no addenda. No additional C3.30 (Pump Integrally Welded Attachments) welds were scheduled during this outage.

This is an Integrally Welded Attachment located on the 1A Centrifugal Charging Pump Support Legs ICCPUMP-1A-LEG. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation.

A leak at this weld would likely result in abnormal Volume Control Tank (VCT) level trends and/or unexpected auto make-ups.

A leak at this weld would likely result in an increase in unidentified reactor coolant leakage. Such a leak would be discovered during performance of the reactor coolant leakage calculation,

which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm. Any increased reactor coolant leakage identified by the calculation would make Duke suspect either the operating or idle CCP, especially if a recent train swap has occurred (normally biweekly). To evaluate either of these indicators an operator would be dispatched to the pump rooms, which would identify any leakage from this weld.

Also, operators perform surveillance once per shift during daily rounds of the room containing the 1A CCP. This surveillance should identify any leak at the weld in question.

Paragraph: D

Although the examination volume as defined in the Risk Informed program and WCAP-14572 Revision 1, Figure IWB-2500-8(c), Table 4.1.1 (Examination Category R-A, Risk Informed Piping Examinations) could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures in accordance with Section XI, Appendix III 1995 Edition with the 1996 Addenda. This is a Dissimilar Metal Weld limited due to material characteristics and single sided access caused by component geometry which prevents two-beam path direction coverage of the examination volume. In order to obtain greater than 90% coverage, this weld would have to be re-designed to allow scanning from both sides. Replacement or re-design of this Class 1 weld is not a viable alternative and would create an undue burden on Duke Energy Corporation. During the examination of this weld, techniques were utilized to obtain the maximum possible coverage. Beginning in 1990 Duke Energy Corporation changed to refracted longitudinal wave search units to examine Dissimilar Metal Welds based upon NRC Information Notice 90-30, "Ultrasonic Inspection Techniques for Dissimilar Metal Welds". The procedure used complied with the requirements of ASME Section XI, Appendix III. The procedure required the use of refracted longitudinal waves to examine the weld and buttered material and shear waves to examine the wrought nozzle and safe base materials. The code required volumetric (UT) examination was the only examination performed for this item. No additional R01.011. (RPV Head to UHI Tube) welds were scheduled during this outage. However three additional (RPV Head to UHI Tube) welds were examined by volumetric (UT) under the station augmented program (G04.001). No recordable conditions were found during the examination of these welds.

The reactor coolant system weld listed above is located on the reactor vessel closure head. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. This weld was rigorously inspected by radiography and dye penetrant during construction and verified to be free from unacceptable fabrication defects. If a leak were to occur at this weld, the reactor coolant leakage calculation which is normally performed daily (and required by Technical Specifications to be performed every 72 hours) would provide an early indication of leakage. The unidentified leakage specification in Technical Specification 3.4.13.1 is 1 gpm. Several other indicators, such as, containment radiation monitors EMF-38, 39 and 40; the containment floor and equipment sump levels; containment humidity instruments; and the ventilation unit condensate drain tank

level would provide an early indication of weld leakage for prompt Operations and Engineering evaluation.

Jim McArdle and Tim Tucker (NDE Level III's) provided Sections II through V and part of Section VI

Ed Hyland, (MNS Systems Engineer) provided part of Section VI

Gary Underwood (Sponsor) compiled the remaining sections

Attachment 1 PT Examination Data C03.030.001

Attachment 2 UT Examination Data R01.011.026

Sponsored By: Gary Underwood Date 6-29-04

Approved By: L. Kevin Rhysse Date 6/29/04

DUKE POWER COMPANY
STATION McGuire UNIT 1
LIQUID PENETRANT EXAMINATION REPORT

Weld/ID No. 1CCPUMP-1A-LEG Material Type: SS CS Inconel
 Diameter 0 Schedule/Thickness /0 ISI PSI Other
 Procedure Rev. No. 19 Field Change No.(s) N/A

W/O No. 98438548-28
 Surface Temperature 86° F
 M&TE S/N MCNDE 27220

SKETCH OF ITEM EXAMINED

Penetrant Materials Category:
 A A(SE) B C D
 A(SE) Approved _____

Penetrant Materials Data:
 Batch Numbers
 Cleaner 01G12K
 Penetrant 97A10K
 Developer 02B03K
 Emulsifier _____
 Fluorescent Nonfluorescent

Black Light Intensity Verified
 Time _____ Date _____
 Light Meter S/N: _____

Acceptance Standard: A D G K
 Other: B E H L
 C F J M

Ind. No.	Indication Type/Dimensions	Reference Documents	Recordable	Reportable
NRI				

PIP S/N: N/A Rejectabl Acceptable

Exam Limitations: Yes 77.74 % Examined No (100% Examined)

Comments:

Examiner: David Zimmerman *David Zimmerman* Level: II Date: 9/10/2002

Examiner: James L. Panel *James L. Panel* Level: II Date: 9/10/2002

Reviewed By: *[Signature]* Level: II Date: 9/17/02

Final Review <i>[Signature]</i>	Date <u>9/19/2002</u>	ANII Review <i>[Signature]</i>	Date <u>9-19-02</u>	Item No. C03.030.001
------------------------------------	--------------------------	-----------------------------------	------------------------	-------------------------

R. Geis 9/26/02

DUKE POWER COMPANY
Limited Examination Coverage Worksheet

NDE-91-1

Revision 0

Examination Volume/Area Defined

Base Metal Weld Near Surface Boltina Inner Radius

Area Calculation

Volume Calculation

138.5 in. of weld length X 2.4 in. wide inspection area =
 332.4 sq. in. total weld area.

Coverage Calculations

Scan #	Angle	Beam Direction	WIDTH Area of Examined (sq.in.)	Length Examined (in.)	AREA Volume of Examined (cu.in.)	AREA Volume of Required (cu.in.)	Percent Coverage
N/A	N/A	N/A	2.4	107.5	258	332.5	
N/A	N/A	N/A	1.9	14.0	26.6	33.6	
					284.6	366.1	77.74

Item No: C03.030.001

Prepared By: David K. Zimmerman

Level: II

Date: 9/10/2002

Reviewed By:

Level: II

Date: 9/17/02

R
9-19-02
 04-MN-002
 Attachment-1
 PAGE 2 OF 5


R
9/10/02

Subject ICCPUMP - A-LEG

By Tommy J. Faneal Date 9/10/2002

Prob No. ITEM# C03.030.001

Checked By David K. Z. Date 9/10/2002



R
11/20/02
8/19/02




PAGE 3 OF 3
II 9/11/02
WELD-SHADED AREA
"NOT TO SCALE"
04-MN-002
ATTACHMENT-1
Page 3 of 5

- FA COUPLING - KOPPERS FAST'S TYPE FS NO. 2, BALANCED, SPACER & GUARD.
- FS COUPLING - KOPPERS FAST'S MODEL B' NO. 3 1/2 L.E.F. & GUARD (SEE NOTE 1)
- AP AUXILIARY LUBE OIL PUMP, BROWN & SHARPE MODEL 35, 2 HP., 60 CYCLES, 3/4" I.D., 575 VOLTS, FRAME 145T
- LG LIFTING LUG - 4 PLACES 1/2" DIA. HOLE.
- OC OIL COOLER - AM. STD. SEE OC030 SELF-C., ASME SEC. III CLASS 3.

QA CONDITION 1

See coupling data sheets.


- NOTES:-
- 1- THIS COUPLING HAS LIMITED END FLOAT (L.E.F.) TO PREVENT MOTOR SHAFT THRUST COLLAR FROM CONTACTING & DAMAGING MOTOR SLEEVE BEARINGS. TO POSITION MOTOR, PULL SHAFT ALL THE WAY TOWARD DRIVEN EQUIPMENT UNTIL THRUST COLLAR CONTACTS BEARING & MOVE BACK 1/8" MARK AND BORE ON SHAFT AND, HOLDING THIS POSITION, MOVE MOTOR FRAME UNTIL MOTOR SHAFT CONTACTS DRIVEN EQUIPMENT'S SHAFT SPACER DIFFERENTIAL.
 - 2- MECHANICAL SEAL FLUSHING LINE FROM SEAL PLATE THRU LOOPED TUBING BACK TO SEAL PLATE FURNISHED BY P.P. SEE DWG SF-48582
 - 3- COOLING WATER DATA FORT:
 - (1) GEAR OIL COOLER: 8 GPM OF BRACKISH WATER @ 100°F MAX. TO PROVIDE 1UX" OF 350 BTU/MIN. COOLING. PRESSURE DROP 1 PSI.
 - (2) LUBE OIL COOLER: OC: 80 GPM OF BRACKISH WATER @ 100°F MAX. TO PROVIDE 1UX" OF 763 BTU/MIN. COOLING. PRESSURE DROP 1 PSI.
 - (3) MOTOR HEAT EXCHANGERS:
 - WATER FLOW FOR EACH EXCHANGER - 15 GPM
 - WATER TEMPERATURE - 95°F. MAX.
 - NOMINAL INLET PRESSURE - 100 PSIG.
 - SEE DWG CN-48582 FOR DETAIL OF OIL COOLERS
 - COOLING WATER PIPING FURNISHED BY PACIFIC PUMP
 - SERVICE WATER IS SUPPLIED TO & REMOVED FROM COOLERS BY CONNECTIONS J-41 & J-41.




SUPPORT LEG

SUPPORT LEG

04-MN-002
ATTACHMENT
Page 4 of 5



Support LEG



Support LEG

DUKE POWER COMPANY						Exam Start: 0510	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 0553	Revision 4
Station: McGuire	Unit: 1	Component/Weld ID: 1RPV1-462C-SE				Date: 09/23/2002	
Weld Length (in.): 19.6	Surface Condition: AS GROUND		Lo: N/A		Surface Temperature: 75 ° F		
Examiner: James L. Panel <i>James L. Panel</i>	Level: II		Scans:			Pyrometer S/N: MCNDE 27221	
Examiner: Gary J. Moss <i>Gary J. Moss</i>	Level: II		45 <input checked="" type="checkbox"/> 59.5 dB 70 <input type="checkbox"/> _____ dB			Cal Due: 01/22/2003	
Procedure: NDE-310	Rev: 0	FC: N/A	45T <input checked="" type="checkbox"/> 48.0 dB 70T <input type="checkbox"/> _____ dB			Configuration: CIRC. WELD	
Calibration Sheet No: 0201036, 0201038			60 <input type="checkbox"/> _____ dB			S2 Flow S1	
			60T <input type="checkbox"/> _____ dB			UHI TUBE to HEAD	
			Other: _____ dB			Scan Surface: OD	
						Applies to NDE-680 only	
						Skew Angle: N/A	

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	45°														

Remarks:				<i>OK 10/1/02</i>			
Limitations: (see NDE-UT-4) <input type="checkbox"/>		90% or greater coverage obtained: yes <input checked="" type="checkbox"/> no <input checked="" type="checkbox"/>		Sheet 1 of 4			
Reviewed By: <i>[Signature]</i>	Level: III	Date: 10/1/02	Authorized Inspector: <i>[Signature]</i>	Date: 10-2-02	Item No: R01.011.026		

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 1RPV1-462C-SE

Item No: R01.011.026

Remarks:

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L 0+0" to L 0+20" INCHES FROM WO C/L + 0.7" to BEYOND
 ANGLE: 0 45 60 Other _____ FROM _____ DEG to _____ DEG

RPV HEAD CONFIGURATON

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 Other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 Other _____ FROM _____ DEG to _____ DEG

NO SCAN SURFACE BEAM DIRECTION
 LIMITED SCAN 1 2 1 2 cw ccw
 FROM L _____ to L _____ INCHES FROM WO _____ to _____
 ANGLE: 0 45 60 Other _____ FROM _____ DEG to _____ DEG

Prepared By: Gary J. Moss *Gary J. Moss* Level: II Date: 9/23/2002 Sketch(s) attached yes no Sheet 2 of 4

Reviewed By: *[Signature]* III Date: 10/1/02 Authorized Inspector: *[Signature]* Date: 10-2-02

9/21/02

04-MN-002
Attachment-1
Page 2 of 5

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0


Examination Volume/Area Defined				
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
3.1" x 0.21" = 0.65 sq. in.	0.65 sq. in. x 20" = 13 cu. in.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45°	S1	0.60	20	12	13	92.31
2	45°	S2	0.38	20	7.6	13	58.46
3	45°	CW	0.48	20	9.6	13	73.85
4	45°	CCW	0.48	20	9.6	13	73.85
		Total	Aggregate	Coverage	38.8	52	74.62


Prepared By: Jay Eaton	Level: III	Date: 10/3/2002	Item No: R01.011.026
Reviewed By: <i>James J. McQuilley</i>	Level: III	Date: 10-3-02	

[Handwritten initials and marks]



Component ID/Weld No. 1 RPV-462C-SE

: Remarks: RPV HEAD TO UHI PIPE




Item No: 201.011.026

Examiner:	Level: III	Date: 10/3/02
Reviewed By: James J. McCuller	Level: III	Date: 10-3-02
Authorized Inspector: Rob Stein		Date: 10-8-02

DETAIL - C
SCALE 4:1

04-MN-002
ATTACHMENT-2
Page 5 of 5



WELD BUILD-UP IN HEAD TO BE OF SUFFICIENT DEPTH TO PREVENT LAMINAR TEARING

RO1-011-026

G OF DATUM-G (SST PART)

6.250 ± .010 DIA

.375 R MIN
INCONEL BUTTERING

STAINLESS STEEL CLAD

.75 R MIN

1.00 REF

INCONEL CLAD

5.000 ± .010 DIA

90° ± 10°

.156 MIN

⊕ X | Y | DIA

THIS DWG TO BE USED FOR BIDDING PURPOSES

± .001/FT

SEE MCFL-1N138 UNIT 1 PIPE CAPPED 5.000 ± .010 DIA HERE

INCONEL

LOW ALLOY WELD METAL

- IRPVI-462A-SEC(0°)
- IRPVI-462B-SEC(90°)
- IRPVI-462C-SEC(180°)
- IRPVI-462D-SEC(270°)

SEE ISO 1N138

APPROVED
 THE APPROVAL OF THE DESIGNER IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE VESSEL AS SHOWN ON THIS DRAWING. THE DESIGNER IS NOT RESPONSIBLE FOR THE OPERATION OF THE VESSEL OR FOR THE RESULTS OF THE OPERATION OF THE VESSEL.
 DUKES POWER COMPANY
 11111 11111 11111

RECEIVED
 JUN 21 1973
 DUKES POWER COMPANY
 DESIGN ENGINEERING

PLANT _____
 UNIT _____
 STATUS _____
 CERTIFICATE NO. _____
 APPROVED _____

SECTION D-D
AUXILIARY HEAD ADAPTER
SCALE 1:2

RISK-INFORMED SEGMENT INC-089

MN 1201-01-113

UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN INCHES AND DECIMALS THEREOF.
 SEE PROCESS SPECIFICATION NO. CA-001 FOR FURTHER INFORMATION.
 11111 11111 11111

ATTACHMENT 2

Relief Request 04-MN-003

**Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality**

Duke Energy Corporation

McGuire Nuclear Station – Unit 2 (EOC-14), Examination Dates October 14, 2000 To March 27, 2002

Second 10-Year Interval – Inservice Inspection Plan

ASME Section XI Code – 1989 Edition with No Addenda

Interval Start Date 03/01/1994 Interval End Date 03/01/2004

Code Case N-460 is applicable.

Limitation I.D. Number	I. System / Component for Which Relief is Requested: Area or Weld to be Examined	II. & III. Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage	IV. Basis for Relief	V. Alternate Examinations or Testing	VI. Justification for the Granting of Relief	VII. Implementation Schedule
2SGA-INLET-W5SE	NC System 2A Steam Generator Inlet Nozzle to Safe End	Exam Category B-F Item No. B05.070.001 Fig. IWB-2500-8 75.00% Volume Coverage	See Paragraph "A" See Attachment I Pages 1-4	None	See Paragraph "J" See Attachment I Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.
2SGA-OUTLET-W6SE	NC System 2A Steam Generator Outlet Nozzle to Safe End	Exam Category B-F Item No. B05.070.002 Fig. IWB-2500-8 75.00% Volume Coverage	See Paragraph "A" See Attachment IA Pages 1-4	None	See Paragraph "J" See Attachment IA Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.
2SGD-INLET-W5SE	NC System 2D Steam Generator Inlet Nozzle to Safe End	Exam Category B-F Item No. B05.070.007 Fig. IWB-2500-8 75.00% Volume Coverage	See Paragraph "A" See Attachment IB Pages 1-4	None	See Paragraph "J" See Attachment IB Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.

Inspection Dates for Item Numbers

B05.070.001	03/09/2002	B09.011.013	03/14/2002
B05.070.002	03/09/2002	B09.011.018	03/14/2002
B05.070.007	03/08/2002	B09.011.169	03/14/2002
B05.070.008	03/08/2002	C03.030.001	02/19/2002
B08.020.001A	03/05/2002		
B09.011.009	02/26/2002		
B09.011.011	03/13/2002		
B09.011.011A	03/03/2002		
B09.011.012	03/14/2002		

**Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality**

**Duke Energy Corporation
McGuire Nuclear Station – Unit 2 (EOC-14)
Second 10-Year Interval – Inservice Inspection Plan
ASME Section XI Code – 1989 Edition with No Addenda**

Limitation I.D. Number	I. System/ Component for Which Relief is Requested: Area or Weld to be Examined	II. & III. Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage	IV. Basis for Relief	V. Alternate Examinations or Testing	VI. Justification for the Granting of Relief	VII. Implementation Schedule
2SGD- OUTLET- W6SE	NC System 2D Steam Generator Outlet Nozzle to Safe End	Exam Category B-F Item No. B05.070.008 Fig. IWB-2500-8 75.00% Volume Coverage	See Paragraph "A" See Attachment 1C Pages 1-4	None	See Paragraph "J" See Attachment 1C Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.
2PZR-SKIRT	NC System Pressurizer Support Skirt to Lower Head (Integral Attachment)	Exam Category B-H Item No. B08.020.001A Fig. IWB-2500-13 75.16% Volume Coverage	See Paragraph "B" See Attachment 2 Pages 1-9	None	See Paragraph "K" See Attachment 2 Pages 1-9	The examination requirements for this interval were met; no additional exams are planned.
2NCW-3673-1	NC System B Loop Cold Leg (Pipe to Elbow near RV Inlet Nozzle)	Exam Category B-J Item No. B09.011.009 Fig. IWB-2500-8 79.01% Volume Coverage	See Paragraph "C" See Attachment 3 Pages 1-4	None	See Paragraph "L" See Attachment 3 Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.
2NC2FW2-1	NC System 14" Pipe to Pipe Weld on Pressurizer Surge Line (Stress Weld)	Exam Category B-J Item No. B09.011.011 Fig. IWB-2500-8 72.73% Volume Coverage	See Paragraph "D" See Attachment 4 Pages 1-3	None	See Paragraph "M" See Attachment 4 Pages 1-3	The examination requirements for this interval were met; no additional exams are planned.
2NC2FW2-1	NC System 14" Pipe to Pipe Weld on Pressurizer Surge Line (Stress Weld)	Exam Category B-J Item No. B09.011.011A Fig. IWB-2500-8 81.82% Surface Area Coverage	See Paragraph "D" See Attachment 4A Pages 1-2	None	See Paragraph "M" See Attachment 4A Pages 1-2	The examination requirements for this interval were met; no additional exams are planned.
2NC2FW22-6	NC System B Loop Cold Leg 10" Elbow to Nozzle Weld	Exam Category B-J Item No. B09.011.012 Fig. IWB-2500-8 61.09% Volume Coverage	See Paragraph "E" See Attachment 5 Pages 1-5	None	See Paragraph "N" See Attachment 5 Pages 1-5	The examination requirements for this interval were met; no additional exams are planned.

**Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality**

**Duke Energy Corporation
McGuire Nuclear Station – Unit 2 (EOC-14)
Second 10-Year Interval – Inservice Inspection Plan
ASME Section XI Code – 1989 Edition with No Addenda**

Limitation I.D. Number	I. System / Component for Which Relief is Requested: Area or Weld to be Examined	II. & III. Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage	IV. Basis for Relief	V. Alternate Examinations or Testing	VI. Justification for the Granting of Relief	VII. Implementation Schedule
2NC2FW22-9	NC System C Loop Cold Leg 10" Pipe to Nozzle Weld	Exam Category B-J Item No. B09.011.013 Fig. IWB-2500-8 61.09% Volume Coverage	See Paragraph "F" See Attachment 6 Pages 1-5	None	See Paragraph "O" See Attachment 6 Pages 1-5	The examination requirements for this interval were met; no additional exams are planned.
2NC2FW16-6	NC System A Loop Hot Leg 6" Elbow to Nozzle Weld	Exam Category B-J Item No. B09.011.018 Fig. IWB-2500-8 59.09% Volume Coverage	See Paragraph "G" See Attachment 7 Pages 1-4	None	See Paragraph "P" See Attachment 7 Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.
2NI2F871	NI System 6" Elbow to Pipe Weld	Exam Category B-J Item No. B09.011.169 Fig. IWB-2500-8 59.09% Volume Coverage	See Paragraph "H" See Attachment 8 Pages 1-4	None	See Paragraph "Q" See Attachment 8 Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.
2CCPUMP-2A-LEG	2A Centrifugal Charging Pump Support Legs (Integrally Welded Attachment)	Exam Category C-C Item No. C03.030.001 Fig. IWC-2500-5 82.65% Surface Area coverage	See Paragraph "I" See Attachment 9 Pages 1-4	None	See Paragraph "R" See Attachment 9 Pages 1-4	The examination requirements for this interval were met; no additional exams are planned.

IV. Basis for Relief

Paragraph: A

(The Steam Generator Inlet and Outlet Nozzle to SE material is stainless steel to carbon steel. The weld has a diameter of 31.00" with a wall thickness of 2.500".)

During the ultrasonic examination of the welds, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 75.00% for all four welds. The percentage of coverage reported represents the aggregate coverage obtained by each scan. A 45 degree scan was performed from the safe end side of the weld achieving 100% coverage from one axial direction, and a 45 degree scan in two opposing circumferential directions achieved 100% coverage. The nozzle configuration allows scanning from only the safe end side of the weld. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible. In order to achieve more coverage, the nozzles would have to be re-designed to allow scanning from both sides of the weld.

The Steam Generator Nozzle-to-Safe End welds were examined to the maximum extent practical using ultrasonic techniques in accordance with the requirements of ASME Section XI, Appendix III of the 1989 Edition. No recordable indications were found during the volumetric and surface examinations of these welds.

Paragraph: B

(The Pressurizer Support Skirt material is carbon steel. The weld diameter is 87.00" with a wall thickness of 1.500".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume in four orthogonal directions could not be obtained. The examination coverage was limited to 75.16%. The percentage of coverage reported represents the aggregate coverage obtained by each scan. The entire examination volume was covered 100% from at least one axial and one circumferential direction. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible. The examination procedure and calibration block was in accordance with ASME Section XI, Appendix I and ASME Section V, Article 5 1989 Edition.

A recordable indication was found during the volumetric examination of this weld. The recordable indication was determined to be a Geometric Reflector. This weld was determined to be acceptable after NDE evaluation.

Paragraph: C

(The B Loop Cold Leg material is stainless steel. The weld diameter is 27.500" and the wall thickness is 2.000".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 79.01%. Limitations are caused by cast austenitic weld metal characteristics and single sided access caused by the location of pipe restraints preventing two-beam path direction coverage of the examination volume. The percentage of coverage reported represents the aggregate coverage obtained by each scan. A 45 degree scan was performed from one side of the weld achieving 100% coverage from one axial direction, and a 45 degree scan in two opposing circumferential directions achieved 100% coverage. An additional 4% was achieved from the restraint side of the weld. The proximity of the restraint limits scanning from two opposing axial directions. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible.

No recordable indications were found during the volumetric and surface examination of this weld.

The most effective ultrasonic technique for the examination of welds in cast austenitic piping uses refracted longitudinal waves. The longitudinal wave is preferred as the austenitic weld metal and buttering create highly attenuative barriers to shear wave ultrasound. The longitudinal wave is less affected by these difficulties. However, the longitudinal wave is affected by mode conversion when it strikes the inside surface of the safe end or pipe at any angle other than a right angle to the surface.

The calculations below show that a 45⁰ refracted longitudinal wave striking the inside surface of a pipe will produce a 22.9⁰ refracted shear wave in addition to the normally expected 45⁰ reflected longitudinal wave.

$$\begin{aligned}\sin^{-1} &= (\sin 45^{\circ} \times V_s) \div V_L \\ &= (0.707 \times 0.123) \div 0.223\end{aligned}$$

Where: \sin^{-1} is the shear wave angle

V_s is the shear wave velocity of the stainless steel safe end/pipe material in inches / μ sec.


V_L is the longitudinal wave velocity of the stainless steel safe/pipe end material in inches/ μ sec.

As shown in the graph below, the mode conversion process creates two sound beams of differing intensities reflecting off the inside surface¹. At incident angles greater than 30 degrees, the shear wave will predominate. However, the shear wave is attenuated and scattered by the cast austenitic material. The examination sensitivity is degraded to such an extent that any examination using the second sound path leg is meaningless. Therefore, the two-beam path direction coverage requirement is impractical.

In order to obtain the required two-beam path direction coverage, the pipe restraints would have to be re-located to allow scanning from both sides.

¹Firestone, F.A.: Tricks with the Supersonic Reflectoscope, J. Soc. Nondestructive Testing, vol. 7, no. 2 Fall 1948.

Reflected Sound Beam Energy In Steel on A Free Face



Paragraph: D

(The Pressurizer Surge Line material is stainless steel. The weld diameter is 14.00" and the wall thickness is 1.406".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 72.73%. Limitations are caused by austenitic weld metal characteristics and single sided access caused by the location of rigid restraints which prevents scanning of the weld from two opposing sides. The percentage of coverage reported represents the aggregate coverage obtained by each scan. A 60 degree scan was performed from one side of the weld achieving 100% coverage from one axial direction, and a 45 degree scan in two opposing circumferential directions achieved 100% coverage. An additional 4% was achieved from the restraint side of the weld. The proximity of the restraint limits scanning from two opposing axial directions. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible. In order to achieve more coverage, the restraint would have to be moved to allow scanning from both sides of the weld.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. Refracted longitudinal waves provide better penetration but cannot be used beyond the first sound path leg. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds.

During the Liquid Penetrant examination for this same weld the required surface examination area could not be obtained. The examination coverage was limited to 81.82%. The Liquid Penetrant exam limitations were caused by the close proximity of a pipe support/restraint that obstructed a portion of the weld and adjacent base metal in two locations.

No recordable indications were found during the volumetric and surface examination of this weld.

Paragraph: E

(The Elbow to Nozzle material is stainless steel. The weld diameter is 10.00" and the wall thickness is 1.000".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 61.09%. The reported percent of coverage represents the aggregate coverage from all scans performed on the weld. A 60 degree shear wave scan was performed from the elbow side of the weld achieving 44.3% coverage of the examination volume from one axial direction and a 45 shear wave degree scan in

two opposing circumferential directions achieved 100% coverage. A supplemental axial scan from the elbow side using a 60 degree refracted longitudinal wave search unit covered 100% of the weld metal and far side base material. Limitations are caused by austenitic weld metal characteristics and single sided access due to the proximity of the nozzle which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. Refracted longitudinal waves provide better penetration but cannot be used beyond the first sound path leg. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds.

No recordable indications were found during the volumetric and surface examination of this weld.

Paragraph: F

(The pipe to nozzle material is stainless steel. The weld diameter is 10.000" and the wall thickness is 1.000".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 61.09%. The reported percent of coverage represents the aggregate coverage from all scans performed on the weld. A 60 degree shear wave scan was performed from the elbow side of the weld achieving 44.3% coverage of the examination volume from one axial direction and a 45 degree shear wave scan in two opposing circumferential directions achieved 100% coverage of the weld base material. A supplemental axial scan from the elbow side using a 60 degree refracted longitudinal wave search unit covered 100% of the weld metal and far side base material. Limitations are caused by austenitic weld metal characteristics and single sided access due to the proximity of the nozzle which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. Refracted longitudinal waves provide better penetration but cannot be used beyond the first sound path leg. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in

the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds.

No recordable indications were found during the volumetric and surface examination of this weld.

Paragraph: G

(The elbow to nozzle material is stainless steel. The weld diameter is 6.000" and the wall thickness is .719".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 59.09%. The reported percent of coverage represents the aggregate coverage from all scans performed on the weld. A 60 degree shear wave scan was performed from the elbow side of the weld achieving 36.36% coverage of the examination volume from one axial direction and a 45 degree shear wave scan in two opposing circumferential directions achieved 100% coverage of the weld and base material. A supplemental axial scan from the elbow side using a 60 degree refracted longitudinal wave search unit covered 100% of the weld metal and far side base material. Limitations are caused by austenitic weld metal characteristics and single sided access due to the proximity of the nozzle which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. Refracted longitudinal waves provide better penetration but cannot be used beyond the first sound path leg. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds.

No recordable indications were found during the volumetric and surface examination of this weld.

Paragraph: H

(The elbow to pipe material is stainless steel. The weld diameter is 6.000" and the wall thickness is .719".)

During the ultrasonic examination of the weld, 100% coverage of the required examination volume could not be obtained. The examination coverage was limited to 59.09%. The reported percent of coverage represents the aggregate coverage from all scans performed on the weld. A 60 degree shear wave scan was performed from the elbow side of the weld achieving 36.36% coverage of the examination volume from one axial direction and a 45 degree shear wave scan in two opposing circumferential directions achieved 100% coverage of the weld and base material. A supplemental axial scan from the elbow side using 60 degree refracted longitudinal wave search unit covered 100% of the weld metal and far side base material. Limitations are caused by austenitic weld metal characteristics and single sided access due to the elbow configuration and the proximity of an adjacent weld which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. Refracted longitudinal waves provide better penetration but cannot be used beyond the second sound path leg. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds.

No recordable indications were found during the volumetric and surface examination of this weld.

Paragraph: I

(The support leg material is stainless steel.)

During the Liquid Penetrant examination of the weld, 100% coverage of the required surface examination area could not be obtained. The examination coverage was limited to 82.65%. The limitations were caused by the geometric configuration of the support legs restricting access for complete examination coverage.

No recordable indications were found during the surface examination of this weld.

VI. Justification for Relief

Paragraph: J

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. These welds were examined using procedures in accordance with ASME Section XI, Appendix III. Ultrasonic examination personnel are qualified in accordance with ASME Section XI, Appendix VII 1989 Edition.

No additional B05.070 welds were scheduled during this outage.

The 2A Steam Generator Inlet and Outlet Nozzle to Safe End Welds (2SGA-Inlet-W5SE and 2SGA-Outlet-W6SE) and the 2D Steam Generator Inlet and Outlet Nozzle to Safe End Welds (2SGD-Inlet-W5SE and 2SGD-Outlet-W6SE) are part of the NC (Reactor Coolant System) boundary. These welds are not exposed to significant neutron fluence and are not prone to negative material property changes (i.e., embrittlement) associated with neutron bombardment. If a leak were to occur at the welds in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at one of these welds would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased Steam Generator enclosure temperature. This parameter is continuously monitored by the Operations via an Operator Aid Computer (OAC) alarm, and is periodically monitored by the System Engineer.
- c) Increased input into the Ventilation Unit Condensate Drain Tank (VUCDT). This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- d) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- e) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the Steam Generator enclosure or containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk-down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walk down should identify any leak at the weld in question

Paragraph: K

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-13 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity.

There is inadequate accessibility to the inside surface (surface C-D) of the Pressurizer Support Skirt Weld to perform the required surface examination. Therefore, an ultrasonic examination was used to inspect the inner examination surface from the skirt's exterior surface per Relief Request 00-001. For additional information reference NRC letter dated August 23, 2001, Docket Numbers 50-369, 50-370 and Tac Numbers MB 2325 and MB 2326. The ultrasonic procedure and the basic calibration block conformed to the requirements of ASME Section XI, Appendix I, 1989 Edition, and ASME Section V, Article 5, 1989 Edition. Ultrasonic examination personnel were qualified in accordance with ASME Section XI Appendix VII, 1989 Edition.

No additional B08.020 welds were scheduled during this outage.

This weld 2PZR-SKIRT joins the pressurizer support skirt to the pressurizer lower head. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e., embrittlement) associated with neutron bombardment. This weld joins the pressurizer support skirt, a non-pressure boundary component, to the lower pressurizer head. Therefore, the weld serves no pressure boundary function. However, if a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also the Containment Ventilation System Engineer.
- b) Increased Pressurizer enclosure temperature. This parameter is continuously monitored by the Operations via an OAC alarm, and is periodically monitored by the System Engineer.
- c) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- d) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours (McGuire normally performs this calculation every 24 Hrs). The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.

- e) Other indicators such as containment radiation monitors EMF-38, 39, and 40, the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the pressurizer enclosure or containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walk down should identify any leak at the weld in question.

Paragraph: L

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures in accordance with ASME Section XI, Appendix III. Ultrasonic examination personnel are qualified in accordance with ASME Section XI Appendix VII, 1989 Edition.

No additional B09.011 cold leg welds were scheduled during this outage.

This is a Pipe to Elbow Weld 2NCW-3673-1 located on the NC (Reactor Coolant System) B Loop Cold Leg near the Reactor Vessel Inlet Nozzle. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walk down should identify any leak at the weld in question.

Paragraph: M

Although the examination volume and surface area as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was ultrasonically examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI). Liquid penetrant examination was performed in accordance with ASME Section V, Article 6 1989 Edition with no addenda.

No additional B09.011 Pressurizer Surge Line welds were scheduled during this outage.

This is a 14" Pipe to Pipe Weld 2NC2FW2-1 located on the NC (Reactor Coolant System) Pressurizer Surge Line. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walkdown is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph: N

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI).

One additional B09.011, 10.00" weld on the NC System was scheduled during this outage. No recordable indications were found during the volumetric and surface examination of this weld.

This is a 10" Elbow to Nozzle Weld 2NC2FW22-6 located on the NC (Reactor Coolant System) B Loop Cold Leg. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph: O

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI).

One additional B09.011, 10.00" weld on the NC System was scheduled during this outage. No recordable indications were found during the volumetric and surface examination of this weld.

This is a 10" Pipe to Nozzle Weld 2NC2FW22-9 located on the NC (Reactor Coolant System) C Loop Cold Leg. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph: P

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI).

Five additional B09.011, 6.00" welds on the NC System were scheduled and examined during this outage. No recordable indications were found on three of these welds. Recordable indications were found on two of the welds. The indications were determined to be Geometric Reflectors, and were determined to be acceptable after NDE evaluation.

This is a 6" Elbow to Nozzle Weld 2NC2FW16-6 located on the NC (Reactor Coolant System) A Loop Hot Leg. This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph: Q

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI).

Four additional B09.011 welds on the NI System were scheduled and examined during this outage. No recordable indications were found during the volumetric and surface examinations of these welds.

This is a 6" Elbow to Pipe Weld 2NI2F871 located on the NI (Safety Injection System). This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following:

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walk down is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph: R

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWC-2500-5 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. The liquid penetrant examination was performed in accordance with ASME Section V, Article 6, 1989 Edition with no addenda.

No additional C03.030 welds were scheduled during this outage.

This is an Integrally Welded Attachment located on the 2A Centrifugal Charging Pump Support Legs 2CCPUMP-2A-LEG. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation.

- a) A leak at this weld would likely result in abnormal Volume Control Tank (VCT) level trends and/or unexpected auto make-ups.
- b) A leak at this weld would likely result in an increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of the reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm. Any increase reactor coolant leakage identified by the calculation would make suspect either the operating or idle CCP especially if a recent train swap has occurred (normally biweekly). To evaluate

either of these indicators an operator would be dispatched to the pump rooms, which would identify any leakage from this weld.

Also, operators perform surveillance once per shift during daily rounds of the room containing the 2A CCP. This surveillance should identify any leak at the weld in question.

The following individuals contributed to the development of this relief request:

Jim McArdle and Tim Tucker (Principal UT and RT NDE Level III Examiners, respectively) provided Sections II through V and part of Section VI.

Ed Hyland, Bryan Meyer and Larry Kunka (MNS Systems Engineers) provided parts of Section VI.

Gary Underwood (McGuire ISI Plan Manager) compiled the remaining sections.

Sponsored By: Gary Underwood Date 7-12-04

Approved By: R. Kevin Rhyme Date 7/13/04

- | | |
|--------------|--|
| Attachment 1 | UT Examination Data B05.070.001, B05.070.002, B05.070.007, B05.070.008 |
| Attachment 2 | UT Examination Data B08.020.001A |
| Attachment 3 | UT Examination Data B09.011.009 |
| Attachment 4 | UT, PT Examination Data B09.011.011, B09.011.011A respectively |
| Attachment 5 | UT Examination Data B09.011.012 |
| Attachment 6 | UT Examination Data B09.011.013 |
| Attachment 7 | UT Examination Data B09.011.018 |
| Attachment 8 | UT Examination Data B09.011.169 |
| Attachment 9 | PT Examination Data C03.030.001 |

DUKE POWER COMPANY						Exam Start: 1001	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 1026	Revision 4
Station: McGuire	Unit: 2	Component/Weld ID: 2SGA-INLET-W5SE				Date: 3/9/2002	
Weld Length (in.): 119.4	Surface Condition: AS MACHINED		Lo: RT "0"		Surface Temperature: <u>78</u> ° F		
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i>	Level: II		Scans:		Pyrometer S/N: <u>MCNDE 27228</u>		
Examiner: <i>Gary Moss</i>	Level: II		45 <input type="checkbox"/> _____ dB 70 <input type="checkbox"/> _____ dB		Cal Due: <u>7/3/2002</u>		
Procedure: NDE-930 Rev: 1	FC: 02-04		45T <input checked="" type="checkbox"/> <u>73**</u> dB 70T <input type="checkbox"/> _____ dB		Configuration: <u>CIRC.</u>		
Calibration Sheet No: 0202056		60 <input type="checkbox"/> _____ dB		60T <input type="checkbox"/> _____ dB		<u>S1</u> Flow <u>S2</u> Safe End to Nozzle Scan Surface: OD Applies to NDE-680 only Skew Angle: <u>N/A</u>	
		Other: <u>33° @ 54dB</u> dB					

IND #	4	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	33°															
NRI	45°															

Remarks: ** SCANNED AT 69dB DUE TO NOISE			
Limitations: (see NDE-UT-4) <input checked="" type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>			Sheet <u>1</u> of <u>4</u>
Reviewed By: <i>[Signature]</i>	Level: <u>III</u>	Date: <u>3/11/02</u>	Authorized Inspector: <i>[Signature]</i> Date: <u>3-13-02</u> Item No: B05.070.001

3/13/02

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2SGA-INLET-W5SE		Item No: B05.070.001	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO <u>2"</u> to <u>Beyond</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input checked="" type="checkbox"/> Other <u>33°</u> FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	Nozzle Configuration
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	

Prepared By: Winfred C. Leeper	Level: II	Date: 3/9/2002	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no	Sheet <u>2</u> of <u>4</u>
Reviewed By: <i>[Signature]</i>	Date: 3/11/02	Authorized Inspector: <i>[Signature]</i>	Date: 3-10-02	

RR 04-MN-003 3/10/02

Station: McGUIRE Unit 2 Rev. File No. Sheet 3 OF 4


Subject: SAFE END TO NOZZLE

WELD# ZSKA-INLET-WSSSE By

Prob No. B05.070.001 Checked by

[Signature] Date 3/10/02
Date

ATTACHMENT 1
RR: 04-MN-003 Page 3 of 4



EXAM AREA:

$$1.17 \text{ IN.} \times 2.55 \text{ IN.} = 2.98 \text{ SQ. IN.}$$

[Handwritten signature]
3/10/02

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
1.17" x 2.55" = 2.98 sq. in.	2.98 sq. in. x 119.4" = 355.81 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	33°	S2	2.98	119.4	355.81	355.81	100.00
2	45°	S1	0	0	0	355.81	0.00
3	45°	CW	2.98	119.4	355.81	355.81	100.00
4	45°	CCW	2.98	119.4	355.81	355.81	100.00
		Total	Aggregate	Coverage	1067.43	1423.24	75.00

R/
BBB
7/3/02
3/10/02

		Item No: B05.070.001
Prepared By: Jay A. Eaton	<i>[Signature]</i>	Level: III Date: 3/10/2002
Reviewed By: <i>David K. [Signature]</i>		Level: <i>III</i> Date: 3/11/02

DUKE POWER COMPANY						Exam Start: 1027	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 1053	Revision 4
Station: McGuire	Unit: 2	Component/Weld ID: 2SGA-OUTLET-W6SE				Date: 3/9/2002	
Weld Length (in.): 119.4	Surface Condition: AS MACHINED		Lo: RT "0"		Surface Temperature: <u>78</u> ° <u>F</u>		
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i>	Level: II		Scans:			Pyrometer S/N: <u>MCNDE 27228</u>	
Examiner: <i>Sam Moss</i>	Level: II		45 <input type="checkbox"/> _____ dB	70 <input type="checkbox"/> _____ dB	Cal Due: <u>7/3/2002</u>		
Procedure: NDE-930	Rev: 1	FC: 02-04	45T <input checked="" type="checkbox"/> <u>73</u> ** dB	70T <input type="checkbox"/> _____ dB	Configuration: <u>CIRC.</u>		
Calibration Sheet No: 0202056			60 <input type="checkbox"/> _____ dB	<u>51</u> Flow <u>52</u> <u>Safe End</u> to <u>Nozzle</u> Scan Surface: OD Applies to NDE-680 only Skew Angle: <u>N/A</u>			
			60T <input type="checkbox"/> _____ dB				
			Other: <u>33° @ 54dB</u> dB				

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE			
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
NRI		33°														
NRI		45°														

Remarks: ** SCANNED AT 69dB DUE TO NOISE					
Limitations: (see NDE-UT-4) <input checked="" type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>				Sheet <u>1</u> of <u>4</u>	
Reviewed By: <i>[Signature]</i>	Level: <u>III</u>	Date: <u>3/11/02</u>	Authorized Inspector: <i>[Signature]</i>	Date: <u>3-8-02</u>	Item No: B05.070.002

RR 04-NN-003 3/11/02

DUKE POWER COMPANY
ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2SGA-OUTLET-W6SE	Item No: B05.070.002	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM WO <u>2"</u> to <u>Beyond</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input checked="" type="checkbox"/> Other <u>33°</u> FROM _____ DEG to _____ DEG	Nozzle Configuration	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG		
Prepared By: Winfred C. Leeper <i>Winfred C. Leeper</i> Level: II Date: 3/9/2002 Reviewed By: <i>[Signature]</i> III Date: 3/11/02	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no	Sheet <u>2</u> of <u>4</u> Authorized Inspector: <i>[Signature]</i> Date: <u>3/13/02</u>

R 3/13/02

Station : M^cGUIRE Unit Z Rev.

File No. Sheet 3 of 4


Subject SAFE END TO NOZZLE

WELD# ZSKA-OUTLET-WUSE By

[Signature] Date 3/10/02

Prob No. B05070.002 Checked by

Date



EXAM AREA:

$$1.17 \text{ in.} \times 2.55 \text{ in.} = 2.98 \text{ sq. in.}$$

[Handwritten signature]
3/13/02
EGR

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined



Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
1.17" x 2.55" = 2.98 sq. in.	2.98 sq. in. x 119.4" = 355.81 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	33°	S2	2.98	119.4	355.81	355.81	100.00
2	45°	S1	0	0	0	355.81	0.00
3	45°	CW	2.98	119.4	355.81	355.81	100.00
4	45°	CCW	2.98	119.4	355.81	355.81	100.00
		Total	Aggregate	Coverage	1067.43	1423.24	75.00

2012/3/10
 3/10/02
 3/10/02

		Item No:	B05.070.002
Prepared By: Jay A. Eaton		Level: III	Date: 3/10/2002
Reviewed By: David K. [Signature]		Level: III	Date: 3/11/02

DUKE POWER COMPANY						Exam Start: 1049		Form NDE-UT-2A			
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 1115		Revision 4			
Station: McGuire		Unit: 2	Component/Weld ID: 2SGD-INLET-W5SE				Date: 3/8/2002				
Weld Length (in.): 119.4		Surface Condition: AS MACHINED			Lo: RT *0*		Surface Temperature: <u>87</u> ° <u>F</u>				
Examiner: Gary J. Moss <i>Gary J. Moss</i> Level: II		FC: 02-04			Scans:		Pyrometer S/N: <u>MCNDE 27228</u>				
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i> Level: II					45 <input type="checkbox"/> _____ dB		70 <input type="checkbox"/> _____ dB		Cal Due: <u>7/3/2002</u>		
Procedure: NDE-930 Rev: 1					45T <input checked="" type="checkbox"/> <u>73**</u> dB		70T <input type="checkbox"/> _____ dB		Configuration: <u>CIRC.</u>		
Calibration Sheet No: 0202055					60 <input type="checkbox"/> _____ dB		60T <input type="checkbox"/> _____ dB		<u>S1</u> Flow <u>S2</u>		
		Other: <u>33° @ 54dB</u> dB				Safe End to Nozzle			Scan Surface: OD		
						Applies to NDE-680 only			Skew Angle: <u>N/A</u>		

IND #	<u>4</u>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE	WRITE SPACE	
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
NRI	33°															
NRI	45°															

Remarks: **SCANNED AT 69 dB DUE TO NOISE**

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no Sheet 1 of 4

Reviewed By: *[Signature]* Level: III Date: 3/11/02 Authorized Inspector: *[Signature]* Date: 3-13-02 Item No: B05.070.007

3/12

DUKE POWER COMPANY
ISI LIMITATION REPORT

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2SGD-INLET-W5SE Item No: B05.070.007 Remarks:

<input checked="" type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION	Nozzle Configuration
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM WO _____ 2" _____ to _____ Beyond _____		
ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input checked="" type="checkbox"/> Other <u>33°</u>	FROM _____ DEG to _____ DEG		

<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM WO _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	FROM _____ DEG to _____ DEG		

<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM WO _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	FROM _____ DEG to _____ DEG		

<input type="checkbox"/> NO SCAN	SURFACE	BEAM DIRECTION	
<input type="checkbox"/> LIMITED SCAN	<input type="checkbox"/> 1 <input type="checkbox"/> 2	<input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
FROM L _____ to L _____	INCHES FROM WO _____ to _____		
ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	FROM _____ DEG to _____ DEG		

Prepared By: Winfred C. Leeper *[Signature]* Level: II Date: 3/9/2002 Sketch(s) attached yes no Sheet 2 of 4

Reviewed By: *[Signature]* III Date: 3/11/02 Authorized Inspector: *[Signature]* Date: 3-13-02

[Handwritten initials]

Station : M^cGUIRE Unit 2 Rev.


File No. _____ Sheet 3 of 4

Subject : SAFE END TO NOZZLE

WELD # ZSKD-INLET-W55E By

[Signature] II Date 3/10/02
Date

Prob No. B05.070.007 Checked by



EXAM AREA:

$1.17 \text{ IN.} \times 2.55 \text{ IN.} = 2.98 \text{ SQ. IN.}$

[Handwritten notes and signatures]
3/10/02
3/13/02

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined				
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
1.17" x 2.55" = 2.98 sq. in.	2.98 sq. in. x 119.4" = 355.81 cu. in.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	33°	S2	2.98	119.4	355.81	355.81	100.00
2	45°	S1	0	0	0	355.81	0.00
3	45°	CW	2.98	119.4	355.81	355.81	100.00
4	45°	CCW	2.98	119.4	355.81	355.81	100.00
		Total	Aggregate	Coverage	1067.43	1423.24	75.00

2/18/02
3-13-02

Prepared By: Jay A. Eaton	Level: III	Date: 3/10/2002
Reviewed By:	Level: III	Date: 3/11/02

Item No: B05.070.007

DUKE POWER COMPANY				Exam Start: 1012	Form NDE-UT-2A	
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS				Exam Finish: 1048	Revision 4	
Station: McGuire	Unit: 2	Component/Weld ID: 2SGD-OUTLET-W6SE			Date: 3/8/2002	
Weld Length (in.): 119.4	Surface Condition: AS MACHINED		Lo: RT "0"	Surface Temperature: <u>87</u> ° <u>F</u>		
Examiner: Gary J. Moss <i>Gary Moss</i> Level: II	FC: 02-04		Scans:		Pyrometer S/N: <u>MCNDE 27228</u>	
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i> Level: II			45 <input type="checkbox"/> _____ dB	70 <input type="checkbox"/> _____ dB	Cal Due: <u>7/3/2002</u>	
Procedure: NDE-930 Rev: 1			45T <input checked="" type="checkbox"/> <u>73</u> ** dB	70T <input type="checkbox"/> _____ dB	Configuration: <u>CIRC.</u>	
Calibration Sheet No: 0202055		60 <input type="checkbox"/> _____ dB		<u>S1</u> Flow <u>S2</u> Safe End to Nozzle Scan Surface: OD Applies to NDE-680 only Skew Angle: <u>N/A</u>		
60T <input type="checkbox"/> _____ dB		Other: <u>33° @ 54dB</u> dB				

IND #	<u>4</u>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI	33°														
NRI	45°														

Remarks: ** SCANNED AT 69dB DUE TO NOISE					
Limitations: (see NDE-UT-4) <input type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>					Sheet <u>1</u> of <u>4</u>
Reviewed By: <i>[Signature]</i>	Level: <u>III</u>	Date: <u>3/11/02</u>	Authorized Inspector: <i>[Signature]</i>	Date: <u>3-13-02</u>	Item No: B05.070.008

R 3/13/02

DUKE POWER COMPANY
ISI LIMITATION REPORT

FORM NDE-UT-4
Revision 1

Component/Weld ID: 2SGD-OUTLET-W6SE Item No: B05.070.008 Remarks:

<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input checked="" type="checkbox"/> Other 33°	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM WO 2" to Beyond FROM _____ DEG to _____ DEG	Nozzle Configuration
---	---	---	----------------------

<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM WO _____ to _____ FROM _____ DEG to _____ DEG	
--	--	--	--

<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM WO _____ to _____ FROM _____ DEG to _____ DEG	
--	--	--	--

<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2	BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw INCHES FROM WO _____ to _____ FROM _____ DEG to _____ DEG	
--	--	--	--

Prepared By: Winfred C. Leeper Level: II Date: 3/9/2002 Sketch(s) attached yes no Sheet 2 of 4

Reviewed By: [Signature] III Date: 3/11/02 Authorized Inspector: [Signature] Date: 3/13/02

Station: M'GUIRE Unit Z Rev.


File No. Sheet 3 of 4

Subject: SAFE END TO NOZZLE

WELD# 2SKD-OUTLET-W6SE By

Date 3/10/02
Checked by
Date

Prob No. 305.070.008



EXAM AREA:

$$1.17 \text{ IN.} \times 2.55 \text{ IN.} = 2.98 \text{ SQ. IN.}$$

M'GUIRE
 3/10/02
 RR 04-MN-003
 Page 3 of 4

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
Revision 0	

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
1.17" x 2.55" = 2.98 sq. in.	2.98 sq. in. x 119.4" = 355.81 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	33°	S2	2.98	119.4	355.81	355.81	100.00
2	45°	S1	0	0	0	355.81	0.00
3	45°	CW	2.98	119.4	355.81	355.81	100.00
4	45°	CCW	2.98	119.4	355.81	355.81	100.00
		Total	Aggregate	Coverage	1067.43	1423.24	75.00

2/18/02
 3/13/02
 [Handwritten initials and marks]

Prepared By: Jay A. Eaton	Level: III	Item No: B05.070.008 Date: 3/10/2002
Reviewed By:	Level: III	Date: 3/14/02

DUKE POWER COMPANY										Exam Start: 1012		NDE-UT-3A		
ULTRASONIC EXAMINATION DATA SHEET FOR LAMINAR REFLECTORS										Exam Finish: 1020		Revision 2		
Station: McGuire			Unit: 2		Component/Weld ID: 2PZR-SKIRT					Date: 03/05/2002				
Nominal Material Thickness (in): 1.5				Weld Length (in.): 273.3			Surface Temperature: 82° Deg F							
Measured Material Thickness (in): 1.69				Lo: 9.2.1			Pyrometer S/N: MCNDE 27227							
Surface Condition: AS GROUND				Calibration Sheet No: 0202049			Cal Due: 07/03/2002							
Examiner: Gary J. Moss <i>Gary J. Moss</i> Level: II			Configuration: SKIRT to LOWER HEAD S2 Flow S1 SKIRT to HEAD											
Examiner: James L. Panel <i>James L. Panel</i> Level: II														
Procedure: NDE-640 Rev: 1 FC: *														
IND NO.	Ampl ≥ rem BW LOB	L1 ≥ rem BW LOB	W1 ≥ rem BW LOB	Mp1 ≥ rem BW LOB	W2 ≥ rem BW LOB	Mp2 ≥ rem BW LOB	L2 ≥ rem BW LOB	W1 ≥ rem BW LOB	Mp1 ≥ rem BW LOB	W2 ≥ rem BW LOB	Mp2 ≥ rem BW LOB	Exam Surf.	Damps	
NRI	0°													

Remarks: * FC 95-18 & 95-19														
					Limitations: see NDE-UT-4 <input type="checkbox"/> None: <input checked="" type="checkbox"/>					Sheet 1 of 29				
Reviewed By: <i>[Signature]</i>			Level: III		Date: 3/10/02		Authorized Inspector: <i>[Signature]</i>			Date: 3/1/02		Item No: 808.020.001A		


2/18/02

DUKE POWER COMPANY						Exam Start: 1012	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 1105	Revision 4
Station: McGuire	Unit: 2	Component/Weld ID: 2PZR-SKIRT				Date: 03/05/2002	
Weld Length (in.): 273.3	Surface Condition: AS GROUND		Lo: 9.2.1		Surface Temperature: <u>82</u> ° F		
Examiner: Gary J. Moss <i>GJM</i>	Level: II	Scans:		Pyrometer S/N: <u>MCNDE 27227</u>			
Examiner: James L. Panel <i>JLP</i>	Level: II	45 <input checked="" type="checkbox"/> <u>60.5</u> dB 70 <input type="checkbox"/> _____ dB		Cal Due: <u>07/03/2002</u>			
Procedure: NDE-952 Rev: 0	FC: 02-05	45T <input checked="" type="checkbox"/> <u>60.5</u> dB 70T <input type="checkbox"/> _____ dB		Configuration: <u>Skirt to Lower Head</u>			
Calibration Sheet No: 0202049, 0202050		30° <input checked="" type="checkbox"/> <u>63.5</u> dB		S2 _____ Flow _____ S1 _____			
		60T <input type="checkbox"/> _____ dB		Skirt to Head			
		Other: <u>0° @ 34</u> dB		Scan Surface: OD			
				Applies to NDE-680 only			
				Skew Angle: N/A			

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE	DO NOT WRITE IN THIS SPACE	
1	30°	350	2.83	Taper-5.7°	0.0°	360°	INT.	IND.	N/A	N/A	N/A	2	1	AX	NO

Remarks:			
Limitations: (see NDE-UT-4) <input checked="" type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>			Sheet <u>2</u> of <u>4</u>
Reviewed By: <i>JLP</i>	Level: <u>II</u>	Date: <u>3/10/02</u>	Authorized Inspector: <i>[Signature]</i> Date: <u>3/10/02</u>
			Item No: <u>923/11/02</u> B08.020.001A

R
3/13/02



Item # B08.020.001A
ID# 2P2R-SKIRT
By: DJ Moss
Date: 3-5-02

PAGE 3 OF 9


[Signature] 3/10/02

[Signature]
3/1/02
R
3/1/02

DUKE POWER COMPANY ULTRASONIC INDICATION RESOLUTION SHEET		Form NDE-UT-8
		Revision 1
<p>Acceptance Standard: IND. 1 - PLOTTING OF INDICATION SHOWS THIS TO BE A GEOMETRICAL REFLECTOR FROM THE I.D. OF THE WELD. INDICATION WOULDNOT HOLD UP TO SKEWING.</p> <p>Item No: B08.020.001A</p>		
Acceptable Indications: IND. 1		
Rejectable Indications: NONE		
These indications have been compared with previous ultrasonic data <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No previous data available		
Examiner: Gary J. Moss	Level: II Date: 03/05/2002	Sheet <u>4</u> of <u>9</u>
Reviewer:	Level: III Date: 3/10/02	Authorized Inspector: <i>[Signature]</i> Date: 3/1/02

GR
3/10/02

PRESSURIZER SUPPORT SKIRT



AREA OF INTEREST

$ABCD - .5" \times 1.0" = .5 \text{ sq. in.}$
 $EFGH - .5" \times 1.0" = .5 \text{ sq. in.}$
 $BDEG - \overline{BG} = l_2 = \frac{\pi R}{180} \alpha = l_2 = \frac{\pi \times 2.75}{180} \times 145 = 6.959 = 6.96 \text{ in.}$
 $\overline{DE} = l_1 = \frac{\pi r}{180} \alpha = l_1 = \frac{\pi \times 1.75}{180} \times 145 = 4.428 = 4.43 \text{ in.}$
 $k = \frac{l_1 + l_2}{2} = 5.695$

$Area = k(R-r) = 5.695 \times (2.75 - 1.75) = \underline{\underline{5.695 = 5.7 \text{ sq. in.}}}$

TOTAL AREA =
 $.5 + .5 + 5.7 = \underline{\underline{6.7 \text{ sq. in.}}}$


ITEM # 308.020.001A
 I.D. # PPR - SKIRT
 BY David K. [Signature]
 DATE 03/05/02

[Signature] 3/10/02
 [Signature]

PRESSURIZER SUPPORT SKIRT

ITEM # BOJ.010.0014
 I.D. # 22ER-SKIRT
 BY: Daniel C. [Signature]
 DATE: 03/05/08

0°, 45° CW & 45° CCW




[Signature]
 3/11/08

PRESSURIZER Support SKIRT

JM III 3/10

ITEM# B01.020.001A
I.D.# 2PER-SKIRT
BY: Daniel K III
DATE: 03/05/02



30° Surface 1 to 2

INSPECTED AREA

ABC - $\frac{9 \times 2}{2} = .09 \text{ sq. in.}$

BCDE - $\frac{5}{2} (.25 + .5) = .1875 = .19 \text{ sq. in.}$

AREA NOT SCANNED = $.09 + .19 = .28 \text{ sq. in.}$

(TOTAL AREA) $6.7 \text{ sq. in.} - (\text{AREA NOT SCANNED}) .28 \text{ sq. in.} =$

COVERAGE = 6.42 sq. in.


7 9
PAGE 8 OF 10
92 92
3/10/02 3/10/02

RR 04-MN-003
3/10/02

JK III 3/1/02

PRESSURIZER SUPPORT SKIRT

ITEM# 301.020.01A
I.D.# 2PZR-SKIRT
BY: David K. III
DATE: 03/05/02



45° SURFACE 2 TO 1.

INSPECTED AREA

ABCD - $\widehat{BD} = l_2 = \frac{\pi R}{180} \alpha = \frac{\pi \times 2.75}{180} \times 53 = 2.54 \text{ in.}$
 $\widehat{AC} = l_1 = \frac{\pi r}{180} \alpha = \frac{\pi \times 1.75}{180} \times 100 = 3.05 \text{ in.}$

$k = \frac{l_1 + l_2}{2} = 2.795$

AREA = $k(R-r) = 2.795 \times (2.75 - 1.75) = 2.795 = \underline{2.8 \text{ sq.in.}}$

CDEF - $.5" \times 1.0" = \underline{.5 \text{ sq.in.}}$

AREA NOT SCANNED = $2.8 + .5 = 3.3 \text{ sq.in.}$

(TOTAL AREA) $6.7 \text{ sq.in.} - (\text{AREA NOT SCANNED}) 3.3 \text{ sq.in.} = 3.4 \text{ sq.in.}$

COVERAGE = 3.4 sq.in.

- AREA SCANNED
- AREA NOT SCANNED

Pa. 801.9

RR 04-MN-003
3/1/02
JK III 3/1/02

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined				
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
SEE DRWG. - 6.7 SQ. IN.	6.7 SQ. IN. X 274 IN. = 1835 CU. IN.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0°	N/A	5.12	274	1402.88	1835	
2	45°	1	3.4	274	931.6	1835	
3	30°	2	6.42	274	1759.08	1835	
4	45°	CW	5.12	274	1402.88	1835	
5	45°	CCW	5.12	274	1402.88	1835	
TOTAL			AGGREGATE	COVERAGE	6899.32	9179	75.16

2011/11/15
 10-11-02
 3/10/02

		Item No: B08.020.001A
Prepared By: <i>David K...</i>	Level: <u>III</u>	Date: 03/05/02
Reviewed By: <i>[Signature]</i>	Level: <u>III</u>	Date: 3/10/02

DUKE POWER COMPANY						Exam Start: 1013	Form NDE-UT-2A
ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS						Exam Finish: 1026	Revision 4
Station: McGuire	Unit: 2	Component/Weld ID: 2ncw-3673-1				Date: 2/26/2002	
Weld Length (in.): 101"	Surface Condition: AS GROUND		Lo: 9.1.1.1		Surface Temperature: 118 ° F		
Examiner: Larry Mauldin <i>Larry Mauldin</i>	Level: III		Scans:		Pyrometer S/N: MCNDE 27227		
Examiner: James L. Panel <i>James Panel</i>	Level: II		45 <input checked="" type="checkbox"/> 68.5 dB 70 <input type="checkbox"/> _____ dB		Cal Due: 7/3/2002		
Procedure: NDE-610	Rev: 4	FC:	45T <input checked="" type="checkbox"/> 75 dB 70T <input type="checkbox"/> _____ dB		Configuration: PC.1 Loop 2) to Elbow (PC.A L		
Calibration Sheet No: 0202028, 0202029			60 <input type="checkbox"/> _____ dB		<i>01/27/02</i> Flow <i>01/27/02</i> ELBOW to PIPE Scan Surface: OD Applies to NDE-680 only Skew Angle: N/A		
			60T <input type="checkbox"/> _____ dB				
			Other: _____ dB				

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps	
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA			DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac					
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac					
NRI	45A															
NRI	45C															

Remarks: *97-01, 98-20, 01-05			
Limitations: (see NDE-UT-4) <input checked="" type="checkbox"/> 90% or greater coverage obtained: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>			Sheet <u>1</u> of <u>4</u>
Reviewed By: <i>[Signature]</i>	Level: <u>III</u>	Date: <u>2/27/02</u>	Authorized Inspector: <i>[Signature]</i> Date: <u>2-28-02</u>
			Item No: B09.011.009

R
G
3/13/02

DUKE POWER COMPANY	FORM NDE-UT-4
ISI LIMITATION REPORT	Revision 1

Component/Weld ID: 2NCW-3673-1	Item No: B09.011.009	Remarks:
--------------------------------	----------------------	----------

<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	DUE TO 18 INCH PIPE RESTRAINT
FROM L <u>16.25"</u> to L <u>34.25"</u> INCHES FROM WO <u>2.0"</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG			

<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	DUE TO 12 INCH PIPE RESTRAINT
FROM L <u>44.5"</u> to L <u>56.5"</u> INCHES FROM WO <u>2.0"</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG			

<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	DUE TO 12 INCH PIPE RESTRAINT
FROM L <u>69.75"</u> to L <u>81.75"</u> INCHES FROM WO <u>2.0"</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG			

<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2	BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	DUE TO 12 INCH PIPE RESTRAINT
FROM L <u>95.0"</u> to L <u>6.0"</u> INCHES FROM WO <u>2.0"</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u>N/A</u> DEG to <u>N/A</u> DEG			

Prepared By: <i>Larry Moulder</i>	Level: <u>III</u>	Date: <u>2-26-02</u>	Sketch(s) attached <input checked="" type="checkbox"/> yes <input checked="" type="checkbox"/> no	Sheet <u>2</u> of <u>4</u>
Reviewed By: <i>[Signature]</i>	Date: <u>2/27/02</u>	Authorized Inspector: <i>[Signature]</i>	Date: <u>2-28-02</u>	

R
G
3/27/02

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1 Revision 0
---	------------------------

Examination Volume/Area Defined	
<input checked="" type="checkbox"/> Base Metal <input checked="" type="checkbox"/> Weld <input type="checkbox"/> Near Surface <input type="checkbox"/> Bolting <input type="checkbox"/> Inner Radius	
Area Calculation	Volume Calculation
3.5 IN. X 0.67 IN. = 2.35 SQ.IN.	2.35 SQ.IN. X 101 IN. = 237.35 CU.IN.


Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45	2	2.35	101	237.35	237.35	
2	45	1	2.35	47	110.45	110.45	
2	45	1	0.0	54	0	126.9	
3	45	CW	2.35	47	110.45	110.45	
3	45	CW	1.68	54	90.72	126.9	
4	45	CCW	2.35	47	110.45	110.45	
4	45	CCW	1.68	54	90.72	126.9	
					750.14	949.4	79.01

Handwritten signature and date: 2-27-02

	Item No: B09.011.009	
Prepared By: <i>Larry Thacker</i>	Level: <i>III</i>	Date: <i>2-26-02</i>
Reviewed By: <i>[Signature]</i>	Level: <i>III</i>	Date: <i>2-27-02</i>

R. G. 3/2/02

MCQUIRE CO INT LOOP WELD



TOTAL EXAM AREA

$ABCD = 3.5 \text{ in.} \times 0.67 \text{ in.} = 2.345 = 2.35 \text{ sq. in.}$

COVERAGE IN RESTRAINT AREAS

S1 TO S2 FULL COVERAGE = 2.35 sq. in.

S2 TO S1 TOTAL LOSS 0.0 sq. in.

CW TO CCW & CCW TO CW

$AECF = 2.5 \text{ in.} \times 0.67 \text{ in.} = 1.675 = 1.68 \text{ sq. in.}$

RESTRAINT WIDTHS

3 @ 12.0 in.

1 @ 18.0 in.

ATTACHMENT 3

RR 04-MN-003 Page 4 of 4

SHEET 4 OF 4

ITEM # B09.011.009

I.D. # 2NCW-3673-1

BY: Larry Mauldin

DATE: 12-26-02

R
G
31/5/02
[Signature]

McGuire Unit #2

EOC14

Item # BO9.011.011
Weld # ZNC'ZFWZ-1

No Data Recorded. Reference Calibration Sheet #'s

0202068-45° & 60°

SHEET 1 OF 3

R.
GA
5/12/02

DUKE POWER COMPANY ISI LIMITATION REPORT		FORM NDE-UT-4
		Revision 1
Component/Weld ID: 2NC2FW2-1	Item No: B09.011.011	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u>19.0"</u> to L <u>25.0"</u> INCHES FROM WO <u>C/L</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw FROM <u>N/A</u> DEG to <u>N/A</u> DEG	RIGID RESTRAINT
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u>41.0"</u> to L <u>3.0"</u> INCHES FROM WO <u>C/L</u> to <u>BEYOND</u> ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input checked="" type="checkbox"/> cw <input checked="" type="checkbox"/> ccw FROM <u>N/A</u> DEG to <u>N/A</u> DEG	RIGID RESTRAINT
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM _____ DEG to _____ DEG	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw FROM _____ DEG to _____ DEG	
Prepared By: <u>Winfred [Signature]</u>	Level: <u>II</u>	Date: <u>3-13-02</u>
Reviewed By: <u>[Signature]</u>	Date: <u>3/13/02</u>	Authorized Inspector: <u>[Signature]</u>
Sketch(s) attached <input type="checkbox"/> yes <input checked="" type="checkbox"/> no		Sheet <u>2</u> of <u>3</u>
Date: <u>3-14-02</u>		

R
04
2/18/02

ATTACHMENT 4
RR 04-MN-003 Page 3 of 3

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
"T" = 1.3" per past ultrasonic data. 1.3"/3 X 2.0" = 0.87 sq. in.	0.87 sq. in. X 44.0" = 38.28 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45	S2	0.87	32.0	27.84	38.28	
2	45	S1	0.87	32.0	27.84	38.28	
3	60	CW	0.87	32.0	27.84	38.28	
4	60	CCW	0.87	32.0	27.84	38.28	
		TOTAL	AGGREGATE	COVERAGE	111.36	153.12	72.73

R/00/000/000/000
 2011/02/13
 3-13-02

		Item No:	B09.011.011
Prepared By:	DAVID K. ZIMMERMAN <i>David K. Zimmerman</i>	Level:	III
Date:	3/13/2002		
Reviewed By:	<i>[Signature]</i>	Level:	III
Date:	3/13/02		

DUKE POWER COMPANY				
STATION <u>McGuire</u> UNIT <u>2</u>				
LIQUID PENETRANT EXAMINATION REPORT				
Weld/ID No. <u>2NC2FW2-1</u>		Material Type: <input checked="" type="checkbox"/> SS <input type="checkbox"/> CS <input type="checkbox"/> Inconel		
Diameter <u>14</u>		Schedule/Thickness <u>160/1.406</u> <input checked="" type="checkbox"/> ISI <input type="checkbox"/> PSI <input type="checkbox"/> Other		
Procedure Rev. No. <u>19</u>		Field Change No.(s) <u>N/A</u>		
W/O No. <u>98395261</u>		SKETCH OF ITEM EXAMINED 		
Surface Temperature <u>75°F</u>				
M&TE S/N: <u>MCNDE 27221</u>				
Penetrant Materials Category: A <input checked="" type="checkbox"/> A(SE) <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> A(SE) Approved _____				
Penetrant Materials Data: Batch Numbers Cleaner <u>99M01K</u> Penetrant <u>97A10K</u> Developer <u>01B09K</u> Emulsifier _____ Fluorescent <input type="checkbox"/> Nonfluorescent <input checked="" type="checkbox"/>				
Black Light Intensity Verified Time _____ Date _____ Light Meter S/N: _____		Acceptance Standard: A <input type="checkbox"/> D <input type="checkbox"/> G <input type="checkbox"/> K <input type="checkbox"/> Other: B <input type="checkbox"/> E <input type="checkbox"/> H <input type="checkbox"/> L <input type="checkbox"/> C <input type="checkbox"/> F <input checked="" type="checkbox"/> J <input type="checkbox"/> M <input type="checkbox"/>		
Ind. No.	Indication Type/Dimensions	Reference Documents	Recordable	Reportable
NRI				

PIP S/N:		Rejectable <input type="checkbox"/>	Acceptable <input checked="" type="checkbox"/>
Exam Limitations:		<input checked="" type="checkbox"/> Yes <u>81.82</u> % Examined	<input type="checkbox"/> No (100% Examined)
Comments: <u>LIMITED C HANGER AS SHOWN ABOVE</u>			
Examiner: Jay A. Eaton		Level: <u>II</u>	Date: <u>3/3/2002</u>
Examiner:		Level:	Date:
Reviewed By:		Level: <u>I</u>	Date: <u>3-4-02</u>
Final Review	Date	ANII Review	Date
		Item No. <u>B09.011.011A</u>	



DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
44" of weld length x 2.5" wide inspection area = 110 sq.in. total weld area.	

Coverage Calculations							
Scan #	Angle	Beam Direction	WELD WIDTH Area of Examined (sq.in.)	Length Examined (in.)	AREA Volume of Examined (cu.in.)	AREA Volume of Required (cu.in.)	Percent Coverage
N/A	N/A	N/A	2.5"	36"	90	110	81.82

		Item No:	B09.011.011A
Prepared By: Jay A. Eaton		Level:	II
Reviewed By: 		Level:	III
		Date:	3/3/2002
		Date:	3/11/02

McGuire Unit #2 EOC14

Item # BO9.011.012
Weld # ZNCZFWZZ-6

No Data Recorded. Reference Calibration Sheet #'s

- 0202069 - 45° & 60°
- 0202070 - 60°L
- _____
- _____
- _____

R
3/2/02

DUKE POWER COMPANY ISI LIMITATION REPORT		FORM NDE-UT-4
		Revision 1
Component/Weld ID: 2NC2FW22-6	Item No: B09.011.012	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u> N/A </u> to L <u> N/A </u> INCHES FROM WO <u> 0.7" </u> to <u> BEYOND </u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u> 0 </u> DEG to <u> 360 </u> DEG	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	NOZZLE CONFIGURATION
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
Prepared By: <u>Winifred P. Beaper</u> Level: <u>II</u> Date: <u>3-14-02</u> Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no Sheet <u>7</u> of <u>5</u>	Reviewed By: <u>[Signature]</u> <u>III</u> Date: <u>3/15/02</u> Authorized Inspector: <u>[Signature]</u> Date: <u>3-15-02</u>	



R
 3/15/02

ATTACHMENT 5

RR 04-MN-003 Page 3 of 5

S2 - FLOW


S1 - NOZZLE



SHEAR CALCULATION


$$(0.33\text{in} \times 0.55\text{in}) + \left(\frac{0.20\text{in} \times 0.33\text{in}}{2}\right) + \left(\frac{0.35\text{in} \times 0.35\text{in}}{2}\right) =$$

$$\text{AREA} = 0.28\text{in}^2$$



PL CALCULATION = TOTAL AREA - SHEAR AREA =


$$0.163\text{in}^2 - 0.28\text{in}^2 = 0.35\text{in}^2$$

 III 5/15/02
 2015/5/15/02

ITEM NO	BOF.011.012
COMPLEXITY	2015/5/15/02
INSP	David K III
DATE	03/14/02
SCALE	FULL

S2 - ELLOW

S1 - NOZZLE



AREA CALCULATION

$$2(0.33\text{in} \times 0.55\text{in}) = 0.36\text{in}^2$$

$$2\left(\frac{0.5\text{in}}{2} [0.33\text{in} + 0.20\text{in}]\right) = 0.27\text{in}^2$$

$$\text{TOTAL AREA} = 0.36\text{in}^2 + 0.27\text{in}^2 = 0.63\text{in}^2$$

[Signature] III Blisbl

ITEM NO	BOF.011.012
COMPONENT	200222-6
INSP	90% Daniel K. III
DATE	03/14/08
SCALE	Full

200222-6
 03/14/08
 Daniel K. III
 III Blisbl

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
Revision 0	

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
SEE ATTACHED DRWG. AREA = 0.63 sq. in.	33.8 in. X 0.63 sq. in. = 21.3 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	60	S2	0	33.8	0	21.3	
2	60	S1	0.28	33.8	9.45	21.3	
3	45	CW	0.63	33.8	21.3	21.3	
4	45	CCW	0.63	33.8	21.3	21.3	
		TOTAL	COVERAGE	AGGREGATE	52.05	85.2	61.09
2	60RL	S1	0.35	33.8	11.83	21.3	
		TOTAL	COVERAGE	SUPPLEMENT	11.83	85.2	13.88

2011/11/13
 80-51-214
 15-214
 15-214

Item No:	B09.011.012
----------	-------------

Prepared By: DAVID K. ZIMMERMAN	Level: III	Date: 3/14/2002
---------------------------------	------------	-----------------

Reviewed By: 	Level: III	Date: 3/15/02
--	------------	---------------

McGuire Unit #2 EOC14

Item # B09.011.013
Weld # ZJLZFWZZ-9

No Data Recorded. Reference Calibration Sheet #'s

0202069 - 45° & 60°

0202070 - 60°L

SHEET 1 OF 5

SR
3/18/02

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2NC2FW22-9		Item No: B09.011.013		Remarks:	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u> N/A </u> to L <u> N/A </u> INCHES FROM WO <u> 0.7" </u> to <u> BEYOND </u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u> 0 </u> DEG to <u> 360 </u> DEG		SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		NOZZLE CONFIGURATION	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG		SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			
Prepared By: <u>Winford P. Reeper</u> Level: <u>II</u> Date: <u>3-14-02</u>		Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no		Sheet <u>2</u> of <u>5</u>	
Reviewed By: <u>[Signature]</u> III Date: <u>3/15/02</u>		Authorized Inspector: <u>[Signature]</u>		Date: <u>3-15-02</u>	


R. G. 3/18

ATTACHMENT-G

RR 04HN-003 Proj 3045

S2 - PIPE

S1 - NOZZLE



SHEAR CALCULATION

$$(0.33\text{in} \times 0.55\text{in}) + \left(\frac{0.2\text{in} \times 0.33\text{in}}{2}\right) + \left(\frac{0.35\text{in} \times 0.35\text{in}}{2}\right) =$$

$$\text{AREA} = 0.28\text{in}^2$$

RL CALCULATION = TOTAL AREA - SHEAR AREA =

$$0.63\text{in}^2 - 0.28\text{in}^2 = 0.35\text{in}^2$$

[Signature]
 DATE 3/15/02

ITEM NO.	R09.01.013
COMPONENT	NOZZLE
DATE	03/14/02
SCALE	FULL


2018/15
 2018/15
 2018/15

ATTACHMENT 6

R104-MN-003 Page No. 5

S2 - PIPE

S1 - NOZZLE



AREA CALCULATION

$$2(0.33\text{in} \times 0.55\text{in}) = 0.36\text{in}^2$$

$$2\left(\frac{0.5\text{in}}{2} \times [0.33\text{in} + 0.30\text{in}]\right) = 0.27\text{in}^2$$

$$\text{TOTAL AREA} = 0.36\text{in}^2 + 0.27\text{in}^2 = 0.63\text{in}^2$$

[Signature]
 III Bristol

ITEM NO.	B09.011.013
COMPONENT	2 NOZZLE 122-9
UNIT	PAVILION 3 III
DATE	03/14/02
SCALE	FULL

FOR ST...
 2/18/12

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
SEE ATTACHED DRWG. AREA = 0.63 sq. in.	33.8 in. X 0.63 sq. in. = 21.3 cu. in.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	60	S2	0	33.8	0	21.3	
2	60	S1	0.28	33.8	9.45	21.3	
3	45	CW	0.63	33.8	21.3	21.3	
4	45	CCW	0.63	33.8	21.3	21.3	
		TOTAL	COVERAGE	AGGREGATE	52.05	85.2	61.09
2	60RL	S1	0.35	33.8	11.83	21.3	
		TOTAL	COVERAGE	SUPPLEMENT	11.83	85.2	13.88

3/15/02

3/15/02
 [Handwritten initials/signature]

Item No:	B09.011.013
----------	-------------

Prepared By: DAVID K. ZIMMERMAN <i>[Signature]</i>	Level: III	Date: 3/14/2002
--	------------	-----------------

Reviewed By: <i>[Signature]</i>	Level: III	Date: 3/15/02
---------------------------------	------------	---------------

McGuire Unit #2 EOC14

Item # BO9.011.018
Weld # ZNC2FW16-6

No Data Recorded. Reference Calibration Sheet #'s

DZ02071 - 45° & 60°

OZ02072 - 60° L


SHEET 1 OF 4

DUKE POWER COMPANY ISI LIMITATION REPORT			FORM NDE-UT-4
			Revision 1
Component/Weld ID: 2NC2FW16-6		Item No: B09.011.018	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u> N/A </u> to L <u> N/A </u> INCHES FROM WO <u> C/L </u> to <u> BEYOND </u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u> 0 </u> DEG to <u> 360 </u> DEG	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	NOZZLE CONFIGURATION	
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u> 7.0" </u> to L <u> 13.0" </u> INCHES FROM WO <u> C/L </u> to <u> BEYOND </u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input checked="" type="checkbox"/> Other <u> 60RL </u> FROM <u> N/A </u> DEG to <u> N/A </u> DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	I-BEAM ADJACENT TO PIPE	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw		
Prepared By: <u>James A. Ben</u>	Level: <u>II</u>	Date: <u>3-14-02</u>	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no
Reviewed By: <u>[Signature]</u>	Level: <u>III</u>	Date: <u>3/14/02</u>	Authorized Inspector: <u>[Signature]</u> Date: <u>3-15-02</u>

R. G. R.


DUKE POWER COMPANY
 UT PROFILE/PLOT SHEET

NDE-UT-5
 Revision 1



Component ID/Weld No. 2 NC2FW-16-6

Remarks:



Item No: 309.011.018

Examiner: <i>James D. Berry</i>	Level: II	Date: 3-14-02
Reviewed By: <i>[Signature]</i>	Level: III	Date: 3-14-02
Authorized Inspector: <i>[Signature]</i>		Date: 3-15-02

R
 GA
 3/18/02



DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
Revision 0	

Examination Volume/Area Defined				
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld	<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting	<input type="checkbox"/> Inner Radius

Area Calculation	Volume Calculation
SEE ATTACHED DRWG. TOTAL AREA = 2.42 sq. in.	2.42 sq. in. X 20.8 in. = 50.33 cu. in.

Coverage Calculations							
Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45	CW	2.42	20.8	50.33	50.33	
2	45	CCW	2.42	20.8	50.33	50.33	
3	60	S2	0	20.8	0	50.33	
4	60	S1	0.88	20.8	18.3	50.33	
		TOTAL	AGGREGATE	COVERAGE	118.96	201.32	59.09
4	60RL	S1	1.54	13.8	21.3	50.33	
		TOTAL	SUPPLEMENT	COVERAGE	21.3	201.32	10.58

2/18/02
 JH
 RR04-KN-003

		Item No: B09.011.018
Prepared By: JAMIE H. RESOR		Date: 3/14/2002
Reviewed By:		Date: 3/14/02

McGuire Unit #2 EOC14

Item # BOA.011.169
Weld # ZNIZF.871

No Data Recorded. Reference Calibration Sheet #'s

0202071 - 45° & 60°

0202072 - 60° L

SHEET 1 OF 4

2/18/07

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2NI2F871	Item No: B09.011.169	Remarks:		
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u> N/A </u> to L <u> N/A </u> INCHES FROM WO <u> C/L </u> to <u> BEYOND </u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input checked="" type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM <u> 0 </u> DEG to <u> 360 </u> DEG	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	ADJACENT WELD		
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L <u> 7.0" </u> to L <u> 13.0" </u> INCHES FROM WO <u> C/L </u> to <u> BEYOND </u> ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input checked="" type="checkbox"/> Other <u> 60RL </u> FROM <u> N/A </u> DEG to <u> N/A </u> DEG	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	THROAT RADIUS OF 6" ELBOW		
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw			
Prepared By: <u>Janet A. Beon</u>	Level: <u>II</u>	Date: <u>3-14-02</u>	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no	Sheet <u>2</u> of <u>4</u>
Reviewed By: <u>[Signature]</u>	Date: <u>3/14/02</u>	Authorized Inspector: <u>[Signature]</u>	Date: <u>3-15-02</u>	

R. Q. 3/14

DUKE POWER COMPANY
UT PROFILE/PLOT SHEET

NDE-UT-5

Revision 1

EXAMINATION SURFACE 1 - PIPE
EXAMINATION SURFACE 2
ELBOW - EXAMINATION SURFACE 2


WELD

1

2

3

4



22 x 11 x .88"

22 x 3 x .46"


22 x 11 x .88"

TOTAL AREA OF TREATMENT 2.42 sq

2.42" x 20.85" = 50.33 TOTAL WELD AREA TO EQUAL 100% VOLUME

Component ID/Weld No. 2N1ZF871

Remarks:



Item No: 309.011.169

Level: II Date: 3-14-02

Level: III Date: 3/14/02

Date: 3-15-02

Examined By: [Signature]
Reviewed By: [Signature]
Authorized Inspector: [Signature]

3/15/02

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
Revision 0	

Examination Volume/Area Defined

Base Metal
 Weld
 Near Surface
 Bolting
 Inner Radius

Area Calculation	Volume Calculation
SEE ATTACHED DRWG. TOTAL AREA = 2.42 sq. in.	2.42 sq. in. X 20.8 in. = 50.33 cu. in.

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45	CW	2.42	20.8	50.33	50.33	
2	45	CCW	2.42	20.8	50.33	50.33	
3	60	S2	0	20.8	0	50.33	
4	60	S1	0.88	20.8	18.3	50.33	
		TOTAL	AGGREGATE	COVERAGE	118.96	201.32	59.09
4	60RL	S1	1.54	13.8	21.3	50.33	
		TOTAL	SUPPLEMENT	COVERAGE	21.3	201.32	10.58

2/18/11
 R. [Signature]
 1/14/02

	Item No:	B09.011.169
Prepared By: JAMIE H. RESOR <i>[Signature]</i>	Level: II	Date: 3/14/2002
Reviewed By: <i>[Signature]</i>	Level: III	Date: 3/14/02

Form NDE-35A Revision 3

DUKE POWER COMPANY			
STATION <u>McGuire</u> UNIT <u>2</u>			
LIQUID PENETRANT EXAMINATION REPORT			
Weld/ID No. <u>2CCPUMP-2A-LEG</u>		Material Type: <input checked="" type="checkbox"/> SS <input type="checkbox"/> CS <input type="checkbox"/> Inconel	
Diameter <u>0</u>		Schedule/Thickness <u>0</u> <input checked="" type="checkbox"/> ISI <input type="checkbox"/> PSI <input type="checkbox"/> Other	
Procedure Rev. No. <u>19</u>		Field Change No.(s) <u>N/A</u>	
W/O No. <u>98395260-01</u>		SKETCH OF ITEM EXAMINED	
Surface Temperature <u>84°F</u>			
M&TE S/N: <u>MCNDE 27228</u>			
Penetrant Materials Category: A <input checked="" type="checkbox"/> A(SE) <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/>			
A(SE) Approved _____			
Penetrant Materials Data: Batch Numbers			
Cleaner <u>89M01K</u>			
Penetrant <u>97A10K</u>			
Developer <u>86M09K</u>			
Emulsifier _____			
Fluorescent <input type="checkbox"/> Nonfluorescent <input checked="" type="checkbox"/>			
Black Light Intensity Verified _____		Acceptance Standard: A <input type="checkbox"/> D <input type="checkbox"/> G <input type="checkbox"/> K <input type="checkbox"/>	
Time _____ Date _____		Other: B <input type="checkbox"/> E <input type="checkbox"/> H <input checked="" type="checkbox"/> L <input type="checkbox"/>	
Light Meter S/N: _____		C <input type="checkbox"/> F <input type="checkbox"/> J <input type="checkbox"/> M <input type="checkbox"/>	
Ind. No.	Indication Type/Dimensions	Reference Documents	Recordable Reportable
NRI			

PIP S/N:	Rejectable <input type="checkbox"/>	Acceptable <input checked="" type="checkbox"/>
Exam Limitations:	<input checked="" type="checkbox"/> Yes <u>82.65</u> % Examined	<input type="checkbox"/> No (100% Examined)
Comments: See attached sheets for limited area examined calculations.		
Examiner: Marion T. Weaver <i>Marion T. Weaver</i>	Level: <u>II</u>	Date: <u>2/19/2002</u>
Examiner: B. Dale Jolly <i>B. Dale Jolly</i>	Level: <u>II</u>	Date: <u>2/19/2002</u>
Reviewed By: <i>T. Trishin</i>	Level: <u>III</u>	Date: <u>2/19/02</u>
Final Review <i>[Signature]</i>	Date <u>2/25/2002</u>	ANII Review <i>[Signature]</i> Date <u>2-25-02</u>
		Item No. <u>C03.030.001</u>

2/25/02

ATTACHMENT 9
RR 04-MN-008 Page 2 of 4





Station MCGUIRE Unit 2 Rev. _____ File No. _____ Sheet _____ Of _____

Subject 2CCPUMP-2A-LEG

By M.T. WEAVER Date 2-19-01

Prob No. ITEM* C03.030.001

Checked By _____ Date _____



WELD-SHADED AREA
"NOT TO SCALE"

DUKE POWER COMPANY Limited Examination Coverage Worksheet	NDE-91-1
	Revision 0


Examination Volume/Area Defined	
<input checked="" type="checkbox"/> Base Metal	<input checked="" type="checkbox"/> Weld
<input type="checkbox"/> Near Surface	<input type="checkbox"/> Bolting
<input type="checkbox"/> Inner Radius	
Area Calculation	Volume Calculation
138.5" of weld length x 2.4" wide inspection area = 332.4 sq.in. total weld area.	

Coverage Calculations							
Scan #	Angle	Beam Direction	^{WIDTH} Area Examined (sq.in.)	Length Examined (in.)	^{AREA} Volume Examined SQ (cu.in.)	^{ACCA} Volume Required SQ. (cu.in.)	Percent Coverage
N/A	N/A	N/A	2.4	114.5	274.8	332.5	82.65


Item No:	C03.030.001
----------	-------------

Prepared By: Marion T. Weaver <i>Marion T. Weaver</i>	Level: II	Date: 2/19/2002
---	-----------	-----------------

Reviewed By: <i>TC Tucker</i>	Level: III	Date: 2/19/02
-------------------------------	------------	---------------



Support LEG.



Support LEG

ATTACHMENT-9
RR 04-MN-003
Page 4 of 4

ATTACHMENT 3

Relief Request 04-MN-004

**Proposed Relief in Accordance with 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality**

Duke Energy Corporation

McGuire Nuclear Station – Unit 2 (EOC-15), March 28, 2002 To October 6, 2003

Second 10-Year Interval – Inservice Inspection Plan

Interval Start Date March 1, 1994. Interval End Date March 1 2004.

ASME Section XI Code – 1989 Edition with No Addenda

Code Case N-460 is applicable

Limitation I.D. Number	I. System / Component for Which Relief is Requested: Area or Weld to be Examined	II. & III. Code Requirement from Which Relief is Requested: 100% Exam Volume Coverage Exam Category Item No. Fig. No. Limitation Percentage	IV. Basis for Relief	V. Alternate Examinations or Testing	VI. Justification for the Granting of Relief	VII. Implementation Schedule
2ND2F-12	ND System 14" Pipe to Valve 2ND2A weld	Exam Category B-J Item No. B09.011.104 Fig. IWB-2500-8 35.20% Volume Coverage	See Paragraph "A" also See Attachment 1 Pages 1-5	None	See Paragraph "E" also See Attachment 1 Pages 1-5	The examination requirements for this interval were met; no additional exams are planned.
2N12FW26-7	NI System 8" Valve 2N1129 to Pipe Weld	Exam Category B-J Item No. B09.011.171 Fig. IWB-2500-8 34.96% Volume Coverage	See Paragraph "B" also See Attachment 2 Pages 1-5	None	See Paragraph "F" also See Attachment 2 Pages 1-5	The examination requirements for this interval were met; no additional exams are planned.
2N12FW26-16	NI System 8" Valve 2N1125 to Pipe Weld	Exam Category B-J Item No. B09.011.172 Fig. IWB-2500-8 34.96% Volume Coverage	See Paragraph "C" also See Attachment 3 Pages 1-5"	None	See Paragraph "F" also See Attachment 3 Pages 1-5"	The examination requirements for this interval were met; no additional exams are planned.
2N12FW26-15	NI System 8" Elbow to Valve 2N1125 Weld	Exam Category C-F-1 Item No. C05.011.168 Fig. IWC-2500-7 34.96% Volume Coverage	See Paragraph "D" also See Attachment 4 Pages 1-5	None	See Paragraph "G" also See Attachment 4 Pages 1-5	The examination requirements for this interval were met; no additional exams are planned.

Inspection Dates for Item Numbers

B09.011.104 09/16/2003
B09.011.171 09/18/2003
B09.011.172 09/18/2003
C05.011.168 09/18/2003

IV. Basis for Relief

Paragraph A:

(The pipe to valve weld material is stainless steel. The weld diameter is 14.00" with a wall thickness of 1.250".)

During the ultrasonic examination of the weld, 100% coverage of the required scan and coverage examination volume could not be obtained. The examination coverage was limited to 35.20%. Limitations are caused by austenitic weld metal characteristics and single sided access caused by the valve configuration which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible. The percent coverage reported represents the aggregate coverage from all shear wave scans performed on the weld and base material. A 45° shear wave axial scan was used to scan from the pipe side of the weld covering 40.8% of the examination volume. Two opposing 45° shear wave circumferential scans were performed on the pipe side of the weld covering 50% of the examination volume.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. A 60° refracted longitudinal wave axial scan was used to supplement the shear wave scan to provide better penetration but cannot be used beyond the first sound path leg. This supplemental scan covered 100% of the examination volume from the pipe side.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds. No recordable indications were found during the volumetric and surface examinations of this weld.

Paragraph B:

(The valve to pipe weld material is stainless steel. The weld diameter is 8.00" with a wall thickness of .906".)

During the ultrasonic examination of the weld, 100% coverage of the required scan and coverage examination volume could not be obtained. The examination coverage was limited to 34.96%. Limitations are caused by austenitic weld metal characteristics and single sided access caused by the valve configuration which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible. The percent coverage reported represents the aggregate coverage from all shear wave scans performed on the weld and base material. A 45° shear wave axial scan was used to scan from the pipe side of the weld covering 39.84% of the examination volume. Two opposing 45° shear wave circumferential scans were performed on the pipe side of the weld covering 50% of the examination volume.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam

when shear waves pass through the weld. A 60° refracted longitudinal wave axial scan was used to supplement the shear wave scan to provide better penetration but cannot be used beyond the first sound path leg. This supplemental scan covered 100% of the examination volume from the pipe side. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds. No recordable indications were found during the volumetric and surface examinations of this weld.

Paragraph C:

(The valve to pipe weld material is stainless steel. The weld diameter is 8.00" with a wall thickness of .906".) During the ultrasonic examination of the weld, 100% coverage of the required scan and coverage examination volume could not be obtained. The examination coverage was limited to 34.96%. Limitations are caused by austenitic weld metal characteristics and single sided access caused by the valve configuration which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the weld volume as defined in Code Case N-460 is not possible. The percent coverage reported represents the aggregate coverage from all shear wave scans performed on the weld and base material. A 45° shear wave axial scan was used to scan from the pipe side of the weld covering 39.84% of the examination volume. Two opposing 45° shear wave circumferential scans were performed on the pipe side of the weld covering 50% of the examination volume.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. A 60° refracted longitudinal wave axial scan was used to supplement the shear wave scan to provide better penetration but cannot be used beyond the first sound path leg. This supplemental scan covered 100% of the examination volume from the pipe side. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds. No recordable indications were found during the volumetric and surface examinations of this weld.

Paragraph D:

(The elbow to valve weld material is stainless steel. The weld diameter is 8.00" with a wall thickness of .906".) During the ultrasonic examination of the weld, 100% coverage of the required scan and coverage examination volume could not be obtained. The examination coverage was limited to 34.96%. Limitations are caused by austenitic weld metal characteristics and single sided access caused by the valve configuration which prevents scanning of the weld from two opposing sides. Obtaining coverage greater than 90% of the

weld volume as defined in Code Case N-460 is not possible. The percent coverage reported represents the aggregate coverage from all shear wave scans performed on the weld and base material. A 45° shear wave axial scan was used to scan from the pipe side of the weld covering 39.84% of the examination volume. Two opposing 45° shear wave circumferential scans were performed on the pipe side of the weld covering 50% of the examination volume.

Duke Energy Corporation does not claim credit for coverage of the far side of austenitic welds. The characteristics of austenitic weld metal attenuate and distort the sound beam when shear waves pass through the weld. A 60° refracted longitudinal wave axial scan was used to supplement the shear wave scan to provide better penetration but cannot be used beyond the first sound path leg. This supplemental scan covered 100% of the examination volume from the pipe side. Duke Energy Corporation uses a combination of shear waves and longitudinal waves to examine single sided austenitic welds.

The procedures, personnel and equipment have been qualified through the Performance Demonstration Initiative (PDI). However, although longitudinal wave search units were used in the qualification and cracks were detected through the weld metal, PDI does not provide a qualification for single sided examinations of austenitic welds. No recordable indications were found during the volumetric and surface examinations of this weld.

Justification for Relief

VI. Paragraph E:

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI). No additional B09.011 welds on the ND System were scheduled during this outage. No recordable indications were found during the volumetric and surface examination of this weld.

This is a 14" Pipe to Valve 2ND2A Weld 2ND2F-12 located on the ND (Residual Heat Removal System). This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following.

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the Ventilation Unit Condensate Drain Tank (VUCDT). This parameter is monitored continuously by Operations via an Operator Aid Computer (OAC) alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of a reactor coolant leakage calculation, which is

required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.

- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walkdown is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph F:

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI). One additional weld on NI System was scheduled this outage. No recordable indications were found during the volumetric and surface examination of this weld.

These are 8" Valves 2NI129/2NI125 to Pipe Welds 2NI2FW26-7/2NI2FW26-16 (respectively) located on the NI (Safety Injection System). These welds are not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the welds in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at these welds would result in the following.

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of a reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walkdown is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

Paragraph G:

Although the examination volume as defined in ASME Section XI 1989 Edition with no addenda, Figure IWB-2500-8 could not be covered, the amount of coverage obtained for this examination provides an acceptable level of quality and integrity. This weld was examined using procedures, personnel and equipment qualified through the Performance Demonstration Initiative (PDI). Eleven additional C05.011 welds on NI System were scheduled during this outage. Two welds had recordable indications on the surface examination. One weld had a Linear indications of .15" and .65", the other weld had a indication of .25". Subsequent evaluation determined these indications were acceptable per the Section XI Code.

This is a 8" SS Elbow to Valve 2NI125 Weld 2NI2FW26-15 located on the NI (Safety Injection System). This weld is not exposed to significant neutron fluence and is not prone to negative material property changes (i.e. embrittlement) associated with neutron bombardment. If a leak were to occur at the weld in question, there are methods by which the leak could be identified for prompt Engineering evaluation. A leak at this weld would result in the following.

- a) Increased containment humidity. This parameter is indicated in the control room and is monitored periodically by Operations and also monitored by the Containment Ventilation System Engineer.
- b) Increased input into the VUCDT. This parameter is monitored continuously by Operations via an OAC alarm and also periodically by the Liquid Radwaste System Engineer and Reactor Coolant System Engineer.
- c) Increase in unidentified reactor coolant leakage. This parameter would be exhibited during performance of a reactor coolant leakage calculation, which is required by Technical Specifications to be performed every 72 hours. The unidentified leakage limit in Technical Specification 3.4.13.1 is 1 gpm.
- d) Other indicators such as containment radiation monitors EMF-38, 39 and 40 the containment floor and equipment sump levels.

Note: The above parameters would be used to identify a leak in the containment, but could not specifically identify this weld as the source of leakage. A containment entry would be required to identify the exact source of the leakage.

Also, a containment walkdown is performed when the unit reaches Mode 3 (full temperature / pressure) during the unit shutdown and startup for each refueling outage. This walkdown should identify any leak at the weld in question.

VIII. Other:

The following individuals contributed to the development of this relief request:

Jim McArdle (Principal UT NDE Level III Examiner) provided Sections II through V and part of Section VI.

Ed Hyland, Bryan Meyer and Larry Kunka (MNS Systems Engineers) provided parts of Section VI.

Gary Underwood (McGuire ISI Plan Manager) compiled the remaining sections.

Sponsored
By:

Gary Underwood

Date

7/12/2004

Approved
By:

L. Kevin Rhyme

Date

7/13/04

Attachment 1	UT Examination Data B09.011.104
Attachment 2	UT Examination Data B09.011.171
Attachment 3	UT, Examination Data B09.011.172
Attachment 4	UT Examination Data C05.011.168



UT Pipe Weld Examination

Relief Request 04-MN-004
ATTACHMENT-1
Page 1 of 5

Site/Unit: McGuire / 2
Summary No.: B09.011.104
Workscope: ISI

Procedure: PDI-UT-2
Procedure Rev.: C
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-109
Page: 1 of 5

Code: Section XI, 1989 Cat./Item: B-J/B9.11.104 Location: N/A
Drawing No.: MCFI-2ND1 Description: Pipe to Valve (2ND2A)
System ID: ND
Component ID: B09.011.104 /2ND2F-12 Size/Length: 14" SS Thickness/Diameter: 1.25
Limitations: Yes - Pipe to Valve Configuration Start Time: 1430 Finish Time: 1600

Examination Surface: Inside Outside Surface Condition: GROUND
Lo Location: Top of Pipe Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 03125
Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27220 Surface Temp.: 79 °F

Cal. Report No.: CAL-03-164, CAL-03-165, CAL-03-166

Angle Used	0	45	45T	60	60RL	
Scanning dB		48	48	64.4	69.4	

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:

Results: Accept Reject Info *RAK 12-3-03*
Percent Of Coverage Obtained > 90%: *92 12/2/03* No ~~75%~~ 35.2% Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Busby, John S.	II-N	<i>John S. Busby</i>	9/16/2003	Jay A Eaton Level III	<i>Jay A Eaton</i>	9/23/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Matteson, Mary F.	II-N	<i>Mary F. Matteson</i>	9/16/2003			
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A				<i>Matteson 9-25-03</i>	

RAK 9/20/03



Ultrasonic Indication Report

RR 04-MN-004
ATTACHMENT-1
Page 2 of 5
Outage No.: MN2EOC15


Site/Unit: McGulre / 2
Summary No.: B09.011.104
Workscope: ISI

Procedure: PDI-UT-2
Procedure Rev.: C
Work Order No.: 98536824

Report No.: UT-03-109
Page: 2 of 5

Search Unit Angle: 45-60 °
Wo Location: Weld CL
Lo Location: Top of Pipe

- Piping Welds
- Ferritic Vessels $\geq 2^*T$
- Other _____



MP	Metal Path	Wmax	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W1	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W2	Distance From Wo At Of Max (Forward)

Comments:

Scan #	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp.	Remarks
			W	MP	W1	MP	W2	MP					
45°	1	60%	1.6"	1.8"	N/A	N/A	N/A	N/A	360°	12"	N/A	Int.	
60°	2	150%	2.5"	2.45"	N/A	N/A	N/A	N/A	360°	0"	N/A	Int.	

Examiner Level II-N Busby, John S.	Signature <i>John S. Busby</i>	Date 9/16/2003	Reviewer Jay A Eaton Level III	Signature <i>Jay A Eaton</i>	Date 9/23/2003
Examiner Level II-N Matteson, Mary F.	Signature <i>Mary F. Matteson</i>	Date 9/16/2003	Site Review	Signature	Date
Other Level N/A N/A	Signature	Date	ANII Review	Signature <i>[Signature]</i>	Date 9-25-03

R/G 9/30/03



Supplemental Report

RR 04-MN-004
ATTACHMENT-1
Page 3 of 5

Report No.: UT-03-109

Page: 3 of 25
of 9/23/03

Summary No.: B09.011.104

Examiner: Busby, John S. *[Signature]*

Level: II-N

Reviewer: JAM EATON L III *[Signature]*

Date: 9/23/03

Examiner: Matteson, Mary F. *[Signature]*

Level: II-N

Site Review: *[Signature]*

Date: *[Blank]*

Other: N/A


Level: N/A

ANII Review: *[Signature]*

Date: 9-25-03

Comments: Plot Sheet

Sketch or Photo: \\ngofs1\dddeal7\dddeal_Server\Graphics\Common\Contour2.jpg



Rev 9/30/03



Supplemental Report

R/Gen
9/30/03

Report No.: UT-03-109

Page: 4 of 5

Summary No.: B09.011.104

Examiner: Busby, John S. *[Signature]* Level: II-N

Reviewer: Jay A Eaton Level III *[Signature]* Date: 9/23/2003

Examiner: Matteson, Mary F. *[Signature]* Level: II-N

Site Review: _____ Date: _____

Other: N/A Level: N/A

ANII Review: *[Signature]* Date: 12/5/03

Comments:

Indication #1-45° & #2-60° are geometric reflectors from counterbore. Review of RT film showed extensive counterbore and near the bottom of this weld there is evidence of thru-wall repair.

RR 04-MN-004
ATTACHMENT-1
Page 4 of 5



Limitation Record

RR04-MN-004
ATTACHMENT-1
Page 5 of 5

Site/Unit: McGuire / 2
Summary No.: B09.011.104
Workscope: ISI


Procedure: PDI-UT-2
Procedure Rev.: C
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-109
Page: 5 of 5

Description of Limitation:

No scan on the downstream side of the weld C/L + 0.5" and beyond due to valve configuration.

Sketch of Limitation:



U.S. SCAN	45/60 S	- 100%	REK 12-3-03
DS. SCAN	60° L	- 100%	REK 12-3-03
CW	45° S	- 50%	(NO SCAN D.S. SIDE)
CCW	45° S	- 50%	(NO SCAN D.S. SIDE)

SUPPLEMENTAL
L WAVE FROM U.S. SIDE!
NO-CREDIT CLAIMED
REK 12-2-03

AGGREGATE COVERAGE = $\frac{140.8}{300} \div 4 = 75\%$
 REK 12-2-03
 REK 12-3-03

Limitations removal requirements:

N/A

Radiation field: N/A

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Busby, John S.	II-N	<i>[Signature]</i>	9/16/2003	Jay A Eaton Level III	<i>[Signature]</i>	9/23/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Matteson, Mary F.	II-N	<i>[Signature]</i>	9/16/2003			
or	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A			<i>[Signature]</i>	9-25-03	

REK 9/30/03



UT Pipe Weld Examination

Relief Request: 04-MN-004
ATTACHMENT-2
Page 1 of 5

Site/Unit: McGuire / 2
Summary No.: B09.011.171
Workscope: ISI
Procedure: PDI-UT-2
Outage No.: MN2EOC15
Procedure Rev.: C
Report No.: UT-03-151
Work Order No.: 98536824
Page: 1 of 1

Code: Section XI, 1989
Drawing No.: MCFI-2NI26
System ID: NI
Component ID: B09.011.171 / 2NI2FW26-7
Limitations: Yes
Cat./Item: B-J/B9.11.171
Location: N/A
Description: Valve (2NI129) to Pipe
Size/Length: 8" SS
Thickness/Diameter: 0.906"
Start Time: 1400
Finish Time: 1500

Examination Surface: Inside Outside
Surface Condition: GROUND SMOOTH
Lo Location: Top of Pipe
Centerline of Weld: ULTRAGEL II
Couplant: ULTRAGEL II
Batch No.: 00325

Temp. Tool Mfg.: FISHER
Serial No.: MCNDE 27219
Surface Temp.: 80 °F
Cal. Report No.: CAL-03-174, CAL-03-175

0	45	45T	60
	47.7	45.7	50.5

Indication(s): Yes No
Scan Coverage: Upstream Downstream CW CCW

Comments:

Results: Accept Reject Info
Percent Of Coverage Obtained > 90%: 92.12/103
Reviewed Previous Data: Yes

Examiner Level II-N Matteson, Mary F.	Signature <i>Mary F. Matteson</i>	Date 9/18/2003	Reviewer Jay A Eaton	Signature <i>Jay A Eaton</i>	Date 9/25/2003
Examiner Level II-N Charbonnet, Shane C.	Signature <i>Shane C. Charbonnet</i>	Date 9/18/2003	Site Review	Signature	Date
Other Level I	Signature	Date	ANII Review	Signature <i>Shane C. Charbonnet</i>	Date 9/27/03

R/GA 9/30/03



UT Pipe Weld Examination

RR 04-MN-004
ATTACHMENT-2
Page 2 of 5

Site/Unit: McGuire / 2

Procedure: NDE-600

Outage No.: MN2EOC15

Summary No.: B09.011.171

Procedure Rev.: 15

Report No.: UT-03-135

Workscope: ISI

Work Order No.: 98536824

Page: 1 of 4

Code: Section XI, 1989 Cat./Item: B-J/B9.11.171 Location: N/A

Drawing No.: MCFI-2NI26 Description: Valve (2NI129) to Pipe

System ID: NI

Component ID: B09.011.171 /2NI2FW26-7 Size/Length: 8" SS Thickness/Diameter: 0.906"

Limitations: Yes Start Time: 0958 Finish Time: 1005

Examination Surface: Inside Outside Surface Condition: GROUND SMOOTH

Lo Location: Top of Pipe Wo Location: ULTRAGEL II Couplant: ULTRAGEL II Batch No.: 01225

Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27221 Surface Temp.: 80 °F

Cal. Report No.: CAL-03-188

Angle Used	0	45	45T	60	60L
Scanning dB					60

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:

Results: Accept Reject Info
Percent Of Coverage Obtained > 90%: 92/12/03 No - 75% 34.96% Reviewed Previous Data: Yes

Examiner	Level III	Signature	Date	Signature	Date
Eaton, Jay A.			9/20/2003	Gayle E Houser Level III	9/25/2003
Examiner	Level	Signature	Date	Signature	Date
Other	Level	Signature	Date	Signature	Date

R/gu 9/20/03



Ultrasonic Indication Report

RR 04-MN-004
ATTACHMENT-2
Page 3 of 5


Site/Unit: McGuire / 2
Summary No.: B09.011.171
Workscope: ISI

Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-135
Page: 2 of 4

Search Unit Angle: 60L °
Wo Location: C/L of Weld
Lo Location: Top of Pipe

- Piping Welds
- Ferritic Vessels $\geq 2^{\circ}T$
- Other _____



MP	Metal Path	Wmax	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W1	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W2	Distance From Wo At Of Max (Forward)

Comments:

Scan #	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp.	Remarks
			W	MP	W1	MP	W2	MP					
S1	1	80	1.4	1.7	N/A	N/A	N/A	N/A	360°	0°	Int	N/A	

Examiner	Level III		Signature	Date	9/20/2003	Reviewer	Gayle E Houser Level III		Signature	Date	9/25/2003
Examiner	Level		Signature	Date		Site Review			Signature	Date	
Other	Level		Signature	Date		ANII Review			Signature	Date	

R/G 9/20/03

9-27-03



Supplemental Report

RR 04-MN-004
ATTACHMENT-2
Page 4 of 5

Report No.: UT-03-135
Page: 3 of 4

Summary No.: B09.011.171

Examiner: Eaton, Jay A. 

Level: III

Reviewer: Gayle E Houser Level III 

Date: 9/25/2003

Examiner: _____

Level: _____

Site Review: _____

Date: _____

Other: _____


Level: _____

ANII Review: 

Date: 9/22/07

Comments: Indication # 1-60°L is a geometric reflector from the weld root / counterbore configuration. This was confirmed by review of RT film.

Sketch or Photo: \\ngofs1\DDdeal7\dddeal_Server\Graphics\Common\ProfileLine2.jpg



RLG
9/30/03



Limitation Record

RR 04-MN-004
ATTACHMENT-2
Page 5 of 5

Site/Unit: McGuire / 2
Summary No.: B09.011.171
Workscope: ISI


Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-135
Page: 4 of 4

Description of Limitation:

Limited due to valve configuration on the Upstream side from the weld C/L + 0.5" and Beyond (360°).

Sketch of Limitation:



ANGLE	SCAN	COVERAGE	REMARKS
60° L	UP S.	0%	SUPPLEMENTAL (60° L FROM DS SIDE) NO CREDIT CLAIMED
45°/60° S	DOWN S.	39.84%	
45°	CW	50%	(NO SCAN UPSIDE)
45°	CCW	50%	(NO SCAN UPSIDE)
		$\frac{139.84}{300} \div 4 = 75\%$	AGGREGATE COVERAGE

Limitations removal requirements:

N/A

Radiation field: N/A

Examiner	Level III		Signature	Date	9/20/2003	Reviewer	Gayle E Houser Level III		Signature	Date	9/25/2003
Examiner	Level		Signature	Date		Site Review			Signature	Date	
	Level		Signature	Date		ANII Review			Signature	Date	9-27-03

Rev 9/23/03



UT Pipe Weld Examination

Relief Request 04-NN-004
ATTACHMENT-3
Page 1 of 5

Site/Unit: McGulre / 2
Summary No.: B09.011.172
Workscope: ISI

Procedure: PDI-UT-2
Procedure Rev.: C
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-152
Page: 1 of 1

Code: Section XI, 1989 Cat./Item: B-J/B9.11.172 Location: N/A
Drawing No.: MCFI-2NI26 Description: Valve (2NI125) to Pipe
System ID: NI
Component ID: B09.011.172 /2NI2FW26-16 Size/Length: 8" SS Thickness/Diameter: 0.906"
Limitations: Yes Start Time: 1440 Finish Time: 1515

Examination Surface: Inside Outside Surface Condition: GROUND SMOOTH

Lo Location: Top of Pipe Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 00325

Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27220 Surface Temp.: 80 °F

Cal. Report No.: CAL-03-174, CAL-03-175

Angle Used	0	45	45T	60		
Scanning dB		44.8	44.8	52.3		

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:

Results: Accept Reject Info pkc 12-3-03
Percent Of Coverage Obtained > 90%: 9/12/2103 No -75% 34.96 Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Matteson, Mary F.	II-N	<i>Mary F. Matteson</i>	9/18/2003	Jay A Eaton Level III	<i>Jay A Eaton</i>	9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Charbonnet, Shane C.	II-N	<i>Shane C. Charbonnet</i>	9/18/2003			
Other	Level	Signature	Date	ANII Review	Signature	Date
					<i>Relief</i>	<u>9-27-03</u>

R/G 9/30/03



UT Pipe Weld Examination

RR 04-MN-004
ATTACHMENT-3
Page 2 of 5

Site/Unit: McGuire / 2
Summary No.: B09.011.172
Workscope: ISI

Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-132
Page: 1 of 4

Code: Section XI, 1989 Cat./Item: B-J/B9.11.172 Location: N/A
Drawing No.: MCFI-2NI26 Description: Valve (2NI125) to Pipe
System ID: NI
Component ID: B09.011.172 /2NI2FW26-16 Size/Length: 8" SS Thickness/Diameter: 0.906"
Limitations: Yes Start Time: 0945 Finish Time: 0951

Examination Surface: Inside Outside Surface Condition: GROUND SMOOTH
Lo Location: Top of Pipe Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 01225
Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27221 Surface Temp.: 80 °F

Cal. Report No.: CAL-03-188

Angle Used	0	45	45T	60	60L	
Scanning dB					60	

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:
60° L wave to gain coverage on the valve side of the weld.

Results: Accept Reject Info
Percent Of Coverage Obtained > 90%: 9/21/03 No 75% 34.96 Reviewed Previous Data: Yes

Examiner	Level III	Signature	Date	Reviewer	Signature	Date
Eaton, Jay A.			9/20/2003	Gayle E Houser Level III		9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Other	Level	Signature	Date	ANII Review	Signature	Date

RR 04 9/30/03



Ultrasonic Indication Report

RR 04-MN-004
ATTACHMENT-3
Page 3 of 5


Site/Unit: McGuire / 2
Summary No.: B09.011.172
Workscope: ISI

Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-132
Page: 2 of 4

Search Unit Angle: 60°L °
Wo Location: C/L of Weld
Lo Location: Top of Pipe

- Piping Welds
- Ferritic Vessels $\geq 2''T$
- Other _____



MP	Metal Path	Wmax	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W1	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W2	Distance From Wo At Of Max (Forward)

Comments:

Scan #	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp.	Remarks
			W	MP	W1	MP	W2	MP					
S1	1	100	1.4	1.7	N/A	N/A	N/A	N/A	360°	0°	Int.	N/A	

Examiner Level III Eaton, Jay A.	Signature 	Date 9/20/2003	Reviewer Gayle E Houser Level III	Signature 	Date 9/25/2003
Examiner Level	Signature	Date	Site Review	Signature	Date
Other Level	Signature	Date	ANII Review	Signature 	Date

R162 9135103



Supplemental Report

RR 04-MN-004
ATTACHMENT-3
Page 4 OF 5

Report No.: UT-03-132
Page: 3 of 4

Summary No.: B09.011.172
Examiner: Eaton, Jay A.
Examiner: _____
Other: _____


Level: III
Level: _____
Level: _____

Reviewer: Gayle E Houser Level III
Site Review: _____
ANII Review: _____

Date: 9/25/2003
Date: _____
Date: 9-27-03

Comments: Indication # 1-60°L is a geometric reflector from the weld root / counterbore configuration. This was confirmed by review of RT film.

Sketch or Photo: \\ngofs1\VDDeaf7\Ideaf_Server\Graphics\Common\ProfileLine2.jpg



Rku 9/30/03



Limitation Record

RR 04-MN-004
ATTACHMENT-3
Page 5 of 5

Site/Unit: McGuire / 2
Summary No.: B09.011.172
Workslope: ISI


Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-132
Page: 4 of 4

Description of Limitation:

Limited due to valve configuration on the Upstream side from the weld C/L + 0.5" and Beyond (360°).

Sketch of Limitation:



ANGLE SCAN

60° L UP S.

45°/60° S DOWN S.

45° CW

45° CCW

COVERAKE 9/12/03

0% 9/12/03
+100% 9/12/03
39.84%
+100% 9/12/03
50% (NO SCAN UPS SIDE)
50% (NO SCAN UPS SIDE)
34.96% AGGREGATE
-300 ÷ 4 = 75% COVERAKE
9/12/03
9/12/03

SUPPLEMENTAL
(60° L FROM DS SIDE)
NO CREDIT CLAIMED

Limitations removal requirements:

N/A

Radiation field: N/A

Examiner	Level III	Signature	Date	Reviewer	Signature	Date
Eaton, Jay A.			9/20/2003	Gayle E Houser Level III		9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
or	Level	Signature	Date	ANII Review	Signature	Date
						9-22-03

R/GA 9/30/03



UT Pipe Weld Examination

Relief Request 04-MN-004

ATTACHMENT 4

Page 1 of 5

Site/Unit: McGuire / 2
 Summary No.: C05.011.168
 Workscope: ISI

Procedure: PDI-UT-2
 Procedure Rev.: C
 Work Order No.: 98536824

Outage No.: MN2EOC15
 Report No.: UT-03-150
 Page: 1 of 1

Code: Section XI, 1989 Cat./Item: C-F-1/C5.11.168 Location: N/A
 Drawing No.: MCFI-2NI26 Description: Elbow to Valve (2NI125)
 System ID: NI
 Component ID: C05.011.168 /2NI2FW26-15 Size/Length: 8" SS Thickness/Diameter: 0.906"
 Limitations: Yes Start Time: 1520 Finish Time: 1602

Examination Surface: Inside Outside Surface Condition: GROUND SMOOTH

Lo Location: Top of Pipe Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 00325

Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27220 Surface Temp.: 80 °F

Cal. Report No.: CAL-03-174, CAL-03-175

Angle Used	0	45	45T	60		
Scanning dB		44.8	44.8	52.3		

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:

Results: Accept Reject Info 9/12/03
 Percent Of Coverage Obtained > 90%: No - 75% 34.96 Reviewed Previous Data: Yes

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Matteson, Mary F.	II-N	<i>Mary F. Matteson</i>	9/18/2003	Jay A Eaton Level III	<i>Jay A Eaton</i>	9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Charbonnet, Shane C.	II-N	<i>Shane C. Charbonnet</i>	9/18/2003			
Other	Level	Signature	Date	ANII Review	Signature	Date
N/A	N/A	<i>Shane C. Charbonnet</i>			<i>Shane C. Charbonnet</i>	9-27-03

RIE 10-1-03



UT Pipe Weld Examination

RIR 04-NW-004
ATTACHMENT-4
Page 2 of 5

Site/Unit: McGuire / 2 Procedure: NDE-600 Outage No.: MN2EOC15
 Summary No.: C05.011.168 Procedure Rev.: 15 Report No.: UT-03-133
 Workscope: ISI Work Order No.: 98536824 Page: 1 of 4

Code: Section XI, 1989 Cat./Item: C-F-1/C5.11.168 Location: N/A
 Drawing No.: MCFI-2NI26 Description: Elbow to Valve (2NI125)
 System ID: NI
 Component ID: C05.011.168 /2NI2FW26-15 Size/Length: 8" SS Thickness/Diameter: 0.906"
 Limitations: Yes Start Time: 0951 Finish Time: 0957

Examination Surface: Inside Outside Surface Condition: GROUND SMOOTH
 Lo Location: Outside Radius of Elbow Wo Location: Centerline of Weld Couplant: ULTRAGEL II Batch No.: 01225
 Temp. Tool Mfg.: FISHER Serial No.: MCNDE 27221 Surface Temp.: 80 °F

Cal. Report No.: CAL-03-188

Angle Used	0	45	45T	60	60L	
Scanning dB					60	

Indication(s): Yes No Scan Coverage: Upstream Downstream CW CCW

Comments:
60° L wave to gain coverage on the valve side of the weld.

Results: Accept Reject Info 8/2/03
 Percent Of Coverage Obtained > 90%: No - 75% 34.96% Reviewed Previous Data: Yes

Examiner	Level III	Signature	Date	Reviewer	Signature	Date
Eaton, Jay A.			9/20/2003	Gayle E Houser Level III		9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Other	Level	Signature	Date	ANII Review	Signature	Date

RIR 10-1-03



Ultrasonic Indication Report

RR 04MN-004
ATTACHMENT-4
Page 3 of 5


Site/Unit: McGuire / 2
Summary No.: C05.011.168
Workscope: ISI

Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-133
Page: 2 of 4

Search Unit Angle: 60°L
Wo Location: C/L of Weld
Lo Location: Top of Pipe

- Piping Welds
- Ferritic Vessels $\geq 2^{\circ}T$
- Other _____



MP	Metal Path	Wmax	Distance From Wo To S.U. At Maximum Response
RBR	Remaining Back Reflection	W1	Distance From Wo At Of Max (Forward)
L	Distance From Datum	W2	Distance From Wo At Of Max (Forward)

Comments:

Scan #	Indication No.	% Of DAC	W Max		Forward Of Max		Backward Of Max		L1 Of Max	L Max	L2 Of Max	RBR Amp.	Remarks
			W	MP	W1	MP	W2	MP					
S1	1	100	1.4	1.7	N/A	N/A	N/A	N/A	360°	0"	Int.	N/A	

Examiner	Level III	Signature	Date	Reviewer	Signature	Date
Eaton, Jay A.		<i>[Signature]</i>	9/20/2003	Gayle E Houser Level III	<i>[Signature]</i>	9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Other	Level	Signature	Date	ANII Review	Signature	Date
					<i>[Signature]</i>	9-27-03


RGU 10-1-03





Supplemental Report

RR 04-MN-004
ATTACHMENT 4
Page 4 of 5

Report No.: UT-03-133
Page: 3 of 4

Summary No.: C05.011.168
Examiner: Eaton, Jay A. 
Examiner: _____
Other: _____


Level: III
Level: _____
Level: _____

Reviewer: Gayle E Houser Level III 
Site Review: _____
ANII Review: 

Date: 9/25/2003
Date: _____
Date: 9-27-03

Comments: Indication # 1-60°L is a geometric reflector from the weld root / counterbore configuration. This was confirmed by review of RT film.

Sketch or Photo: \\ngofs1\DDdeal7\dddeal_Server\Graphics\Common\ProfileLine2.jpg



Riser 10-1-03



Limitation Record

RR 04-MN-004
ATTACHMENT-4
Page 5 of 5

Site/Unit: McGuire / 2
Summary No.: C05.011.168
Workscope: ISI


Procedure: NDE-600
Procedure Rev.: 15
Work Order No.: 98536824

Outage No.: MN2EOC15
Report No.: UT-03-133
Page: 4 of 4

Description of Limitation:

Limited due to valve configuration on the Upstream side from the weld C/L + 0.5" and Beyond (360°).

Sketch of Limitation:



ANGLE	SCAN	COVERAGE
60° L	UP S.	0% 100% @ 12/2/03 39.84% 100% @ 12/2/03
45°/60° S	DOWN S.	100% @ 12/2/03
45°	CW	50% (NO SCAN UPSIDE)
45°	CCW	50% (NO SCAN UPSIDE)
		34.96% AGGREGATE COVERAGE
		$\frac{139.84\%}{300} \div 4 = 75\%$

Supplemental (60° L FROM DS SIDE) NO CREDIT CLAIMED
RR 12-3-03

Limitations removal requirements:

N/A

Radiation field: N/A

Examiner	Level III	Signature	Date	Reviewer	Signature	Date
Eaton, Jay A.			9/20/2003	Gayle E Houser Level III		9/25/2003
Examiner	Level	Signature	Date	Site Review	Signature	Date
Examiner	Level	Signature	Date	ANII Review	Signature	Date
						9/27/03

RR 10-1-03