

August 23, 2004

Mr. Dennis L. Koehl
Site Vice-President
Point Beach Nuclear Plant
Nuclear Management Company, LLC
6590 Nuclear Road
Two Rivers, WI 54241-9516

SUBJECT: POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2
NOTIFICATION OF AN NRC TRIENNIAL FIRE PROTECTION BASELINE
INSPECTION 05000266/2004010(DRS); 05000301/2004010(DRS)

Dear Mr. Koehl:

On November 1, 2004, the NRC will begin a triennial fire protection baseline inspection at the Point Beach Nuclear Plant, Units 1 and 2. This inspection will be performed in accordance with the NRC baseline Inspection Procedure 71111.05.

The schedule for the inspection is as follows:

- Information gathering visit - October 20 - 22, 2004
- On-site inspection activity - November 1 - 5, 2004 and November 15 - 19, 2004

The purpose of the information gathering visit is: (1) to obtain information and documentation needed to support the inspection; (2) to become familiar with the Point Beach Nuclear Plant fire protection programs, fire protection features, post-fire safe shutdown capabilities and plant layout; and (3) to arrange administrative details such as office space, availability of knowledgeable office personnel and to ensure unescorted site access privileges.

Experience has shown that the baseline fire protection inspections are extremely resource intensive both for the NRC inspectors and the licensee staff. In order to minimize the inspection impact on the site and to ensure a productive inspection for both organizations, we have enclosed a request for documents needed for the inspection. These documents have been divided into four groups. The first group lists information necessary to aid the inspection team in choosing specific focus areas for the inspection. It is requested that this information be provided to the lead inspector via mail or electronically no later than October 11, 2004. The second group lists information necessary to ensure that the inspection team is adequately prepared for the inspection. This information should be available on-site no later than October 20, 2004. The third group of requested documents are those items that the team will review, or need access to, during the inspection. Please have this information available by the first day of the on-site portion of the inspection (November 1, 2004). The fourth group lists information necessary to aid the inspection team in tracking issues identified as a result of the inspection. It is requested that this information be provided to the lead inspector as the

information is generated during the inspection. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the on-site portions of the inspection.

The lead inspector for this inspection is Mr. George Hausman. We understand that our regulatory contact for this inspection is Ms. Fritzi Flentje of your organization. If there are any questions about the inspection or the material requested, please contact the lead inspector at (630) 829-9743 or via e-mail at gmh1@nrc.gov.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Julio F. Lara, Chief
Electrical Engineering Branch
Division of Reactor Safety

Docket Nos. 50-266; 50-301
License Nos. DPR-24; DPR-27

Enclosure: Fire Protection Inspection Document Request

See Attached Distribution

cc w/encl: F. Kuester, President and Chief
Executive Officer, We Generation
J. Cowan, Executive Vice President
Chief Nuclear Officer
D. Cooper, Senior Vice President, Group Operations
J. McCarthy, Site Director of Operations
D. Weaver, Nuclear Asset Manager
Plant Manager
Regulatory Affairs Manager
Training Manager
Site Assessment Manager
Site Engineering Director
Emergency Planning Manager
J. Rogoff, Vice President, Counsel & Secretary
K. Duveneck, Town Chairman
Town of Two Creeks
Chairperson
Public Service Commission of Wisconsin
J. Kitsembel, Electric Division
Public Service Commission of Wisconsin
State Liaison Officer

cc w/encl: F. Kuester, President and Chief
Executive Officer, We Generation
J. Cowan, Executive Vice President
Chief Nuclear Officer
D. Cooper, Senior Vice President, Group Operations
J. McCarthy, Site Director of Operations
D. Weaver, Nuclear Asset Manager
Plant Manager
Regulatory Affairs Manager
Training Manager
Site Assessment Manager
Site Engineering Director
Emergency Planning Manager
J. Rogoff, Vice President, Counsel & Secretary
K. Duveneck, Town Chairman
Town of Two Creeks
Chairperson
Public Service Commission of Wisconsin
J. Kitsembel, Electric Division
Public Service Commission of Wisconsin
State Liaison Officer

ADAMS Distribution:

WDR
DFT
HKC
RidsNrrDipmlipb
GEG
HBC
PGK1
DRPIII
DRSIII
PLB1
JRK1

information is generated during the inspection. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the on-site portions of the inspection.

The lead inspector for this inspection is Mr. George Hausman. We understand that our regulatory contact for this inspection is Ms.Fritzi Flentje of your organization. If there are any questions about the inspection or the material requested, please contact the lead inspector at (630) 829-9743 or via e-mail at gmh1@nrc.gov.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Julio F. Lara, Chief
Electrical Engineering Branch
Division of Reactor Safety

Docket Nos. 50-266; 50-301
License Nos. DPR-24; DPR-27

Enclosure: Fire Protection Inspection Document Request

See Attached Distribution:

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML042370018.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RIII	E	RIII	RIII	RIII
NAME	JLara for GHausman:tr		PLouden	JLara	
DATE	08/23/04		08/23/04	08/23/04	

OFFICIAL RECORD COPY

INITIAL DOCUMENT REQUEST

FIRE PROTECTION INSPECTION DOCUMENT REQUEST

Inspection Report: 05000266/2004010(DRS); 05000301/2004010(DRS)

Inspection Dates: October 20 - 22, 2004 (Information Gathering)
November 1 - 5, 2004 (On-site Inspection Activity)
November 15 - 19, 2004 (On-site Inspection Activity)

Inspection Procedures: IP 71111.05, "Fire Protection"

Inspectors: Lead Inspector: G. Hausman
Team Members: D. Schrum
FP Contractor

Observer: A. Dahbur

Information Requested Prior to the Information Gathering Visit

The following information is requested by October 11, 2004. If you have any questions regarding this information, please call the lead inspector as soon as possible. All information may be sent electronically (to Mr. George M. Hausman, e-mail address gmh1@nrc.gov) or provided on compact disc (preferred method).

- (1) The reactor plant's Individual Plant Examination for External Events (IPEEE) for fire, results of any post-IPEEE reviews for fire, and listings of actions taken/plant modifications conducted in response to IPEEE information for fire. Alternatively, probabilistic risk analyses for fire and associated information, if it exists and is more recent than the IPEEE.
- (2) A list of fire areas requiring alternative shutdown capability, i.e., those areas for which 10 CFR Part 50, Appendix R, Section III.G requirements are satisfied under Section III.G.3.

Information Requested During the Information Gathering Visit (October 20 - 22, 2004)

This information is requested to be available on-site during the information gathering visit.

- (1) The current version of the Fire Protection Program and Fire Hazards Analysis.
- (2) Listing of plant fire protection licensing basis documents.
- (3) The NRC Safety Evaluation Reports (SERs) and actual copies of the 50.59 reviews which form the licensing basis for the reactor plant's post-fire safe shutdown configuration.
- (4) A list of Generic Letter 86-10 evaluations.

INITIAL DOCUMENT REQUEST

- (5) A list of applicable codes and standards related to the design of plant fire protection features. The list should include National Fire Protection Association (NFPA) code versions committed to (i.e., the NFPA codes of record).
- (6) A list of plant deviations from code commitments.
- (7) Post-fire safe shutdown analyses, including post-fire safe shutdown systems and separation analysis.
- (8) Piping and instrumentation (flow) diagrams showing the components used to achieve and maintain hot standby and cold shutdown for fires outside the control room and those components used for those areas requiring alternative shutdown capability.
- (9) Plant layout and equipment drawings which identify the physical plant locations of hot standby and cold shutdown equipment for selected fire zones/areas (to be determined during information gathering visit).
- (10) Plant layout drawings which identify plant fire area delineation, areas protected by automatic fire suppression and detection, and the locations of fire protection equipment for selected fire zones/areas (to be determined during information gathering visit).
- (11) Listing of open and closed fire protection condition reports (problem identification forms and their resolution reports) for the past three years.
- (12) Listing of fire impairments for the previous year.
- (13) Pre-fire plans for selected fire zones/areas (to be determined during information gathering visit).
- (14) Plant operating procedures which would be used and describe shutdown for a postulated fire in selected fire zones/areas (to be determined during information gathering visit).
- (15) A listing of the protection methodologies identified under 10 CFR Part 50, Appendix R, Section III.G used to achieve compliance for selected fire zones/areas (to be determined during information gathering visit). That is, please specify whether 3-hour rated fire barriers (Section III.G.2.a), 20-foot separation along with detection and suppression (Section III.G.2.b), 1-hour rated fire barriers with detection and suppression (Section III.G.2.c), or alternative shutdown capability (Section III.G.3) is used for each selected fire zone/area.
- (16) One-line schematic drawings of the electrical distribution system for 4160 Volts - alternating current (Vac) down to 480 Vac.
- (17) One-line schematic drawings of the electrical distribution system for 250 Volts - direct current (Vdc) and 125 Vdc systems as applicable.

INITIAL DOCUMENT REQUEST

- (18) A listing of abbreviations/designators for plant systems.
- (19) Organization charts of site personnel down to the level of fire protection staff personnel.
- (20) A phone list for on-site licensee personnel.

In addition, during the information gathering visit, it is requested that licensee staff be available for the following:

- (1) Informal discussion on plant procedures operators would use in the event of fire and under what conditions would the plant be shutdown using alternative shutdown methodology.
- (2) Informal discussion on the plant's safe shutdown cable routing database and the plant-wide cable routing database, as applicable.
- (3) A tour of alternative shutdown and risk significant fire areas.

Information Requested to be Available on First Day of Inspection (November 1, 2004)

- (1) List of the fire protection program implementing procedures (e.g., administrative controls, surveillance testing, fire brigade).
- (2) List of maintenance and surveillance testing procedures for alternative shutdown capability and fire barriers, detectors, pumps and suppression systems.
- (3) List of maintenance procedures which routinely verify fuse breaker coordination in accordance with the post-fire safe shutdown coordination analysis.
- (4) List of procedures/instructions that control the configuration of the reactor plant's fire protection program, features, and post-fire safe shutdown methodology and system design.
- (5) List of procedures/instructions that govern the implementation of plant modifications, maintenance, and special operations, and their impact on fire protection.
- (6) Coordination calculations and/or justifications that verify fuse/breaker coordination for selected fire zones/areas (to be determined during information gathering visit) that are fed off of the same electrical buses as components in the protected safe shutdown train.
- (7) Significant fire protection and post-fire safe shutdown related design change package descriptions (including their associated 10 CFR 50.59 evaluations) and Generic Letter (GL) 86-10 evaluations.
- (8) Gaseous suppression system pre-operational testing, if applicable, for selected fire zones/areas (to be determined during information gathering visit).

- (9) Hydraulic calculations and supporting test data which demonstrate operability for water suppression systems, if applicable, for selected fire zones/areas (to be determined during information gathering visit).
- (10) Alternating current (AC) coordination calculations for 4160 Vac down to 480 Vac electrical systems.
- (11) The three most recent fire protection Quality Assurance (QA) audits and/or fire protection self-assessments.
- (12) Corrective action documents (e.g., condition reports, including status of corrective actions) generated as a result of the three most recent fire protection Quality Assurance (QA) audits and/or fire protection self-assessments.

Information Requested to Be Provided Throughout the Inspection

- (1) Copies of any corrective action documents generated as a result of the team's questions or queries during this inspection.
- (2) Copies of the list of questions submitted by the team members and the status/resolution of the information requested (provide daily during the inspection to each team member).