

Richard L. Anderson
Vice President - Nuclear Operations

PPL Susquehanna, LLC
769 Salem /Boulevard
Berwick, PA 18603
Tel. 570.542.3883 Fax 570.542.1504
RLAnderson@pplweb.com



August 13, 2004

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop O-P1-17
Washington, D.C. 20555-0001

SUSQUEHANNA STEAM ELECTRIC STATION
MONTHLY OPERATING REPORTS
Docket Nos. 50-387/NPF-14 and 50-388/NPF-22
PLA-005799

The July 2004 Monthly Operating Reports for Susquehanna SES Units 1 and 2 are attached.

Very truly yours,

A handwritten signature in black ink, appearing to read "Richard L. Anderson", is written over a horizontal line.


Richard L. Anderson

JJH/cmm

cc: NRC Region 1
NRC Sr. Resident Inspector, Mr. A. Blamey
NRC Project Manager, Mr. R V. Guzman

JE24

OPERATING DATA REPORT



DOCKET NO.	50-387
UNIT	One
DATE	08/13/2004
COMPLETED BY	J. J. Hennings
TELEPHONE	(570) 542-3747

OPERATING STATUS


1. Unit Name: Susquehanna Steam Electric Station (U1)
2. Reporting Period: July 2004
3. Design Electrical Rating (Net MWe): 1177*
4. Maximum Dependable Capacity (Net MWe) 1135*

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>5,111</u>	<u>185,400</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>3,830.2</u>	<u>154,315.0</u>
7. Hours Generator On-Line	<u>744</u>	<u>3,780.4</u>	<u>152,020.0</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>842,572</u>	<u>4,045,505</u>	<u>156,658,943</u>

NOTES:

*Design Electrical Rating (DER) and Maximum Dependable Capacity (MDC) has been changed starting with the May reporting period due to turbine modifications that were completed in April.

UNIT SHUTDOWNS



DOCKET NO.	50-387
UNIT	One
DATE	08/13/2004
COMPLETED BY	J. J. Hennings
TELEPHONE	(570) 542-3747

REPORT MONTH July 2004

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action To Prevent Recurrence
						No shutdowns this month

Summary: There were no power reductions greater than 20% this month.

1.
F. Forced
S. Scheduled

2.
Reason:
A – Equipment Failure (Explain)
B – Maintenance or Test
C – Refueling
D – Regulatory Restriction

E – Operator Training & Licensee Exam
F – Administrative
G – Operational Error (Explain)

3.
Method:
1 – Manual
2 – Manual Scram
3 – Automatic Scram
4 – Continuation from
previous month
5 – Other

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-387

Completed by: J. J. Hennings


Date: 08/13/04

Telephone: (570) 542-3747

Challenges to Main Steam Safety Relief Valves

None.

OPERATING DATA REPORT



DOCKET NO.	<u>50-388</u>
UNIT	<u>Two</u>
DATE	<u>08/13/04</u>
COMPLETED BY	<u>J. J. Hennings</u>
TELEPHONE	<u>(570) 542-3747</u>


OPERATING STATUS

1. Unit Name: Susquehanna Steam Electric Station (U2)
2. Reporting Period: July 2004
3. Design Electrical Rating (Net MWe): 1182
4. Maximum Dependable Capacity (Net MWe): 1140

	This Month	Yr.-to-Date	Cumulative
5. Hours in Reporting Period	<u>744</u>	<u>5,111</u>	<u>170,640</u>
6. Number of Hours Reactor Was Critical	<u>744</u>	<u>5,111</u>	<u>149,006.8</u>
7. Hours Generator On-Line	<u>744</u>	<u>5,111</u>	<u>147,019.6</u>
8. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
9. Net Electrical Energy Generated (MWH)	<u>841,351</u>	<u>5,867,351</u>	<u>154,625,362</u>

NOTES:

UNIT SHUTDOWNS



DOCKET NO.	50-388
UNIT	Two
DATE	08/13/04
COMPLETED BY	J. J. Hennings
TELEPHONE	(570) 542-3747

REPORT MONTH July 2004

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Cause & Corrective Action to Prevent Recurrence
						No shutdowns this month.

Summary: On 07/29/04, reactor power was manually reduced to 78% power due to a loss of offgas/condenser vacuum caused by an electrical transient at a 13.8KV load center. Unit 2 returned to 100% power on 07/30/04.

1.

F. Forced
S. Scheduled

2.

Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & Licensee Exam
- F - Administrative
- G - Operational Error (Explain)

3.

Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Continuation from previous month
- 5 - Other

SUSQUEHANNA STEAM ELECTRIC STATION

Docket Number: 50-388
Completed by: J. J. Hennings

Date: 08/13/2004
Telephone: (570) 542-3747

Challenges to Main Steam Safety Relief Valves

None.