

Unknown

From: Stoetzel, Gregory A
Sent: Tuesday, May 25, 2004 4:07 PM
To: Parkhurst, Mary Ann
Cc: Miller, Beverly M; Hickey, Eva E
Subject: RE: Adequacy of RAI Responses

Mary Ann -

In my review of the RAI responses, I noted the following:

1. They did not provide responses to RAI E3.8-12 (provide RADTRAN runs), RAI E5.4.2-2 (LADTAP input parameters), and RAI E5.4.3-1 (question on how collective dose was calculated).
2. RAI E5.4.2-1 (regarding occupational doses) - The Applicant provided occupational dose estimates for several of the PPE reactor designs but did not provide a reference(s) for the estimates.

Thanks,

Greg

-----Original Message-----

From: Parkhurst, Mary Ann
Sent: Tuesday, May 25, 2004 8:49 AM
To: Vail, Lance W; Hendrickson, Paul L; Hickey, Eva E; Jaksch, John A; Miller, Beverly M; Neitzel, Duane A; Paul Nickens; Ramsdell, James V Jr (Van); Sackschewsky, Michael R; Sandusky, William F III; Stoetzel, Gregory A
Subject: Adequacy of RAI Responses

North Anna Crew,

Stacey is asking whether Dominion's responses to the RAI are adequate or whether a telecon is needed. Any feedback on them that I should pass on to NRC at this time?

Mary Ann Parkhurst
Battelle (PNNL), K3-55
(509) 375-6893
Fax (509) 375-6936
P. O. Box 999
Richland, WA 99352
[Express mail street address:
902 Battelle Blvd]

-----Original Message-----

From: Stacey Imboden [mailto: SXF@nrc.gov]
Sent: Tuesday, May 25, 2004 6:06 AM
To: Parkhurst, Mary Ann
Subject: Re: Dominion Nuclear North Anna, LLC North Anna Early Site Permit Application Response to Request for Additional Information Regarding Environmental Portion of ESP Application. Document Date: 05/17/2004

Mary Ann,

Regarding the Environmental RAI's sent in on 5/17 by Dominion, does the lab team feel that the responses are

adequate? Or do we need a telecon to clarify responses?

Thanks,
Stacey

>>> Michael Collins 05/24/04 05:01PM >>>
RE-DISTRIBUTED
w/corrected distribution list

ADAMS DISTRIBUTION NOTIFICATION.
D074 - Docket 52-008 - Dominion Energy (North Anna) Early Site Permit (ESP)

Title: Dominion Nuclear North Anna, LLC North Anna Early Site Permit Application Response to Request for Additional Information Regarding Environmental Portion of ESP Application. Docket Number: 05200008 Document Date: 05/17/2004 Author Name: Grecheck E S Author Affiliation: Dominion Nuclear North Anna, LLC Addressee Name: Addressee Affiliation: NRC/Document Control Desk
Document Type: Letter
Document Type: Request for Additional Information (RAI)
Availability: Publicly Available
Document Sensitivity: Non-Sensitive
Comment: Data files contained on CD-ROM Submitted with Document were not added to ADAMS. Copies of the CD-ROM are available from the NRC Public Document Room and the NRC File Center.

Electronic Recipients can RIGHT CLICK and OPEN the first Attachment to View the Document in ADAMS. The Document may also be viewed by searching for Accession Number ML041450037.

- Additional file - inserts for Section 4 3 7.msg
- Another question on GASPAR.msg
- Assessment of Technical Basis for ESP Spent Fuel Transporta.msg
- Computer Code Request.msg
- Files for Section 3 4 of North Anna EIS.msg
- Fresh Fuel Shipments.msg
- FW Another question on GASPAR.msg
- FW Gaspar Code.msg
- Gaspar Code.msg
- GASPAR input file for North Anna.msg
- GASPAR Population Dose Calculations.msg
- North Anna ESP Acceptance Review.msg
- North Anna GASPAR Analysis.msg
- North Anna sections.msg
- NRCDOSE Update.msg
- Question on NRCDOSE 2 3 2.msg
- RE Adequacy of RAI Responses.msg
- RE Another question on GASPAR.msg
- RE Comments to NRC.msg
- RE Fresh Fuel Shipments.msg
- RE NA Other Radionuclides.msg
- RE North Anna Accidents.msg

- RE North Anna GASPAR Analysis.msg
- RE North Anna Schedule and Info.msg
- RE Question on NRCDOSE 2 3 2.msg
- RE RADTRAN Case Matrix.msg
- RE Radtran Plans for North Anna men

RE: Adequacy of RAI Responses Properties

General | Recipients

 RE: Adequacy of RAI Responses

Type: Standard message form

Location: D:\NRC\North Anna\Predecisional-Disk2\Utortf

Size:

Sent: 05/25/2004 4:07:22 PM

Received: 05/25/2004 4:07:22 PM

Last changed: 03/09/2004 11:42:07 AM

Options for this item

<input type="checkbox"/>	Print	Properties
<input type="checkbox"/>	Print	Message
<input type="checkbox"/>	Copy	

Read Receipt requested: No

Delivery Receipt requested: No

OK Cancel Help

ADTRAN runs), RAI E5.4.2-2 (LADTAP input
 use was calculated).

ant provided occupational dose estimates for several
 for the estimates.

Original Message---

From: Parkhurst, Mary Ann

Sent: Tuesday, May 25, 2004 8:49 AM