

From: Michael Webb
To: WBrice@entergy.com
Date: 6/3/04 2:09PM
Subject: RAI Questions regarding RBS Drywell Bypass Test Interval Extension - With attachment

Bill,

I have attached RAI questions that were forwarded to me by the staff of the Civil and Engineering Mechanics Section of the Mechanical and Civil Engineering Branch of the Division of Engineering regarding River Bend Station License Amendment Request (LAR 2004-02) dated February 16, 2004, (NRC TAC MC2071) which seeks a one-time extension of the Drywell Bypass Test Interval.

After you and your colleagues have had a chance to evaluate them, we can set up a call to discuss them further if you desire to do so.

Thanks,
Mike Webb
NRC Project Manager for Rver Bend Station
301-415-1347

RIVER BEND STATION
DOCKET. 50-458
PM: Michael Webb

Mail Envelope Properties (40BF6948.95D : 5 : 21368)

Subject: RAI Questions regarding RBS Drywell Bypass Test Interval Extension -
With attachment

Creation Date: 6/3/04 2:09PM

From: Michael Webb

Created By: MKW@nrc.gov

Recipients	Action	Date & Time
entergy.com WBrice (<u>WBrice@entergy.com</u>)	Transferred	06/03/04 02:09PM
nrc.gov owf2_po.OWFN_DO SNB BC (Stewart Bailey)	Delivered Opened	06/03/04 02:09PM 06/03/04 03:41PM
nrc.gov owf4_po.OWFN_DO MKW BC (Michael Webb)	Delivered Opened	06/03/04 02:09PM 06/03/04 02:26PM
Post Office	Delivered	Route
owf2_po.OWFN_DO	06/03/04 02:09PM	entergy.com
owf4_po.OWFN_DO	06/03/04 02:09PM	nrc.gov
Files	Size	Date & Time
RBS DWBT RAIs EMEB.wpd	3819	06/03/04 02:03PM
MESSAGE	1400	06/03/04 02:09PM

Options

Auto Delete: No

Expiration Date: None

Notify Recipients: Yes

Priority: Standard

Reply Requested: No

Return Notification: None

Concealed Subject: No

Security: Standard

To Be Delivered: Immediate

Status Tracking: Delivered & Opened

REQUEST FOR ADDITIONAL INFORMATION
LICENSE AMENDMENT REQUEST LAR-2004-02
ONE-TIME EXTENSION OF DRYWELL BYPASS LEAKAGE TEST INTERVAL
RIVER BEND STATION, UNIT 1
TAC NO. MC2071

1. The amendment request states that two drywell bypass leakage tests (DBWTs) have been performed. Provide the results of these tests and describe any remedial actions taken to restore leakage to acceptable limits.
2. Discuss whether significant drywell leakage can be detected during normal operation.
3. The DWBTs and inspections complement each other in ensuring the structural and functional integrity of the drywell and containment. The amendment request does not provide information related to the structural and functional integrity of the drywell. Describe the inspections (i.e., inservice inspection program or other programs) used to verify the integrity of the drywell boundary, including the drywell head to flange connections and other drywell penetrations. Provide a summary of the acceptance criteria, degradations found during these examinations (including location, size, root cause, etc.), and corrective actions taken.

ATTACHMENT