

From: Nanette Gilles
To: Eddie Grant; Tom Mundy
Date: 7/23/04 9:23AM
Subject: DRAFT REQUEST FOR ADDITIONAL INFORMATION

RESENT DUE TO WRONG FILE BEING ATTACHED PREVIOUSLY

Please find attached a draft request for additional information (RAI) for the Clinton ESP review. This question pertains to the staff's review in the area of emergency planning (this is the formerly "missing" RAI 13.3-12). Exelon may request a phone call to seek clarification on the question before it is issued by letter. Please contact me to let me know if you wish to arrange such a call or if you have other questions.

Sincerely,

Nanette Gilles
Senior Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Phone (301) 415-1180

CC: Michael Scott; Raj Anand; Robert Moody

Mail Envelope Properties

(41011152.A76 : 20 : 21456)

Subject: DRAFT REQUEST FOR ADDITIONAL INFORMATION
Creation Date: 7/23/04 9:23AM
From: Nanette Gilles
Created By: NVG@nrc.gov

Recipients	Action	Date & Time
exeloncorp.com	Transferred	07/23/04 09:23AM
eddie.grant (Eddie Grant)		
thomas.mundy (Tom Mundy)		

nrc.gov		
owf4_po.OWFN_DO	Delivered	07/23/04 09:23AM
MLS3 CC (Michael Scott)	Opened	07/23/04 12:38PM
REM2 CC (Robert Moody)	Opened	07/23/04 09:24AM
RKA CC (Raj Anand)	Opened	07/23/04 09:30AM

Post Office	Delivered	Route
owf4_po.OWFN_DO	07/23/04 09:23AM	exeloncorp.com nrc.gov

Files	Size	Date & Time
--------------	-------------	------------------------

MESSAGE	1477	07/23/04 09:23AM
ClintonRAIs(3)_1.wpd	2582	05/27/04 09:51AM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened

RAI No. 13.3-12

Discuss the extent to which the Clinton early site permit application is intended to address Evaluation Criteria V.H.1 and V.H.2 of Supplement 2 to NUREG-0654/FEMA-REP-1 for the TSC, OSC, and EOF; including addressing NUREG-0696. If the application is intended to address these two Evaluation Criteria, provide additional information to address applicable NUREG-0696 criteria. Also, state whether or not Exelon intends to use the existing TSC, OSC, and EOF, which support the existing Clinton unit, for the ESP site. If so, provide information consistent with Evaluation Criteria V.H.1 and V.H.2 regarding the impact of the new reactor on these facilities.