

Detroit Edison



August 30, 2004
NRC-04-0065

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington D C 20555-0001

Reference: Fermi 2
NRC Docket No. 50-341
NRC License No. NPF-43

Subject: Transmittal of Cycle 10 Core Operating Limits Report, Revision 1

In accordance with Fermi 2 Technical Specification 5.6.5, Detroit Edison hereby submits a copy of the Core Operating Limits Report (COLR), Cycle 10, Revision 1. This COLR will be used until completion of the Fermi 2 tenth operating cycle.

Should you have any questions or require additional information, please contact me at (734) 586-4258.

Sincerely,

A handwritten signature in black ink, appearing to be 'N.K. Peterson'.

Norman K. Peterson
Manager – Nuclear Licensing

Enclosure

cc: E. R. Duncan [w/o Enclosure]
D. P. Beaulieu [w/ Enclosure]
NRC Resident Office [w/Enclosure]
Regional Administrator - Region III [w/Enclosure]
Supervisor, Electric Operators,
Michigan Public Service Commission [w/o Enclosure]

A001

**ENCLOSURE TO
NRC-04-0065**

**CORE OPERATING LIMITS REPORT
[COLR]**

CYCLE 10


REVISION 1


FERMI 2


CORE OPERATING LIMITS REPORT


CYCLE 10

REVISION 1

Prepared by:  8/25/2004
B. L. Myers
Technical Expert - Nuclear Fuel
Date

Reviewed by:  8/25/2004
T. W. Morrison
Station Nuclear Engineer
Date

 8/25/04
P. R. Kiel
COLR Checklist Reviewer
Date

Approved by:  8/25/04
for R. A. Gailliez ^{TMFR-04-0138}
Supervisor - Reactor Engineering
Date

August 2004

TABLE OF CONTENTS

1.0 INTRODUCTION AND SUMMARY	4
2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE	5
2.1 Definition	5
2.2 Determination of MAPLHGR Limit.....	5
2.2.1 Calculation of MAPFAC(P)	7
2.2.2 Calculation of MAPFAC(F)	8
3.0 MINIMUM CRITICAL POWER RATIO	9
3.1 Definition	9
3.2 Determination of Operating Limit MCPR	9
3.3 Calculation of MCPR(P).....	10
3.3.1 Calculation of K_p	11
3.3.2 Calculation of τ	12
3.4 Calculation of MCPR(F).....	13
4.0 LINEAR HEAT GENERATION RATE	14
4.1 Definition	14
4.2 Determination of LHGR Limit	14
4.2.1 Calculation of LHGRFAC(P)	15
4.2.2 Calculation of LHGRFAC(F)	17
5.0 CONTROL ROD BLOCK INSTRUMENTATION.....	18
5.1 Definition	18
6.0 REFERENCES	19

LIST OF TABLES

TABLE 1	FUEL TYPE-DEPENDENT STANDARD MAPLHGR LIMITS.....	6
TABLE 2	FLOW-DEPENDENT MAPLHGR LIMIT COEFFICIENTS.....	8
TABLE 3	OLMCPR _{100/105} AS A FUNCTION OF EXPOSURE AND τ	10
TABLE 4	FLOW-DEPENDENT MCPR LIMIT COEFFICIENTS.....	13
TABLE 5	STANDARD LHGR LIMITS FOR VARIOUS FUEL TYPES.....	14
TABLE 6	FLOW-DEPENDENT LHGR LIMIT COEFFICIENTS	17
TABLE 7	CONTROL ROD BLOCK INSTRUMENTATION SETPOINTS WITH FILTER.....	18

1.0 INTRODUCTION AND SUMMARY

This report provides the cycle specific plant operating limits, which are listed below, for Fermi 2, Cycle 10, as required by Technical Specification 5.6.5. The analytical methods used to determine these core operating limits are those previously reviewed and approved by the Nuclear Regulatory Commission in GESTAR II.

The cycle specific limits contained within this report are valid for the full range of the licensed operating domain.

<u>OPERATING LIMIT</u>	<u>TECHNICAL SPECIFICATION</u>
APLHGR	3.2.1
MCPR	3.2.2
LHGR	3.2.3
RBM	3.3.2.1

APLHGR	=	AVERAGE PLANAR LINEAR HEAT GENERATION RATE
MCPR	=	MINIMUM CRITICAL POWER RATIO
LHGR	=	LINEAR HEAT GENERATION RATE
RBM	=	ROD BLOCK MONITOR SETPOINTS

2.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE

TECH SPEC IDENT	OPERATING LIMIT
3.2.1	APLHGR

2.1 Definition

The AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR) shall be applicable to a specific planar height and is equal to the sum of the LINEAR HEAT GENERATION RATES (LHGRs) for all the fuel rods in the specified bundle at the specified height divided by the number of fuel rods in the fuel bundle at the height.

2.2 Determination of MAPLHGR Limit

The maximum APLHGR (MAPLHGR) limit is a function of reactor power, core flow, fuel type, and average planar exposure. The limit is developed, using NRC approved methodology described in References 1 and 2, to ensure gross cladding failure will not occur following a loss of coolant accident (LOCA). The MAPLHGR limit ensures that the peak clad temperature during a LOCA will not exceed the limits as specified in 10CFR50.46(b)(1) and that the fuel design analysis criteria defined in References 1 and 2 will be met.

The MAPLHGR limit during dual loop operation is calculated by the following equation:

$$MAPLHGR_{Limit} = \text{MIN} (MAPLHGR (P), MAPLHGR (F))$$

where:

$$MAPLHGR (P) = MAPFAC (P) \times MAPLHGR_{sm}$$

$$MAPLHGR (F) = MAPFAC (F) \times MAPLHGR_{sm}$$

Within four hours after entering single loop operation, the MAPLHGR limit is calculated by the following equation:

$$MAPLHGR_{Limit} = \text{MIN} (MAPLHGR (P), MAPLHGR (F), MAPLHGR (SLO))$$

where:

$$MAPLHGR (SLO) = 0.73 \times MAPLHGR_{sm}$$

MAPLHGR_{STD}, the standard MAPLHGR limit, is defined at a power of 3430 MWt and flow of 105 Mlbs/hr for each fuel type as a function of average planar exposure and is presented in Table 1. When hand calculations are required, MAPLHGR_{STD} shall be determined by interpolation from Table 1. MAPFAC(P), the core power-dependent MAPLHGR limit adjustment factor, shall be calculated by using Section 2.2.1. MAPFAC(F), the core flow-dependent MAPLHGR limit adjustment factor, shall be calculated by using Section 2.2.2.

**TABLE 1
FUEL TYPE-DEPENDENT
STANDARD MAPLHGR LIMITS**

<u>Exposure GWD/ST</u>	<u>MAPLHGR KW/FT</u>
0.0	13.42
19.72	13.42
27.22	12.29
63.50	8.90

This MAPLHGR Limit Array applies to all Cycle 10 fuel

Fuel Types

- | | |
|---|--|
| 14 = GE11-P9CUB380-12GZ-100T-146-T6 | 17 = GE11-P9CUB380-11GZ-100T-146-T6-2542 |
| 15 = GE11-P9CUB378-4G6/8G5-100T-146-T6-3955 | 18 = GE11-P9CUB404-12GZ-100T-146-T6-2543 |
| 16 = GE11-P9CUB396-13GZ-100T-146-T6-3954 | 19 = GE11-P9CUB408-12GZ-100T-146-T6-2604 |
| | 20 = GE11-P9CUB380-12GZ-100T-146-T6-2605 |

2.2.1 Calculation of MAPFAC(P)

The core power-dependent MAPLHGR limit adjustment factor, MAPFAC(P), shall be calculated by one of the following equations:

For $0 \leq P < 25$:

No thermal limits monitoring is required.

For $25 \leq P < 30$:

With turbine bypass OPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$MAPFAC(P) = 0.606 + 0.0038(P - 30)$$

For core flow > 50 Mlbs/hr,

$$MAPFAC(P) = 0.586 + 0.0038(P - 30)$$

With turbine bypass INOPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$MAPFAC(P) = 0.490 + 0.0050(P - 30)$$

For core flow > 50 Mlbs/hr,

$$MAPFAC(P) = 0.438 + 0.0050(P - 30)$$

For $30 \leq P \leq 100$:

$$MAPFAC(P) = 1.0 + 0.005224(P - 100)$$

where: P = Core power (fraction of rated power times 100).

2.2.2 Calculation of MAPFAC(F)

The core flow-dependent MAPLHGR limit adjustment factor, MAPFAC(F), shall be calculated by the following equation:

$$MAPFAC(F) = \text{MIN}(1.0, A_F \times \frac{WT}{100} + B_F)$$

where:

- WT = Core flow (Mlbs/hr).
- A_F = Given in Table 2.
- B_F = Given in Table 2.

TABLE 2 FLOW-DEPENDENT MAPLHGR LIMIT COEFFICIENTS

Maximum Core Flow* (Mlbs/hr)	A _F	B _F
110	0.67874	0.4358

*As limited by the Recirculation System MG Set mechanical scoop tube stop setting.

3.0 MINIMUM CRITICAL POWER RATIO

TECH SPEC IDENT	OPERATING LIMIT
3.2.2	MCPR

3.1 Definition

The MINIMUM CRITICAL POWER RATIO (MCPR) shall be the smallest Critical Power Ratio (CPR) that exists in the core for each type of fuel. The CPR is that power in the assembly that is calculated by application of the appropriate correlation(s) to cause some point in the assembly to experience boiling transition, divided by the actual assembly operating power.

3.2 Determination of Operating Limit MCPR

The required Operating Limit MCPR (OLMCPR) at steady-state rated power and flow operating conditions is derived from the established fuel cladding integrity Safety Limit MCPR and an analysis of abnormal operational transients. To ensure that the Safety Limit MCPR is not exceeded during any anticipated abnormal operational transient, the most limiting transients have been analyzed to determine which event will cause the largest reduction in CPR. Three different core average exposure conditions are evaluated. The result is an Operating Limit MCPR which is a function of exposure and τ . τ is a measure of scram speed, and is defined in Section 3.3.2.

The OLMCPR shall be calculated by the following equation:

$$OLMCPR = \text{MAX}(MCPR(P), MCPR(F))$$

MCPR(P), the core power-dependent MCPR operating limit, shall be calculated using Section 3.3.

MCPR(F), the core flow-dependent MCPR operating limit, shall be calculated using Section 3.4.

In case of Single Loop Operation, the Safety Limit MCPR is increased to account for increased uncertainties in core flow measurement and TIP measurement, but the OLMCPR does not change. This is due to the fact that sufficient conservatism exists in the power-dependent MCPR operating limits to allow for the increase in the SLMCPR without requiring a corresponding increase in the OLMCPR.

3.3 Calculation of MCPR(P)

MCPR(P), the core power-dependent MCPR operating limit, shall be calculated by the following equation:

$$MCPR(P) = K_P \times OLMCPR_{100/105}$$

K_P , the core power-dependent MCPR Operating Limit adjustment factor, shall be calculated by using Section 3.3.1.

$OLMCPR_{100/105}$ shall be determined by interpolation from Table 3, and τ shall be calculated by using Section 3.3.2.

TABLE 3 OLMCPR_{100/105} AS A FUNCTION OF EXPOSURE AND τ

<u>CONDITION</u>	<u>EXPOSURE (MWD/ST)</u>		<u>OLMCPR_{100/105}</u>
Both Turbine Bypass and Moisture Separator Reheater OPERABLE	BOC to 8800	$\tau = 0$	1.30
		$\tau = 1$	1.37
	8800 to 10300	$\tau = 0$	1.32
		$\tau = 1$	1.39
	10300 to EOC	$\tau = 0$	1.35
		$\tau = 1$	1.46
Either Turbine Bypass or Moisture Separator Reheater INOPERABLE	BOC to EOC	$\tau = 0$	1.40
		$\tau = 1$	1.51
Both Turbine Bypass and Moisture Separator Reheater INOPERABLE	BOC to EOC	$\tau = 0$	1.43
		$\tau = 1$	1.54

3.3.1 Calculation of K_P

The core power-dependent MCPR operating limit adjustment factor, K_P , shall be calculated by using one of the following equations:

For $0 \leq P < 25$:

No thermal limits monitoring is required.

For $25 \leq P < 30$:

When turbine bypass is OPERABLE,

$$K_P = \frac{(K_{BYP} + (0.026 \times (30 - P)))}{OLMCPR_{100/105}}$$

where: $K_{BYP} = 1.92$ for core flow ≤ 50 Mlbs/hr
 $= 2.25$ for core flow > 50 Mlbs/hr

When turbine bypass is INOPERABLE,

$$K_P = \frac{(K_{BYP} + (0.055 \times (30 - P)))}{OLMCPR_{100/105}}$$

where: $K_{BYP} = 2.28$ for core flow ≤ 50 Mlbs/hr
 $= 3.06$ for core flow > 50 Mlbs/hr

For $30 \leq P < 45$:

$$K_P = 1.28 + (0.0134 \times (45 - P))$$

For $45 \leq P < 60$:

$$K_P = 1.15 + (0.00867 \times (60 - P))$$

For $60 \leq P \leq 100$:

$$K_P = 1.0 + (0.00375 \times (100 - P))$$

where: $P =$ Core power (fraction of rated power times 100).

3.3.2 Calculation of τ

The value of τ , which is a measure of the conformance of the actual control rod scram times to the assumed average control rod scram time in the reload licensing analysis, shall be calculated by using the following equation:

$$\tau = \frac{(\tau_{ave} - \tau_B)}{\tau_A - \tau_B}$$

where: $\tau_A = 1.096$ seconds

$$\tau_B = 0.830 + 0.019 \times 1.65 \sqrt{\frac{N_1}{\sum_{i=1}^n N_i}} \text{ seconds}$$

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}$$

$n =$ number of surveillance tests performed to date in cycle,

$N_i =$ number of active control rods measured in the i^{th} surveillance test,

$\tau_i =$ average scram time to notch 36 of all rods measured in the i^{th} surveillance test, and

$N_1 =$ total number of active rods measured in the initial control rod scram time test for the cycle (Technical Specification Surveillance Requirement 3.1.4.4).

The value of τ shall be calculated and used to determine the applicable OLMCPR_{100/105} value from Table 3 within 72 hours of the conclusion of each control rod scram time surveillance test required by Technical Specification Surveillance Requirements 3.1.4.1, 3.1.4.2, and 3.1.4.4. Prior to performance of the initial scram time measurements for the cycle, a τ value of 1.0 shall be used to determine the applicable OLMCPR_{100/105} value from Table 3.

3.4 Calculation of MCPR(F)

MCPR(F), the core flow-dependent MCPR operating limit, shall be calculated by using the following equation:

$$MCPR(F) = \text{MAX}(1.21, (A_F \times \frac{WT}{100} + B_F))$$

where:

- WT = Core flow (Mlbs/hr).
- A_F = Given in Table 4.
- B_F = Given in Table 4.

TABLE 4 FLOW-DEPENDENT MCPR LIMIT COEFFICIENTS

Maximum Core Flow* (Mlbs/hr)	A _F	B _F
110	-0.6012	1.743

*As limited by the Recirculation System MG Set mechanical scoop tube stop setting.

4.0 LINEAR HEAT GENERATION RATE

TECH SPEC IDENT	OPERATING LIMIT
3.2.3	LHGR

4.1 Definition

The LINEAR HEAT GENERATION RATE (LHGR) shall be the heat generation rate per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the unit length. By maintaining the operating LHGR below the applicable LHGR limit, it is assured that all thermal-mechanical design bases and licensing limits for the fuel will be satisfied.

4.2 Determination of LHGR Limit

The maximum LHGR limit is a function of reactor power, core flow, fuel and rod type, and fuel rod nodal exposure. The limit is developed, using NRC approved methodology described in References 1 and 2, to ensure the cladding will not exceed its yield stress and that fuel thermal-mechanical design criteria will not be violated during any postulated transient events. The LHGR limit ensures the fuel mechanical design requirements as defined in References 1 and 2 will be met.

TABLE 5
STANDARD LHGR LIMITS FOR VARIOUS FUEL TYPES

Uranium Only Fuel Rods		Most Limiting Gadolinia Bearing Fuel Rods	
Exposure GWD/ST	LHGR KW/FT	Exposure GWD/ST	LHGR KW/FT
0.0	14.40	0.0	12.30
13.24	14.40	10.32	12.30
27.22	12.29	23.44	10.50
63.50	8.90	57.51	7.60

The LHGR Limit Arrays apply to all Cycle 10 fuel

Fuel Types

14 = GE11-P9CUB380-12GZ-100T-146-T6	17 = GE11-P9CUB380-11GZ-100T-146-T6-2542
15 = GE11-P9CUB378-4G6/8G5-100T-146-T6-3955	18 = GE11-P9CUB404-12GZ-100T-146-T6-2543
16 = GE11-P9CUB396-13GZ-100T-146-T6-3954	19 = GE11-P9CUB408-12GZ-100T-146-T6-2604
	20 = GE11-P9CUB380-12GZ-100T-146-T6-2605

The LHGR limit during dual loop operation is calculated by the following equation:

$$LHGR_{Limit} = \text{MIN} (LHGR (P), LHGR (F))$$

where:

$$LHGR (P) = LHGRFAC (P) \times LHGR_{std}$$

$$LHGR (F) = LHGRFAC (F) \times LHGR_{std}$$

LHGR_{STD}, the standard LHGR limit, is defined at a power of 3430 MWt and flow of 105 Mlbs/hr for each fuel and rod type as a function of fuel rod nodal exposure and is presented in Table 5. Table 5 contains only the most limiting Gadolinia LHGR limit for the maximum allowed Gadolinia concentration of the applicable fuel product line. When hand calculations are required, LHGR_{STD} shall be determined by interpolation from Table 5. LHGRFAC(P), the core power-dependent LHGR limit adjustment factor, shall be calculated by using Section 4.2.1. LHGRFAC(F), the core flow-dependent LHGR limit adjustment factor, shall be calculated by using Section 4.2.2.

4.2.1 Calculation of LHGRFAC(P)

The core power-dependent LHGR limit adjustment factor, LHGRFAC(P), shall be calculated by one of the following equations:

For $0 \leq P < 25$:

No thermal limits monitoring is required.

For $25 \leq P < 30$:

With turbine bypass OPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$LHGRFAC(P) = 0.606 + 0.0038 (P - 30)$$

For core flow > 50 Mlbs/hr,

$$LHGRFAC(P) = 0.586 + 0.0038 (P - 30)$$

With turbine bypass INOPERABLE,

For core flow ≤ 50 Mlbs/hr,

$$LHGRFAC(P) = 0.490 + 0.0050(P - 30)$$

For core flow > 50 Mlbs/hr,

$$LHGRFAC(P) = 0.438 + 0.0050(P - 30)$$

For $30 \leq P \leq 100$:

$$LHGRFAC(P) = 1.0 + 0.005224(P - 100)$$

where: $P =$ Core power (fraction of rated power times 100).

4.2.2 Calculation of LHGRFAC(F)

The core flow-dependent LHGR limit adjustment factor, LHGRFAC(F), shall be calculated by the following equation:

$$LHGRFAC(F) = \text{MIN}(1.0, A_F \times \frac{WT}{100} + B_F)$$

where:

- WT = Core flow (Mlbs/hr).
- A_F = Given in Table 6.
- B_F = Given in Table 6.

TABLE 6 FLOW-DEPENDENT LHGR LIMIT COEFFICIENTS

Maximum Core Flow* (Mlbs/hr)	A _F	B _F
110	0.67874	0.4358

*As limited by the Recirculation System MG Set mechanical scoop tube stop setting.

5.0 CONTROL ROD BLOCK INSTRUMENTATION

TECH SPEC IDENT	SETPOINT
3.3.2.1	RBM

5.1 Definition

The nominal trip setpoints and allowable values of the control rod withdrawal block instrumentation are shown in Table 6. These values are consistent with the bases of the APRM Rod Block Technical Specification Improvement Program (ARTS) and the MCPR operating limits.

TABLE 7 CONTROL ROD BLOCK INSTRUMENTATION SETPOINTS WITH FILTER

Setpoint	Trip Setpoint	Allowable Value
LPSP	27.0	28.4
IPSP	62.0	63.4
HPSP	82.0	83.4
LTSP	117.0	118.9
ITSP	112.2	114.1
HTSP	107.2	109.1
DTSP	94.0	92.3

where:

- LPSP Low power setpoint; Rod Block Monitor (RBM) System trip automatically bypassed below this level
- IPSP Intermediate power setpoint
- HPSP High power setpoint
- LTSP Low trip setpoint
- ITSP Intermediate trip setpoint
- HTSP High trip setpoint
- DTSP Downscale trip setpoint

6.0 REFERENCES

1. "General Electric Standard Application for Reactor Fuel (GESTAR II)," NEDE-24011-P-A, Revision 14 as amended by Amendment 25
2. "The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-of-Coolant Accident - SAFER/GESTR Application Methodology," NEDE 23785-1-PA, Revision 1, October 1984
3. "Fermi-2 SAFER/GESTR-LOCA, Loss-of-Coolant Accident Analysis," NEDC-31982P, July 1991, and Errata and Addenda No. 1, April 1992
4. "Fuel Bundle Information Report for Fermi 2 Reload 9 Cycle 10," Global Nuclear Fuel, 0000-0007-4899-FIBR, Revision 0, January 2003
5. "Supplemental Reload Licensing Report for Fermi 2 Reload 9, Cycle 10," Global Nuclear Fuel, 0000-0007-4899-SRLR, Revision 0, January 2003
6. Letter from T. G. Colburn to W. S. Orser, "Fermi-2 - Amendment No. 87 to Facility Operating License No. NPF-43 (TAC NO. M82102)," September 9, 1992
7. Letter from J. F. Stang to W. S. Orser, "Amendment No. 53 to Facility Operating License No. NPF-43: (TAC No. 69074)," July 27, 1990
8. "Maximum Extended Operating Domain Analysis for Detroit Edison Company Enrico Fermi Energy Center Unit 2," GE Nuclear Energy, NEDC-31843P, July 1990
9. "Cycle 10 Offrated ARTS Limits" letter TMFR 03-0061 from P. R. Kiel to File dated April 11, 2003
10. "Power Range Neutron Monitoring System," DC-4608, Vol. XI DCD, Rev. B and DC-4608 Vol. I Rev. D.
11. Letter from Andrew J. Kugler (USNRC) to Douglas R. Gipson (Detroit Edison), "Fermi-2 - Issuance of Amendment RE: Safety Limit Minimum Critical Power Ratio Limits for Cycle 8 (TAC NO. MA7372)," dated March 30, 2000
12. Letter from Greg Porter to B. L. Myers, "Scram Times for Improved Tech Specs." GP-99014, October 22, 1999 containing DRF A12-00038-3, Vol. 4 information from G. A. Watford, GE, to Distribution, Subject: Scram Times versus Notch Position

6.0 REFERENCES

13. Methodology and Uncertainties for Safety Limit MCPR Evaluations, NEDC-32601P-A, August 1999
14. Power Distribution Uncertainties for Safety Limit MCPR Evaluation, NEDC-32694P-A, August 1999
15. R-Factor Calculation Method for GE11, GE12, and GE13 Fuel, NEDC-32505P-A, Revision 1, July 1999
16. "Improved LHGR Limits (designated as "GE11/13-UPGRADE") for GE11 Fuel in Fermi," Global Nuclear Fuel, GNF-J1103057-265, August 2001
17. "Turbine Control Valve Out-Of-Service for Enrico Fermi Unit-2," GE -- Nuclear Energy, GE-NE-J11-03920-07-01, October 2001
18. Licensing Topical Report, "Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors," Volume 1, NEDO-24154-A 78NED290R1, August 1986
19. GE 10 CFR Part 21 Communication SC04-12, "Non-Conservative SLMCPR", August 24, 2004
20. GNF Letter from L. R. Conner to Linda Bugoci, "PRC SC04-12 Impact on Fermi 2 Cycle 10 Safety and Operating Limits", LRC-DTE-KH1-04-067, dated August 24, 2004