

**4rd NRC – AERB Nuclear Safety Projects Meeting  
August 30 – September 3, 2004**

# **Passive System LOCA Frequency Development for Risk-Informed Revision of 10 CFR 50.46**



Robert L Tregoning, Senior Materials Engineer  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Regulatory Research  
Email: [rlt@nrc.gov](mailto:rlt@nrc.gov) Phone: 301-415-6657



## United States Nuclear Regulatory Commission

### Motivation

- Determine part of the technical basis for developing alternative design basis break size for use in 10 CFR 50.46, Appendix K, and GDC 35 (Emergency Core Cooling System Rule).

### Scope and Objectives

- Develop piping and non-piping passive system LOCA frequencies as a function of leak rate and operating time up to the end of the license extension period using expert elicitation.
- Determine LOCA frequency distributions for typical plant operational cycle and history.



## United States Nuclear Regulatory Commission

### Expert Elicitation Process

- Expert opinion (elicitation) is a formal process for providing quantitative estimates for the frequency of physical phenomena when the required data is sparse or when the subject is too complex to adequately model.
  - LOCA events are rare.
  - Number and disparity of possible failure modes is too complex to accurately model.
- Elicitation has been used at NRC previously.
  - Development of seismic hazard curves.
  - Performance assessments for high-level radioactive waste repository.
  - Determination of reactor pressure vessel flaw distributions.



## United States Nuclear Regulatory Commission

### Formal Elicitation Approach

- Select panel and facilitation team.
- Develop technical issues.
- Quantify base case estimates.
  - Develop quantitative estimates for well-defined piping conditions.
  - Two estimates using PFM and two estimates from service history analysis.
  - Quantify non-piping precursors and targeted failure scenarios.
- Formulate elicitation questions.
- Conduct individual elicitations.
- Analyze quantitative results and qualitative rationale.
- Summarize and document results.



## United States Nuclear Regulatory Commission

### LOCA Size Classification


- LOCA sizes based on leak rate to group plant system response characteristics.
- First three categories encompassed traditional definitions utilized in NUREG-1150 and NUREG/CR-5750.
- Three more LBLOCA categories added to examine trends with larger break sizes.

Category	Leak Rate Threshold (gpm)	LOCA Size
1	> 100	SB
2	> 1500	MB
3	> 5000	LB
4	> 25,000	LB a
5	> 100,000	LB b
6	> 500,000	LB c



# United States Nuclear Regulatory Commission

## General Issue Classification



- Elicitation focuses on passive system LOCAs.
- Important piping and non-piping variables identified.
- Elicitation structures supports top down and bottom up analysis.



## United States Nuclear Regulatory Commission

### Elicitation Questions


- Questions on the following topic areas.
  - Base Case Evaluation.
  - Regulatory and Utility Safety Culture pertaining to LOCA initiating events.
  - LOCA frequencies of Piping Components.
  - LOCA frequencies of Non-Piping Components.
- Questions are asked relevant to a set of conditions and quantitatively linked to the base case results.
- Each question asks for mid, low, and high values.
- Rationale is provided and discussed for important issues and values provided by each expert.



# United States Nuclear Regulatory Commission

## Total LOCA Frequencies

- BWR.
  - Decreases are gradual with LOCA size due to IGSCC concerns.
  - Only non-piping failures contribute to largest breaks.
- PWR.
  - Smallest LOCA frequencies are high due to steam generator and CRDM concerns.
  - Non-piping frequency contributions are also important largest LOCA sizes.








# United States Nuclear Regulatory Commission

## Comparison with Prior Studies

Plant Type	LOCA Size	Current Day (25 yrs)
		Comparison with NUREG/CR-5750 (Current/CR-5750)
BWR	SB	0.7
	MB	2.6
	LB	0.3
PWR	SB	0.8
	MB	7.2
	LB	0.6



- Frequencies are lower than WASH-1400 estimates.
- Elicitation and NUREG/CR-5750 results are comparable.



## United States Nuclear Regulatory Commission

### Summary

- Formal elicitation process used to estimate generic BWR and PWR passive-system LOCA frequencies.
- Developed quantitative estimates for piping and non-piping base cases for anchoring elicitation responses.
- Panelists provided quantitative estimates supported by qualitative rationale.
- Results.
  - Generally good agreement about LOCA contributing factors.
  - Large individual uncertainty and panel variability in quantifying estimates.
  - Results are comparable to NUREG/CR-5750 estimates.