

September 13, 2004

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNIT 1 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING THE ALLOWABLE VALUE FOR REACTOR
VESSEL WATER LEVEL (TAC NO. MC2305)

Dear Mr. Singer:

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated March 9, 2004, the Tennessee Valley Authority submitted an application to revise the Technical Specifications and the licensing basis for the Browns Ferry Nuclear Plant, Unit 1. The proposed revision is related to the reduction of the allowable value used for the reactor vessel water level for several instrument functions.

The NRC staff has reviewed your submittal and finds that a response to the enclosed request for additional information is needed before we can complete the review. This request was discussed with Mr. Steven Kane of your staff on August 9, 2004, and it was agreed that a response would be provided within 30 days of receipt of this letter. If you have any questions, please contact me at (301) 415-1496.

Sincerely,

/RA/

Kahtan N. Jabbour, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-259

Enclosure: Request for Additional Information

cc w/encl: See next page

September 13, 2004

Mr. Karl W. Singer
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: BROWNS FERRY NUCLEAR PLANT, UNIT 1 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING THE ALLOWABLE VALUE FOR REACTOR
VESSEL WATER LEVEL (TAC NO. MC2305)

Dear Mr. Singer:

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated March 9, 2004, the Tennessee Valley Authority submitted an application to revise the Technical Specifications and the licensing basis for the Browns Ferry Nuclear Plant, Unit 1. The proposed revision is related to the reduction of the allowable value used for the reactor vessel water level for several instrument functions.

The NRC staff has reviewed your submittal and finds that a response to the enclosed request for additional information is needed before we can complete the review. This request was discussed with Mr. Steven Kane of your staff on August 9, 2004, and it was agreed that a response would be provided within 30 days of receipt of this letter. If you have any questions, please contact me at (301) 415-1496.

Sincerely,

/RA/

Kahtan N. Jabbour, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-259

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsOgcRp
PDII-2 R/F	RidsAcrsAcnwMailCenter
RidsNrrDlpmLpdii-2 (MMarshall)	RidsRgn2MailCenter (SCahill)
RidsNrrLABClayton (Hard Copy)	RidsNrrDlpmDpr
GThomas	FAkstulewicz
RidsNrrPMKJabbour	EMarinos
HLi	CGratton

ADAMS Accession No.: ML042570212

NRR-088

OFFICE	PDII-2/PM	PDII-2/LA	SRSB/SC	EEIB/SC	PDII-2/SC(A)
NAME	KJabbour	BClayton	FAkstulewicz	EMarinos	MMarshall
DATE	9/10/04	9/10/04	9/10/04	9/13/04	9/13/04

OFFICIAL RECORD COPY

Mr. Karl W. Singer
Tennessee Valley Authority

BROWNS FERRY NUCLEAR PLANT

cc:

Mr. Ashok S. Bhatnagar, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Robert G. Jones
Browns Ferry Unit 1 Plant Restart Manager
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. James E. Maddox, Vice President
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Kurt Krueger, Plant Manager
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Timothy E. Abney, Manager
Licensing and Industry Affairs
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Michael D. Skaggs
Site Vice President
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, AL 35611

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

State Health Officer
Alabama Dept. of Public Health
RSA Tower - Administration
Suite 1552
P.O. Box 303017
Montgomery, AL 36130-3017

Mr. John C. Fornicola, Manager
Nuclear Assurance and Licensing
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Chairman
Limestone County Commission
310 West Washington Street
Athens, AL 35611

Mr. Jon R. Rupert, Vice President
Browns Ferry Unit 1 Restart
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

REQUEST FOR ADDITIONAL INFORMATION

ALLOWABLE VALUE FOR REACTOR VESSEL WATER LEVEL

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNIT 1

DOCKET NO. 50-259

1. Please provide a copy of the document that calculates the new instrument allowable value for Reactor Vessel Water Level - Low (Level 3) function. Discuss the instrument setpoint methodology used to calculate the allowable values.
2. The proposed new allowable value of the Reactor Vessel Water Level - Low is about 10 inches below the original allowable value, that will delay the protective action to mitigate the consequence of an accident. Please discuss any impact to the automatic load sequencer initiation which will provide emergency power to the Emergency Core Cooling System (ECCS) related components.
3. The original Level 3 allowable value in the Reactor Protection System (RPS) was 538 inches, and in the ECCS was 544 inches. The proposed new Level 3 allowable value in the RPS and in the ECCS are set at the same allowable value of 528 inches. Discuss any impact on system interaction by setting at the same value.
4. Please provide a simplified figure that shows, as a minimum, the elevations of the water in the reactor vessel for Level 3 and the top of active fuel.
5. Please discuss the assumptions that resulted in a small reduction of the peak clad temperature for a small-break loss-of-coolant accident analysis.

Enclosure