

September 16, 2004

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON SEPTEMBER 8, 2004, TO DISCUSS
RESOLUTION OF THE STAFF'S OUTSTANDING QUESTIONS/CONCERNS
REGARDING LEAK-BEFORE-BREAK AS APPLIED TO LICENSE
AMENDMENT REQUEST (LAR) 03-18 FOR THE STEAM GENERATOR
4-VOLT ALTERNATE REPAIR CRITERIA

On September 8, 2004, representatives of Pacific Gas & Electric Company (PG&E) met with the NRC staff to make a presentation on their resolution of the staff's outstanding questions/concerns regarding leak-before-break (LBB) as applied to LAR 03-18 for the steam generator 4-volt alternate repair criteria.

The meeting began with PG&E's discussion of the purpose of LBB, main steam line leak detection system (LDS), fracture mechanics perspective on LDS response time, no need for technical specifications to control LDS, and the LDS sensitivity analysis.

The staff had questions on the presentation. In response, PG&E stated that they will consider installing a new, diverse, redundant leak detection system. PG&E also stated that they will submit the response to the staff's request for additional information for the review and approval of the LAR. Following the meeting, the staff expressed its appreciation to PG&E for their presentation.

An attendance list is provided in the attachment. The presentation slides used during the meeting are available in ADAMS under Accession No. ML042530674.

/RA/

Girija S. Shukla, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Attachment: Attendance List

cc w/att: See next page

September 16, 2004

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF MEETING HELD ON SEPTEMBER 8, 2004, TO DISCUSS
RESOLUTION OF THE STAFF'S OUTSTANDING QUESTIONS/CONCERNS
REGARDING LEAK-BEFORE-BREAK AS APPLIED TO LICENSE
AMENDMENT REQUEST (LAR) 03-18 FOR THE STEAM GENERATOR
4-VOLT ALTERNATE REPAIR CRITERIA

On September 8, 2004, representatives of Pacific Gas & Electric Company (PG&E) met with the NRC staff to make a presentation on their resolution of the staff's outstanding questions/concerns regarding leak-before-break (LBB) as applied to LAR 03-18 for the steam generator 4-volt alternate repair criteria.

The meeting began with PG&E's discussion of the purpose of LBB, main steam line leak detection system (LDS), fracture mechanics perspective on LDS response time, no need for technical specifications to control LDS, and the LDS sensitivity analysis.

The staff had questions on the presentation. In response, PG&E stated that they will consider installing a new, diverse, redundant leak detection system. PG&E also stated that they will submit the response to the staff's request for additional information for the review and approval of the LAR. Following the meeting, the staff expressed its appreciation to PG&E for their presentation.

An attendance list is provided in the attachment. The presentation slides used during the meeting are available in ADAMS under Accession No. ML042530674.

/RA/

Girija S. Shukla, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Attachment: Attendance List

cc w/att: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDlpmLpdiv2 (RGramm)
PDIV-2 Reading	JTatum
RidsNrrDlpm (LMarsh/JLyons)	JTsao
RidsNrrDlpmLpdiv (HBerkow)	PYChen
RidsNrrPMGShukla	SLong
RidsNrrLAEPeyton	PLoeser
RidsOgcMailCenter	KKavanagh
RidsAcrcAcnwMailCenter	BJones (Region IV)
TMensah (NRR/PMAS)	JDixon-Herrey

Package No.: ML042580441

Meeting Notice: ML042460331

ADAMS Accession No.: ML042580429

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	GShukla:mp	EPeyton	RGramm
DATE	9/16/04	9/15/04	9/16/04

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML042580429.wpd

MEETING WITH PACIFIC GAS AND ELECTRIC COMPANY

ATTENDANCE LIST

SEPTEMBER 8, 2004

PACIFIC GAS & ELECTRIC COMPANY

S. Ketelsen
T. Baldwin
M. Mayer

OTHER

A. Deardorff (Structural Integrity Associates)
T. Menelly (Westinghouse)

NRC

R. Gramm
G. Shukla
J. Tatum
J. Tsao
P. Y. Chen
S. Long
P. Loeser
K. Kavanagh
J. Dixon-Herrity

Diablo Canyon Power Plant, Units 1 and 2

cc:

NRC Resident Inspector
Diablo Canyon Power Plant
c/o U.S. Nuclear Regulatory Commission
P.O. Box 369
Avila Beach, CA 93424

Sierra Club San Lucia Chapter
c/o Henriette Groot
1000 Montecito Road
Cayucos, CA 93430

Ms. Nancy Culver
San Luis Obispo
Mothers for Peace
P.O. Box 164
Pismo Beach, CA 93448

Chairman
San Luis Obispo County Board of
Supervisors
Room 370
County Government Center
San Luis Obispo, CA 93408

Mr. Truman Burns
Mr. Robert Kinoshian
California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, CA 94102

Diablo Canyon Independent Safety
Committee
ATTN: Robert R. Wellington, Esq.
Legal Counsel
857 Cass Street, Suite D
Monterey, CA 93940

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Richard F. Locke, Esq.
Pacific Gas & Electric Company
P.O. Box 7442
San Francisco, CA 94120

Mr. David H. Oatley, Vice President
and General Manager
Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

City Editor
The Tribune
3825 South Higuera Street
P.O. Box 112
San Luis Obispo, CA 93406-0112

Mr. Ed Bailey, Chief
Radiologic Health Branch
State Department of Health Services
P.O. Box 997414 (MS 7610)
Sacramento, CA 95899-7414

Mr. James D. Boyd, Commissioner
California Energy Commission
1516 Ninth Street (MS 31)
Sacramento, CA 95814

Mr. James R. Becker, Vice President
Diablo Canyon Operations
and Station Director
Diablo Canyon Power Plant
P.O. Box 3
Avila Beach, CA 93424

Mr. Gregory M. Rueger
Senior Vice President, Generation and
Chief Nuclear Officer
Pacific Gas and Electric Company
Diablo Canyon Power Plant
P.O. Box 3
Avila Beach, CA 93424