



444 South 16th Street Mall
Omaha NE 68102-2247

September 14, 2004
LIC-04-0026

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: August 2004 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for August 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

A handwritten signature in black ink, appearing to read "D. Bannister".

D. J. Bannister
Manager – Fort Calhoun Station

DJB/EPM/epm

Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME **Fort Calhoun Station**
DATE September 2, 2004
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: August 2004

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	744	5,591	220,4590
Number of Hours Generator was On-line:	744	5,574	219,099
Unit Reserve Shutdown Hours:	0		
Net Electrical Energy Generated (MWh):	351,015	2,655,952	95,182,054

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the month of August 2004.