



FRAMATOME ANP

An AREVA and Siemens Company

FRAMATOME ANP, Inc.

September 10, 2004
NRC:04:051

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Comments on Draft Safety Evaluation for BAW-10241(P), Revision 0, "BHTP DNB Correlation Applied with LYNXT"

Ref.: 1. Letter, Stephen Dembek (NRC) to James F. Mallay (Framatome ANP), "Draft Safety Evaluation for Topical Report BAW-10241P, Revision 0, 'BHTP Correlation Applied in LYNXT' (TAC No. MB7033)," August 30, 2004.

The NRC issued a draft safety evaluation on BAW-10241(P) and requested that Framatome ANP review the document for proprietary material and for any factual errors (Reference 1). Framatome ANP has reviewed the draft SER provided in Reference 1.

We have determined that the draft safety evaluation contains information that was identified in the topical report as being proprietary information. A marked-up copy of the draft SER is provided in Attachment A omitting the proprietary information and identifying three minor clarifications.

Attachment B provides a summary table of the omitted proprietary information and minor clarifications.

Framatome appreciates this opportunity to offer clarifying comments.

Very truly yours,


James F. Mallay, Director
Regulatory Affairs

Enclosures

cc: M. C. Honcharik
Project 728

TO/IO
Y601

Attachment A



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

BAW-10241P, REVISION 0, "BHTP DNB CORRELATION APPLIED WITH LYNXT"

FRAMTOME ANP

PROJECT NO. 728

1 **1.0 INTRODUCTION**

2 By letter dated December 19, 2002 (Reference 1), Framatome ANP (FANP) requested NRC
3 review of topical report (TR) BAW-10241P, "BHTP DNB Correlation Applied with LYNXT." This
4 TR describes a departure from nucleate boiling (DNB) correlation that has been developed
5 using the LYNXT thermal-hydraulic code (Reference 2) for fuel designs equipped with high
6 thermal performance (HTP) spacer grids. The BHTP DNB correlation is based on the approved
7 HTP DNB correlation (Reference 3). Adjustments have been made in some of the coefficients
8 (A, B, and HTERM) used to describe the performance of this spacer grid design when the
9 LYNXT (Reference 4) code is used. The HTP DNB correlation was developed using the
10 XCOBRA-IIIC thermal-hydraulic code (Reference 5).

11 The review includes the subject TR and supplemental information provided by FANP in letters
12 dated June 6 and September 3, 2003, and February 11, June 17, and August 9, 2004
13 (References 6 through 10).

14 **2.0 REGULATORY EVALUATION**

15 The requirement for analysis of this type originates in Title 10 of the *Code of Federal*
16 *Regulations* Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants."
17 Specifically, Criterion 10, "Reactor Design" applies. Criterion 10 states:

18 The reactor core and associated coolant, control, and protection systems shall
19 be designed with appropriate margin to assure that specified acceptable fuel
20 design limits are not exceeded during any condition of normal operation,
21 including the effects of anticipated operational occurrences.

22 NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear
23 Power Plants," Sections 4.2, "Fuel System Design" and 4.4, "Thermal and Hydraulic Design,"
24 provide detailed guidance that is acceptable to the staff in meeting the regulatory requirements
25 given above. FANP has applied this guidance in BAW-10241P, Revision 0.

- 2 -

1 **3.0 SUMMARY OF TOPICAL REPORT**

2 BAW-10241P documents ^{the} development of the FANP BHTP DNB correlation applied with LYNXT
3 for use in DNB analysis of ~~Mark-BHTP~~ BHTP fuel design. BHTP represents an extension of the
4 previously approved HTP correlation. The primary difference between the two codes (LYNXT
5 versus XCOBRA-IIIC) associated with critical heat flux (CHF) data reduction is the water
6 properties (Reference 5, ASME property functions versus ASME saturated steam table).

7 The data from a high pressure test loop at Columbia University's ^{BHTP} Heat Transfer Research
8 Facility (Reference 3) were used as a data base for the BHTP correlation development. The
9 BHTP data base (Reference 7) consists of data from ~~test sections~~
10 representing the typical Westinghouse HTP designs used for FANP development and ~~test sections~~
11 ~~representing the typical Westinghouse HTP designs used for FANP development and~~
12 ~~representing the typical Westinghouse HTP designs used for FANP development and~~ other vendors' HTP designs in heated lengths, power shapes,
13 presence of spacers and, in some cases, containing intermediate flow mixers (IFMs).

13 A complete summary of the measured data and the predicted values of relevant variables to the
14 development of the correlation is provided in Reference 7. Dependence of the BHTP
15 correlation on fuel design parameters is also described in the TR. Comparison of correlation
16 predictions to experimental measurements are provided as qualification of its adequacy. The
17 determination of the 95/95 safety limit for BHTP is discussed in the subject submittal
18 (Reference 2).

19 **4.0 TECHNICAL EVALUATION**

20 **4.1 BHTP Test Data Base Description**

21 The BHTP correlation data base consists of ~~data points~~ data points from ~~tests~~ tests performed in a high
22 pressure test loop at the Columbia University Heat Transfer Research Facility.

23 These test section characteristics were varied to represent fuel array design for 14x14 through
24 17x17 rod arrays using both uniform and non-uniform axial power shape. The radial power
25 distribution was non-uniform for all test assemblies. Rod positions were maintained by HTP
26 spacers. The tests were conducted with assemblies with and without IFMs. Fuel design
27 parameters of the test assemblies varied: from 0.36 to 0.44 inch for the fuel rod diameter; from
28 0.496 to 0.580 inch for the rod pitch; from 8 to 26.4 inches for the axial spacer span; from 0.457
29 to 0.533 inch for the lattice subchannel hydraulic diameter; and from 7.9 to 14 feet for heated
30 length. Established coolant conditions (Reference 7) of the tests varied: from 1775 to 2425
31 psia for pressure; from 0.897 to 3.549 Mb/hft² for local mass flux; from 383.9 to 644.3 Btu/lb
32 for inlet enthalpy; and from -0.130 to 0.344 for local quality.

33 Thermocouples are employed to detect the occurrence of DNB in the tests. They are located at
34 the axial position listed in Table 3.5 of Reference 3. For each set of ~~Mark-BHTP~~ BHTP spacer grid
35 bundle test data, the LYNXT code was used to predict the local thermal-hydraulic conditions
36 (mass velocity, thermodynamic quality, heat flux, and pressure) axially along the test section
37 heated length. The predicted local conditions at the point of detected burnout are provided in
38 the summary of results for the BHTP data base (Reference 7).

- 3 -

1 4.2 BHTP DNB Correlation Development

2 The correlation is an empirically derived function of the local coolant thermodynamic state and
3 mass flux at which DNB is observed to occur in the experiment. The base correlation is
4 developed based on local coolant conditions at the point of DNB predicted from test data for the
5 uniform axial power distribution. The local coolant conditions are calculated with the approved
6 LYNXT computer code (Reference 4). The predicted DNB heat flux is modified by factors
7 which account for the effect of non-uniform axial power distribution and fuel assembly design
8 parameters. This aspect is the same as the formulation used in the approved HTP DNB
9 correlation (Reference 3).

10 The local conditions data from each CHF test statepoint form the data base for the BHTP CHF
11 correlation. These data (mass velocity, thermal dynamic quality, heat flux, pressure, local
12 thermodynamic quality and axial location) were used to determine the coefficients of the BHTP
13 CHF correlation. The method used for coefficient determination is a least squares fit that
14 minimizes the deviation of predicted CHF to the measured CHF ratio of predicted over
15 measured (P/M) around a mean of 1.0. All the BHTP coefficients were re-optimized with the
16 exception of those in the fuel design factor (FDF) term that includes coefficients b7 through
17 b14. The BHTP correlation optimization is documented in the FANP calculational file
18 supporting TR BAW-10241P.

19 The BHTP DNB correlation is used in the following steps: (1) local coolant conditions are
20 calculated as a function of radial and axial position within the assembly with a LYNXT
21 subchannel model; (2) the DNB heat flux is calculated at each position within the assembly
22 using the local coolant conditions determined in step 1; and (3) the DNB ratio is calculated as
23 the ratio of predicted DNB heat flux to operating heat flux at each position within the assembly.
24 Minimum DNB ratio (MDNBR) is selected as the least value of the DNB ratio to occur in the
25 assembly. The MDNBR is then used as a measure of the margin to DNB for the operating
26 assembly.

27 4.3 Qualification of BHTP DNB Correlation

28 The approved LYNXT computer code was used to predict DNB heat fluxes to be compared
29 against the measured heat fluxes. The key variables measured at the point of DNB, such as
30 inlet temperature, inlet mass flux, exit pressure and bundle power, were used as boundary
31 conditions in the LYNXT calculations.

32 Comparison between the predicted location of DNB and the heated rod and thermocouple
33 number at which the primary DNB indication was recorded, indicated the adequacy of the
34 model. The P/M heat fluxes were plotted for all tests to indicate the degree of agreement
35 between the prediction using the BHTP correlation and the measured data. The plots showed
36 good agreement in tests and for the other cases nearly all the data fell within the 95/95
37 tolerance limit lines.

38 The frequency distribution of P/M ratios for the entire data base was used to determine the
39 95/95 safety limit for the HTP correlation using a distribution free method, the same method
40 which had been used to determine the HTP DNB correlation limit (Reference 2).

- 4 -

1 4.4 Applicability of BHTP Correlation

2 The DNB-based safety limit for the first plant to use the Mark-BHTP fuel design will
3 conservatively represent the allowable pressure-temperature conditions for transition core
4 situations (Mark-B10 fuel with Mark-BHTP fuel), as well as the full core situation (all Mark-BHTP
5 fuel) (Reference 6). Operational and safety limits are being set for core power level, axial
6 power imbalance, control rod insertion, and maximum rod relative power to preserve acceptable
7 DNB performance based on the BHTP correlation predictions. In addition, a variable low
8 pressure trip function provides protection to assure the plant does not reach or exceed the
9 DNB-based safety limit of the technical specifications. The DNB-based operational and safety
10 limits established for the plant provide hot pin/hot subchannel protection for acceptable plant
11 operation, based on the local coolant conditions satisfying the correlation range of applicability
12 defined in Table 1.1 of BAW-10241P. In response to the staff concern on the actions to be
13 taken when local conditions fall outside the application ranges for limiting hot rod/hot
14 subchannel, a treatment for qualities below the low quality limit and for pressures above the
15 upper pressure limit was addressed in Reference 9. The staff has reviewed the justification for
16 the approach to treat the out-of-approved range local conditions and has found them
17 acceptable in principle, because the approach will result in a conservative CHF value.
18 However, the staff will impose an allowable extension beyond the approved range for maximum
19 pressure, but not exceeding 2600 psia and there will be no limit below the approved range for
20 minimum quality. It will be subject to plant-specific review if the condition cannot be met. This
21 conclusion is only applied to this review based on the data bases available to support the
22 subject TR.

23 The BHTP correlation range of applicability, stated in Table 1.1 of BAW-10241P for local
24 coolant conditions, is used in establishing the DNB-based limits associated with the above
25 described operational and safety limits. The BHTP correlation range of applicability, stated in
26 Table 1.2 of BAW-10241P, for fuel design parameters must be verified by the licensee prior to
27 performing any DNB analyses using the BHTP correlation. The staff has reviewed acceptable
28 ranges for both local coolant conditions and fuel design parameters against the BHTP data
29 base in BAW-10241P and the data base in Reference 3. The acceptable ranges are provided
30 in Table 1 and Table 2 attached to this safety evaluation.

31 5.0 CONCLUSION

32 The staff has reviewed BAW-10241P and the supplemental information (References 6 through
33 10) to determine acceptability of the BHTP correlation for use in DNB analysis of the HTP fuels
34 and has concluded as follows:

- 35 (1) Based on the data in Reference 3, the BHTP DNB correlation is applicable to fuels
36 whose design characteristics fall within the correlation data base in Table 2 below.
- 37 (2) Based on the data in Reference 7, the application of the BHTP correlation for DNB
38 analysis is restricted to the operating conditions given in Table 1, except as noted in
39 Condition 5 below.
- 40 (3) The BHTP correlation limit is determined to be as stated in the subject TR
41 (Reference 2).

- 5 -

- 1 (4) DNB penalty relative to DNB prediction for a full core of Mark-BHTP fuel during
2 transition core application shall be addressed in the plant-specific application.
- 3 (5) Actions for analyzing the operating conditions outside of the approved ranges of the
4 maximum pressure, but less than 2500 psia are acceptable in principle for this
5 application (Reference 9). Extrapolations below the minimum quality range using the
6 process described in the TR are permitted with no lower limit. Any other extrapolation
7 requires a plant-specific review.
- 8 6.0 REFERENCES
- 9 1. Letter from James F. Mallay, Framatome ANP to USNRC, Issuance of BAW-10241P,
10 "BHTP DNB Correlation Applied with LYNXT," for Review and Acceptance, dated
11 December 19, 2002. (ADAMS Accession No. ML023600367)
- 12 2. Topical Report BAW-10241P, Revision 0, "BHTP DNB Correlation Applied with LYNXT,"
13 December 2002. (ADAMS Accession Nos. ML023600394; non-proprietary version
14 ML023600376)
- 15 3. EMF-92-153(P)(A), Supplement 1, "HTP: Departure from Nuclear Boiling Correlation for
16 High Thermal Performance Fuel," March 1994. (ADAMS Accession Nos. 9403240220
17 for letter; 943240228 for proprietary version of TR; 9403240222 for non-proprietary
18 version of TR)
- 19 4. BAW-10156-A, Revision 1, "LYNXT Core Transient Thermal-Hydraulic Program,"
20 August 1993. (ADAMS Accession Nos. 9309130187 for letter; 09130194 for TR)
- 21 5. XN-NF-75-21(P)(A), Revision 2, "XCOBRA-IIIC: A Computer Code to Determine the
22 Distribution of Coolant during Steady State and Transient Operation," January 1986.
23 (ADAMS Accession No. 8605140222)
- 24 6. Letter from James F. Mallay, Framatome ANP to USNRC, "Response to RAI [Request
25 for Additional Information] Regarding BAW-10241(P), Revision 0, 'BHTP DNB
26 Correlation Applied with LYNXT,'" dated June 6, 2003. (ADAMS Accession No.
27 ML031710023)
- 28 7. Letter from James F. Mallay, Framatome ANP to USNRC, "Response to RAI Regarding
29 BAW-10241(P), Revision 0, 'BHTP DNB Correlation Applied with LYNXT,'" dated
30 September 3, 2003. (ADAMS Accession Nos. ML032480676 for letter and non-
31 proprietary version of attachment; ML032480690 for proprietary version of attachment)
- 32 8. Letter from James F. Mallay, Framatome ANP to USNRC, "Response to RAI Regarding
33 BAW-10241(P), Revision 0, 'BHTP DNB Correlation Applied with LYNXT,'" dated
34 February 11, 2004. (ADAMS Accession Nos. ML040440489 for letter and non-
35 proprietary version of attachment; ML040440491 for proprietary version of attachment)

- 6 -

- 1 9. Letter from James F. Mallay, Framatome ANP to USNRC, "Response to RAI Regarding
2 BAW-10241(P), Revision 0, 'BHTP DNB Correlation Applied with LYNXT,'" dated
3 June 17, 2004. (ADAMS Accession No. ML041750287)
- 4 10. Letter from James F. Mallay, Framatome ANP to USNRC, Additional Information
5 Related to the Review of BAW-10241(P), dated August 9, 2004. (ADAMS Accession
6 No. ML04229252)
- 7 Attachment: Table 1: Range of Coolant Conditions for BHTP Correlation
8 Table 2: Range of Fuel Design Parameters for BHTP Correlation
- 9 Principal Contributor: T. Huang
- 10 Date: August 30, 2004

1 **Table 1: Range of Coolant Conditions for BHTP Correlation**

2	Pressure (psia)	1775 to 2425
3	Local Mass Flux (Mlb/hr/ft ²)	0.897 to 3.549
4	Inlet Enthalpy (Btu/lb)	383.9 to 644.3
5	Local Quality	-0.130 to 0.344

6 **Table 2: Range of Fuel Design Parameters for BHTP Correlation**

7	Fuel Rod Diameter (in)	0.360 to 0.440
8	Fuel Rod Pitch (in)	0.496 to 0.580
9	Axial Spacer Span (in)	10.5 to 26.2
10	Hydraulic Diameter (in)	0.4571 to 0.5334
11	Heated Length (ft)	9.8 to 14.0

Attachment B

SUMMARY TABLE OF PROPOSED CHANGES

PAGE NO.	LINE(S) NO.	PROPOSED CHANGE AND REASON
2	3	Change "Mark-B" to "the."
2	8	Change "BTP" to "BHTP."
2	9 - 11	Omitted proprietary data.
2	21	Omitted proprietary data.
2	34	Omit "Mark-B."
3	34	Omitted proprietary data.
3	36	Omitted proprietary data; added "...most..."

.