

SEP 13 2004


LR-N04-0405



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 1
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **August 2004** are being forwarded.

Sincerely,

Carl J. Fricker
Salem Plant Manager

Attachments

C Distribution

IE24

DOCKET NO.: 50-272
 UNIT: Salem 1
 DATE: 9/7/04
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period August 2004

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)
 No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1193		
1159		
Month	Year-to-date	Cumulative
744	4397	155063
744	4263	150215
0	0	0
871073	4726671	153727319

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-272
UNIT: Salem 1
DATE: 9/7/04
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 1 began the month at approximately 100% power. The unit remained at 100% power for the month.
- At the end of the month, Salem 1 completed 68 days of continuous on-line operation.