#### September 30, 2004

Mr. Mark E. Warner, Site Vice President c/o James M. Peschel Seabrook Station FPL Energy Seabrook, LLC PO Box 300 Seabrook, NH 03874

SUBJECT: SEABROOK STATION, UNIT NO. 1, CORRECTION LETTER, RE: AMENDMENT NO. 97, CHANGE TO EMERGENCY POWER SYSTEMS (TAC NO. MC0635)

Dear Mr. Warner:

On September 21, 2004, the U.S. Nuclear Regulatory Commission issued Amendment No. 97 to Facility Operating License No. NPF-86 for the Seabrook Station, Unit No. 1 (Seabrook). The amendment revised the Technical Specifications to extend the Emergency Diesel Generator allowed outage time from 72 hours to a period of 14 days and to allow extension of the current 2-hour time requirement to 4 hours for verification of redundant component operability.

Subsequent to the issuance of the amendment, which had a 30-day implementation period, it was brought to our attention that the FPL Energery Seabrook, LLC, letter of August 25, 2003 (ML032410059), requested a 90-day implementation period which we had intended to incorporate into the amendment. Please replace the page in your copy of the amendment with the enclosed corrected page. We apologize for any confusion or inconvenience that may have been caused by not including the requested implementation period.

Sincerely,

# /RA/

Scott P. Wall, Project Manager, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosure: As stated

cc w/encl: See next page

#### September 30, 2004

Mr. Mark E. Warner, Site Vice President c/o James M. Peschel Seabrook Station FPL Energy Seabrook, LLC PO Box 300 Seabrook, NH 03874

# SUBJECT: SEABROOK STATION, UNIT NO. 1, CORRECTION LETTER, RE: AMENDMENT NO. 97, CHANGE TO EMERGENCY POWER SYSTEMS (TAC NO. MC0635)

Dear Mr. Warner:

Dookot No. 50 442

On September 21, 2004, the U.S. Nuclear Regulatory Commission issued Amendment No. 97 to Facility Operating License No. NPF-86 for the Seabrook Station, Unit No. 1 (Seabrook). The amendment revised the Technical Specifications to extend the Emergency Diesel Generator allowed outage time from 72 hours to a period of 14 days and to allow extension of the current 2-hour time requirement to 4 hours for verification of redundant component operability.

Subsequent to the issuance of the amendment, which had a 30-day implementation period, it was brought to our attention that the FPL Energery Seabrook, LLC, letter of August 25, 2003 (ML032410059), requested a 90-day implementation period which we had intended to incorporate into the amendment. Please replace the page in your copy of the amendment with the enclosed corrected page. We apologize for any confusion or inconvenience that may have been caused by not including the requested implementation period.

Sincerely, /RA/

Project Directorate I

Scott P. Wall, Project Manager, Section 2

Division of Licensing Project Management Office of Nuclear Reactor Regulation

Enclosure: As stated cc w/encl: See next page								
DISTRIBUTIC	<u>DN</u> :							
PUBLIC	DCollins	SWall	CRaynor	OGC	GMatakas, RGN I			
PDI-2 R/F	TBoyce	RJenkins	MMcConnell	GHill(2)	DLPM DPR			
ACRS	MRubin							

Accession Numbers: Letter ML042670357

OFFICE	PDI-2/PM	PDI-2/LA	OGC w/nlo	PDI-2/SC
NAME	SWall	CRaynor	RHoefling	Dcollins for JClifford
DATE	9/29/04	9/29/04	9/28/04	9/29/04

# **OFFICIAL RECORD COPY**

#### Seabrook Station, Unit No. 1

CC:

Mr. J. A. Stall Senior Vice President, Nuclear and Chief Nuclear Officer Florida Power & Light Company P.O. Box 14000 Juno Beach, FL 33408-0420

Mr. Peter Brann Assistant Attorney General State House, Station #6 Augusta, ME 04333

Resident Inspector U.S. Nuclear Regulatory Commission Seabrook Nuclear Power Station P.O. Box 1149 Seabrook, NH 03874

Town of Exeter 10 Front Street Exeter, NH 03823

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Office of the Attorney General One Ashburton Place, 20th Floor Boston, MA 02108

Board of Selectmen Town of Amesbury Town Hall Amesbury, MA 01913

Mr. Dan McElhinney Federal Emergency Management Agency Region I J.W. McCormack P.O. & Courthouse Building, Room 401 Boston, MA 02109

Mr. Jack Devine Polestar Applied Technology One First Street, Suite 4 Los Altos, CA 94019 Mr. Stephen McGrail, Director ATTN: James Muckerheide Massachusetts Emergency Management Agency 400 Worcester Road Framingham, MA 01702-5399

Philip T. McLaughlin, Attorney General
Steven M. Houran, Deputy Attorney
General
33 Capitol Street
Concord, NH 03301

Mr. Donald Bliss, Director New Hampshire Office of Emergency Management State Office Park South 107 Pleasant Street Concord, NH 03301

Mr. Gene F. St. Pierre Station Director Seabrook Station FPL Energy Seabrook, LLC P.O. Box 300 Seabrook, NH 03874

Mr. M. S. Ross, Managing Attorney Florida Power & Light Company P.O. Box 14000 Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar Vice President - Nuclear Engineering Florida Power & Light Company P.O. Box 14000 Juno Beach, FL 33408-0420

James M. Peschel Regulatory Programs Manager Seabrook Station FPL Energy Seabrook, LLC PO Box 300 Seabrook, NH 03874

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-86 is hereby amended to read as follows:
  - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 97, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 90 days of issuance.

# FOR THE NUCLEAR REGULATORY COMMISSION

# /RA by Dan Collins for/

James W. Clifford, Chief, Section 2 Project Directorate I Division of Licensing Project Management Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: September 21, 2004