



Entergy Operations, Inc.  
1340 Echelon Parkway  
Jackson, Mississippi 39213-8298  
Tel 601-368-5758

F. G. Burford  
Acting Director  
Nuclear Safety & Licensing

CNRO-2004-00060

September 21, 2004

U. S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Washington, DC 20555-0001

**SUBJECT:** Relief Requests ANO1-ISI-001 and ANO1-ISI-003 -  
Response to Request for Additional Information (TAC No. MC1490)

Arkansas Nuclear One, Unit 1  
Docket No. 50-313  
License No. DPR-51

**REFERENCE:** Entergy Operations, Inc. letter CNRO-2003-00063 to the NRC dated  
December 2, 2003

Dear Sir or Madam:

In the referenced letter, Entergy Operations, Inc., (Entergy) requested relief from the requirements of ASME Section XI pertaining to volumetric examination of pressure-retaining welds for Arkansas Nuclear One, Unit 1 (ANO-1). In several locations, the required coverage cannot be obtained due to interference or geometry.

In an e-mail to Entergy on January 14, 2004, the NRC staff provided a comment pertaining to these requests. Specifically, the staff asked that Entergy provide data sheets and results of the ultrasonic examination for those welds that showed no indication of degradation. To address the staff's comments, Entergy has revised Requests ANO1-ISI-001 and ANO1-ISI-003, which are contained in Enclosures 1 and 2, respectively, and is providing the requested data sheets in Enclosure 3. These revised requests supercede the originals in their entirety. Changes are denoted by revision bars in the page margins.

In addition to providing revised relief requests ANO1-ISI-001 and ANO1-ISI-003, Entergy is withdrawing ANO1-ISI-002 and ANO1-ISI-004. These requests are no longer needed because of Code actions in process and steam generator replacement plans.

A047

Should you have any questions regarding this letter, please contact Guy Davant at (601) 368-5756.

This letter contains no new commitments.

Very truly yours,



FGB/GHD/ghd

Enclosures: 1. Relief Request ANO1-ISI-001  
2. Relief Request ANO1-ISI-003  
3. Calibration Data Sheets Supporting Relief Requests ANO1-ISI-001 and ANO1-ISI-003

cc: Mr. W. A. Eaton (ECH)  
Mr. J. S. Forbes (ANO)

Dr. Bruce. S. Mallett  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

U. S. Nuclear Regulatory Commission  
Attn: Mr. T. W. Alexion  
MS O-7 D1  
Washington, DC 20555-0001

NRC Senior Resident Inspector  
Arkansas Nuclear One  
P. O. Box 310  
London, AR 72847

**ENCLOSURE 1**

**CNRO-2004-00060**

**RELIEF REQUEST  
ANO1-ISI-001**

**ENTERGY OPERATIONS, INC.  
RELIEF REQUEST  
ANO1-ISI-001**

**I. ASME COMPONENTS**

Components/Numbers: Pressurizer and steam generator nozzles listed in Table 1

ASME Code Class: 1

- References:
1. ASME Section XI 1992 Edition, Table IWB-2500-1
  2. ASME Section XI 1980 Edition with the Winter 1981 Addenda
  3. Letter from the NRC to Entergy Operations, Inc., *Evaluation of Entergy Operations, Inc. Request for Authorization to Update Inservice Inspection Programs to the 1992 and Portions of the 1993 ASME Boiler and Pressure Vessel Code, Section XI for Arkansas Nuclear One, Units 1 and 2, Grand Gulf Nuclear Station, River Bend Station, and Waterford Steam Electric Station, Unit 3 (TAC Nos. M94472, M94471, M94454, M94473, and M94488)*, dated December 12, 1996
  4. ASME Code Case N-460 – Alternative Examination Coverage for Class 1 and 2 Welds, Section XI, Division 1

Examination Category: B-D

Item Numbers: B3.110, B3.130, B3.140

Unit / Inspection Interval Applicability: Arkansas Nuclear One Unit 1 – third (3<sup>rd</sup>) 10-year interval

**II. ASME CODE REQUIREMENT(S)**

ASME Section XI, Table IWB-2500-1, Examination Category B-D, Item B3.110 requires essentially 100% volumetric examination of the pressurizer nozzle-to-vessel welds.

ASME Section XI, Table IWB-2500-1, Examination Category B-D, Items B3.130 and B3.140 require essentially 100% volumetric examination of the steam generator nozzle-to-vessel welds and inner radius sections.

ASME Code Case N-460 allows a reduction in coverage for Class 1 and 2 welds due to interference or geometry as long as the overall coverage is greater than 90%.

### III. RELIEF REQUESTED

Pursuant to 10 CFR 50.55a(g)(6)(i), Entergy Operations, Inc. (Entergy) requests relief from achieving the Code-required coverage when performing volumetric examinations of the components identified in Table 1, below.

<u>Table 1</u> <u>Limited B-D Examinations</u>				
<u>Item #</u>	<u>Item ID</u>	<u>Description</u>	<u>Coverage (%)</u>	<u>Reason for Limitation</u>
B3.110	05-012	Pressurizer relief valve nozzle-to-vessel weld	45	Nozzle Configuration
B3.110	05-013	Pressurizer spray nozzle-to-head weld	38	Nozzle Configuration
B3.130	03-008	Steam generator outlet nozzle-to-head weld (Reactor Coolant Pump C cold leg)	40.4	Nozzle Configuration and Support Skirt
B3.140	03-009	Steam generator outlet nozzle-to-lower head inner radius (Reactor Coolant Pump C cold leg)	90.7	Steam Generator Support Skirt

### IV. BASIS FOR RELIEF

During the ultrasonic examination of the pressurizer and steam generator nozzle welds (ID #s 05-012, 05-013, and 03-008) and the inner radius section (ID #03-009) listed in Table 1 above, 100% coverage of the required examination volume could not be obtained due to nozzle configuration. Specifically for the nozzle welds, effective volumetric examination can only be performed from the shell side of the welds. In addition, the steam generator support skirt limits accessibility to the steam generator outlet nozzle inner radius sections. Examination coverage calculation sheets provided in the attachment of this relief request show the nozzle configuration, limitations, and beam plots of the different examination angles used. The weld volume was scanned using 0°, 45°, 60°, and 70° beam angles; no recordable indications (as defined in Reference 2) were located in the volume that was examined. The heat affected zones for ID #s 03-008, 05-012, and 05-013 were captured as shown in the associated examination coverage calculation sheets.

Nozzle inner radius limitations of ID #03-009 are caused by the ratio of the nozzle outside diameter (OD) to the vessel thickness. When the nozzle OD is small in relation to vessel thickness, more coverage can be obtained when scanning from the vessel side. Conducting examinations from the nozzle boss and OD blend is not practical, due to the complex beam angles and skews that must be calculated and then maintained during manual scanning in order to achieve an effective examination. To maximize coverage,

the volume was scanned using 60° and 70° beam angles. During the second inspection interval, the contractor performing the examination claimed 100% coverage. However, when performing this examination during the third interval using current techniques, Entergy was able to obtain only 90.7% coverage. No recordable indications (as defined in Reference 2) were identified in either exam; therefore, Entergy has reasonable assurance that any potential degradation would have been identified in the volume examined.

Radiography is not practical because of the geometry of the components, which prevents proper placement of the film and exposure source. To perform the Code-required examination would require modifying and/or replacing the components. The examinations performed on the subject items, in addition to the examination of other nozzle-to-vessel welds and inner radius sections contained in the program, would detect generic degradation, if it existed, demonstrating an acceptable level of integrity.

#### **V. PROPOSED ALTERNATIVE EXAMINATIONS**

Entergy has examined the subject components to the extent practical and will continue to perform pressure testing on the pressurizer and the steam generator as required by the Code.

#### **VI. CONCLUSION**

10 CFR 50.55a(g)(6)(i) states:

The Commission will evaluate determinations under paragraph (g)(5) of this section that code requirements are impractical. The Commission may grant such relief and may impose such alternative requirements as it determines is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

Due to design configuration, it is impractical to obtain greater than 90% coverage on ID #s 03-008, 05-012, and 05-013 and 100% of the inner radius section of ID #03-009. To obtain the required coverage would necessitate modifying and/or replacing components. Examinations performed on the subject components, in addition to examinations of similar welds and inner radius sections contained in the program, would detect generic degradation, if it existed, thereby demonstrating an acceptable level of integrity. Therefore, Entergy requests the NRC staff authorize the proposed alternative pursuant to 10 CFR 50.55a(g)(6)(i).

**ATTACHMENT**

**RELIEF REQUEST  
ANO1-ISI-001**

**EXAMINATION COVERAGE CALCULATION SHEETS**

**WELD 03-008**





# EXAMINATION COVERAGE CALCULATION SHEET

Attachment #: A

ANO 1

ANO 2

Grand Gulf

River Bend

Waterford 3

Component ID: 03-008

Report No.: 198ISIUT060

Material Type: CS clad


Vessel Weld T: -9.0°

Angles Used: 45° 60° 70° S - 1/2 V, 0° L

### NOTES:

- 1 The 1/2T dimension on each side of the weld is for Class 1 vessel volume.
- 2 This is an approximate percent of the examination volume for which coverage was obtained.
- 3 The plot shown is a representation of the actual profile and not to scale.

### 45° Shear-wave Scan Directions




No Coverage

Direction #1

Direction #2

### 60° Shear-wave scan directions



No Coverage


Direction #1

Direction #2


*Handwritten signature:*  
Hantha  
PJ 182  
2/24/02



# EXAMINATION COVERAGE CALCULATION SHEET



No Coverage     
 Direction #1     
 Direction #2



No Coverage     
 Direction #3     
 Direction #4

Required scan coverage:  
 Weld ~30.2%, Base material head side ~68.7%, Base material nozzle side ~22.3%  
**TOTAL EXAM VOLUME OBTAINED: 40.4%**

**COMMENTS:** Steam generator cold leg nozzle to lower head. This is primarily a single sided examination. Scans were performed from the nozzle side to supplement coverage with minimal effect. The support skirt prevented scanning around the total circumference of the nozzle. The cumulative coverage estimation includes the code required base metal coverage adjacent to the weld and the factor of multiple angles from multiple directions.

*Randley*  
7/24/02

**INNER RADIUS 03-009**



# EXAMINATION COVERAGE CALCULATION SHEET

Attachment #: A

ANO 1

ANO 2

Grand Gulf

River Bend

Waterford 3

Component ID: 03-009

Report No.: 198ISUT082\_063

Material Type: CS clad

Vessel Weld T: -9.0°


Angles Used: 45° 60° 70° S - 1/2 V

### NOTES:

- 1 The examination volume for Class 1 nozzles includes 1/2" radial distance into the nozzle from the inside radius (see figure IWB-2500-7(b)).
- 2 This is an approximate percent of the examination volume for which coverage was obtained.
- 3 The plot shown is a representation of the actual profile and not to scale.

#### 45° Shear-wave Scan Directions

03-009



No Coverage




Direction #1



Direction #2

#### 60° Shear-wave scan directions

03-009



No Coverage



Direction #1



Direction #2


*Ranther*  
P3182  
6/26/07



# EXAMINATION COVERAGE CALCULATION SHEET

70° Shear-wave Scan directions

03-009



No Coverage



Direction #1




Direction #2

Illustration of support skirt limitation

LIMITED OR NO SUPPORT AREA

03-009



No Coverage



Direction #3



Direction #4

Required scan coverage obtained:

**CUMULATIVE TOTAL EXAM VOLUME OBTAINED: 90.7%**

**COMMENTS:** Steam generator cold leg nozzle to lower head. This is primarily a single sided examination. Scans were performed from the nozzle side to supplement coverage with minimal effect. The support skirt prevented scanning around the total circumference of the nozzle. The cumulative coverage estimation includes a summary of the scans with multiple angles from the accessible directions.

*Randall*  
 10282  
 6/25/07

**WELD 05-012**



# EXAMINATION COVERAGE CALCULATION SHEET

Attachment #: A

<input checked="" type="checkbox"/> ANO 1	<input type="checkbox"/> ANO 2	<input type="checkbox"/> Grand Gulf	<input type="checkbox"/> River Bend	<input type="checkbox"/> Waterford 3
---	--------------------------------	-------------------------------------	-------------------------------------	--------------------------------------

Component ID: 05-012

Report No.: 198ISIUT010, 030, 031, 038


Material Type: CS clad

Vessel Weld T: ~5.0"


Angles Used: 45° 60° 70° S - 1/2 V, 0° L

### NOTES:

- 1 The 1/2T dimension on each side of the weld is for Class 1 vessel volume.
- 2 This is an approximate percent of the examination volume for which coverage was obtained.
- 3 The plot shown is a representation of the actual profile and not to scale.



No Coverage       Direction #1       Direction #2




No Coverage       Direction #1       Direction #2



# EXAMINATION COVERAGE CALCULATION SHEET

70° Shear-wave Scan directions



No Coverage




Direction #1



Direction #2

All angle Circ Scan Shear-wave scan directions and 0° L-wave



No Coverage



Direction #3



Direction #4

Required scan coverage obtained:

Weld ~ 18.6 %, Base material head side ~ 92.9 %, Base material nozzle side ~ 22.1 %

**TOTAL EXAM VOLUME OBTAINED: 45%**

**COMMENTS:** Pressurizer spray nozzle to head weld. This is a single sided examination. The cumulative coverage estimation includes the code required base metal coverage adjacent to the weld and the factor of multiple angles from multiple directions. Coverage illustrations depict added scans with .5" diameter transducers to increase coverage, 1" diameter transducers were used for the primary examination.



**WELD 05-013**



# EXAMINATION COVERAGE CALCULATION SHEET

Attachment #: A

<input checked="" type="checkbox"/> ANO 1	<input type="checkbox"/> ANO 2	<input type="checkbox"/> Grand Gulf	<input type="checkbox"/> River Bend	<input type="checkbox"/> Waterford 3
---	--------------------------------	-------------------------------------	-------------------------------------	--------------------------------------

Component ID: 05-013

Report No.: 199ISIUT018, 019


Material Type: CS clad

Vessel Weld T: -5.5°


Angles Used: 45° 60° 70° S - 1/2 V, 0° L

## NOTES:

- 1 The 1/2T dimension on each side of the weld is for Class 1 vessel volume.
- 2 This is an approximate percent of the examination volume for which coverage was obtained.
- 3 The plot shown is a representation of the actual profile and not to scale.




No Coverage       Direction #1       Direction #2



No Coverage       Direction #1       Direction #2

70° Shear-wave Scan directions



No Coverage




Direction #1



Direction #2

All angle Circ Scan Shear-wave scan directions and 0° L-wave



No Coverage



Direction #3



Direction #4

Required scan coverage obtained:

Weld ~15.9 %, Base material head side ~ 65.7%, Base material nozzle side ~32.5%

**TOTAL EXAM VOLUME OBTAINED: 38%**

**COMMENTS:** Pressurizer head to safety nozzle. This is primarily a single sided examination. Scans were performed from the nozzle side to supplement coverage with minimal effect. The cumulative coverage estimation includes the code required base metal coverage adjacent to the weld and the factor of multiple angles from multiple directions. Coverage illustrations depict only one location of a complicated nozzle geometry.

**ENCLOSURE 2**

**CNRO-2004-00060**

**RELIEF REQUEST  
ANO1-ISI-003**

**ENTERGY OPERATIONS, INC.  
RELIEF REQUEST  
ANO1-ISI-003**

**I. ASME COMPONENTS**

Component/Number: Steam generator A upper shell-to-upper nozzle belt circumferential weld 03-047

ASME Code Class: 2

References:

1. ASME Section XI 1992 Edition, Table IWC-2500-1
2. ASME Section XI 1980 Edition with the Winter 1981 Addenda
3. Letter from the NRC to Entergy Operations, Inc., *Evaluation of Entergy Operations, Inc. Request for Authorization to Update Inservice Inspection Programs to the 1992 and Portions of the 1993 ASME Boiler and Pressure Vessel Code, Section XI for Arkansas Nuclear One, Units 1 and 2, Grand Gulf Nuclear Station, River Bend Station, and Waterford Steam Electric Station, Unit 3 (TAC Nos. M94472, M94471, M94454, M94473, and M94488)*, dated December 12, 1996
4. ASME Code Case N-460 – Alternative Examination Coverage for Class 1 and 2 Welds, Section XI, Division 1

Examination Category: C-A

Item Numbers: C1.10

Unit / Inspection Interval Applicability: Arkansas Nuclear One Unit 1 – third (3<sup>rd</sup>) 10-year interval

**II. ASME CODE REQUIREMENT(S)**

ASME Section XI, Table IWC-2500-1, Examination Category C-A, Item C1.10 requires essentially 100% volumetric examination of the pressure retaining welds. ASME Code Case N-460 allows a reduction in coverage for Class 1 and 2 welds due to interference or geometry as long as the overall coverage is greater than 90%.

**III. RELIEF REQUESTED**

Pursuant to 10 CFR 50.55a(g)(6)(i), Entergy Operations, Inc. (Entergy) requests relief from achieving the Code-required coverage (> 90%) when performing volumetric examinations of the subject weld. See information in Table 1.

<u>Table 1</u> <u>Limited C-A Examination</u>			
<u>Item ID</u>	<u>Description</u>	<u>Coverage (%)</u>	<u>Reason for Limitation</u>
03-047	Steam generator upper nozzle belt-to-upper shell weld	75.1	Nozzle-to-vessel configuration

**IV. BASIS FOR RELIEF**

During the ultrasonic examination of Weld 03-047, 100% coverage of the required examination volume could not be obtained due to the configuration of the steam generator. Specifically, effective volumetric examination was limited by the nozzle belt taper. Examination coverage calculation sheets provided in the attachment of this relief request show the shell-to-nozzle belt configuration, limitations, and the beam plots of the different examination angles used. The volume was scanned using 45°, 60°, and 70° beam angles. The heat affected zone was captured as shown in the examination coverage calculation sheets.

One mid-wall recordable indication (as defined in Reference 2) exists in the examined volume and is completely contained within that volume. It has been evaluated per ASME IWC-3500 and determined to be acceptable. Additionally, ultrasonic data from the most recent examination has been compared with data from the previous examination; this comparison indicates no change in the indication.

Radiography is not practical because of the geometry of the component, which prevents proper placement of the film and exposure source. To perform the Code-required examination would require modifying and/or replacing the component. The examinations performed on Weld 03-047, in addition to the examination of other steam generator welds contained in the program, would detect generic degradation, if it existed, thereby demonstrating an acceptable level of integrity.

**V. PROPOSED ALTERNATIVE EXAMINATIONS**

Entergy has examined Weld 03-047 to the extent practical and will continue to perform pressure testing on the weld as required by the Code.

**VI. CONCLUSION**

10 CFR 50.55a(g)(6)(i) states:

The Commission will evaluate determinations under paragraph (g)(5) of this section that code requirements are impractical. The Commission may grant such relief and may impose such alternative requirements as it determines is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility.

Due to design configuration, it is impractical to obtain greater than 90% coverage on Weld 03-047. To obtain the required coverage would necessitate modifying and/or replacing the component. Examinations performed on the subject weld, in addition to examinations of similar welds contained in the program, would detect generic degradation, if it existed, thereby demonstrating an acceptable level of integrity. Therefore, Entergy requests the NRC staff authorize the proposed alternative pursuant to 10 CFR 50.55a(g)(6)(i).

**ATTACHMENT**  
**RELIEF REQUEST**  
**ANO1-ISI-003**  
**WELD 03-047**  
**EXAMINATION COVERAGE CALCULATION SHEETS**





# EXAMINATION COVERAGE CALCULATION SHEET

Attachment #: A

<input checked="" type="checkbox"/> ANO 1	<input type="checkbox"/> ANO 2	<input type="checkbox"/> Grand Gulf	<input type="checkbox"/> River Bend	<input type="checkbox"/> Waterford 3
---	--------------------------------	-------------------------------------	-------------------------------------	--------------------------------------

Component ID: 03-047

Report No.: 99ISIUT027


Material Type: CS

Vessel Weld T: ~5.5"


Angles Used: 45°<sup>1V</sup>, 60°<sup>0</sup> S - ½ V, 0°<sup>0</sup> L

### NOTES:

- 1 The ½" dimension on each side of the weld is for Class 2 vessel volume.
- 2 This is an approximate percent of the examination volume for which coverage was obtained.
- 3 The plot shown is a representation of the actual profile and not to scale.




No Coverage      Direction #1      Direction #2




No Coverage      Direction #1      Direction #2

70° Shear-wave Scan directions



No Coverage     
 Direction #1     
 Direction #2

All angle Circ Scan Shear-wave Scan directions and 0° L-wave



No Coverage     
 Direction #3     
 Direction #4

Required scan coverage:

Weld ~87.5%, Base material nozzle belt side ~37.8%, Base material shell side 100%

**TOTAL EXAM VOLUME OBTAINED: 75.1%**

**COMMENTS:** Steam generator upper nozzle belt to upper shell weld. The primary limitation was on the required circumferential scans on the upper nozzle belt taper, base material. The cumulative coverage estimation includes the code required base metal coverage adjacent to the weld and the factor of multiple angles from multiple directions.

*Randley*  
2/24/02

**ENCLOSURE 3**

**CALIBRATION DATA SHEETS  
SUPPORTING RELIEF REQUESTS ANO1-ISI-001 AND ANO1-ISI-003**

**WELD 03-008**



ANO Outage: 1R14

ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT060

Unit 1

Page 1 of 2

ISI  PSI  INFO

MAINTENANCE  WQT

Exam/Item ID 03-008

Comp/System E24A

DWG # MID-2

Cat / Item B-D / B 3.130

Exam Comp Temp 65°F

Item Config NOZZLE-TO-LOWER HEAD

Exam Surface EXTERNAL

Company RAYTHEON

Code Edition ASME XI 1980/W81

Procedure No. 1415.038 / 4

Cal. Block No. 40805

Cal. Block Temp 70°F

Size N/A T 9.0"

Ferritic  Austenitic

Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1016	1013
Initial Cal Date	4/27/98	4/27/98
Intermediate Time	1115	1135
Intermediate Date	1210	1220
Final Cal Time	1240	1242
Final Cal Date	4/27/98	4/27/98

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>

Remarks/Reason for Incomplete Scan(s)

SIMULATOR-45°, 5TH ECHO FROM 2" RADIUS ON ROMPAS, 80% FSH @ 7 SCREEN DIV. @ 48.2dB, 60°, 40% FSH @ 8 SCREEN DIV. @ 59.8dB. SCANNED FROM NOZZLE SIDE FOR SUPPLEMENTAL COVERAGE. SEE REPORT 198ISIUT061 FOR ADDITIONAL SCANS. NOTE EXAM LIMITATIONS ON PAGE 2.

Further Evaluation Required?  Yes  No

Examiners: Ronald V. Swain Level: II Date: 4/27/98

RON V SWAIN

Jason Pollsen  
Jason Pollsen

Level: II Date: 4/27/98

Search Unit #1

Instrument Settings

Manufacture: KBA

Serial No.: C06285

Size: 1.0"

Shape: ROUND

Freq: 1.0

Style: GAMMA

Exam Angle: 45° Mode SHEAR

Measured Angle: 46°

Wedge Style: ABWS

Cable Type: RG 58 Len: 126"

Ref Block: 789937

Make/Model: Staveley / Sonic 136

Serial No: 821K

Delay: 0.793 Range: 20.0"

M'tl Cal/Vel: 0.127 Pulser: 222

Damping: 500 Reject: OFF

Rep. Rate: 1KHz Freq: 1.0Mhz

Filter: 1 Mode: P/E


Reference Sensitivity

Axial: 48.2dB Circ: 48.2dB

SDH Sensitivity: 48.2dB

Exam Sensitivity

Axial: 60.4dB Circ: 60.4dB



Screen Range = 20.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #2

Instrument Settings

Manufacture: KBA

Serial No.: 000NBB

Size: 1.0"

Shape: ROUND

Freq: 1.0

Style: GAMMA

Exam Angle: 60° Mode SHEAR

Measured Angle: 60°

Wedge Style: ABWS

Cable Type: RG 58 Len: 126"

Ref Block: 789937

Make/Model: Staveley / Sonic 136

Serial No: 821K

Delay: 1.28 Range: 25.0"

M'tl Cal/Vel: 0.129 Pulser: 222

Damping: 500 Reject: OFF

Rep. Rate: 1KHz Freq: 1.0Mhz

Filter: 1 Mode: P/E


Reference Sensitivity

Axial: 59.8dB Circ: N/A

SDH Sensitivity: 57.6dB

Exam Sensitivity

Axial: 75.0dB Circ: N/A



Screen Range = 25.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: Stanley Date: 4/28/98 Reviewers: Lap Shu ISI Date: 4-28-98

ANII: C.W. Sharpe Date: 4-28-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															

Page 2 of 20



ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT061

Unit 1

Page 1 of 1

ISI  PSI  INFO

MAINTENANCE  WQT

Exam/Item ID 03-008

Comp/System E24A

DWG # MID-2

Cat / Item B-D / B 3 130

Exam Comp Temp 65°F

Item Config NOZZLE-TO-LOWER HEAD

Exam Surface EXTERNAL

Company RAYTHEON

Code Edition ASME XI 1980/W81

Procedure No. 1415.038 / 4

Cal. Block No. 40805

Cal. Block Temp 70°F

Size N/A "T" 9.0"

Ferritic  Austenitic

Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1026	1030
Initial Cal Date	4/27/98	4/27/98
Intermediate Time	1145	1100
Intermediate Time		
Final Cal Time	1243	1245
Final Cal Date	4/27/98	4/27/98

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input checked="" type="radio"/>	<input type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input type="radio"/>	<input checked="" type="radio"/>
Scan 5, CCW	<input type="radio"/>	<input checked="" type="radio"/>

Couplant Type: ULTRAGEL II  
 Couplant Batch: 95125  
 Therm SN: 62450  
 Cal Due: 1/12/99

### Remarks/Reason for Incomplete Scan(s)

SIMULATOR-70°, 7TH ECHO ON ROMPAS 50% FSH @ 8 SCREEN DIV. @ 85.4dB. 0°, 5TH BACK ECHO ON ROMPAS 60% FSH @ 3.4 SCREEN DIV @ 36.4 dB. 70° EXAM SENSITIVITY IS CLAD INTERFACE SIGNAL @ 20% FSH. 0° IS BACKWALL @ 80% FSH. SCANNED FROM NOZZLE SIDE FOR SUPPLEMENTAL COVERAGE. 0° EXAMINATION WAS LAM SCAN AND WELD VOLUME. SCANNED FROM NOZZLE SIDE FOR SUPPLEMENTAL COVERAGE. SEE REPORT 198ISIUT060 FOR ADDITIONAL SCANS. NOTE EXAM LIMITATIONS ON PAGE 2.

Futher Evaluation Required?  Yes  No

Examiners: Ronald V. Swain Level: II Date: 4/27/98

RON V SWAIN

Jason Polisensky Level: II Date: 4/27/98


JASON POLISENSKY

### Search Unit #1

Manufacture: KBA  
 Serial No.: C05213  
 Size: 1.0" Shape: ROUND  
 Freq: 1.0 Style: GAMMA  
 Exam Angle: 70° Mode SHEAR  
 Measured Angle: 69°  
 Wedge Style: ABWS  
 Cable Type: RG 58 Len: 12'6"  
 Ref Block: 789937

### Instrument Settings

Make/Model: Staveley / Sonic 136  
 Serial No: 821K  
 Delay: 1.460 Range: 25.0"  
 M'd Cal/Vel: 0.130 Pulser: 222  
 Damping: 500 Reject: OFF  
 Rep. Rate: 1K Freq: 1.0Mhz  
 Filter: 1 Mode: P/E  
 Reference Sensitivity  
 Axial: 65.4/68.4 Circ: N/A  
 SDH Sensitivity: 65.4/68.4 dB  
 Exam Sensitivity  
 Axial: 74.4dB Circ: N/A



Screen Range = 20.0"

Depth  Metal Path


Instrument Linearity Acceptable:  Amp  Vert  Horiz

### Search Unit #2

Manufacture: KBA  
 Serial No.: A22105SP  
 Size: 1.0" Shape: ROUND  
 Freq: 2.25 Style: GAMMA  
 Exam Angle: 0° Mode LONG.  
 Measured Angle: N/A  
 Wedge Style: N/A  
 Cable Type: RG 58 Len: 12'6"  
 Ref Block: 789937

### Instrument Settings

Make/Model: Staveley / Sonic 136  
 Serial No: 821K  
 Delay: 0.00 Range: 15.0"  
 M'd Cal/Vel: 0.231 Pulser: 222  
 Damping: 500 Reject: OFF  
 Rep. Rate: 1K Freq: 2.25  
 Filter: 1 Mode: P/E  
 Reference Sensitivity  
 Axial: N/A Circ: N/A  
 SDH Sensitivity: 38.4dB  
 Exam Sensitivity  
 Axial: 48.8dB Circ: N/A



Screen Range = 15.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: K. Anil Date: 4-28-98 Reviewers: Logan Date: 4-28-98

ANII: C.W. Thompson Date: 4-28-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															

Page 3 of 20

**INNER RADIUS 03-009**



ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT062

Unit 1

Page 1 of 2

ISI  PSI  INFO  
 MAINTENANCE  WQT

Exam/Item ID 03-009

Comp/System E24A

DWG # MID-2

Cat / Item B-D / B3.140

Exam Comp Temp 65°F

Item Config NOZZLE IR

Exam Surface EXTERNAL

Company RAYTHEON

Code Edition ASME XI 1980/WS1

Procedure No. 1415.031 / 3

Cal. Block No. 40805

Cal. Block Temp 70°F

Size N/A T 9.0"

Ferritic  Austenitic  
 Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1016	1013
Initial Cal Date	4/27/98	4/27/98
Intermediate Time	1115	1135
Intermediate Time	1210	1220
Final Cal Time	1240	1242
Final Cal Date	4/27/98	4/27/98

Scans Performed	Completed	
	Yes	No
Scan 1, 0 if Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>

Couplant Type: ULTRAGEL II  
Couplant Batch: 95125  
Therm SN: 62450  
Cal Due: 1/12/99

### Remarks/Reason for Incomplete Scan(s)

SIMULATOR-45°, 5TH ECHO FROM 2" RADIUS ON ROMPAS, 80% FSH @ 7 SCREEN DIV. @ 48.2dB. 60°, 40% FSH @ 8 SCREEN DIV. @ 59.8dB. SCANNED FROM NOZZLE SIDE FOR SUPPLEMENTAL COVERAGE. SEE REPORT 198ISIUT063 FOR ADDITIONAL SCANS. NOTE EXAM LIMITATIONS ON PAGE 2.

Further Evaluation Required?  Yes  No

Examiners: Ronald V. Swain Level: II Date: 4/27/98

RON V SWAIN

Jason Pollsen  
Jason Pollsen


Level: II Date: 4/27/98

### Search Unit #1

Manufacture: KBA  
Serial No.: C08285  
Size: 1.0" Shape: ROUND  
Freq: 1.0 Style: GAMMA  
Exam Angle: 45° Mode SHEAR  
Measured Angle: 46°  
Wedge Style: ABWS  
Cable Type: RG 58 Len: 12'6"  
Ref Block: 789937

### Instrument Settings

Make/Model: Staveley / Sonic 136  
Serial No: 821K  
Delay: 0.793 Range: 20.0"  
M'tl Cal/Vel: 0.127 Pulser: 222  
Damping: 500 Reject: OFF  
Rep. Rate: 1K Freq: 1.0MHz  
Filter: 1 Mode: P/E  
Reference Sensitivity  
Axial: Skew 54.4 CIRC: N/A  
SDH Sensitivity: 48.2dB  
Exam Sensitivity  
Axial: 60.4dB CIRC: N/A



Screen Range = 20.0"

Depth  Metal Path


Instrument Linearity Acceptable:  Amp  Vert  Horiz

### Search Unit #2

Manufacture: KBA  
Serial No.: 000NBB  
Size: 1.0" Shape: ROUND  
Freq: 1.0 Style: GAMMA  
Exam Angle: 60° Mode SHEAR  
Measured Angle: 60°  
Wedge Style: ABWS  
Cable Type: RG 58 Len: 12'6"  
Ref Block: 789937

### Instrument Settings

Make/Model: Staveley / Sonic 136  
Serial No: 821K  
Delay: 1.28 Range: 25.0"  
M'tl Cal/Vel: 0.129 Pulser: 222  
Damping: 500 Reject: OFF  
Rep. Rate: 1K Freq: 1.0MHz  
Filter: 1 Mode: P/E  
Reference Sensitivity  
Axial: Skew 69.0 CIRC: N/A  
SDH Sensitivity: 57.6dB  
Exam Sensitivity  
Axial: 75.0dB CIRC: N/A



Screen Range = 25.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: Ben Panther Date: 4/28/98 Reviewers: Ly Sh I I I Date: 4-28-98

ANI: C.W. Thompson Date: 4-28-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															





ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT063

Unit 1  
Page 1 of 1

ISI  PSI  INFO  
 MAINTENANCE  WQT

Exam/Item ID 03-009  
Comp/System E24A  
DWG # MID-2  
Cat / Item B-D / B3.140

Exam Comp Temp 65°F  
Item Config NOZZLE IR  
Exam Surface EXTERNAL

Company RAYTHEON  
Code Edition ASME XI 1980/W81  
Procedure No. 1415.031 / 3

Cal. Block No. 40805  
Cal. Block Temp 70°F  
Size N/A T 9.0"

Ferritic  Austenitic  
 Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1028	
Initial Cal Date	4/27/98	
Intermediate Time	1145	
Intermediate Time		
Final Cal Time	1243	
Final Cal Date	4/27/98	

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input type="radio"/>	<input checked="" type="radio"/>
Scan 5, CCW	<input type="radio"/>	<input checked="" type="radio"/>

Couplant Type: ULTRAGEL II  
Couplant Batch: 95125  
Therm SN: 62450  
Cal Due: 1/12/99

Remarks/Reason for Incomplete Scan(s)

SIMULATOR-70°, 7TH ECHO ON ROMPAS 50% FSH @ 8 SCREEN DIV. @ 65.4dB, 70° EXAM SENSITIVITY IS CLAD INTERFACE SIGNAL @ 20% FSH, 0° IS BACKWALL @ 80% FSH. SCANNED FROM NOZZLE SIDE FOR SUPPLEMENTAL COVERAGE. SCANNED FROM NOZZLE SIDE FOR SUPPLEMENTAL COVERAGE. SEE REPORT 198ISIUT062 FOR ADDITIONAL SCANS.


Further Evaluation Required?  Yes  No

Examiners: *Ronald V. Swain* Level: II Date: 4/27/98  
RON V SWAIN

*Jason Polinsky* Level: II Date: 4/27/98  
Jason Polinsky

### Search Unit #1

Manufacture: KBA  
Serial No.: C05213  
Size: 1.0" Shape: ROUND  
Freq: 1.0 Style: GAMMA  
Exam Angle: 70° Mode SHEAR  
Measured Angle: 69°  
Wedge Style: ABWS  
Cable Type: RG 58 Len: 12'6"  
Ref Block: 789937



Screen Range = 20.0"

Depth  Metal Path


Instrument Linearity Acceptable:  Amp  Vert  Horiz

### Instrument Settings

Make/Model: Staveley / Sonic 136  
Serial No: 821K  
Delay: 1.460 Range: 25.0"  
M/H Cal/Vel: 0.130 Pulser: 222  
Damping: 500 Reject: OFF  
Rep. Rate: 1K Freq: 1.0MHz  
Filter: 1 Mode: P/E  
Reference Sensitivity  
Axial: 65.4/68.4 Circ: N/A  
SDH Sensitivity: 65.4/68.4 dB  
Exam Sensitivity  
Axial: 74.4dB Circ: N/A

### Search Unit #2

Manufacture: N/A  
Serial No.: N/A  
Size: N/A Shape: N/A  
Freq: N/A Style: N/A  
Exam Angle: N/A Mode N/A  
Measured Angle: N/A  
Wedge Style: N/A  
Cable Type: N/A Len: N/A  
Ref Block: N/A



Screen Range = N/A

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

### Instrument Settings

Make/Model: Staveley / Sonic 136  
Serial No: N/A  
Delay: N/A Range: N/A  
M/H Cal/Vel: N/A Pulser: N/A  
Damping: N/A Reject: N/A  
Rep. Rate: N/A Freq: N/A  
Filter: N/A Mode: N/A  
Reference Sensitivity  
Axial: N/A Circ: N/A  
SDH Sensitivity: N/A  
Exam Sensitivity  
Axial: N/A Circ: N/A

Reviewers: *Ken Tomlin* Date: 4/28/98 Reviewers: *Logan IJI* Date: 4-28-98  
ANI: *C.W. Johnson* Date: 4-28-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															

**WELD 05-012**



ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT010

Unit 1

Page 1 of 1

ISI  PSI  INFO

MAINTENANCE  WQT

Exam/Item ID 05-012

Comp/System N/A

DWG # M1G-69

Cat / Item B-D / B3.110

Exam Comp Temp 90°F

Item Config SPRAY NOZZLE TO HEAD

Exam Surface OD

Company RAYTHEON

Code Edition ASME XI 1980/W81

Procedure No. 1415.038 / 4

Cal. Block No. 40908

Cal. Block Temp 85°F

Size 20.0" T 5.0"

Ferritic  Austenitic

Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1335	1345
Initial Cal Date	4/5/98	4/5/98
Intermediate Time	N/A	N/A
Intermediate Time	N/A	N/A
Final Cal Time	1629	1631
Final Cal Date	4/5/98	4/5/98

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>

Couplant Type: ULTRAGEL II  
 Couplant Batch: 95125  
 Therm SN: 62837  
 Cal Due: 1/12/99

Remarks/Reason for Incomplete Scan(s)

THE WEDGE FOR THE 35° TRANSDUCER WAS ANO-35-01. THE WEDGE FOR THE 45° TRANSDUCER WAS ANO-020. SCANS 4 AND 5 PERFORMED WITH THE 45° TRANSDUCER ONLY. THE 35° TRANSDUCER WAS USED TO INCREASE THE AMOUNT OF COVERAGE. THE WELD WAS IDENTIFIED BY THE DRAWING. REFERENCE REPORT 198ISIUT030 & 198ISIUT031 FOR THE ADDITIONAL SCANS AN ANGLES.

*Exam one side 45% coverage K8 1/2/98*

Further Evaluation Required?  Yes  No


Examiners:

*Jay Miller*  
 JAY MILLER

Level: II Date: 4/5/98

*Neil B. Prestwich*  
 NEIL B PRESTWICH

Level: II Date: 4/5/98



Screen Range = 10.0"

Depth  Metal Path

Search Unit #1

Manufacture: KBA

Serial No.: A17203

Size: 1.0"

Freq: 2.25

Exam Angle: 35° Mode SHEAR

Measured Angle: 37°

Wedge Style: MSWS

Cable Type: RG 58 Len: 126"

Ref Block: 789937

Instrument Settings

Make/Model: SONIC 136

Serial No: 471F

Delay: .482" Range: 10.0"

M'd Cal/Vel: .129"/us Pulsar: 222 ns

Damping: 200 ohms Reject: OFF

Rep. Rate: 1 KHZ Freq: 2.25

Filter: 1 Mode: P/E

Reference Sensitivity

Axial: 48.2 dB Circ: N/A

SDH Sensitivity: 44.2 dB

Exam Sensitivity

Axial: 58.2 dB Circ: N/A

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #2

Manufacture: KBA

Serial No.: K24023

Size: 1.0"

Freq: 2.25

Exam Angle: 45° Mode SHEAR

Measured Angle: 47°

Wedge Style: MSW

Cable Type: RG 58 Len: 126"

Ref Block: 789937

Instrument Settings

Make/Model: SONIC 136

Serial No: 471F

Delay: .846" Range: 10.0"

M'd Cal/Vel: .129"/us Pulsar: 222 ns

Damping: 200 ohms Reject: OFF

Rep. Rate: 1 KHZ Freq: 2.25

Filter: 1 Mode: P/E


Reference Sensitivity

Axial: 45.2dB Circ: 45.2dB

SDH Sensitivity: 45.2dB

Exam Sensitivity

Axial: 59.2dB Circ: 59.2dB



Screen Range = 10.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: *K Pantler*

Date: 4/10/98

Reviewers: *Lawry ISI*

Date: 4-13-98

ANII: *C.W. Thompson*

Date: 4-13-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															NO RECORDABLE INDICATIONS

NOTE: The 35-degree transducer did not result in increased coverage as initially expected. Therefore, no associated examination coverage calculation sheet was developed for the 35-degree scan.



ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT030

Unit 1

Page 1 of 3

ISI  PSI  INFO  
 MAINTENANCE  WQT

Exam/Item ID 05-012

Comp/System N/A

DWG # MIG-69

Cal / Item B-D / B3.110

Exam Comp Temp 90° F

Item Config SPRAY NOZZLE TO HEAD

Exam Surface EXTERIOR

Company RAYTHEON

Code Edition ASME XI 1980W81

Procedure No. 1415.038 / 4

Cal. Block No. 40908

Cal. Block Temp 85° F

Size 20.0" T 5.0"

Ferritic  Austenitic  
 Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1355	1405
Initial Cal Date	4/5/98	4/5/98
Intermediate Time	N/A	N/A
Intermediate Time	N/A	N/A
Final Cal Time	1638	1644
Final Cal Date	4/5/98	4/5/98

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>

Couplant Type: ULTRAGEL II  
Couplant Batch: 95125  
Therm SN: 62837  
Cal Due: 1/12/99

Remarks/Reason for Incomplete Scan(s)

THE WEDGE FOR THE 60° IS S/N ANO-007. THE WEDGE FOR THE 70° IS S/N ANO-98-01. REFERENCE REPORT 198ISIUT010 AND 198ISIUT031 FOR ADDITIONAL SCANS/ANGLES. WELD IDENTIFIED BY THE DRAWING. SCAN 4 & 5 PERFORMED WITH THE 60° ONLY. 70° TRANSDUCER WAS PERFORMED TO INCREASE THE AMOUNT OF COVERAGE.

Further Evaluation Required?  Yes  No

Examiners: Jay Miller Level: II Date: 4/5/98  
JAY MILLER


Neil B. Prestwich Level: II Date: 4/5/98  
NEIL B PRESTWICH

Search Unit #1

Instrument Settings

Manufacture: KBA  
Serial No.: J25217  
Size: 1.0" Shape: ROUND  
Freq: 2.25 Style: GAMMA  
Exam Angle: 60° Mode SHEAR  
Measured Angle: 61.5°  
Wedge Style: MSW  
Cable Type: RG 58 Len: 12' 6"  
Ref Block: 789937

Make/Model: SONIC 136  
Serial No: 471F  
Delay: 1.28" Range: 15.0"  
M'tl Cal/Vel: .129"/us Pulser: 222 ns  
Damping: 200 ohms Reject: OFF  
Rep. Rate: 1 KHZ Freq: 2.25  
Filter: 1 Mode: P/E  
Reference Sensitivity  
Axial: 52.2 dB Circ: 52.2 dB  
SDH Sensitivity: 52.2 dB  
Exam Sensitivity  
Axial: 60.2 dB Circ: 60.2 dB



Screen Range = 15.0" d.1

Depth  Metal Path


Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #2

Instrument Settings

Manufacture: KBA  
Serial No.: K24022  
Size: 1.0" Shape: ROUND  
Freq: 2.25 Style: GAMMA  
Exam Angle: 70° Mode SHEAR  
Measured Angle: 72°  
Wedge Style: MSW  
Cable Type: RG 58 Len: 12' 6"  
Ref Block: 789937

Make/Model: SONIC 136  
Serial No: 471F  
Delay: 1.43" Range: 20.0"  
M'tl Cal/Vel: .129"/us Pulser: 222 ns  
Damping: 200 ohms Reject: OFF  
Rep. Rate: 1 KHZ Freq: 2.25  
Filter: 1 Mode: P/E  
Reference Sensitivity  
Axial: 56.0 dB Circ: N/A  
SDH Sensitivity: 56.0 dB  
Exam Sensitivity  
Axial: 62.0 dB Circ: N/A



Screen Range = 20.0" d.5

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: K. Pantha Date: 4/12/98 Reviewers: Long Shu ISI Date: 4-13-98  
ANII: C.W. Thompson Date: 4-13-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
GEO	1	3	60°	50%	N/A	1" CW	N/A	360°	N/A	10.5	N/A	N/A	12.1"	N/A	I. D. GEOMETRY - 360° INTERMITTENT AT VARIOUS AMPLITUDES
GEO	2	3	70°	100%	N/A	5" CCW	N/A	360°	N/A	13.25	N/A	N/A	15.4"	N/A	I. D. GEOMETRY - 360° INTERMITTENT AT VARIOUS AMPLITUDES



ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT038

Unit 1

Page 1 of 2

ISI  PSI  INFO

MAINTENANCE  WQT

Exam/Item ID 05-012

Comp/System N/A

DWG # M1G-69

Cat / Item B-D / B3.110

Exam Comp Temp 75°F

Item Config SPRAY NOZZLE TO HEAD

Exam Surface EXTERIOR

Company RAYTHEON

Code Edition ASME XI 1980/W81

Procedure No. 1415.038 / 4

Cal. Block No. 40908

Cal. Block Temp 68°F

Size 20.0" T 5.0"

Ferritic  Austenitic

Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	0919	0937
Initial Cal Date	4/9/98	4/9/98
Intermediate Time	N/A	N/A
Intermediate Time	N/A	N/A
Final Cal Time	1327	1333
Final Cal Date	4/9/98	4/9/98

Scans Performed	Completed	
	Yes	No
Scan 1, 0 if Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>

Couplant Type: ULTRAGEL II

Couplant Batch: 95125

Therm SN: 62837

Cal Due: 1/12/99

Remarks/Reason for Incomplete Scan(s)

SUPPLEMENTAL SCANS WITH .5" TRANSDUCERS TO INCREASE COVERAGE VOLUME. REFERENCE REPORTS 198ISIUT010, 030 & 031 FOR PREVIOUS INFORMATION AND COVERAGE PLOTS.

Further Evaluation Required?  Yes  No


Examiners:

*Jay Miller*  
JAY MILLER

Level: II Date: 4/9/98

*Neil B. Prestwich*  
NEIL B PRESTWICH

Level: II Date: 4/9/98



Screen Range = 10.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #1

Manufacture: KBA

Serial No.: 44077

Size: .50" Shape: ROUND

Freq: 2.25 Style: GAMMA

Exam Angle: 45° Mode SHEAR

Measured Angle: 45°

Wedge Style: MSW-QC

Cable Type: RG 174 Len: 12'

Ref Block: 94-6545

Instrument Settings

Make/Model: SONIC 136

Serial No: 471F

Delay: .470" Range: 10"

M'tl Cal/Vel: .124"/US Pulser: 222 NS

Damping: 500 OHMS Reject: OFF

Rep. Rate: 4 KHZ Freq: 2.25

Filter: 1 Mode: P/E

Reference Sensitivity

Axial: 35.8 dB Circ: 35.8 dB

SDH Sensitivity: 35.8 dB

Exam Sensitivity

Axial: 49.8 dB Circ: 4938 dB

Search Unit #2

Manufacture: KBA

Serial No.: 45264

Size: .50" Shape: ROUND

Freq: 2.25 Style: GAMMA

Exam Angle: 60° Mode SHEAR

Measured Angle: 58°

Wedge Style: MSW-QC

Cable Type: RG 174 Len: 12'

Ref Block: 94-6545

Instrument Settings

Make/Model: SONIC 136

Serial No: 471F

Delay: .462" Range: 15.0"

M'tl Cal/Vel: .124"/US Pulser: 222 NS

Damping: 500 OHMS Reject: OFF

Rep. Rate: 4 KHZ Freq: 2.25

Filter: 1 Mode: P/E


Reference Sensitivity

Axial: 52.8 dB Circ: 52.8 dB

SDH Sensitivity: 42.4 dB/52.8 dB

Exam Sensitivity

Axial: 66.8 dB Circ: 66.8 dB



Screen Range = 15.0"

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: *K Panther*

Date: 4/16/98

Reviewers: *Lip Jy ISI*

Date: 4-13-98

ANI: *C.W. Thompson*

Date: 4-13-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
GEO	1	3	45°	100%	N/A	TDC	N/A	360°	N/A	-0.6"	N/A	N/A	2.7"	N/A	I. D. GEOMETRY - 360° INTERMITTENT
GEO	2	3	60°	100%	N/A	TDC	N/A	360°	N/A	-0.1"	N/A	N/A	3.25"	N/A	I. D. GEOMETRY - 360° INTERMITTENT
GEO	3	3	60°	50%	N/A	TDC	N/A	360°	N/A	1.6"	N/A	N/A	5.0"	N/A	I. D. GEOMETRY - 360° INTERMITTENT



ANO Outage: 1R14

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 198ISIUT031

Unit 1

Page 1 of 1

ISI  PSI  INFO

MAINTENANCE  WQT

Exam/Item ID 05-012

Comp/System N/A

DWG # M1G-69

Cat / Item B-D / B3.110

Exam Comp Temp 90°F

Item Config SPRAY NOZZLE TO HEAD

Exam Surface EXTERIOR

Company RAYTHEON

Code Edition ASME XI 1980W81

Procedure No. 1415 038 / 4

Cal. Block No. 40908

Cal. Block Temp 85°F

Size 20.0" T 5.0"

Ferritic  Austenitic

Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	1325	N/A
Initial Cal Date	4/5/98	
Intermediate Time	N/A	N/A
Intermediate Time	N/A	N/A
Final Cal Time	1644	N/A
Final Cal Date	4/5/98	

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input checked="" type="radio"/>	<input type="radio"/>
Scan 2, with flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 3, against flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 4, CW	<input type="radio"/>	<input checked="" type="radio"/>
Scan 5, CCW	<input type="radio"/>	<input checked="" type="radio"/>

Remarks/Reason for Incomplete Scan(s)

\*\* 0° SCAN FOR PLANAR FLAWS IN THE WELD, SCANNED +12 ABOVE REFERENCE dB. REFERENCE REPORT 198ISIUT010 AND 198ISIUT030 FOR ADDITIONAL SCANS/ANGLES. WELD IDENTIFIED BY DRAWING.

198ISNT 038 FOR ADDED SCANS.

R 4/10/98


Further Evaluation Required?  Yes  No

Examiners: Jay Miller  
JAY MILLER

Level: II Date: 4/5/98

Neil B. Prestwich  
NEIL B PRESTWICH

Level: II Date: 4/5/98



Screen Range =  $\frac{S \times (SD)}{10.0}$

Depth  Metal Path

## Search Unit #1

Manufacture: KBA

Serial No.: A22105SP

Size: 1.0"

Freq: 2.25

Exam Angle: 0°

Measured Angle: N/A

Wedge Style: N/A

Cable Type: RG 58

Ref Block: 789937

Shape: ROUND

Style: GAMMA

Mode: P/E

N/A

N/A

N/A

Len: 12" 6"

## Instrument Settings

Make/Model: SONIC 136

Serial No.: 471F

Delay: -0.044" Range: 10.0"

M'd Cal/Vel: .228"/us Pulsar: 222 ns

Damping: 200 ohms Reject: OFF

Rep. Rate: 1 KHZ Freq: 2.25

Filter: 1 Mode: P/E

Reference Sensitivity

Axial: N/A Circ: N/A

SDH Sensitivity: 30.0 dB

Exam Sensitivity

Axial: \*\* Circ: \*\*

Instrument Linearity Acceptable:  Amp  Vert  Horiz

## Search Unit #2

Manufacture: N/A

Serial No.: N/A

Size: N/A

Freq: N/A

Exam Angle: N/A

Measured Angle: N/A

Wedge Style: N/A

Cable Type: N/A

Ref Block: N/A

Shape: N/A

Style: N/A

Mode: N/A

N/A

N/A

N/A

N/A

Len: N/A

## Instrument Settings

Make/Model: N/A

Serial No.: N/A

Delay: N/A Range: N/A

M'd Cal/Vel: N/A Pulsar: N/A

Damping: N/A Reject: N/A

Rep. Rate: N/A Freq: N/A

Filter: N/A Mode: N/A


Reference Sensitivity

Axial: N/A Circ: N/A

SDH Sensitivity: N/A

Exam Sensitivity

Axial: N/A Circ: N/A



Screen Range = N/A

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: K Panther

Date: 4/10/98

Reviewers: Logan ISI

Date: 4-13-98

ANI: C.W. Shoyko

Date: 4-13-98

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															NO RECORDABLE INDICATIONS

**WELD 05-013**



ANO Outage: 1R15

ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

1R15

Data Sheet # 199ISIUT018

Unit 1 Page 1 of 22

ISI PSI INFO MAINTENANCE WQT

Exam/Item ID 05-013 Comp/System PRESSURIZER DWG # MIG-69

Cat/Item B-D / B3.110

Exam Comp Temp 120°

Item Config PZR Upper Head to Relief Nozzle

Exam Surface EXTERIOR

Company RAYTHEON

Code Edition ASME XI 1980WB1

Procedure No. 1415.038 / 5

Cal. Block No. 40908

Cal. Block Temp 110°


Size T 5.5"

Ferritic Austenitic

Dissimilar Clad

Cal Checks table with columns SU1, SU2 and rows Initial, Intermediate, Final Cal Time and Date.

Scans table with columns Performed, Completed (Yes/No) and rows Scan 1-5.



Screen Range = 10.0"

Depth Metal Path

Search Unit #1

Manufacture: KBA Serial No.: L04120 Size: 1.0" Shape: ROUND Freq: 2.25 Style: GAMMA Exam Angle: 0° Mode LONG. Measured Angle: N/A Wedge Style: N/A Cable Type: RG-58 Len: 12' Ref Block: 90-4722

Instrument Settings

Make/Model: SONIC 136 Serial No.: 1118M Delay: 0.242 Range: 10.0" M'd Cal/Vel: 0.235 Pulser: 222 Damping: 500 Reject: OFF Rep. Rate: 1K Freq: 2.25 Filter: 1 Mode: P/E Reference Sensitivity Axial: 34.8dB Circ: N/A SDH Sensitivity: 34.8dB Exam Sensitivity Axial: 53.2dB Circ: N/A

Instrument Linearity Acceptable: Amp Vert Horiz

Remarks/Reason for Incomplete Scan(s)


SEE DATA SHEET #199ISIUT019 FOR 60° AND 70° SHEAR EXAMINATION DATA

See 199ISIUT031 and 032 for supplemental coverage. KB 9/29/99

Further Evaluation Required? Yes No

Examiners: Neil B. Prestwich Level: II Date: 9/20/99

Daniel Schanink Level: II Date: 9/20/99



Screen Range = 10.0"

Depth Metal Path

Search Unit #2

Manufacture: KBA Serial No.: C06285 Size: 1.0" Shape: ROUND Freq: 1.0 Style: GAMMA Exam Angle: 45° Mode SHEAR Measured Angle: 46° Wedge Style: MSW Cable Type: RG 58 Len: 12' Ref Block: 90-4722

Instrument Settings

Make/Model: SONIC 136 Serial No.: 1118M Delay: 1.03 Range: 10.0" M'd Cal/Vel: 0.128 Pulser: 500 Damping: 500 Reject: OFF Rep. Rate: 1K Freq: 1.0 Filter: 1 Mode: P/E Reference Sensitivity Axial: 48.6dB Circ: 48.6dB SDH Sensitivity: 48.6dB Exam Sensitivity Axial: 60.6dB Circ: 60.6dB

Instrument Linearity Acceptable: Amp Vert Horiz

Reviewers: Neil B. Prestwich Date: 9-25-99 Reviewers: Dantha Date: 9/27/99 ANII: C.W. Johnson Date: 9-29-99 ISI Log Sky 9-29-99

Results table with columns Ind #, Scan, Ang., %DAC, L1, Lmax, L2, Ind Len, W1, Wmax, W2, S1, Smax, S2, Remarks.

Page 13 of 20





ANO Outage: 1R15

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 199ISIUT019

Unit 1

Page 1 of 1

ISI       PSI       INFO  
 MAINTENANCE       WQT

Exam/Item ID 05-013

Comp/System PRESSURIZER

DWG # MIG-69

Cal/Item B-D / B3.110

Exam Comp Temp 120°

Item Config PZR Upper Head to Relief Nozzle

Exam Surface EXTERIOR

Company RAYTHEON

Code Edition ASME XI 1980/W81

Procedure No. 1415.038 / 5

Cal Block No. 40908

Cal Block Temp 110°

Size T 5.5"

Ferritic       Austenitic  
 Dissimilar       Clad

Cal Checks	SU1	SU2
Initial Cal Time	1030	1045
Initial Cal Date	9/17/99	9/17/99
Intermediate Time	1745	1750
Intermediate Date	N/A	N/A
Final Cal Time	1955	2000
Final Cal Date	9/17/99	9/17/99

Scans Performed	Completed	
	Yes	No
Scan 1, 0 if Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>

Remarks/Reason for Incomplete Scan(s)

SEE DATA SHEET# 099ISIUT018 FOR 0° AND 45° SHEAR EXAMINATION DATA. WELD IDENTIFIED BY DRAWING.


*See 199ISIUT031 and 032 for supplemental coverage. RP 9/28/99*

Further Evaluation Required?  Yes  No

Examiners: Neil B. Prestwich Level: II Date: 9/20/99

NEIL B PRESTWICH

Daniel Schanink Level: II Date: 9/20/99  
DANIEL SCHANINK



Screen Range = 15.0"

Depth       Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #1


Instrument Settings

Manufacture: KBA      Make/Model: SONIC 136  
 Serial No.: 000NBB      Serial No: 1118M  
 Size: 1.0"      Shape: round      Delay: 1.270      Range: 15.0"  
 Freq: 1.0      Style: GAMMA      MTI Cal/Vel: 0.127      Pulsar: 500  
 Exam Angle: 60°      Mode: SHEAR      Damping: 500      Reject: OFF  
 Measured Angle: 63°      Rep. Rate: 1K      Freq: 1.0  
 Wedge Style: MSW      Filter: 1      Mode: P/E  
 Cable Type: RG 58      Len: 12'      Reference Sensitivity  
 Ref Block: 90-4722      Axial: 52.4dB      Circ: 52.4dB  
 Exam Sensitivity  
 Axial: 64.4dB      Circ: 64.4dB

Search Unit #2

Instrument Settings

Manufacture: KBA      Make/Model: SONIC 136  
 Serial No.: C05213      Serial No: 1118M  
 Size: 1.0"      Shape: ROUND      Delay: 1.540      Range: 20.0"  
 Freq: 1.0      Style: GAMMA      MTI Cal/Vel: 0.127      Pulsar: 500  
 Exam Angle: 70°      Mode: SHEAR      Damping: 500      Reject: OFF  
 Measured Angle: 70°      Rep. Rate: 1K      Freq: 1.0  
 Wedge Style: MSW      Filter: 1      Mode: P/E  
 Cable Type: RG 58      Len: 12'      Reference Sensitivity  
 Ref Block: 90-4722      Axial: 58.6dB      Circ: N/A  
 Exam Sensitivity  
 Axial: 70.8dB      Circ: N/A



Screen Range = 20.0"

Depth       Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: Paul Hines Date: 9-25-99      Reviewers: Jonathan Date: 9/20/99  
 ANR: C.W. Thompson Date: 9-29-99      ISI Log Pgy 9-29-99

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															ACCEPTABLE



ANO Outage: 1r15

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 199ISIUT031

Unit 1

Page 1 of 1

ISI  PSI  INFO  
 MAINTENANCE  WQT

Exam/Item ID OS-013

Comp/System PRESSURIZER

DWG # MIG-69

Cat / Item B-D / B 3.110

Exam Comp Temp 83°

Item Config PZR Upper Head to Relief Nozzl

Exam Surface EXTERIOR

Company RAYTHEON

Code Edition ASME XI 1980W81

Procedure No. 1415.038 / 5

Cal. Block No. 40908

Cal. Block Temp 75°

Size NA T 5.5"

Ferritic  Austenitic

Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	0724	
Initial Cal Date	9/28/99	
Intermediate Time	0901	
Intermediate Time	0911	
Final Cal Time	0944	
Final Cal Date	9/28/99	

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input checked="" type="radio"/>	<input type="radio"/>
Scan 2, with flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 3, against flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 4, CW	<input type="radio"/>	<input checked="" type="radio"/>
Scan 5, CCW	<input type="radio"/>	<input checked="" type="radio"/>

Couplant Type: ULTRAGEL II

Couplant Batch: 98325

Therm SN: 190847

Cal Due: 10/5/99

Remarks/Reason for Incomplete Scan(s)

WELD IDENTIFIED BY DRAWING. SUPPLEMENTAL COVERAGE EXAM TO REPORT #'S 199ISIUT018 AND 199ISIUT019.

Further Evaluation Required?  Yes  No


Examiners:

*Daniel Schanink*  
DANIEL SCHANINK

Level: II Date: 9/28/99

*Ronald V Swain*  
RONALD V SWAIN

Level: III Date: 9/28/99



Screen Range = 6"

Depth  Metal Path

Search Unit #1

Manufacture: HARRISONIC

Serial No.: CM0208-S

Size: .5" Shape: round

Freq: 2.25 Style: NA

Exam Angle: 0° Mode: LONG

Measured Angle: NA

Wedge Style: INTEGRAL

Cable Type: RG 174 Len: 6'

Ref Block: 94-6548

Instrument Settings

Make/Model: SONIC 136

Serial No: 136-154

Delay: 0.022 Range: 6"

M'd Cal/Vel: .227 Pulser: 222

Damping: 500 Reject: OFF

Rep. Rate: 4K Freq: 2.25

Filter: 2 Mode: P/E

Reference Sensitivity

Axial: 22.0 Circ: 22.0

SDH Sensitivity: 22.0

Exam Sensitivity

Axial: 42.0 Circ: 42.0

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #2

Manufacture: N/A

Serial No.: NA

Size: N/A Shape: NA

Freq: N/A Style: NA

Exam Angle: NA Mode: NA

Measured Angle: NA

Wedge Style: NA

Cable Type: NA Len: NA

Ref Block: NA

Instrument Settings

Make/Model: NA

Serial No: NA

Delay: NA Range: NA

M'd Cal/Vel: NA Pulser: NA

Damping: NA Reject: NA

Rep. Rate: NA Freq: NA

Filter: NA Mode: NA

Reference Sensitivity

Axial: NA Circ: N/A

SDH Sensitivity: NA

Exam Sensitivity

Axial: NA Circ: N/A

Screen Range = NA

Depth  Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers:

*Randall*

Date: 9/29/99

Reviewers: *ISI Log*

Date: 9-29-99

ANII:

*C.W. Thompson*

Date: 9-29-99

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															ACCEPTABLE



ANO Outage: 1r15

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 199ISIUT032

Unit 1  
Page 1 of 1

ISI       PSI       INFO  
 MAINTENANCE       WQT

Exam/Item ID 05-013  
Comp/System PRESSURIZER  
DWG # MIG-69

Cal / Item B-D / B 3.110

Exam Comp Temp 83°  
Item Config PZR Upper Head to Relief Nozzl  
Exam Surface EXTERIOR

Company RAYTHEON  
Code Edition ASME XI 1980/W81  
Procedure No. 1415.038 / 5

Cal. Block No. 40908  
Cal. Block Temp 75°  
Size NA " 5.5"  
 Ferritic       Austenitic  
 Dissimilar       Clad

Cal Checks	SU1	SU2
Initial Cal Time	0748	0818
Initial Cal Date	9/28/99	9/28/99
Intermediate Time	0927	0912
Intermediate Time	0939	0926
Final Cal Time	0947	0950
Final Cal Date	9/28/99	9/28/99

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>


Couplant Type: ULTRAGEL II  
Couplant Batch: 98325  
Therm SN: 190847  
Cal Due: 10/5/99

Remarks/Reason for Incomplete Scan(s)

WELD IDENTIFIED BY DRAWING. SUPPLEMENTAL COVERAGE EXAM TO REPORT #'S 199ISIUT018 AND 199ISIUT019.

Examiners: Daniel Schanink Level: II Date: 9/28/99  
                  DANIEL SCHANINK  
Ronald V. Swain Level: III Date: 9/28/99  
                  RONALD V SWAIN

Further Evaluation Required?  Yes  No



Screen Range = 10"


Depth       Metal Path

Search Unit #1

Instrument Settings

Manufacture: KBA      Make/Model: SONIC 136  
Serial No.: 000YYF      Serial No: 136-154  
Size: .50      Shape: ROUND      Delay: .394      Range: 10"  
Freq: 1.0      Style: MSW      M'tl Cal/Vel: .126      Pulsar: 500  
Exam Angle: 45°      Mode: SHEAR      Damping: 500      Reject: OFF  
Measured Angle: 45°      Rep. Rate: 2K      Freq: 1MHZ  
Wedge Style: MSWQC      Filter: 2      Mode: P/E  
Cable Type: RG 174      Len: 6'      Reference Sensitivity  
Ref Block: 94-6546      Axial: 35.2      Circ: 35.2  
SDH Sensitivity: 35.2  
Exam Sensitivity  
Axial: 47.2      Circ: 47.2

Instrument Linearity Acceptable:  Amp       Vert       Horiz



Screen Range = 12"

Depth       Metal Path

Search Unit #2

Instrument Settings

Manufacture: KBA      Make/Model: SONIC 136  
Serial No.: 00141Y      Serial No: 136-154  
Size: .50      Shape: ROUND      Delay: .510      Range: 12"  
Freq: 1.0      Style: MSW      M'tl Cal/Vel: .126      Pulsar: 500  
Exam Angle: 60°      Mode: SHEAR      Damping: 500      Reject: OFF  
Measured Angle: 57°      Rep. Rate: 2K      Freq: 1MHZ  
Wedge Style: MSWQC      Filter: 2      Mode: PE  
Cable Type: RG 174      Len: 6'      Reference Sensitivity  
Ref Block: 94-6546      Axial: 45.2      Circ: 45.2  
SDH Sensitivity: 45.2  
Exam Sensitivity  
Axial: 57.2      Circ: 57.2

Instrument Linearity Acceptable:  Amp       Vert       Horiz

Reviewers: Renther Date: 9/28/99      Reviewers: ISS Date: 9-29-99  
ANII: C.W. Thompson Date: 9-29-99

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															ACCEPTABLE

Page 16 of 20

**WELD 03-047**



ANO Outage: 1R15

ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

1R15

Data Sheet # 199ISIUT027

Unit 1

Page 1 of 1

- ISI  PSI  INFO
- MAINTENANCE  WQT

Exam/Item ID 03-047

Comp/System STEAM GEN. E24A

DWG # MID-2

Cat / Item C-A / C 1.10

Exam Comp Temp 87°

Item Config Upper Shell to Upper Nozzle Bel

Exam Surface OD

Company RAYTHEON

Code Edition ASME XI 1980/W81

Procedure No. 1415.038 / 5

Cal. Block No. UT-35

Cal. Block Temp 72°

Size NA T 5.5"

- Ferritic  Austenitic
- Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	08:37	08:35
Initial Cal Date	9/24/99	9/24/99
Intermediate Time	17:26	17:18
Intermediate Time	08:23	08:24
Final Cal Time	11:38	11:39
Final Cal Date	9/25/99	9/25/99

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input checked="" type="radio"/>	<input type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input type="radio"/>	<input checked="" type="radio"/>
Scan 4, CW	<input type="radio"/>	<input checked="" type="radio"/>
Scan 5, CCW	<input type="radio"/>	<input checked="" type="radio"/>

Remarks/Reason for Incomplete Scan(s)

WELD IDENTIFIED BY DRAWING. 70° USED FOR SCAN 2 ONLY. DATUM O AT CENTERLINE OF MANWAY. INDICATION #1 PREVIOUSLY RECORDED 3/15/1992 AT 212.75" L. REFER TO REPORT # ISI UT 048-1. INSULATION RING LIMITATIONS TO 70° SCAN AT 20"-26", 90"-96", 233"-237", 301"-307" AND 354"-357".


Further Evaluation Required?  Yes  No

Examiners: Daniel Schanink Level: II Date: 9/25/99

DANIEL SCHANINK

Neil B. Prestwich Level: II Date: 9/25/99

NEIL B PRESTWICH



Screen Range = 20

- Depth
- Metal Path

Search Unit #1

Manufacture: KBA

Serial No.: C05213

Size: 1.0" Shape: ROUND

Freq: 1.0 Style: GAMMA

Exam Angle: 70° Mode: SHEAR

Measured Angle: 70°

Wedge Style: MSW

Cable Type: RG 58 Len: 12'

Ref Block: 90 4722

Instrument Settings

Make/Model: STAVELY

Serial No: 136-1118M

Delay: 1.54 Range: 20

M'fl Cal/Vel: .127 Pulser: 500

Damping: 500 Reject: OFF

Rep. Rate: 1K Freq: 1MHz

Filter: 1 Mode: PE

Reference Sensitivity

Axial: 64.0 Circ: 64.0

SDH Sensitivity: 58.0

Exam Sensitivity

Axial: 76.0 Circ: NA

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #2

Manufacture: KBA

Serial No.: L04120

Size: 1.0" Shape: ROUND

Freq: 2.25 Style: GAMMA

Exam Angle: 0° Mode: LONG

Measured Angle: NA

Wedge Style: N/A

Cable Type: RG 58 Len: 12'

Ref Block: 90 4722

Instrument Settings

Make/Model: STAVELY

Serial No: 136-1118M

Delay: .107 Range: 10

M'fl Cal/Vel: .234 Pulser: 222

Damping: 500 Reject: OFF

Rep. Rate: 1K Freq: 1

Filter: 1 Mode: PE


Reference Sensitivity

Axial: 28.0 Circ: 28.0

SDH Sensitivity: 28.0

Exam Sensitivity

Axial: 48.0 Circ: 48.0



Screen Range = 10

- Depth
- Metal Path

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: Ken Penzler Date: 9/24/99 Reviewers: SSI Date: 9-24-99

ANIL: C.W. Thompson Date: 9-24-99

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
RI	1	2	70	80	221.2"	221.4"	222.1"	0.9"	4.80"	5.70"	8.80"	5.00"	5.80"	8.80"	FABRICATON DEFECT. Acceptable AS 9/29/99



ANO Outage: 1R15

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 199ISIUT028

Unit 1  
Page 1 of 1

ISI     PSI     INFO  
 MAINTENANCE     WQT

Exam/Item ID 03-047  
Comp/System STEAM GEN. E24A  
DWG # MID-2

Cat / Item C-A / C 1.10

Exam Comp Temp 87°

Item Config Upper Shell to Upper Nozzle Bel

Exam Surface OD

Company RAYTHEON  
Code Edition ASME XI 1980/W81  
Procedure No. 1415.038 / 5

Cal. Block No. UT-35

Cal. Block Temp 72°

Size NA T 5.5"

Ferritic     Austenitic  
 Dissimilar     Clad

Cal Checks	SU1	SU2
Initial Cal Time	08:49	NA
Initial Cal Date	9/24/99	
Intermediate Time	17:22	NA
Intermediate Time	08:20	NA
Final Cal Time	11:37	NA
Final Cal Date	9/25/99	

Scans Performed	Completed	
	Yes	No
Scan 1, 0 If Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input type="radio"/>	<input checked="" type="radio"/>

Couplant Type: ULTRAGEL II  
Couplant Batch: 98325  
Therm SN: 194268  
Cal Due: 1/5/00


Remarks/Reason for Incomplete Scan(s)

WELD IDENTIFIED BY DRAWING. FULL VEE CALIBRATION UTILIZED FOR ADDITIONAL COVERAGE.

Further Evaluation Required?  Yes  No

Examiners: Daniel Schanink Level: II Date: 9/25/99  
DANIEL SCHANINK

Neil B. Prestwich Level: II Date: 9/25/99  
NEIL B PRESTWICH



Screen Range = 1020"

Depth     Metal Path

Search Unit #1

Manufacture: KBA  
Serial No.: C06285  
Size: 1.0" Shape: ROUND  
Freq: 1.0 Style: GAMMA  
Exam Angle: 45° Mode: SHEAR  
Measured Angle: 46°  
Wedge Style: MSW  
Cable Type: RG 58 Len: 12'  
Ref Block: 90-4722

Instrument Settings

Make/Model: STAVEL  
Serial No: 1.12 136-1118M 20"  
Delay: 1.03 Range: 10"  
M'd Cal/Vel: .128 Pulser: 500  
Damping: 500 Reject: OFF  
Rep. Rate: 1K Freq: 1MHZ  
Filter: 1 Mode: PE  
Reference Sensitivity  
Axial: 44.6/53.0 Circ: 44.6/53.0  
SDH Sensitivity: 44.6/53.0  
Exam Sensitivity  
Axial: 64.0 Circ: 64.0

Instrument Linearity Acceptable:  Amp     Vert     Horiz

Search Unit #2

Manufacture: N/A  
Serial No.: NA  
Size: N/A Shape: NA  
Freq: N/A Style: NA  
Exam Angle: NA Mode: NA  
Measured Angle: NA  
Wedge Style: NA  
Cable Type: NA Len: NA  
Ref Block: NA

Instrument Settings

Make/Model: NA  
Serial No: NA  
Delay: NA Range: NA  
M'd Cal/Vel: NA Pulser: NA  
Damping: NA Reject: NA  
Rep. Rate: NA Freq: NA  
Filter: NA Mode: NA  
Reference Sensitivity  
Axial: NA Circ: NA  
SDH Sensitivity: NA  
Exam Sensitivity  
Axial: NA Circ: NA

Screen Range = NA

Depth     Metal Path

Instrument Linearity Acceptable:  Amp     Vert     Horiz

Reviewers: Alantha Date: 9/28/99 Reviewers: ISS LS Date: 9-29-99

ANII: C.W. Johnson Date: 9-29-99

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
NRI															ACCEPTABLE



ANO Outage: 1R15

# ULTRASONIC CALIBRATION / EXAMINATION DATA SHEET

Data Sheet # 199ISIUT026

Unit 1

Page 1 of 3

ISI  PSI  INFO  
 MAINTENANCE  WQT

Exam/Item ID 03-047

Comp/System STEAM GEN. E24A

DWG # MID-2

Cal/Item C-A 1 C 1.10

Exam Comp Temp 87°

Item Config Upper Shell to Upper Nozzle Bel

Exam Surface OD

Company RAYTHEON

Code Edition ASME XI 1980WW81

Procedure No. 1415.038 1 5

Cal. Block No. UT-35

Cal. Block Temp 72°

Size NA "T" 5.5"

Ferritic  Austenitic  
 Dissimilar  Clad

Cal Checks	SU1	SU2
Initial Cal Time	0845	09:15
Initial Cal Date	9/24/99	9/24/99
Intermediate Time	17:22	17:23
Intermediate Time	08:20	08:22
Final Cal Time	11:37	11:39
Final Cal Date	9/25/99	9/25/99

Scans Performed	Completed	
	Yes	No
Scan 1, 0 if Req'd	<input type="radio"/>	<input checked="" type="radio"/>
Scan 2, with flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 3, against flow	<input checked="" type="radio"/>	<input type="radio"/>
Scan 4, CW	<input checked="" type="radio"/>	<input type="radio"/>
Scan 5, CCW	<input checked="" type="radio"/>	<input type="radio"/>


Couplant Type: ULTRAGEL II  
Couplant Batch: 98325  
Therm SN: 194268  
Cal Due: 1/5/00

Remarks/Reason for Incomplete Scan(s)

WELD IDENTIFIED BY DRAWING. 60° USED FOR SCAN 2 AND 3. 45° USED FOR SCAN 4 AND 5. DATUM O AT CENTERLINE OF MANWAY. INDICATION #1 PREVIOUSLY RECORDED 3/15/1992 AT 212.75" L. REFER TO REPORT # ISI UT 0-0-1. INSULATION RING LIMITATIONS TO 60° SCAN 2 AT 20"-26", 90"-96", 233"-237", 301"-307" AND 354"-357".

Examiners: Daniel R. Schanink Level: II Date: 9/25/99  
DANIEL SCHANINK  
Neil B. Prestwich Level: II Date: 9/25/99  
NEIL B PRESTWICH

Further Evaluation Required?  Yes  No



Screen Range = 10

Depth  Metal Path

Search Unit #1


Manufacture: KBA  
Serial No.: C06285  
Size: 1.0" Shape: ROUND  
Freq: 1.0 Style: GAMMA  
Exam Angle: 45° Mode: SHEAR  
Measured Angle: 46°  
Wedge Style: MSW  
Cable Type: RG 58 Len: 12'  
Ref Block: 90 4722

Instrument Settings

Make/Model: STAVELY  
Serial No: 138-1118M  
Delay: 1.03 Range: 10  
M'd Cal/Vel: .128 Pulser: 500  
Damping: 500 Reject: OFF  
Rep. Rate: 1K Freq: 1MHZ  
Filter: 1 Mode: PE  
Reference Sensitivity  
Axial: NA Circ: 44.6  
SDH Sensitivity: 44.6  
Exam Sensitivity  
Axial: NA Circ: 64.6

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Search Unit #2



Screen Range = 15

Depth  Metal Path

Manufacture: KBA  
Serial No.: 000NBB  
Size: 1.0" Shape: ROUND  
Freq: 1.0 Style: GAMMA  
Exam Angle: 60° Mode: SHEAR  
Measured Angle: 62°  
Wedge Style: MSW  
Cable Type: RG 58 Len: 12'  
Ref Block: 90 4722

Instrument Settings

Make/Model: STAVELY  
Serial No: 136-1118M  
Delay: 1.47 Range: 15  
M'd Cal/Vel: .127 Pulser: 500  
Damping: 500 Reject: OFF  
Rep. Rate: 1K Freq: 1  
Filter: 1 Mode: PE  
Reference Sensitivity  
Axial: 61.0 Circ: NA  
SDH Sensitivity: 51.6  
Exam Sensitivity  
Axial: 71.6 Circ: NA

Instrument Linearity Acceptable:  Amp  Vert  Horiz

Reviewers: Ken Penner Date: 9/29/99 Reviewers: ISI Lgs Date: 9-29-99  
ANII: C.W. Thompson Date: 9-29-99

Results	Ind #	Scan	Ang.	%DAC	L1	Lmax	L2	Ind Len	W1	Wmax	W2	S1	Smax	S2	Remarks
R1	2	2	60	80	221.5"	221.8	222.2"	0.70"	3.70"	4.40"	4.8"	3.90"	4.50"	5.40"	FABRICATION DEFECT. Acceptable R1 9/28/99